

California Code of Regulations
Title 24, Article 680

680-12. Gas Chlorination Equipment Rooms

- (a) Switch Location.** Switches for the control of mechanical ventilation and lighting fixtures in a room used for gas chlorination equipment shall be located adjacent to the entry door outside the of the room. Each switch shall be clearly labeled “Turn On Before Entering”.
- (b) Equipment Interlocks** The gas chlorine feeding devices shall be interlocked with the pool recirculating pump so that the gas chlorine feeding devices shall not operate when the recirculating pump is off or during the filter backwash cycle.

680-13. Emergency Switch for Spa Pools

A clearly labeled emergency shut-off switch for the control of both the recirculation system and the aeration and/or jet system shall be installed adjacent to the spa pool.