

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Certificate #: 92- 1007

<u>Model Designation:</u> <i>ProSeries 2500 System</i>	<u>System Type</u> Under Counter	<u>Replacement Elements:</u> ProSeries 2500
---	-------------------------------------	--

Date Issued: January 6, 2007

Manufacturer: Everpure Inc.

Rated Service Flow: 0.5 gpm

Rated Service Capacity: not applicable

Technology: mechanical

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems claiming cyst reduction may be used on water containing cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Asbestos

Organic:

None

Certificate #: 91- 1014

<u>Model Designation:</u> <i>Brita Water Filtration Pitcher - Slim Model OB11</i>	<u>System Type</u> Pour Through	<u>Replacement Elements:</u> OB03
--	------------------------------------	--------------------------------------

<i>Brita Water Filtration Pitcher - Space Saver Model OB21</i>	Pour Through	OB03
--	--------------	------

<i>Brita Water Filtration Pitcher - Atlantis Model OB32</i>	Pour Through	OB03
---	--------------	------

<i>Brita Water Filtration Pitcher - Classic Model OB01</i>	Pour Through	OB03
--	--------------	------

<i>Brita Water Filtration Pitcher - Deluxe Model OB26</i>	Pour Through	OB03
---	--------------	------

<i>Brita Water Filtration Pitcher - Riviera Model OB35</i>	Pour Through	OB03
--	--------------	------

<i>Brita Water Filtration Pitcher - Grand Model OB36 Clear, Violet, Yellow & Green</i>	Pour Through	OB03
--	--------------	------

<i>Brita Water Filtration Pitcher - Aqualux Model OB37</i>	Pour Through	OB03
--	--------------	------

<i>Brita Water Filtration Pitcher - Chrome Model OB39</i>	Pour Through	OB03
---	--------------	------

<i>Brita Water Filtration Pitcher - Pacifica Model OB41</i>	Pour Through	OB03
---	--------------	------

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

<i>Brita Water Filtration Pitcher - Vintage Model OB43</i>	Pour Through	OB03
<i>Brita Water Filtration Pitcher - Bella Model OB44</i>	Pour Through	OB03
<i>Brita Water Filtration Pitcher -Everyday Model OB46</i>	Pour Through	OB03
<i>Brita Water Filtration Pitcher -Marina Model OB47</i>	Pour Through	OB03
<i>Brita Water Filtration Pitcher -Oceania Model OB48</i>	Pour Through	OB03

Date Issued: September 9, 2006

Date Revised: August 6, 2010

Manufacturer: Brita LP

Rated Service Flow: not applicable

Rated Service Capacity: 40 gallons

Technology: GAC/ion exchange

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Cadmium

Copper

Mercury

Organic:

None

Certificate #: 92- 1053

Model Designation:

Seagull IV X-1 (CA)

System Type

Under Counter

Replacement Elements:

HC-1SG (CA)

RS-1SG (CA)

Date Issued: May 1, 2007

Manufacturer: General Ecology, Inc.

Rated Service Flow: 1 gpm

Rated Service Capacity: 1000 gal.

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems claiming cyst reduction may be used on water containing cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (Protozoan)

Turbidity

Inorganic/Radiological:

None

Organic:

1,4-dichlorobenzene

Chlordane

Trichloroethylene (TCE)

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 92- 1068

Model Designation:

ProSeries 1500 System

System Type

Under Counter

Replacement Elements:

ProSeries 1500

Date Issued: August 28, 2007

Manufacturer: Everpure Inc.

Rated Service Flow: 0.5 gpm

Rated Service Capacity: not applicable

Technology: mechanical

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems claiming cyst reduction may be used on water containing cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Asbestos

Organic:

None

Certificate #: 92- 1069

Model Designation:

Seagull IV X-2 (CA)

System Type

Under Counter

Replacement Elements:

HC-2SG (CA)

RS-2SG (CA)

Date Issued: May 1, 2007

Manufacturer: General Ecology, Inc.

Rated Service Flow: 2 gpm

Rated Service Capacity: 2000 gallons

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems claiming cyst reduction may be used on water containing cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (Protozoan)

Turbidity

Inorganic/Radiological:

None

Organic:

1,4-dichlorobenzene

Chlordane

Trichloroethylene (TCE)

Certificate #: 96- 1234

Model Designation:

Doulton HIP/Ultracarb NSF

System Type

Under Counter

Replacement Elements:

Ultracarb NSF

Doulton HIP/Ultracarb Inline NSF

In Line

Ultracarb NSF

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: July 24, 2006

Manufacturer: Fairey Industrial Ceramics
Limited

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 600 gallons

Technology: ceramic/carbon

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems claiming cyst reduction may be used on water containing cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Lead

Organic:

None

Certificate #: 97- 1294

<u>Model Designation:</u>	<u>System Type</u>	<u>Replacement Elements:</u>
<i>MP750SB</i>	Under Counter	CB6
<i>MP750SC</i>	Counter Top	CB6
<i>MP750SSCT</i>	Counter Top	CB6
<i>MP750SI</i>	In Line	CB6
<i>MPC500B</i>	In Line	CB6
<i>MPC500C</i>	In Line	CB6
<i>MPC500I</i>	In Line	CB6
<i>MP-SSCT</i>	In Line	CB6
<i>MPCT</i>	Counter Top	CB6

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: June 23, 2007

Manufacturer: Multi-Pure Corporation

Rated Service Flow: 0.75 gpm

Rated Service Capacity: 750 gallons

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems claiming cyst reduction may be used on water containing cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Chlordane

PCBs

Toxaphene

MTBE

VOCs

Certificate #: 97- 1295

Model Designation:

Multi-Pure MP1200EL

System Type

Under Counter

Replacement Elements:

CB6

Date Issued: June 23, 2007

Manufacturer: Multi-Pure Corporation

Rated Service Flow: 0.75 gpm

Rated Service Capacity: 1200 gallons

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems claiming cyst reduction may be used on water containing cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Chlordane

PCBs

Toxaphene

MTBE

VOCs

Certificate #: 98- 1345

Model Designation:

AquaPure EP25/EP25

System Type

Under Counter

Replacement Elements:

EP 25

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: April 9, 2008

Manufacturer: Cuno, Inc.

Rated Service Flow: 0.6 gpm

Rated Service Capacity: 1150 gallons

Technology: mechanical/carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems claiming cyst reduction may be used on water containing cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Atrazine

Benzene

Carbofuran

p-Dichlorobenzene

Lindane

2.4 D reduction

Certificate #: 98- 1352

Model Designation:

Brita Faucet Filtration System FF-100

System Type

Faucet Mount

Replacement Elements:

FR-200

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: June 23, 2008

Date Revised: October 28, 2010

Manufacturer: Brita LP

Rated Service Flow: 0.58 gpm

Rated Service Capacity: 100 gallons

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems claiming cyst reduction may be used on water containing cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Organic:

Atrazine

Benzene

Lindane

Trichloroethylene

Alachlor

Carbofuran

Chlordane

2,4-D

Carbon tetrachloride

Endrin

o-Dichlorobenzene

VOCs

Chlorobenzene

Ethylbenzene

Methoxychlor

Styrene

Tetrachloroethylene

Toluene

Toxaphene

Trihalomethanes (THMs)

Simazine

Certificate #: 99- 1409

Model Designation:

WF1-NLC200

System Type

In Line
Refrigerator

Replacement Elements:

NLC200

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: December 14, 2009

Manufacturer: Whirlpool Corporation

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 200 gallons

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems claiming cyst reduction may be used on water containing cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Lead

Organic:

None

Certificate #: 99- 1410

Model Designation:

WF1-NLCS200

System Type

In Line
Refrigerator

Replacement Elements:

NLCS200

Date Issued: December 14, 2009

Date Revised: February 5, 2007

Manufacturer: Sears Roebuck and
Company

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 200 gallons

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems claiming cyst reduction may be used on water containing cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Lead

Organic:

None

Certificate #: 00- 1413

Model Designation:

Kohler K-200/K-201

System Type

Under Counter

Replacement Elements:

K-201

Kohler K6665-F/K-201

Under Counter

K-201

Kohler K6666-F/K-201

Under Counter

K-201

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: January 19, 2010

Manufacturer: Kohler Co.

Rated Service Flow: 1.5 gpm

Rated Service Capacity: 1500 gallons

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems claiming cyst reduction may be used on water containing cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

None

Organic:

None

Certificate #: 00- 1414

Model Designation:

Kohler K-200/K-202

Kohler K-6665-F/K-202

Kohler K-6666-F/K-202

System Type

Under Counter

Under Counter

Under Counter

Replacement Elements:

K-202

K-202

K-202

Date Issued: January 19, 2010

Manufacturer: Kohler Co.

Rated Service Flow: 0.6 gpm

Rated Service Capacity: 1500 gallons

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems claiming cyst reduction may be used on water containing cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Lead

Organic:

None

Certificate #: 99- 1420

Model Designation:

Water Factory EVP 2400

System Type

In Line

Replacement Elements:

EVP 2400

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: March 14, 2010

Manufacturer: 3M Purification

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 1400 gallons

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems claiming cyst reduction may be used on water containing cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Lead

Organic:

None

Certificate #: 00- 1423

Model Designation:

Amana WF-40

System Type

In Line
Refrigerator

Replacement Elements:

WF-40

Date Issued: March 14, 2010

Manufacturer: Cuno Incorporated

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 300 gallons

Technology: carbon block/ion exchange

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems claiming cyst reduction may be used on water containing cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Organic:

Atrazine

Lindane

2,4-D

Certificate #: 00- 1426

Model Designation:

FM DWS 1500

System Type

Under Counter

Replacement Elements:

47-5574704

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: March 14, 2010

Date Revised: June 2, 2008

Manufacturer: Cuno/Water Factory

Rated Service Flow: 0.6 gpm

Rated Service Capacity: 1500 gallons

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Inorganic/Radiological:

Lead

Asbestos

Organic:

None

Certificate #: 00- 1431

Model Designation:

Kenmore 12527302

System Type

In Line
Refrigerator

Replacement Elements:

46 9014

Date Issued: April 4, 2010

Manufacturer: Sears Roebuck & Co.

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 300 gallons

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems claiming cyst reduction may be used on water containing cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Organic:

Atrazine

Lindane

2,4-D

Certificate #: 01- 1475

Model Designation:

Kenmore NGFC-2000

System Type

In Line
Refrigerator

Replacement Elements:

FC-100

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: May 2, 2006

Manufacturer: Sears Roebuck & Co.

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 400 gallons

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems claiming cyst reduction may be used on water containing cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Lead

Mercury

Organic:

Alachlor

Atrazine

Lindane

2,4-D

Toxaphene

Certificate #: 02- 1513

Model Designation:

Zuvo Purator UC-3

System Type

Counter Top

Replacement Elements:

UC3-PB1 (filter)

UC3-UVL (lamp)

Date Issued: April 29, 2007

Manufacturer: Zuvo Water LLC

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 500 gallons

Technology: UV w/ carbon

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems claiming cyst reduction may be used on water containing cysts.

This system is intended for the supplemental bactericidal treatment of either treated and disinfected public drinking water or other drinking water that has been tested and deemed acceptable for human consumption by the state or local agency having jurisdiction. This system is designed to reduce normally occurring non-pathogenic

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Non-pathogenic microorganisms

Inorganic/Radiological:

Lead

Organic:

None

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 02- 1520

Model Designation:

WRO-3500

System Type

Under Counter

Replacement Elements:

WROM-230TN (membrane)
D-15 (pre filter)
D-20 (post filter)

Date Issued: May 8, 2007

Manufacturer: American Plumber

Rated Service Flow: 7.6 gpd

Rated Service Capacity: not applicable

Technology: reverse osmosis

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems claiming cyst reduction may be used on water containing cysts.

¹Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Arsenic¹

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Fluoride

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

None

Certificate #: 02- 1521

Model Designation:

WRO-3000

System Type

Under Counter

Replacement Elements:

WROM-230T (membrane)
D-15 (pre filter)
D-20 (post filter)

Date Issued: May 8, 2007

Manufacturer: American Plumber

Rated Service Flow: 7.6 gpd

Rated Service Capacity: not applicable

Technology: reverse osmosis

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems claiming cyst reduction may be used on water containing cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Copper

Fluoride

Lead

Selenium

Organic:

None

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 02- 1522

Model Designation:

Ultrifiner UF50N-CBVOC

System Type

Under Counter

Replacement Elements:

Prefilter: 18557
RO Membrane: 18644
VOC Postfilter: 18773

Date Issued: July 29, 2007

Date Revised: June 30, 2009

Manufacturer: Aquion Partners

Rated Service Flow: 15.35 gpd

Rated Service Capacity: 100 gallons

Technology: RO w/ carbon

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Arsenic¹

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Fluoride

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

VOCs by surrogate

Certificate #: 03- 1549

Model Designation:

Whirlpool WF-NL240V

System Type

In Line
Refrigerator

Replacement Elements:

NL240V

Whirlpool WF-L400V

In Line
Refrigerator

L400V

Date Issued: January 21, 2008

Manufacturer: Whirlpool Corp.

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 400 gal

Technology: carbon block

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Lead

Mercury

Organic:

Benzene

p-Dichlorobenzene

Toxaphene

Carbofuran

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 03- 1551

Model Designation:

Whirlpool WF-NLC240V

System Type

In Line
Refrigerator

Replacement Elements:

NLC240V

Whirlpool WF-LC400V

In Line
Refrigerator

LC400V

Date Issued: January 21, 2008

Manufacturer: Whirlpool Corp.

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 400 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Atrazine

2,4-D

Benzene

p-Dichlorobenzene

Toxaphene

Certificate #: 03- 1558

Model Designation:

Sears-Kenmore WF-NLC240V

System Type

In Line

Replacement Elements:

NLC240V

Sears-Kenmore WF-LC400V

In Line

LC400V

Date Issued: March 3, 2008

Manufacturer: Sears Roebuck Co

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 400 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Atrazine

2,4-D

Benzene

p-dichlorobenzene

Toxaphene

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Certificate #: 03- 1569

<u>Model Designation:</u>	<u>System Type</u>	<u>Replacement Elements:</u>
<i>Multi-Pure MP880SB</i>	Under Counter	CB11As
<i>Multi-Pure MP880SC</i>	Counter Top	CB11As
<i>Multi-Pure MP880SI</i>	In Line	CB11As
<i>Multi-Pure MP880EL(960 gallons)</i>	Under Counter	CB11As

Date Issued: May 22, 2008

Manufacturer: Multi-Pure Drinking
Water Systems

Rated Service Flow: 1.0 gpm

Rated Service Capacity: 600 gallons

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the filtration system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Arsenic V (50 ppb)

Asbestos

Lead

Mercury

Organic:

Chlordane

MTBE

PCB

Toxaphene

VOCs by chloroform surrogate

Certificate #: 03- 1571

<u>Model Designation:</u>	<u>System Type</u>	<u>Replacement Elements:</u>
<i>Multi-Pure CB-As-SB</i>	Counter Top In Line Under Counter	CBTAs
<i>Multi-Pure CB-As-SC</i>	Counter Top In Line Under Counter	CBTAs
<i>Multi-Pure CB-As-SI</i>	Counter Top In Line Under Counter	CBTAs

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Multi-Pure CB-As-SB-PID(960 gallons) Counter Top In CBTAs
Line Under
Counter

Multi-Pure CB-As-SC-PID(960 gallons) Counter Top In CBTAs
Line Under
Counter

Date Issued: June 11, 2008

Manufacturer: Multi-Pure Drinking
Water Systems

Rated Service Flow: 1.0 gpm

Rated Service Capacity: 600 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Arsenic V (50 ppb)

Asbestos

Lead

Mercury

Organic:

Chlordane

PCB

Toxaphene

MTBE

VOCs by chloroform surrogate

Certificate #: 03- 1580

Model Designation:

Multi-Pure CB-VOC-SB

System Type

Counter Top In
Line Under
Counter

Replacement Elements:

CBTVOC

Multi-Pure CB-VOC-SC

Counter Top In
Line Under
Counter

CBTVOC

Multi-Pure CB-VOC-SI

Counter Top In
Line Under
Counter

CBTVOC

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Date Issued: June 25, 2008

Manufacturer: Multi-Pure Drinking
Water Systems

Rated Service Flow: 1.0 gpm

Rated Service Capacity: 750 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Chlordane

MTBE

PCB

Toxaphene

VOCs

Certificate #: 03- 1582

Model Designation:

Multi-Pure CB-AS-PB

System Type

In Line Under
Counter

Replacement Elements:

CBNAs

Multi-Pure CB-AS-PI

In Line Under
Counter

CBNAs

Multi-Pure CB-AS-PB-PID(960 gallons)

In Line Under
Counter

CBNAs

Date Issued: June 25, 2008

Manufacturer: Multi-Pure Drinking
Water Systems

Rated Service Flow: 1.0 gpm

Rated Service Capacity: 600 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the filter system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Arsenic V (50 ppb)

Asbestos

Lead

Mercury

Organic:

Chlordane

MTBE

PCB

Toxaphene

VOCs

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 03- 1583

Model Designation:

UKF8001AXX-750

System Type

In Line
Refrigerator

Replacement Elements:

UKF8001

46 9006-750

In Line
Refrigerator

46 9006

67003523-750

In Line
Refrigerator

UKF8001

Date Issued: September 16, 2008

April 22, 2009

Manufacturer: Cuno Inc.

Rated Service Flow: 0.78 gpm

Rated Service Capacity: 750 gal.

Technology: mechanical/carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Atrazine

Lindane

Benzene

Carbofuran

p-dichlorobenzene

Toxaphene

Tetrachloroethylene

Certificate #: 03- 1586

Model Designation:

Maytag UKF7003AXX (with PID)

System Type

In Line
Refrigerator

Replacement Elements:

UKF7003AXX

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Date Issued: December 9, 2008

Manufacturer: Cuno Inc.

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 416 gal.

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Benzene

Carbofuran

p-Dichlorobenzene

Certificate #: 03- 1591

Model Designation:

Pentek QC10-CBR

System Type

In Line Under Counter

Replacement Elements:

QC10-CBRR

Date Issued: October 20, 2008

Manufacturer: Pentek

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 500 gal.

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Lead

Organic:

Atrazine

Lindane

Certificate #: 04- 1600

Model Designation:

GXSL55 F

System Type

Under Counter

Replacement Elements:

FQSLF

GQSL55 F

Under Counter

FQSLF

GXSL55 R

Under Counter

FQSLF

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Date Issued: February 9, 2009
Manufacturer: General Electric Company
Rated Service Flow: 0.78 gpm
Rated Service Capacity: 1200gal
Technology: mechanical/carbon block
Comments:
 Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:
Microbiological/Turbidity:
 Cysts
 Turbidity
Inorganic/Radiological:
 Asbestos
 Lead
 Mercury
Organic:
 Atrazine
 Lindane
 2-4,D
 Toxaphene

Certificate #: 04- 1601

<u>Model Designation:</u>	<u>System Type</u>	<u>Replacement Elements:</u>
<i>GXSV65 F</i>	Under Counter	FQSVF
<i>GQSV65 F</i>	Under Counter	FQSVF
<i>GNSV70 FBL</i>	Under Counter	FQSVF
<i>GNSV75 FWW</i>	Under Counter	FQSVF
<i>GXSV65 R</i>	Under Counter	FQSVF
<i>GNSV75 RWW</i>	Under Counter	FQSVF
<i>GNSV70 RBL</i>	Under Counter	FQSVF

Date Issued: February 9, 2009
Manufacturer: General Electric Company
Rated Service Flow: 0.6 gpm
Rated Service Capacity: 160 gal
Technology: mechanical/carbon block
Comments:
 Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:
Microbiological/Turbidity:
 Cysts
 Turbidity
Inorganic/Radiological:
 Asbestos
 Lead
 Mercury
Organic:
 Atrazine
 Lindane
 Benzene
 VOCs

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 04- 1604

Model Designation:

Everpure H-300-HSD

System Type

Under Counter

Replacement Elements:

H-300-HSD

Date Issued: March 4, 2009

Manufacturer: Everpure, Inc.

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 300 gal

Technology: mechanical/GAC

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

Lead

Organic:

VOCs

Certificate #: 04- 1605

Model Designation:

*Kenmore Advanced Refrigerator Filter
TIKB1*

System Type

In Line
Refrigerator

Replacement Elements:

T1RFKB1

Kenmore TIKB1

In Line
Refrigerator

T1RFKB1

Kenmore Ultimate II TIKB1

In Line
Refrigerator

T1RFKB1

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: January 5, 2009

Manufacturer: Sears, Roebuck and
Company

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 100 gal

Technology: mechanical/carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Alachlor

Atrazine

Benzene

Endrin

Ethylbenzene

Lindane

VOCs

Monochlorobenzene

MTBE

o-dichlorobenzene

Styrene

Tetrachloroethylene

Toxaphene

Trihalomethanes

Certificate #: 04- 1606

Model Designation:

***Kenmore Advanced Refrigerator Filter
T1KB2***

Kenmore Ultimate II T1KB2

System Type

In Line
Refrigerator

In Line
Refrigerator

Replacement Elements:

T1RFKB2

T1RFKB2

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: January 5, 2009

Manufacturer: Sears, Roebuck and
Company

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 200 gal

Technology: mechanical/carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Alachlor

Atrazine

Benzene

Endrin

Ethylbenzene

Lindane

Monochlorobenzene

o-dichlorobenzene

Styrene

Tetrachloroethylene

Toxaphene

Certificate #: 03- 1607

Model Designation:

Pentek RO-3000

System Type

Under Counter

Replacement Elements:

ROM-230T

D-15

D-20

Date Issued: December 23, 2008

Manufacturer: Pentek

Rated Service Flow: 7.6 gpd

Rated Service Capacity: not applicable

Technology: reverse osmosis

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Copper

Fluoride

Lead

Selenium

Organic:

None

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 03- 1608

Model Designation:

Pentek RO-3500

System Type

Under Counter

Replacement Elements:

ROM-230TN

D-15

D-20

Date Issued: December 23, 2008

Manufacturer: Pentek

Rated Service Flow: 7.6 gpd

Rated Service Capacity: not applicable

Technology: reverse osmosis

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Arsenic¹

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Fluoride

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

None

Certificate #: 04- 1611

Model Designation:

WF-NLC120V

System Type

In Line
Refrigerator

Replacement Elements:

NLC120V

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: February 2, 2009

Manufacturer: Whirlpool Corporation

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 120

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Benzene

Endrin

Ethyl Benzene

O-Dichlorobenzene

p-Dichlorobenzene

Toxaphene

1,2,4-trichlorobenzene

Certificate #: 04- 1612

Model Designation:

WF-NL120V

System Type

In Line
Refrigerator

Replacement Elements:

NL120V

WF-L200V w/PID capacity 200 gallons

In Line
Refrigerator

L200V

Date Issued: February 2, 2009

Manufacturer: Whirlpool Corporation

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 120 gallons

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Lead

Mercury

Organic:

Benzene

Ethyl Benzene

O-Dichlorobenzene

p-Dichlorobenzene

Toxaphene

1,2,4-trichlorobenzene

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Certificate #: 04- 1613

<u>Model Designation:</u>	<u>System Type</u>	<u>Replacement Elements:</u>
<i>WF-NLC120V</i>	In Line Refrigerator	NLC120V
<i>WF-LC200V w/PID capacity 200 gallons</i>	In Line Refrigerator	LC200V

Date Issued: February 2, 2009

Manufacturer: Sears, Roebuck & Co.

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 120

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Benzene

Endrin

Ethyl Benzene

O-Dichlorobenzene

p-Dichlorobenzene

Toxaphene

1,2,4-trichlorobenzene

Certificate #: 04- 1635

<u>Model Designation:</u>	<u>System Type</u>	<u>Replacement Elements:</u>
<i>Whirlpool Advanced T1WB2</i>	In Line Refrigerator	T1RFBW2
<i>Whirlpool Advanced T1WB2L</i>	In Line Refrigerator	T1RFBW2
<i>Kitchenaid Advanced T1WB2</i>	In Line Refrigerator	T1RFBW2
<i>Kitchenaid Advanced T1WB2L</i>	In Line Refrigerator	T1RFBW2

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: April 8, 2009

Manufacturer: Whirlpool Corporation

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 200 gals

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Alachlor

Atrazine

Benzene

o-Dichlorobenzene

Endrin

Ethylbenzene

Lindane

Monochlorobenzene

Styrene

Tetrachloroethylene

Toxaphene

Certificate #: 04- 1643

Model Designation:

***Brita Aqua View On Tap Faucet
Filtration System AVFF-100***

System Type

Faucet Mount

Replacement Elements:

AVFR-200

Date Issued: April 29, 2009

Manufacturer: Brita LP

Rated Service Flow: 0.58 gpm

Rated Service Capacity: 100 gal

Technology: GAC

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Organic:

None

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Certificate #: 04- 1647

<u>Model Designation:</u> GE RO Filtration System GXRMI0RBL	<u>System Type</u> Under Counter	<u>Replacement Elements:</u> FX12M (RO Membrane) FX12P (Pre and Post Filters)
---	-------------------------------------	---

Date Issued: July 27, 2009

Manufacturer: General Electric Company

Rated Service Flow: 10 gpd

Rated Service Capacity: N/A

Technology: reverse osmosis

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Arsenic (pentavalent)¹

Barium

Cadmium

Chromium (hexalent)

Chromium (trivalent)

Copper

Fluoride

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

None

Certificate #: 04- 1650

<u>Model Designation:</u> T.F.C.-335	<u>System Type</u> Under Counter	<u>Replacement Elements:</u> S7028 (prefilter) S1229RS (membrane) S7025 (post filter)
 T.F.C.-435	 Under Counter	 S7028 (prefilter) S1229RS (membrane) S7025 (first post filter) S7206W-JG (second post filter)

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: June 29, 2009

Manufacturer: Microline

Rated Service Flow: 14 gal/day

Rated Service Capacity: not applicable

Technology: reverse osmosis

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Inorganic/Radiological:

Arsenic (pentavalent)¹

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Fluoride

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

None

Certificate #: 04- 1651

Model Designation:

Rayne Pure Plus

System Type

Under Counter

Replacement Elements:

S7028RC (prefilter)

S1229RS (membrane)

S7025RC (first post filter)

S7206W-JG (second post filter)

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Date Issued: June 29, 2009

Manufacturer: Rayne Corporation

Rated Service Flow: 14 gal/day

Rated Service Capacity: not applicable

Technology: reverse osmosis

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Inorganic/Radiological:

Arsenic (pentavalent)¹

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Fluoride

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

None

Certificate #: 04- 1660

Model Designation:

Samsung DA61-00159A-B

System Type

In Line
Refrigerator

Replacement Elements:

DA29-00003

Samsung DA97-06317A

In Line
Refrigerator

DA29-00003G

Date Issued: July 7, 2009

Manufacturer: Cuno Incorporated

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 300 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Benzene

Carbofuran

p-Dichlorobenzene

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 04- 1661

Model Designation:

RWF DISP

System Type

In Line
Refrigerator

Replacement Elements:

RWF DISP

Date Issued: August 26, 2009

Manufacturer: Viking Range Corporation

Rated Service Flow: 0.78 gpm

Rated Service Capacity: 750 gals

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Atrazine

Lindane

Toxaphene

Certificate #: 04- 1665

Model Designation:

Mach 2030S

System Type

Water Softener

Replacement Elements:

None

Date Issued: October 13, 2009

Manufacturer: Kinetico Incorporated

Rated Service Flow: 9 gpm

Rated Service Capacity: Not Applicable

Technology: ion exchange

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Barium

Radium 226/228

Organic:

None

Certificate #: 04- 1666

Model Designation:

Mach 2040S OD

System Type

Water Softener

Replacement Elements:

None

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: October 13, 2009

Manufacturer: Kinetico Incorporated

Rated Service Flow: 11 gpm

Rated Service Capacity: Not Applicable

Technology: ion exchange

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Barium

Radium 226/228

Organic:

None

Certificate #: 04- 1667

Model Designation:

Mach 2060 S

System Type

Water Softener

Replacement Elements:

None

Date Issued: October 13, 2009

Manufacturer: Kinetico Incorporated

Rated Service Flow: 11.5 gpm

Rated Service Capacity: Not Applicable

Technology: ion exchange

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Barium

Radium 226/228

Organic:

None

Certificate #: 04- 1668

Model Designation:

Mach 2060 S OD

System Type

Water Softener

Replacement Elements:

None

Date Issued: October 13, 2009

Manufacturer: Kinetico Incorporated

Rated Service Flow: 20 gpm

Rated Service Capacity: Not Applicable

Technology: ion exchange

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Barium

Radium 226/228

Organic:

None

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 04- 1669

Model Designation:

Mach 2100 S

System Type

Water Softener

Replacement Elements:

None

Date Issued: October 13, 2009

Manufacturer: Kinetico Incorporated

Rated Service Flow: 12 gpm

Rated Service Capacity: Not Applicable

Technology: ion exchange

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Barium

Radium 226/228

Organic:

None

Certificate #: 04- 1670

Model Designation:

Mach 2100 S OD

System Type

Water Softener

Replacement Elements:

None

Date Issued: October 13, 2009

Manufacturer: Kinetico Incorporated

Rated Service Flow: 21 gpm

Rated Service Capacity: Not Applicable

Technology: ion exchange

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Barium

Radium 226/228

Organic:

None

Certificate #: 04- 1672

Model Designation:

Mach 4040 S OD

System Type

Water Softener

Replacement Elements:

None

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Date Issued: October 13, 2009

Manufacturer: Kinetico Incorporated

Rated Service Flow: 11 gpm

Rated Service Capacity: Not Applicable

Technology: ion exchange

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Barium

Radium 226/228

Organic:

None

Certificate #: 05- 1677

Model Designation:

GE Smartwater PXRQ15F

System Type

Under Counter

Replacement Elements:

FQROPF (Pre and Post Filter)
FQROMF (Membrane)

GE Smartwater PNRQ15FBL

Under Counter

FQROPF (Pre and Post Filter)
FQROMF (Membrane)

GE Smartwater PXRQ15RBL

Under Counter

FQROPF (Pre and Post Filter)
FQROMF (Membrane)

GE Smartwater PNRQ15RBL

Under Counter

FQROPF (Pre and Post Filter)
FQROMF (Membrane)

Date Issued: January 6, 2005

Date Revised: April 30, 2010

Manufacturer: General Electric Company

Rated Service Flow: 8.46 gpd

Rated Service Capacity: 900 gal

Technology: reverse osmosis

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Arsenic¹

Asbestos

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Lead

Selenium

Organic:

None

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 05- 1684

Model Designation:

General Electric GXSF18G

System Type

Water Softener

Replacement Elements:

None

Date Issued: January 15, 2010

Manufacturer: General Electric Company

Rated Service Flow: 7 gpm

Rated Service Capacity: N/A

Technology: ion exchange

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Barium

Radium 226/228

Organic:

None

Certificate #: 05- 1698

Model Designation:

GE MWF

System Type

In Line
Refrigerator

Replacement Elements:

MWF

Date Issued: February 2, 2010

Manufacturer: General Electric Company

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 300 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Atrazine

Benzene

Carbofuran

Endrin

Lindane

Tetrachloroethylene

Toxaphene

1,4-dichlorobenzene

2, 4-D

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Certificate #: 05- 1702

<u>Model Designation:</u>	<u>System Type</u>	<u>Replacement Elements:</u>
<i>Whirlpool Deluxe T1WG2</i>	In Line Refrigerator	T2RFGW2
<i>Whirlpool Deluxe T1WG2L</i>	In Line Refrigerator	T2RFGW2
<i>KitchenAid Deluxe T1WG2</i>	In Line Refrigerator	T2RFGW2
<i>KitchenAid Deluxe T1WG2L</i>	In Line Refrigerator	T2RFGW2

Date Issued: April 6, 2010

Manufacturer: Whirlpool Corporation

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 200 gals

Technology: carbon block

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:
Microbiological/Turbidity:
 None
Inorganic/Radiological:
 Lead
 Mercury
Organic:
 Benzene
 Carbofuran
 o-Dichlorobenzene
 Toxaphene

Certificate #: 05- 1703

<u>Model Designation:</u>	<u>System Type</u>	<u>Replacement Elements:</u>
<i>Whirlpool Deluxe T2WG2</i>	In Line Refrigerator	T2RFGW2
<i>Whirlpool Deluxe T2WG2L</i>	In Line Refrigerator	T2RFGW2
<i>KitchenAid Deluxe T2WG2</i>	In Line Refrigerator	T2RFGW2
<i>KitchenAid Deluxe T2WG2L</i>	In Line Refrigerator	T2RFGW2

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: April 6, 2010

Manufacturer: Whirlpool Corporation

Rated Service Flow: 0.85 gpm

Rated Service Capacity: 200 gals

Technology: carbon block

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Lead

Mercury

Organic:

Benzene

Carbofuran

o-Dichlorobenzene

Toxaphene

Certificate #: 05- 1704

Model Designation:

Micromax 6500 TFC

System Type

Under Counter

Replacement Elements:

47-126001PRI Sediment Prefilter

66-5706PRI RO Module

47-227001PRI Post Filter

47-125001PRI Carbon Prefilter

Date Issued: December 12, 2005

Manufacturer: Puronics Water Systems,
Inc.

Rated Service Flow: 10.9 gal/day

Rated Service Capacity: n/a

Technology: reverse osmosis

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Arsenic (pentavalent)¹

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Fluoride

Lead

Radium 226/228

Selenium

Organic:

None

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Certificate #: 05- 1706

<u>Model Designation:</u>	<u>System Type</u>	<u>Replacement Elements:</u>
<i>GE Profile PNRQ20FBL</i>	Under Counter	FQROPF Prefilter FQROMF Membrane FQROPF Postfilter
<i>GE Profile PNRQ20FBB</i>	Under Counter	FQROPF Prefilter FQROMF Membrane FQROPF Postfilter
<i>GE Profile PNRQ20FCC</i>	Under Counter	FQROPF Prefilter FQROMF Membrane FQROPF Postfilter
<i>GE Profile PNRQ20FWW</i>	Under Counter	FQROPF Prefilter FQROMF Membrane FQROPF Postfilter
<i>GE Profile PNRQ21LRB</i>	Under Counter	FQROPF Prefilter FQROMF Membrane FQROPF Postfilter
<i>GE Profile PNRQ21LBN</i>	Under Counter	FQROPF Prefilter FQROMF Membrane FQROPF Postfilter
<i>GE Profile PNRQ21LBC</i>	Under Counter	FQROPF Prefilter FQROMF Membrane FQROPF Postfilter
<i>GE Profile PNRQ20RBL</i>	Under Counter	FQROPF Prefilter FQROMF Membrane FQROPF Postfilter
<i>GE Profile PNRQ21RBN</i>	Under Counter	FQROPF Prefilter FQROMF Membrane FQROPF Postfilter
<i>GE Profile PNRQ21RRB</i>	Under Counter	FQROPF Prefilter FQROMF Membrane FQROPF Postfilter

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: April 18, 2010

Manufacturer: General Electric Company

Rated Service Flow: 13.16 gpd

Rated Service Capacity: 900 gal

Technology: reverse osmosis

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. System has been tested for reduction of arsenic at concentrations of 0.050 mg/L or less. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Arsenic¹

Asbestos

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Lead

Selenium

Organic:

None

Certificate #: 05- 1708

Model Designation:

Sub-Zero 4290510

System Type

In Line
Refrigerator

Replacement Elements:

4204490

Date Issued: April 18, 2010

Manufacturer: 3M Purification Inc.

Rated Service Flow: 0.78 gpm

Rated Service Capacity: 750 gals

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Atrazine

Benzene

Carbofuran

Lindane

p-dichlorobenzene

Toxaphene

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 05- 1711

<u>Model Designation:</u>	<u>System Type</u>	<u>Replacement Elements:</u>
<i>Hague WaterMax 52 AMQ</i>	Water Softener	N/A
<i>Hague WaterMax 62 AMQ</i>	Water Softener	N/A

Date Issued: June 22, 2010

Manufacturer: Hague Quality Water,
International

Rated Service Flow: 8 gpm

Rated Service Capacity: N/A

Technology: ion exchange

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Barium

Radium 226/228

Organic:

None

Certificate #: 05- 1712

<u>Model Designation:</u>	<u>System Type</u>	<u>Replacement Elements:</u>
<i>Hague Watermax 52 APQ</i>	Water Softener	N/A
<i>Hague Watermax 62 APQ</i>	Water Softener	N/A

Date Issued: June 22, 2010

Manufacturer: Hague Quality Water,
International

Rated Service Flow: 8 gpm

Rated Service Capacity: N/A

Technology: ion exchange

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Barium

Radium 226/228

Organic:

None

Certificate #: 05- 1713

<u>Model Designation:</u>	<u>System Type</u>	<u>Replacement Elements:</u>
<i>Hague WaterMax 53 BEQ</i>	Water Softener	N/A
<i>Hague WaterMax 63 BEQ</i>	Water Softener	N/A

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: June 22, 2010

Manufacturer: Hague Quality Water,
International

Rated Service Flow: 8 gpm

Rated Service Capacity: N/A

Technology: ion exchange

Comments:

Do not use with water that is
microbiologically unsafe or of unknown
quality, without adequate disinfection before
or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Barium

Radium 226/228

Organic:

None

Certificate #: 05- 1714

Model Designation:

Hague WaterMax 53 MAQ

Hague WaterMax 63 MAQ

System Type

Water Softener

Water Softener

Replacement Elements:

N/A

N/A

Date Issued: June 22, 2010

Manufacturer: Hague Quality Water,
International

Rated Service Flow: 8 gpm

Rated Service Capacity: N/A

Technology: ion exchange

Comments:

Do not use with water that is
microbiologically unsafe or of unknown
quality, without adequate disinfection before
or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Barium

Radium 226/228

Organic:

None

Certificate #: 05- 1715

Model Designation:

Hague WaterMax 53 MXQ

Hague WaterMax 63 MXQ

System Type

Water Softener

Water Softener

Replacement Elements:

N/A

N/A

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: June 22, 2010

Manufacturer: Hague Quality Water,
International

Rated Service Flow: 8 gpm

Rated Service Capacity: N/A

Technology: ion exchange

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Barium

Radium 226/228

Organic:

None

Certificate #: 05- 1717

Model Designation:

Hague Maximizer 96 MM

System Type

Water Softener

Replacement Elements:

N/A

Date Issued: June 22, 2010

Manufacturer: Hague Quality Water,
International

Rated Service Flow: 8 gpm

Rated Service Capacity: N/A

Technology: ion exchange

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Barium

Radium 226/228

Organic:

None

Certificate #: 05- 1718

Model Designation:

Waterboss 700

System Type

Water Softener

Replacement Elements:

N/A

Date Issued: December 21, 2010

Manufacturer: Waterboss

Rated Service Flow: 8 gpm

Rated Service Capacity: N/A

Technology: ion exchange

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Barium

Radium 226/228

Organic:

None

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 05- 1719

Model Designation:

Waterboss 900

System Type

Water Softener

Replacement Elements:

N/A

Date Issued: December 21, 2010

Manufacturer: Waterboss

Rated Service Flow: 8 gpm

Rated Service Capacity: N/A

Technology: ion exchange

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Barium

Radium 226/228

Organic:

None

Certificate #: 05- 1720

Model Designation:

Waterboss 950

System Type

Water Softener

Replacement Elements:

N/A

Date Issued: December 21, 2010

Manufacturer: Waterboss

Rated Service Flow: 8 gpm

Rated Service Capacity: N/A

Technology: ion exchange

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Barium

Radium 226/228

Organic:

None

Certificate #: 05- 1728

Model Designation:

WP-2-LCV

System Type

Under Counter

Replacement Elements:

Sediment Pre-filter: 104023

Lead, Cysts, VOC Filter: #101014

Lead, Cysts, VOC Filter: #101014

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: August 17, 2005

Manufacturer: Watts Premier

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 600 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

Lead

Organic:

VOCs

Certificate #: 06- 1729

Model Designation:

Everpure S-104

System Type

Under Counter

Replacement Elements:

S-104

Date Issued: May 5, 2006

Manufacturer: Everpure, Inc.

Rated Service Flow: 1000 gallons

Rated Service Capacity: 0.5 gpm

Technology: GAC

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems claiming cyst reduction may be used on water containing cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Organic:

None

Certificate #: 05- 1730

Model Designation:

Micromax 6000 TFC

System Type

Plumbed In To
Separate Tap

Replacement Elements:

47-124001PRI Sediment Prefilter
66-5706PRI RO Module
47-227001PRI Post Filter

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: December 12, 2005

Manufacturer: Puronics Water Systems,
Inc.

Rated Service Flow: 10.9 gal/day

Rated Service Capacity: N/A

Technology: reverse osmosis

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Arsenic (pentavalent)¹

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Fluoride

Lead

Radium 226/228

Selenium

Organic:

None

Certificate #: 06- 1732

<u>Model Designation:</u>	<u>System Type</u>	<u>Replacement Elements:</u>
WP4-50	Under Counter	membrane: 110019
RO4M-50	Under Counter	membrane: 110019
RO5M-50	Under Counter	membrane: 110019
WP5-50	Under Counter	membrane: 110019

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: June 27, 2006

Date Revised: December 3, 2007

Manufacturer: Watts Premier

Rated Service Flow: 17.32 gpd

Rated Service Capacity: N/A

Technology: reverse osmosis

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Arsenic¹ (pentavalent)

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Fluoride

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Perchlorate (≤ 100 ug/L)³

Organic:

None

Certificate #: 06- 1735

Model Designation:

Kuna Water Cleone-2

System Type

Under Counter

Replacement Elements:

CL-20 20 micron Sediment Prefilter

CL-5 5 micron Sediment Prefilter

CL-C Activated Carbon Prefilter

CL-TFC-43-E RO Membrane Element

CL-Inline Activated Carbon Postfilter

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: March 13, 2006

Date Revised: September 14, 2007

Manufacturer: Kuna Group AB

Rated Service Flow: 60.8 gpd

Rated Service Capacity: N/A

Technology: reverse osmosis

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

*This system is acceptable for treatment of influent concentrations of no more than 27 mg/L nitrate and 3 mg/L nitrite in combination measured as N and is certified for nitrate/nitrite reduction only for water supplies with a pressure of 280 kPa (40 psig) or greater. A sampling and analysis test kit for nitrate is provided for checking the

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Copper

Fluoride

Lead

Nitrate/Nitrite*

Organic:

None

Certificate #: 05- 1736

Model Designation:

Multi-Pure MPAD

Multi-Pure MPADC

System Type

Counter Top

Counter Top

Replacement Elements:

CB6AD

CBTAD

Date Issued: October 20, 2010

Manufacturer: Multi-Pure Drinking
Water Systems

Rated Service Flow: 0.75 gpm

Rated Service Capacity: 750 gals

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Chlordane

MTBE

PCB

Toxaphene

VOCs

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 07- 1737

Model Designation:

WF-FM100

System Type

Faucet Mount

Replacement Elements:

WF-FMC100

Date Issued: January 5, 2007

Manufacturer: Protect Plus, LLC

Rated Service Flow: 0.6 gpm

Rated Service Capacity: 100 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Benzene

Carbofuran

Dinoseb

Lindane

Tetrachloroethylene

Certificate #: 07- 1739

Model Designation:

Dupont WF-PT100

System Type

Pour Through

Replacement Elements:

WF-PTC100

Date Issued: January 11, 2007

Manufacturer: Protect Plus, LLC

Rated Service Flow: 2.0 gpm

Rated Service Capacity: 40 gal

Technology: carbon block

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Cadmium

Lead

Mercury

Organic:

Atrazine

Carbofuran

Lindane

1,2,4-Trichlorobenzene

Certificate #: 07- 1740

Model Designation:

Dupont WF-PT350

System Type

Pour Through

Replacement Elements:

WF-PTC100

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: January 11, 2007

Manufacturer: Protect Plus, LLC

Rated Service Flow: 2.0 gpm

Rated Service Capacity: 120 gal

Technology: carbon block

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Cadmium

Lead

Mercury

Organic:

Atrazine

Carbofuran

Lindane

1,2,4-Trichlorobenzene

Certificate #: 07- 1743

Model Designation:

WF-FM100

System Type

Faucet Mount

Replacement Elements:

WF-FMC300

Date Issued: January 5, 2007

Manufacturer: Protect Plus, LLC

Rated Service Flow: 0.6 gpm

Rated Service Capacity: 100 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Atrazine

Benzene

Carbofuran

Dinoseb

Lindane

Tetrachloroethylene

2,4-D

Certificate #: 07- 1744

Model Designation:

Dupont WF-PT100

System Type

Pour Through

Replacement Elements:

WF-PTC300

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: January 11, 2007

Manufacturer: Protect Plus, LLC

Rated Service Flow: 2.0 gpm

Rated Service Capacity: 40 gal

Technology: carbon block

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Cadmium

Lead

Mercury

Organic:

Atrazine

Carbofuran

Chlorobenzene

Endrin

Lindane

Methoxychlor

Simazine

Tetrachloroethylene

1,2-Dichlorobenzene

1,2,4-Trichlorobenzene

Certificate #: 07- 1745

Model Designation:

Dupont WF-PT350

System Type

Pour Through

Replacement Elements:

WF-PTC300

Date Issued: January 11, 2007

Manufacturer: Protect Plus, LLC

Rated Service Flow: 2.0 gpm

Rated Service Capacity: 120 gal

Technology: carbon block

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Cadmium

Lead

Mercury

Organic:

Atrazine

Carbofuran

Chlorobenzene

Endrin

Lindane

Methoxychlor

Simazine

Tetrachloroethylene

1,2-Dichlorobenzene

1,2,4-Trichlorobenzene

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 08- 1747

Model Designation:

AC-30 2 gal, AC-30M 3 gal, AC-30L 9 gal, AC-30 Plus 2 gal w/PID, AC-30M Plus 3 gal w/PID, AC-30L Plus 9 gal w/PID

System Type

Under Counter

Replacement Elements:

00401538 Pre Filter
01007402 Membrane
01004768 Polishing Post Filter

Date Issued: May 20, 2008

Manufacturer: Culligan International

Rated Service Flow: n/a

Rated Service Capacity: n/a

Technology: reverse osmosis

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

This is a protocol certificate only and will be used to support testing of a device.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Lead

Radium 226/228

Selenium

Organic:

None

Certificate #: 05- 1749

Model Designation:

*Brita Faucet Filtration System
OPFF-100*

System Type

Faucet Mount

Replacement Elements:

FR-200

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: December 13, 2005

Date Revised: October 28, 2010

Manufacturer: Brita LP

Rated Service Flow: 0.58 gal

Rated Service Capacity: 100 gallons

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems claiming cyst reduction may be used on water containing cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Organic:

Atrazine

Benzene

Lindane

Trichloroethylene

Alachlor

Carbofuran

Chlordane

2,4-D

Carbon tetrachloride

Endrin

o-Dichlorobenzene

VOCs

Ethylbenzene

Methoxychlor

Styrene

Chlorobenzene

Toluene

Tetrachloroethylene

Toxaphene

Trihalomethanes (THMs)

Simazine

Certificate #: 06- 1772

Model Designation:

MACguard 7500

System Type

Under Counter

Replacement Elements:

9308

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: February 2, 2006

Manufacturer: Kinetico Incorporated

Rated Service Flow: 0.75 gpm

Rated Service Capacity: 500 gallons

Technology: mechanical

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems claiming cyst reduction may be used on water containing cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Inorganic/Radiological:

Lead

Organic:

MTBE

VOCs

Certificate #: 06- 1773

Model Designation:

DA97-03175A

System Type

Integrated
Refrigerator

Replacement Elements:

DA29-00012A

Date Issued: February 1, 2011

Manufacturer: Cuno Incorporated

Rated Service Flow: 0.75 gpm

Rated Service Capacity: 300 gallons

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Atrazine

Benzene

Carbofuran

Lindane

p-dichlorobenzene

Toxaphene

2-4, D

Certificate #: 06- 1774

Model Designation:

Kenmore 5231JA2006-S

System Type

In Line
Refrigerator

Replacement Elements:

5231JA2006

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: January 12, 2006

Manufacturer: Sears Roebuck and
Company

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 300 gallons

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Lead

Mercury

Organic:

Atrazine

Benzene

Lindane

2, 4-D

Certificate #: 06- 1775

Model Designation:

9000 077095 Bosch

System Type

In Line
Refrigerator

Replacement Elements:

9000 077104

Miele 07134220

In Line
Refrigerator

07134220

9000 077096 Daewoo

In Line
Refrigerator

9000 077104

Date Issued: March 10, 2006

Date Revised: March 9, 2009

Manufacturer: Cuno, Incorporated

Rated Service Flow: 0.75 gpm

Rated Service Capacity: 740 gals

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

None

Organic:

None

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 05- 1776

Model Designation:

Whirlpool WHCF-IMTOL

System Type

In Line
Refrigerator

Replacement Elements:

WHCF-IMTOL

Date Issued: December 21, 2005

Manufacturer: Whirlpool Corporation

Rated Service Flow: 0.78 gpm

Rated Service Capacity: 750 gallons w/o

Technology: mechanical/carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Lead

Organic:

None

Certificate #: 06- 1777

Model Designation:

EcoWater EWS VOC

System Type

Under Counter

Replacement Elements:

EWS VOC

Date Issued: June 15, 2006

Manufacturer: EcoWater Systems

Rated Service Flow: 0.6 gpm

Rated Service Capacity: 250 gallons

Technology: carbon block

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

None

Organic:

MTBE

VOCs

Certificate #: 06- 1780

Model Designation:

Whirlpool WHER25

System Type

Under Counter

Replacement Elements:

Pre/Post-filter: WHERF
RO membrane: WHEERM

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: June 22, 2006

Manufacturer: Ecodyne Water Systems
LLC

Rated Service Flow: 14.53 gals

Rated Service Capacity: not applicable

Technology: reverse osmosis

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Arsenic¹ (pentavalent)

Asbestos

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

None

Certificate #: 06-1781

Model Designation:

Dacor AFF4

System Type

In Line
Refrigerator

Replacement Elements:

AFF4

Date Issued: March 13, 2006

Manufacturer: Cuno, Incorporated

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 416 gals

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Benzene

Carbofuran

p-dichlorobenzene

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Certificate #: 06- 1783

<u>Model Designation:</u>	<u>System Type</u>	<u>Replacement Elements:</u>
<i>EcoWater ERO-375E-CP</i>	Under Counter	Pre/Post filter: 7278913 RO Membrane: 7278905
<i>EcoWater ERO-375E-BN</i>	Under Counter	Pre/Post filter: 7278913 RO Membrane: 7278905
<i>EcoWater ERO-375E-WH</i>	Under Counter	Pre/Post filter: 7278913 RO Membrane: 7278905
<i>EcoWater ERO-375-CP</i>	Under Counter	Pre/Post filter: 7278913 RO Membrane: 7278905
<i>EcoWater ERO-375-BN</i>	Under Counter	Pre/Post filter: 7278913 RO Membrane: 7278905
<i>EcoWater ERO-375-WH</i>	Under Counter	Pre/Post filter: 7278913 RO Membrane: 7278905
<i>EcoWater ERO-375-BK</i>	Under Counter	Pre/Post filter: 7278913 RO Membrane: 7278905
<i>EcoWater ERO-375E-BK</i>	Under Counter	Pre/Post filter: 7278913 RO Membrane: 7278905
<i>EcoWater ERO-375-RB</i>	Under Counter	Pre/Post filter: 7278913 RO Membrane: 7278905
<i>EcoWater ERO-375E-RB</i>	Under Counter	Pre/Post filter: 7278913 RO Membrane: 7278905
<i>EcoWater HERO-375E-WH</i>	Under Counter	Pre/Post filter: 7278913 RO Membrane: 7278905
<i>EcoWater HERO-375E-CP</i>	Under Counter	Pre/Post filter: 7278913 RO Membrane: 7278905
<i>EcoWater HERO-375E-BN</i>	Under Counter	Pre/Post filter: 7278913 RO Membrane: 7278905
<i>EcoWater HERO-375E-BK</i>	Under Counter	Pre/Post filter: 7278913 RO Membrane: 7278905
<i>EcoWater HERO-375E-RB</i>	Under Counter	Pre/Post filter: 7278913 RO Membrane: 7278905

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: April 24, 2006

Date Revised: June 19, 2008

Manufacturer: EcoWater Systems

Rated Service Flow: 17.4 gallons/day

Rated Service Capacity: not applicable

Technology: reverse osmosis

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Arsenic¹ (pentavalent)

Asbestos

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Lead

Nitrate/Nitrite

Radium 226/228

Selenium

Organic:

None

Certificate #: 06- 1786

Model Designation:

WIC-600

System Type

In Line

Replacement Elements:

600R

DW-600

In Line

600R

Date Issued: March 9, 2006

Manufacturer: American Plumber

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 500 gals

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Lead

Organic:

Atrazine

Lindane

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Certificate #: 06- 1787

<u>Model Designation:</u>	<u>System Type</u>	<u>Replacement Elements:</u>
<i>UKF9001AXX-100</i>	In Line Refrigerator	UKF8001
<i>Kenmore 46 9992-100</i>	In Line Refrigerator	46 9006

Date Issued: April 6, 2006

Revised: June 25, 2010

Manufacturer: 3M Purification

Rated Service Flow: 0.55 gpm

Rated Service Capacity: 100 gals

Technology: mechanical/carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Atrazine

Benzene

Carbofuran

Chlorobenzene

o-dichlorobenzene

p-dichlorobenzene

Endrin

Ethylbenzene

Lindane

MTBE

Tetrachloroethylene

Toxaphene

VOCs by chloroform surrogate

Certificate #: 06- 1789

<u>Model Designation:</u>	<u>System Type</u>	<u>Replacement Elements:</u>
<i>PUR 2-Stage DS-1800Z</i>	Pour Through	CRF-950Z
<i>PUR 2-Stage CR-6000</i>	Pour Through	CRF-950Z
<i>PUR 2-Stage CR-6000C</i>	Pour Through	CRF-950Z
<i>PUR 2-Stage CR-5000</i>	Pour Through	CRF-950Z
<i>PUR 2-Stage CR-4000</i>	Pour Through	CRF-950Z

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: April 25, 2006

Date Revised: Dec. 17, 2010

Manufacturer: The Procter and Gamble
Company

Rated Service Flow: N/A

Rated Service Capacity: 40 gal

Technology: GAC

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Inorganic/Radiological:

Cadmium

Copper

Mercury

Organic:

Atrazine

Benzene

Carbon tetrachloride

Simazine

Tetrachloroethylene

2, 4-D

Certificate #: 06-1790

Model Designation:

Viking, RWFFR-750

System Type

In Line
Refrigerator

Replacement Elements:

RWFFR

Date Issued: June 1, 2006

Manufacturer: CUNO Incorporated, a 3M
Company

Rated Service Flow: 0.78 gpm

Rated Service Capacity: 750 gals

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Atrazine

Benzene

Carbofuran

Lindane

p-Dichlorobenzene

Toxaphene

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Certificate #: 06- 1791

<u>Model Designation:</u>	<u>System Type</u>	<u>Replacement Elements:</u>
Clear ₂ O CWS100A	Faucet Line Pitcher	CWF100, CWF101, CWF103, CWF1012, CWF1014, CWF1016, CWF1032, CWF1034
Clear ₂ O CWS100A2	Faucet Line Pitcher	CWF100, CWF101, CWF103, CWF1012, CWF1014, CWF1016, CWF1032, CWF1034
Clear ₂ O CWS100AW	Faucet Line Pitcher	CWF100, CWF101, CWF103, CWF1012, CWF1014, CWF1016, CWF1032, CWF1034
Clear ₂ O CWS100B	Faucet Line Pitcher	CWF100, CWF101, CWF103, CWF1012, CWF1014, CWF1016, CWF1032, CWF1034
Clear ₂ O CWS100B2	Faucet Line Pitcher	CWF100, CWF101, CWF103, CWF1012, CWF1014, CWF1016, CWF1032, CWF1034

Date Issued: June 2, 2006
Date Revised: February 20, 2008
Manufacturer: Applica Consumer
 Products, Inc.
Rated Service Flow: 1 gpm
Rated Service Capacity: 50 gals
Technology: carbon block
Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:
Microbiological/Turbidity:
 Cysts
 Turbidity
Inorganic/Radiological:
 Asbestos
 Cadmium
 Lead
 Mercury
Organic:
 MTBE
 Toxaphene
 VOCs

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 06- 1792

Model Designation:
Aquasana, AQ-4000

System Type
Counter Top

Replacement Elements:
AQ-4025

Date Issued: July 28, 2006

Manufacturer: Sun Water Systems, Inc.

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 500 gals

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:
Cysts

Inorganic/Radiological:
Lead

Organic:
MTBE
VOCs

Certificate #: 06- 1793

Model Designation:
Aqua Pure, AP easy Cyst - FF

System Type
In Line

Replacement Elements:
AP easy C-Cysts - FF

Date Issued: June 2, 2006

Manufacturer: Cuno, Incorporated, a 3M company

Rated Service Flow: 1.5 gpm

Rated Service Capacity: 2000 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:
Cysts

Inorganic/Radiological:
None

Organic:
None

Certificate #: 06- 1795

Model Designation:
ChoiceFlo F7425

System Type
Under Counter

Replacement Elements:
9500
9501
9600
9601

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

<i>ChoiceFlo F7430</i>	Under Counter	9500 9501 9600 9601
<i>ChoiceFlo F7434</i>	Under Counter	9500 9501 9600 9601
<i>ChoiceFlo F87244</i>	Under Counter	9500 9501 9600 9601
<i>ChoiceFlo F87254</i>	Under Counter	9500 9501 9600 9601
<i>ChoiceFlo F87264</i>	Under Counter	9500 9501 9600 9601
<i>ChoiceFlo F87420</i>	Under Counter	9500 9501 9600 9601
<i>ChoiceFlo F87424</i>	Under Counter	9500 9501 9600 9601
<i>ChoiceFlo F87440</i>	Under Counter	9500 9501 9600 9601
<i>ChoiceFlo F87444</i>	Under Counter	9500 9501 9600 9601

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: June 6, 2006

Manufacturer: Moen Incorporated

Rated Service Flow: 1.0 gpm

Rated Service Capacity: 750 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Lead

Mercury

Organic:

Atrazine

Lindane

Toxaphene

Certificate #: 06-1797

Model Designation:

Homespring UF 211C

System Type

Point Of Entry

Replacement Elements:

26017 Mechanical Filtration

23107 12" SS Mesh Pre-Filter

Homespring UFC 211C

Point Of Entry

26017 Mechanical Filtration

23106 12" GAC - Taste and Odor

Date Issued: July 24, 2006

Manufacturer: Zenon Environmental Inc.

Rated Service Flow: 4.5 gpm

Rated Service Capacity: 130,000 gal

Technology: mechanical/GAC

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

None

Organic:

None

Certificate #: 06-1800

Model Designation:

Sylvan Source M-600

System Type

Wall Mount

Replacement Elements:

None

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Date Issued: June 20, 2006

Date Revised: October 12, 2006

Manufacturer: Sylvan Source

Rated Service Flow: not applicable

Rated Service Capacity: not applicable

Technology: distillation

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

¹This system is acceptable for treatment of influent perchlorate concentrations of no more than 100 ug/L.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Arsenic (pentavalent)

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Fluoride

Lead

Mercury

Perchlorate (≤ 100 ug/L)¹

Selenium

Organic:

None

Certificate #: 06- 1801

Model Designation:

EC4 150 CV

System Type

Point Of Entry

Replacement Elements:

N/A

Date Issued: July 28, 2006

Manufacturer: RainSoft Div of Aquion
Water Treatment Products

Rated Service Flow: 10.4 gpm

Rated Service Capacity: N/A

Technology: ion exchange

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Barium

Radium 226/228

Organic:

None

Certificate #: 06- 1802

Model Designation:

EC4 100 CV

System Type

Point Of Entry

Replacement Elements:

N/A

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Date Issued: July 18, 2006

Manufacturer: Cuno Incorporated

Rated Service Flow: 0.78 gpm

Rated Service Capacity: 750 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Atrazine

Benzene

Carbofuran

Lindane

p-dichlorobenzene

Toxaphene

Certificate #: 06- 1807

Model Designation:

Choice Flo 77200

System Type

Under Counter

Replacement Elements:

9500

9501

9502

Aquasuite

Under Counter

9600

9601

9602

Date Issued: July 31, 2006

Manufacturer: Moen Incorporated

Rated Service Flow: 1.0 gpm

Rated Service Capacity: 750 gals

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

turbidity

Inorganic/Radiological:

Lead

Mercury

Organic:

Atrazine

Lindane

Toxaphene

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Certificate #: 06- 1810

<u>Model Designation:</u>	<u>System Type</u>	<u>Replacement Elements:</u>
Kenmore 625.384260	Water Softener	N/A
Kenmore 625.394260	Water Softener	N/A

Date Issued: August 14, 2006

Manufacturer: Sears Roebuck & Company

Rated Service Flow: 9.5 gpm

Rated Service Capacity: n/a

Technology: ion exchange

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Barium

Radium 226/228

Organic:

None

Certificate #: 06- 1812

<u>Model Designation:</u>	<u>System Type</u>	<u>Replacement Elements:</u>
006820860	In Line Refrigerator	0060218743

Date Issued: August 22, 2006

Manufacturer: Cuno Incorporated

Rated Service Flow: 0.75 gpm

Rated Service Capacity: 750 gals

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Atrazine

Benzene

Carbofuran

Lindane

Toxaphene

1,4 dichlorobenzene

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Certificate #: 06- 1813

<u>Model Designation:</u>	<u>System Type</u>	<u>Replacement Elements:</u>
<i>Kenmore Ultra filter 450 625.381560</i>	Under Counter	42-38056 Filter 3857705 Membrane
<i>Kenmore Ultra filter 650 625.385560</i>	Under Counter	42-38056 Filter 3857705 Membrane

Date Issued: October 12, 2006

Manufacturer: Sears Roebuck and Company

Rated Service Flow: 14.53 gpd

Rated Service Capacity: n/a

Technology: reverse osmosis

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Arsenic¹ (pentavalent)

Asbestos

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

None

Certificate #: 06- 1815

<u>Model Designation:</u>	<u>System Type</u>	<u>Replacement Elements:</u>
<i>Cuno Aqua Pure AP-RO5500</i>	Under Counter	5598101 5608401

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: August 17, 2006

Manufacturer: Cuno Incorporated

Rated Service Flow: 11 gpd

Rated Service Capacity: n/a

Technology: reverse osmosis

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Arsenic¹ (pentavalent)

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Fluoride

Lead

Radium 226/228

Selenium

Organic:

None

Certificate #: 06- 1816

Model Designation:

Culligan International WP-1

System Type

Pour Through

Replacement Elements:

WP-1R

Date Issued: August 25, 2006

Manufacturer: Culligan International

Rated Service Flow: n/a

Rated Service Capacity: 50 gals

Technology: GAC/ion exchange

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Copper

Mercury

Organic:

None

Certificate #: 06- 1821

Model Designation:

Pi Mag Deluxe 13151

System Type

Under Counter

Replacement Elements:

13152

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: September 29, 2006

Manufacturer: Nikken

Rated Service Flow: 0.75 gpm

Rated Service Capacity: 800 gals

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Lead

Organic:

MTBE

VOCs

Certificate #: 06-1822

Model Designation:

PiMag Deluxe 13155

System Type

Under Counter

Replacement Elements:

13152

Date Issued: September 29, 2006

Manufacturer: Nikken

Rated Service Flow: 0.75 gpm

Rated Service Capacity: 800 gals

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Lead

Organic:

MTBE

VOCs

Certificate #: 06-1823

Model Designation:

*PUR 2-Stage Pitcher w/ Flavor Options
CR-5000*

System Type

Pour Through

Replacement Elements:

CRF-950Z

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: September 25, 2006

Date Revised: August 27, 2010

Manufacturer: The Procter and Gamble
Company

Rated Service Flow: 2 gpd

Rated Service Capacity: 40 gals

Technology: GAC

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

*Lead reduction tested by PACE Analytical Services Inc., to the 2005 NSF/ANSI Standard 53. These devices are **not certified** to the **current** NSF/ANSI Drinking Water Standards for Lead reduction requirements.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Inorganic/Radiological:

Cadmium

Copper

*Lead *NSF/ANSI Std 53 2005

Mercury

Organic:

Atrazine

Benzene

Carbofuran

Simazine

Tetrachloroethylene

Toluene

Trihalomethanes

2, 4-D

Certificate #: 06- 1824

Model Designation:

*PUR 3-Stage Horizontal w/ Flavor
Options FM-5050W*

System Type

Pour Through

Replacement Elements:

RF-9999

*PUR 3-Stage Horizontal w/ Flavor
Options FM-5050C*

Pour Through

RF-9999

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: September 25, 2006

Manufacturer: The Procter and Gamble
Company

Rated Service Flow: 0.66 gpm

Rated Service Capacity: 100 gals

Technology: GAC

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Alachlor

Atrazine

Benzene

Carbofuran

Carbon Tetrachloride

Chlordane

Endrin

Ethylbenzene

Heptachlor Epoxide

Lindane

Methoxychlor

Monochlorobenzene

MTBE

o-Dichlorobenzene

Simazine

Styrene

Tetrachloroethylene

Toluene

Toxaphene

Trichloroethylene

Trihalomethane

2, 4-D

2, 4, 5-TP

Certificate #: 06-1826

Model Designation:

Omni Filter CBF1 Series A

System Type

Under Counter

Replacement Elements:

CB1 Series A

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: October 12, 2006

Manufacturer: Omni Filter

Rated Service Flow: 1.0 gpm

Rated Service Capacity: 1,000 gals

Technology: mechanical/carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

None

Organic:

None

Certificate #: 06-1827

Model Designation:

Omni Filter CBF3 Series B

System Type

Under Counter

Replacement Elements:

CB3 Series B

Date Issued: October 12, 2006

Manufacturer: Omni Filter

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 400 gals

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

MTBE

VOCs

Certificate #: 06-1828

Model Designation:

GXPL03H

System Type

Pour Through

Replacement Elements:

FXPL3CAD

Date Issued: October 12, 2006

Manufacturer: General Electric

Rated Service Flow: n/a

Rated Service Capacity: 40 gals

Technology: GAC/ion exchange

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Cadmium

Copper

Lead

Mercury

Organic:

None

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 07- 1833

Model Designation:

*Sub Zero Biomatrikx Carbon Block
200-075-50M-075*

System Type

Component

Replacement Elements:

Certification is for component.

Date Issued: February 6, 2007

Manufacturer: KX Industries L.P.

Rated Service Flow: 0.5 gpm

Rated Service Capacity: Variable

Technology: carbon block

Comments:

Do not use for the treatment of water that is visually contaminated (cloudy) or has an obvious contamination source, such as contamination by raw sewage.

Complete candidate systems must pass the Microbiological Interception Protocol for Validation of KX Industries Carbon Treatment Technology - State of California (CA DHS), version 3-17-05 for health claims of cysts, bacteria and virus.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Bacteria

Virus

Inorganic/Radiological:

None

Organic:

None

Certificate #: 06- 1834

Model Designation:

GE MSWF

System Type

In Line
Refrigerator

Replacement Elements:

MSWF

Date Issued: December 6, 2006

Manufacturer: General Electric Company

Rated Service Flow: 0.90 gpm

Rated Service Capacity: 300 gals

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Atrazine

Benzene

Carbofluran

Lindane

p-Dichlorobenzene

Toxaphene

2, 4-D

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 06- 1835

Model Designation:

EcoPure ECOP20

System Type

Under Counter

Replacement Elements:

ECODWF

Date Issued: December 21, 2006

Manufacturer: Ecodyne

Rated Service Flow: 0.6 gpm

Rated Service Capacity: 270 gals

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

Lead

Organic:

MTBE

VOCs

Certificate #: 06- 1836

Model Designation:

EcoPure ECOP30

System Type

Under Counter

Replacement Elements:

ECOROF pre/post filter

ECOROM RO Membrane

Date Issued: December 21, 2006

Manufacturer: Ecodyne

Rated Service Flow: 14.53 gal/day

Rated Service Capacity: n/a

Technology: reverse osmosis

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Arsenic¹ (pentavalent)

Asbestos

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

None

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 07- 1837

Model Designation:

WF-FM350

System Type

Faucet Mount

Replacement Elements:

WF-FMC100

Date Issued: January 5, 2007

Manufacturer: Protect Plus, LLC

Rated Service Flow: 0.45 gpm

Rated Service Capacity: 200 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Benzene

Carbofuran

Dinoseb

Lindane

Tetrachloroethylene

Certificate #: 07- 1838

Model Designation:

WF-FM350

System Type

Faucet Mount

Replacement Elements:

WF-FMC300

Date Issued: January 5, 2007

Manufacturer: Protect Plus, LLC

Rated Service Flow: 0.45 gpm

Rated Service Capacity: 200 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Atrazine

Benzene

Carbofuran

Dinoseb

Lindane

Tetrachloroethylene

2,4-D

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 07- 1839

Model Designation:

Fresca Pure FP3000

System Type

Counter Top

Replacement Elements:

RC-30-FP

Date Issued: February 1, 2007

Manufacturer: Royal Prestige

Rated Service Flow: 0.75 gpm

Rated Service Capacity: 480 gallons

Technology: carbon block

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Lead

Organic:

MTBE

Certificate #: 07- 1851

Model Designation:

Omni Filter OT32 Series "B"

System Type

Under Counter

Replacement Elements:

CB3 Series "B"

RS2

Date Issued: March 8, 2007

Manufacturer: OmniFilter, A Division of
STA-RITE

Rated Service Flow: 0.5gpm

Rated Service Capacity: 400 gallons

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems claiming cyst reduction may be used on water containing cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Inorganic/Radiological:

Lead

Asbestos

Mercury

Organic:

MTBE

VOCs

Certificate #: 07- 1852

Model Designation:

Kenmore 46-38446

System Type

In Line
Refrigerator

Replacement Elements:

None

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: July 23, 2007
Revised September 15, 2010
Manufacturer: Sears Roebuck
Rated Service Flow: 0.5 gpm
Rated Service Capacity: 2,000 gal
Technology: carbon block
Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:
Cysts
Inorganic/Radiological:
Lead
Organic:
None

Certificate #: 07- 1853

Model Designation:

InSinkErator F-201

System Type

Under Counter

Replacement Elements:

F 601R

Date Issued: May 3, 2007
Manufacturer: InSinkErator
Rated Service Flow: 1.0 gpm
Rated Service Capacity: 500 gals
Technology: carbon block
Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:
Cysts
Inorganic/Radiological:
Asbestos
Lead
Mercury
Organic:
Atrazine
Benzene
Carbofuran
Lindane
p-dichlorobenzene
2,4-D

Certificate #: 08- 1854

Model Designation:

NeoPack P-5200L

System Type

Counter Top

Replacement Elements:

WJSF11-PLUS Plus Sediment Filter
WJCF8-PRE Pre-carbon Filter
WJMF11S-30 RO Membrane Filter
WJCF8-POST Post-carbon Filter
WJCC-02 Ceramic Filter

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

CHUNG CHUL I P-03CL

Counter Top

WJSF11-PLUS Plus Sediment Filter
WJCF8-PRE Pre-carbon Filter
WJMF11S-30 RO Membrane Filter
WJCF8-POST Post-carbon Filter
WJFF7 Fine Filter

Date Issued: June 24, 2008

Manufacturer: Woongjin Coway Co LTD

Rated Service Flow: 0.07 gpm

Rated Service Capacity: 210 gal

Technology: RO/GAC/Mech

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Arsenic (Pentavalent)¹

Barium

Cadmium

Chromium (Hexavalent)

Chromium (Trivalent)

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

VOCs

Certificate #: 08- 1855

Model Designation:

NeoPack P-5200R

System Type

Counter Top

Replacement Elements:

WJSF11-PLUS Plus Sediment Filter
WJCF8-PRE Pre-carbon Filter
WJMF11-50 RO Membrane Filter
WJCF8-POST Post-carbon Filter
WJCC-02 Ceramic Filter

CHUNG CHUL I P-03CR

Counter Top

WJSF11-PLUS Plus Sediment Filter
WJCF8-PRE Pre-carbon Filter
WJMF11-50 RO Membrane Filter
WJCF8-POST Post-carbon Filter
WJFF7 Fine Filter

CHUNG CHUL II P-03DR

Counter Top

WJSF11-PLUS Plus Sediment Filter
WJCF8-PRE Pre-carbon Filter
WJMF11-50 RO Membrane Filter
WJCF8-POST Post-carbon Filter
WJFF7 Fine Filter

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: June 24, 2008

Manufacturer: Woongjin Coway Co LTD

Rated Service Flow: 0.07 gpm

Rated Service Capacity: 210 gal

Technology: RO/GAC/Mech

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Arsenic (Pentavalent)¹

Barium

Cadmium

Chromium (Hexavalent)

Chromium (Trivalent)

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

VOCs

Certificate #: 08- 1856

Model Designation:

Lyon CP-01CL

System Type

Counter Top

Replacement Elements:

WJSF11-PLUS Plus Sediment Filter

WJCF8-PRE Pre-carbon Filter

WJMF11S-30 RO Membrane Filter

WJCF8-POST Post-carbon Filter

WJCC-02 Ceramic Filter

Date Issued: June 24, 2008

Manufacturer: Woongjin Coway Co LTD

Rated Service Flow: 0.07 gpm

Rated Service Capacity: 210 gal

Technology: RO/GAC/Mech

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Arsenic (Pentavalent)¹

Barium

Cadmium

Chromium (Hexavalent)

Chromium (Trivalent)

Lead

Mercury

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

VOCs

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 08- 1857

Model Designation:

Lyon CP-01CR

System Type

Counter Top

Replacement Elements:

WJSF11-PLUS Plus Sediment Filter
WJCF8-PRE Pre-carbon Filter
WJMF11-50 RO Membrane Filter
WJCF8-POST Post-carbon Filter
WJCC-02 Ceramic Filter

Date Issued: June 24, 2008

Manufacturer: Woongjin Coway Co LTD

Rated Service Flow: 0.07 gpm

Rated Service Capacity: 210 gal

Technology: RO/GAC/Mech

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Arsenic (Pentavalent)¹

Barium

Cadmium

Chromium (Hexavalent)

Chromium (Trivalent)

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

VOCs

Certificate #: 08- 1862

Model Designation:

Locky CP-03BL

System Type

Counter Top

Replacement Elements:

WJNF11 Neo-Sense Filter
WJMF11S-30 RO Membrane Filter
WJCF8-POST Post-carbon Filter
WJFF7 Fine Filter
WJCC-02 Ceramic Filter

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: June 24, 2008

Manufacturer: Woongjin Coway Co LTD

Rated Service Flow: 0.07 gpm

Rated Service Capacity: 197 gal

Technology: RO/GAC/Mech

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Arsenic (Pentavalent)¹

Barium

Cadmium

Chromium (Hexavalent)

Chromium (Trivalent)

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

VOCs

Certificate #: 08- 1863

Model Designation:

Locky CP-03BR

System Type

Counter Top

Replacement Elements:

WJNF11 Neo-Sense Filter

WJMF11-50 RO Membrane Filter

WJCF8-POST Post-carbon Filter

WJFF7 Fine Filter

WJCC-02 Ceramic Filter

Date Issued: June 24, 2008

Manufacturer: Woongjin Coway Co LTD

Rated Service Flow: 0.07 gpm

Rated Service Capacity: 197 gal

Technology: RO/GAC/Mech

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Arsenic (Pentavalent)¹

Barium

Cadmium

Chromium (Hexavalent)

Chromium (Trivalent)

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

VOCs

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 08- 1864

Model Designation:

Nurisu CHP-01BL

System Type

Counter Top

Replacement Elements:

WJSF11-PLUS Plus Sediment Filter
WJCF8-PRE Pre-carbon Filter
WJMF11S-30 RO Membrane Filter
WJCF11-POST Post-carbon Filter
WJCC-02 Ceramic Filter

Date Issued: June 24, 2008

Manufacturer: Woongjin Coway Co LTD

Rated Service Flow: 0.07 gpm

Rated Service Capacity: 251 gal

Technology: RO/GAC/Mech

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Arsenic (Pentavalent)¹

Barium

Cadmium

Chromium (Hexavalent)

Chromium (Trivalent)

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

VOCs

Certificate #: 08- 1865

Model Designation:

Nurisu CHP-01BR

System Type

Counter Top

Replacement Elements:

WJSF11-PLUS Plus Sediment Filter
WJCF8-PRE Pre-carbon Filter
WJMF11-50 RO Membrane Filter
WJCF11-POST Post-carbon Filter
WJCC-02 Ceramic Filter

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: June 24, 2008

Manufacturer: Woongjin Coway Co LTD

Rated Service Flow: 0.07 gpm

Rated Service Capacity: 251 gal

Technology: RO/GAC/Mech

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Arsenic (Pentavalent)¹

Barium

Cadmium

Chromium (Hexavalent)

Chromium (Trivalent)

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

VOCs

Certificate #: 08- 1866

Model Designation:

Mach CHP-03AL

System Type

Counter Top

Replacement Elements:

WJNF11 Neo-Sense Filter

WJMF11S-30 RO Membrane Filter

WJCF11-POST Post-carbon Filter

WJFF7 Fine Filter

WJCC-02 Ceramic Filter

Date Issued: June 24, 2008

Manufacturer: Woongjin Coway Co LTD

Rated Service Flow: 0.07 gpm

Rated Service Capacity: 229 gal

Technology: RO/GAC/Mech

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Arsenic (Pentavalent)¹

Barium

Cadmium

Chromium (Hexavalent)

Chromium (Trivalent)

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

VOCs

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 08- 1867

Model Designation:

Mach CHP-03AR

System Type

Counter Top

Replacement Elements:

WJNF11 Neo-Sense Filter
WJMF11-50 RO Membrane Filter
WJCF11-POST Post-carbon Filter
WJFF7 Fine Filter
WJCC-02 Ceramic Filter

Date Issued: June 24, 2008

Manufacturer: Woongjin Coway Co LTD

Rated Service Flow: 0.07 gpm

Rated Service Capacity: 229 gal

Technology: RO/GAC/Mech

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Arsenic (Pentavalent)¹

Barium

Cadmium

Chromium (Hexavalent)

Chromium (Trivalent)

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

VOCs

Certificate #: 08- 1868

Model Designation:

Calas CHP-01AL

System Type

Counter Top

Replacement Elements:

WJSF14-PLUS Plus Sediment Filter
WJCF14-PRE Pre-carbon Filter
WJMF14-50 RO Membrane Filter
WJCF14-POST Post-carbon Filter
WJUVF-4W-PUMP UV Bulb

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: June 24, 2008

Manufacturer: Woongjin Coway Co LTD

Rated Service Flow: 0.07 gpm

Rated Service Capacity: 359 gal

Technology: RO/GAC/Mech

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Arsenic (Pentavalent)¹

Barium

Cadmium

Chromium (Hexavalent)

Chromium (Trivalent)

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

VOCs

Certificate #: 08- 1869

Model Designation:

Taupo CHP-05AL

System Type

Counter Top

Replacement Elements:

WJNF11 Neo-Sense Filter

WJMF11S-30 RO Membrane Filter

WJFCF11-POST Post-carbon Filter

WJCC-02 Ceramic Filter

Date Issued: June 24, 2008

Manufacturer: Woongjin Coway Co LTD

Rated Service Flow: 0.07 gpm

Rated Service Capacity: 229 gal

Technology: RO/GAC/Mech

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Arsenic (Pentavalent)¹

Barium

Cadmium

Chromium (Hexavalent)

Chromium (Trivalent)

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

VOCs

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 07- 1871

Model Designation:

Kenmore 625.385010

System Type

Under Counter

Replacement Elements:

42-34381

Date Issued: June 7, 2007

Manufacturer: Sears Roebuck and
Company

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 270 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

Lead

Organic:

MTBE

VOCs

Certificate #: 07- 1872

Model Designation:

PIT-1

System Type

Pour Through

Replacement Elements:

PR-1

PR-3

Date Issued: June 11, 2007

Manufacturer: Culligan International

Rated Service Flow: 2.5 gpd

Rated Service Capacity: 50 gal

Technology: carbon block/ion exchange

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Copper

Mercury

Organic:

None

Certificate #: 10- 1873

Model Designation:

System Type

Under Counter

Replacement Elements:

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: March 26, 2010

Manufacturer: Culligan International
Company

Rated Service Flow:

Rated Service Capacity:

Technology: RO/Ion Exchange

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

This is a protocol certificate only and will be used to support testing of a device.

Contaminants Reduced:

Microbiological/Turbidity:

Inorganic/Radiological:

Arsenic III

Organic:

Certificate #: 07- 1881

Model Designation:

GE GXULQ

System Type

Under Counter

Replacement Elements:

GXULQR

GE GNULQ

Under Counter

GXULQR

Date Issued: July 6, 2007

Manufacturer: General Electric Company

Rated Service Flow: 2 gpm

Rated Service Capacity: 2000 gal

Technology: carbon block

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

Turbidity

Inorganic/Radiological:

None

Organic:

None

Certificate #: 07- 1882

Model Designation:

RO-Pure 531401/533401

System Type

Under Counter

Replacement Elements:

105351 Sediment Pre-Filter

105351 Carbon Pre-Filter

105331 RO Membrane

105341 Carbon Post-Filter

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Date Issued: September 21, 2007

Manufacturer: Watts Premier

Rated Service Flow: N/A

Rated Service Capacity: N/A

Technology: reverse osmosis/carbon

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

Arsenic¹

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Fluoride

Lead

Nitrate / Nitrite²

Perchlorate

Selenium

Organic:

None

Certificate #: 07- 1883

Model Designation:

WFM-17

System Type

Faucet Mount

Replacement Elements:

WFM-17R

Date Issued: August 31, 2007

Manufacturer: Culligan International

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 200 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Lead

Organic:

Atrazine

Lindane

Certificate #: 07- 1884

Model Designation:

QRS 844 H

System Type

Point Of Entry

Replacement Elements:

14826 Carbon Filter

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: September 14, 2007
Manufacturer: RainSoft div of Aquion
Water Treatment Products
Rated Service Flow: 6 gpm
Rated Service Capacity: 20,250 gal
Technology: GAC
Comments:
Do not use with water that is
microbiologically unsafe or of unknown
quality, without adequate disinfection before
or after the system.

Contaminants Reduced:
Microbiological/Turbidity:
None
Inorganic/Radiological:
None
Organic:
VOCs

Certificate #: 07- 1885

Model Designation:

QRS 1044 H

System Type

Point Of Entry

Replacement Elements:

14826 Carbon Filter

Date Issued: September 14, 2007
Manufacturer: RainSoft div of Aquion
Water Treatment Products
Rated Service Flow: 8 gpm
Rated Service Capacity: 31,500 gal
Technology: GAC
Comments:
Do not use with water that is
microbiologically unsafe or of unknown
quality, without adequate disinfection before
or after the system.

Contaminants Reduced:
Microbiological/Turbidity:
None
Inorganic/Radiological:
None
Organic:
VOCs

Certificate #: 07- 1887

Model Designation:

WCH-1500

System Type

Pour Through

Replacement Elements:

GF-80

WCH-1500BY

Pour Through

GF-80

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Date Issued: September 10, 2007

Revised October, 6, 2010

Manufacturer: Conair Corporation
(Cuisinart Division)

Rated Service Flow: 48 gal

Rated Service Capacity:

Technology: GAC

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Cadmium

Copper

Mercury

Lead

Organic:

Benzene

Tetrachloroethylene

Toluene

Certificate #: 07- 1889

Model Designation:

P3200C

System Type

Counter Top

Replacement Elements:

2902RC

P3200W

Counter Top

2902RC

Date Issued: October 22, 2007

Manufacturer: Paragon Water Systems

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 500 gals

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Lead

Mercury

Organic:

MTBE

VOCs

Certificate #: 08- 1895

Model Designation:

PIWG2

System Type

In Line
Refrigerator

Replacement Elements:

P2RFGW2

PIWG2L

In Line
Refrigerator

P2RFGW2

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Date Issued: March 24, 2008

Manufacturer: Whirlpool Corp

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 200 gal

Technology: carbon block

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Lead

Mercury

Organic:

Benzene

O-dichlorobenzene

Toxaphene

Certificate #: 08- 1896

Model Designation:

P2WG2

System Type

In Line
Refrigerator

Replacement Elements:

P2RFGW2

P2WG2L

In Line
Refrigerator

P2RFGW2

Date Issued: March 24, 2008

Manufacturer: Whirlpool Corp

Rated Service Flow: 0.85 gpm

Rated Service Capacity: 200 gal

Technology: carbon block

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Lead

Mercury

Organic:

Benzene

O-dichlorobenzene

Toxaphene

Certificate #: 08- 1900

Model Designation:

Good Water Machine AC-30

System Type

Under Counter

Replacement Elements:

Particulate Prefilter: 00-4015-38
GAC Prefilter: 01-0125-80
RO Module: 01-0074-02 or
GAC Postfilter: 01-0042-91

Good Water Machine AC-30 PLUS

Under Counter

Particulate Prefilter: 00-4015-38
GAC Prefilter: 01-0125-80
RO Module: 01-0074-02 or
GAC Postfilter: 01-0042-91

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Date Issued: August 13, 2008

Manufacturer: Culligan International

Rated Service Flow: 14.5 gpd

Rated Service Capacity: n/a

Technology: RO/GAC/Carbon Block

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Lead

Radium 226/228

Selenium

Organic:

None

Certificate #: 08- 1901

Model Designation:

Good Water Machine AC-30M

System Type

Under Counter

Replacement Elements:

Particulate Prefilter: 00-4015-38

GAC Prefilter: 01-0125-80

RO Module: 01-0074-02 or

GAC Postfilter: 01-0042-91

Good Water Machine AC-30M Plus

Under Counter

Particulate Prefilter: 00-4015-38

GAC Prefilter: 01-0125-80

RO Module: 01-0074-02 or

GAC Postfilter: 01-0042-91

Date Issued: August 13, 2008

Manufacturer: Culligan International

Rated Service Flow: 11.8 gpd

Rated Service Capacity: n/a

Technology: RO/GAC/Carbon Block

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Lead

Radium 226/228

Selenium

Organic:

None

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 08- 1902

Model Designation:

SQC3

System Type

Under Counter

Replacement Elements:

Sediment/Carbon prefilter
R.O. Membrane 66-4706G2
Carbon post filter 47-55710G2

SQC4

Under Counter

Sediment prefilter 47-55702G2
Carbon prefilter 47-55704G2
R.O. Membrane 66-4706G2
Carbon post filter 47-55710G2

Date Issued: March 20, 2008

Manufacturer: CUNO Inc., a 3M
Company

Rated Service Flow: 8.28 gallons/day

Rated Service Capacity: not applicable

Technology: reverse osmosis

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Arsenic ¹ (Pentavalent)

Barium

Cadmium

Chromium (Hexavalent)

Chromium (Trivalent)

Copper

Fluoride

Lead

Radium 226 / 228

Selenium

Organic:

None

Certificate #: 08- 1904

Model Designation:

Metro CHP-04AL

System Type

Counter Top

Replacement Elements:

WJSF14-PLUS Plus Sediment Filter
WJCF14-PRE Pre-carbon Filter
WJMF14-50 RO Membrane Filter
WJFCF14-POST Post-carbon Filter
WJUUVF-4W-PUMP UV Bulb

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: June 24, 2008

Manufacturer: Woongjin Coway Co LTD

Rated Service Flow: 0.07 gpm

Rated Service Capacity: 359 gal

Technology: RO/GAC/Mech

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Arsenic (Pentavalent)¹

Barium

Cadmium

Chromium (Hexavalent)

Chromium (Trivalent)

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

VOCs

Certificate #: 08- 1905

Model Designation:

Metro CHP-04AR

System Type

Counter Top

Replacement Elements:

WJSF14-PLUS Plus Sediment Filter

WJCF14-PRE Pre-carbon Filter

WJMF14-75 RO Membrane Filter

WJFCF14-POST Post-carbon Filter

WJUUVF-4W-PUMP UV Bulb

Date Issued: June 24, 2008

Manufacturer: Woongjin Coway Co LTD

Rated Service Flow: 0.07 gpm

Rated Service Capacity: 359 gal

Technology: RO/GAC/Mech

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Arsenic (Pentavalent)¹

Barium

Cadmium

Chromium (Hexavalent)

Chromium (Trivalent)

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

VOCs

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 08- 1906

Model Designation:

Sally CHP-06EL

System Type

Counter Top

Replacement Elements:

WJNF14 Neo-Sense Filter
WJMF14-50 RO Membrane Filter
WJFCF14-POST Post-carbon Filter
WJCC-02 Ceramic Filter

Date Issued: June 24, 2008

Manufacturer: Woongjin Coway Co LTD

Rated Service Flow: 0.07 gpm

Rated Service Capacity: 282 gal

Technology: RO/GAC/Mech

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Arsenic (Pentavalent)¹

Barium

Cadmium

Chromium (Hexavalent)

Chromium (Trivalent)

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

VOCs

Certificate #: 08- 1907

Model Designation:

Sally CHP-06ER

System Type

Counter Top

Replacement Elements:

WJNF14 Neo-Sense Filter
WJMF14-75 RO Membrane Filter
WJFCF14-POST Post-carbon Filter
WJCC-02 Ceramic Filter

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Date Issued: June 24, 2008

Manufacturer: Woongjin Coway Co LTD

Rated Service Flow: 0.07 gpm

Rated Service Capacity: 282 gal

Technology: RO/GAC/Mech

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Arsenic (Pentavalent)¹

Barium

Cadmium

Chromium (Hexavalent)

Chromium (Trivalent)

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

VOCs

Certificate #: 08- 1909

Model Designation:

Good Water Machine AC-30L

System Type

Under Counter

Replacement Elements:

Particulate Prefilter: 00-4015-38

GAC Prefilter: 01-0125-80

RO Module: 01-0074-02 or

GAC Postfilter: 01-0042-91

Good Water Machine AC-30L PLUS

Under Counter

Particulate Prefilter: 00-4015-38

GAC Prefilter: 01-0125-80

RO Module: 01-0074-02 or

GAC Postfilter: 01-0042-91

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: August 13, 2008

Manufacturer: Culligan International

Rated Service Flow: 11.7 gpd

Rated Service Capacity: n/a

Technology: RO/GAC/Carbon Block

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Lead

Radium 226/228

Selenium

Organic:

None

Certificate #: 08- 1910

Model Designation:

Advanced Filtration System 3US-PS01

System Type

Under Counter

Replacement Elements:

3US-PF01

Date Issued: September 23, 2008

Date Revised: October 7, 2010

Manufacturer: Filtrete™ Brand from 3M

Rated Service Flow: 1.5 gpm

Rated Service Capacity: 2000 gallons

Technology: mechanical/GAC

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

None

Organic:

None

Certificate #: 08- 1911

Model Designation:

EP15/EP15

System Type

Under Counter

Replacement Elements:

EP15

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: October 16, 2008

Manufacturer: Cuno Inc. a 3M company

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 2000 gal

Technology: mechanical/GAC

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

None

Organic:

None

Certificate #: 08-1912

Model Designation:

WHKF-DUF-DB1

System Type

Under Counter

Replacement Elements:

WHKF-DB1

Date Issued: June 12, 2008

Manufacturer: Whirlpool Corporation

Rated Service Flow: 1.0 gpm

Rated Service Capacity: 1000 gallons

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

None

Organic:

None

Certificate #: 08-1913

Model Designation:

WHKF-IMTOL

System Type

In Line

Replacement Elements:

N/A

Date Issued: June 12, 2008

Manufacturer: Whirlpool Corporation

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 750 gallons

Technology: carbon block

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Lead

Organic:

None

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 08- 1915

Model Designation:

FM-2 Lead Plus

System Type

Under Counter

Replacement Elements:

47-55711G2

47-55707G2

Date Issued: December 18, 2008

Manufacturer: Cuno Inc. a 3M company

Rated Service Flow: 500 gpm

Rated Service Capacity: 0.6 gal

Technology: mechanical/carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Lead

Organic:

None

Certificate #: 08- 1916

Model Designation:

KWC PureStream Plus Z534.330

System Type

In Line

Replacement Elements:

Z.633.398

Date Issued: June 23, 2008

Manufacturer: Cuno Inc. a 3M company

Rated Service Flow: 0.92 gpm

Rated Service Capacity: 500 gal

Technology: mechanical/carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

Asbestos

Lead

Organic:

None

Certificate #: 09- 1917

Model Designation:

LINX 140

System Type

Under Counter

Replacement Elements:

LINX 100 TDS Cartridge

LINX 100 Sediment Filter

LINX 100 Carbon Filter

LINX Cooler

Under Counter

LINX 100 TDS Cartridge

LINX 100 Sediment Filter

LINX 100 Carbon Filter

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: November 10, 2009

Manufacturer: Pionetics Corporation

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 3.17 gal, 12 liters

Technology: Regenerative Ion Exchange

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

¹This system is acceptable for treatment of influent concentrations of no more than 27 mg/L nitrate and 3 mg/L nitrite in combination measured as N and is certified for nitrate/nitrite reduction only for water supplies with a pressure of 280 kPa (40 psig) or greater. A sampling and analysis test kit for nitrate is provided for checking the

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Nitrate/Nitrite¹

Organic:

None

Certificate #: 08-1918

Model Designation:

Whirlpool PIWB2L

System Type

In Line
Refrigerator

Replacement Elements:

P1RFBW2

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Date Issued: June 13, 2008

Manufacturer: Whirlpool Corporation

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 200 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Alachlor

Atrazine

Benzene

Chlorobenzene

Endrin

Ethylbenzene

Lindane

o-Dichlorobenzene

Styrene

Tetrachloroethylene

Toxaphene

Certificate #: 08-1919

Model Designation:

Whirlpool/ Kenmore P1KB2

Sears/Ultimate II P1KB2

System Type

In Line
Refrigerator

In Line
Refrigerator

Replacement Elements:

P1RFKB2

P1RFKB2

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: June 13, 2008

Manufacturer: Whirlpool Corporation

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 200 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Alachlor

Atrazine

Benzene

Chlorobenzene

Endrin

Ethylbenzene

Lindane

o-Dichlorobenzene

Styrene

Tetrachloroethylene

Toxaphene

Certificate #: 08-1920

Model Designation:

Whirlpool PIWB2

System Type

In Line
Refrigerator

Replacement Elements:

PIRFBW2

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: June 13, 2008

Manufacturer: Whirlpool Corporation

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 200 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Alachlor

Atrazine

Benzene

Chlorobenzene

Endrin

Ethylbenzene

Lindane

o-Dichlorobenzene

Styrene

Tetrachloroethylene

Toxaphene

Certificate #: 08-1921

Model Designation:

Whirlpool/Kenmore P1KB1

System Type

In Line
Refrigerator

Replacement Elements:

P1RFKB1

Sears/Ultimate II P1KB1

In Line
Refrigerator

P1RFKB1

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: June 13, 2008

Manufacturer: Whirlpool Corporation

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 100 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Alachlor

Atrazine

Benzene

Chlorobenzene

Endrin

Ethylbenzene

Lindane

VOCs

MTBE

o-Dichlorobenzene

Styrene

Tetrachloroethylene

Toxaphene

Trihalomethanes (TTHMs)

Certificate #: 08- 1922

Model Designation:

Whirlpool PWF-L400V

System Type

In Line
Refrigerator

Replacement Elements:

PL400V

Date Issued: June 12, 2008

Manufacturer: Whirlpool Corporation

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 400 gal

Technology: carbon block

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Lead

Mercury

Organic:

Benzene

Carbofuran

p-Dichlorobenzene

Toxaphene

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 08- 1923

Model Designation:

Whirlpool PWF-NL240V

System Type

In Line
Refrigerator

Replacement Elements:

PNL240V

Date Issued: June 12, 2008

Manufacturer: Whirlpool Corporation

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 240 gal

Technology: carbon block

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Lead

Mercury

Organic:

Benzene

Carbofuran

p-Dichlorobenzene

Toxaphene

Certificate #: 08- 1924

Model Designation:

Whirlpool UKF7003

System Type

In Line
Refrigerator

Replacement Elements:

UKF7003

Date Issued: June 12, 2008

Manufacturer: Whirlpool Corporation

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 250gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Lead

Organic:

None

Certificate #: 08- 1925

Model Designation:

UKF7003

System Type

In Line
Refrigerator

Replacement Elements:

UKF7003

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Date Issued: June 12, 2008

Manufacturer: Whirlpool Corporation

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 416 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Organic:

Benzene

Carbofuran

Certificate #: 08-1926

Model Designation:

Always Fresh H₂O HFC-1000

SEMPER CLEAR SCFF-PLUS

System Type

In Line

In Line

Replacement Elements:

RC-HFC-1000

RC-SCFF-PLUS

Date Issued: June 12, 2008

Revised: 6/30/2010

Manufacturer: Waterline Technology

Rated Service Flow: 1.5 gpm

Rated Service Capacity: 500 gal

Technology: Mech Filter/Carbon

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Lead

Organic:

MTBE

Trihalomethanes

VOCs

Certificate #: 08-1927

Model Designation:

Always Fresh H₂O SF-1000

Semper Clear SCSF-PLUS

System Type

In Line

In Line

Replacement Elements:

RC-SF-1000

RC-SCSF-PLUS

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: June 12, 2008

Revised: 6/30/2010

Manufacturer: Waterline Technology

Rated Service Flow: 0.75 gpm

Rated Service Capacity: 1000 gal

Technology: Mech Filter/Carbon

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Lead

Organic:

None

Certificate #: 10- 1928

Model Designation:

***Culligan International
Company Aqua-Cleer Advanced Drinking
Water System with RO30***

System Type

Under Counter

Replacement Elements:

RO-30 01020268 - RO Membrane

Date Issued: July 16, 2010

Manufacturer: Culligan

Rated Service Flow: 11.09 gpd

Rated Service Capacity: N/A

Technology: reverse osmosis

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Arsenic¹ (pentavalent) 50 ppb

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Fluoride

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

None

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 08- 1929

Model Designation:

***Woongjin Coway Co. LTD Wellion
CPE-06AL***

System Type

Counter Top

Replacement Elements:

WJSF11-PLUS
WJCF8-PRE
WJMF11-NF
WJIF11-S
WJCC-02

Date Issued: June 20, 2008

Manufacturer: Woongjin Coway Co.
LTD

Rated Service Flow: 0.07 gpm

Rated Service Capacity: 251 gal

Technology: Mech

Comments:

Do not use with water that is
microbiologically unsafe or of unknown
quality, without adequate disinfection before
or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

None

Organic:

VOCs

Certificate #: 08- 1930

Model Designation:

***Woongjin Coway Co. LTD Petit
CHP-06DL***

System Type

Counter Top

Replacement Elements:

WJNF8-S
WJFMF8-20-S
WJCC-02
WJIF8-S

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: August 20, 2008

Manufacturer: Woongjin Coway Co.
LTD

Rated Service Flow: 0.05 gpm

Rated Service Capacity: 165 gal

Technology: RO/GAC/Mech

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Arsenic (pentavalent)¹

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

VOCs

Certificate #: 08- 1931

Model Designation:

Body Glove BG-3000

System Type

Under Counter

Replacement Elements:

Body Glove BG-3000C

Date Issued: September 29, 2008

Date Revised: October 16, 2008

Manufacturer: 3M Brand from 3M

Rated Service Flow: 0.75 gpm

Rated Service Capacity: 450 gal

Technology: mechanical/carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

Asbestos

Lead

Organic:

Trihalomethanes

VOCs

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 08- 1932

Model Designation:

Body Glove BG-3000S

System Type

Under Counter

Replacement Elements:

BG-3000R

Date Issued: September 29, 2008

Date Revised: October 21, 2010

Manufacturer: 3M Brand from 3M

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 350 gal

Technology: mechanical/carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

Asbestos

Lead

Organic:

MTBE

Trihalomethanes

VOCs

Certificate #: 08- 1933

Model Designation:

Aqua Pure AP-DWS1000

System Type

Under Counter

Replacement Elements:

AP-DW80

AP-DW90

Date Issued: August 4, 2008

Manufacturer: Cuno Inc. a 3M company

Rated Service Flow: 0.6 gpm

Rated Service Capacity: 625 gal

Technology: mechanical/carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Lead

Organic:

MTBE

VOCs

Certificate #: 08- 1934

Model Designation:

*Woongjin Coway Co. LTD Lyon2
CP-07BL0*

System Type

Counter Top

Replacement Elements:

WJNF8-S

WJMF8-20-S

WJCC-02

WJIF8

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: September 11, 2008

Manufacturer: Woongjin Coway Co.
LTD

Rated Service Flow: 0.07 gpm

Rated Service Capacity: 165 gal

Technology: RO/GAC/Adsorptive

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Arsenic¹

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

VOCs

Certificate #: 08- 1935

Model Designation:

***Woongjin Coway Co. LTD VALUE P-07
QL***

System Type

Counter Top

Replacement Elements:

WJNF11

WJMF11S-30

WJIF8

WJCC-02

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: September 11, 2008

Manufacturer: Woongjin Coway Co.
LTD

Rated Service Flow: 0.07 gpm

Rated Service Capacity: 197 gal

Technology: RO/GAC/Adsorptive

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Arsenic¹

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

VOCs

Certificate #: 08- 1936

Model Designation:

***Whirlpool Corporation
WHKF-DUF-DB2***

System Type

Under Counter

Replacement Elements:

WHKF-DB2

Date Issued: July 23, 2008

Manufacturer: Whirlpool Corporation

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 400 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

MTBE

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 08- 1937

Model Designation:

Whirlpool Corporation WHKF-IMPLUS

System Type

In Line
Refrigerator

Replacement Elements:

WHKF-R-PLUS

Date Issued: July 23, 2008

Manufacturer: Whirlpool Corporation

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 240 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

2,4-D

Atrazine

Benzene

Toxaphene

p-Dichlorobenzene

Certificate #: 08- 1938

Model Designation:

Body Glove BG-1000

System Type

Under Counter

Replacement Elements:

BG-1000C

Date Issued: October 3, 2008

Date Revised: October 16, 2008

Manufacturer: 3M Brand from 3M

Rated Service Flow: 0.75 gpm

Rated Service Capacity: 1000 gal

Technology: mechanical/carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

Asbestos

Lead

Organic:

None

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 08- 1939

Model Designation:

Body Glove BG-12000

System Type

Under Counter

Replacement Elements:

BG-12000C

Date Issued: October 3, 2008

Date Revised: October 16, 2008

Manufacturer: 3M Brand from 3M

Rated Service Flow: 0.75 gpm

Rated Service Capacity: 1000 gal

Technology: mechanical/carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

Asbestos

Lead

Organic:

MTBE

TTHM

VOCs

Certificate #: 08- 1940

Model Designation:

*Zero Technologies, LLC ZeroWater
ZP-001*

System Type

Pour Through

Replacement Elements:

ZF-201

Date Issued: August 5, 2008

Date Revised: August 19, 2010

Manufacturer: Zero Technologies, LLC

Rated Service Flow: 4.5 gpd

Rated Service Capacity: 22.5 gal

Technology: Mech Filter/GAC/Ion

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Chromium (hexavalent)

Chromium (trivalent)

Lead

Mercury

Organic:

None

Certificate #: 09- 1941

Model Designation:

Complete

System Type

Under Counter

Replacement Elements:

C-Complete

Complete Cooler

Under Counter

C-Complete

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Date Issued: January 28, 2009

Manufacturer: Cuno Inc. a 3M company

Rated Service Flow: 0.75 gpm

Rated Service Capacity: 750 gal

Technology: mechanical/carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Atrazine

Benzene

Carbofuran

Lindane

p-Dichlorobenzene

Toxaphene

Certificate #: 09- 1942

Model Designation:

LC

System Type

Under Counter

Replacement Elements:

C-LC

LC Cooler

Under Counter

C-LC

Date Issued: January 28, 2009

Manufacturer: Cuno Inc. a 3M company

Rated Service Flow: 0.75 gpm

Rated Service Capacity: 750 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

Lead

Organic:

None

Certificate #: 10- 1944

Model Designation:

*Culligan International Company
Aqua-Clear Advanced Drinking Water
System with RO30 and TD*

System Type

Under Counter

Replacement Elements:

RO-30 01020268 - RO Membrane

TD-01020274 - Post Filter

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: July 16, 2010

Manufacturer: Culligan

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 1000 gals

Technology: RO w/ carbon

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Arsenic¹ (pentavalent) 50 ppb

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Fluoride

Lead

Mercury

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

MTBE

VOCs

Certificate #: 10- 1947

Model Designation:

***Culligan International Company
Aqua-Clear Advanced Drinking Water
System with TD***

System Type

Under Counter

Replacement Elements:

TD- 01020274

Date Issued: July 16, 2010

Manufacturer: Culligan

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 1000 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Lead

Mercury

Organic:

MTBE

VOCs

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 10- 1948

Model Designation:

***Culligan International Company Aqua
Cler Advanced Drinking Water System
with RO30 and AS3***

System Type

Under Counter

Replacement Elements:

RO-30 01020268 - RO Membrane
AS3 - P1020272 - Post Filter

Date Issued: July 16, 2010

Manufacturer: Culligan International
Company

Rated Service Flow: 0.035 gpm

Rated Service Capacity: 1000 gal

Technology: RO/Ion Exchange

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Arsenic¹ (pentavalent) 50 ppb

Arsenic¹ (trivalent) 50 ppb

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Fluoride

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

None

Certificate #: 10- 1949

Model Designation:

***Culligan International Company Aqua
Cler Advanced Drinking Water System
with RO30, TD and AS3***

System Type

Under Counter

Replacement Elements:

RO-30 01020268 - RO Membrane
TD - 01020274 - Post Filter
AS3 - P1020272 - Post Filter

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Date Issued: July 16, 2010

Manufacturer: Culligan International
Company

Rated Service Flow: 0.035 gpm

Rated Service Capacity: 1000 gal

Technology: RO/Ion/Carbon

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Arsenic¹ (pentavalent) 50 ppb

Arsenic¹ (trivalent) 50 ppb

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Fluoride

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

MTBE

VOCs

Certificate #: 08-1952

Model Designation:

GE SmartWater GX1S50R

GE SmartWater GXRLQ

System Type

Under Counter

Under Counter

Replacement Elements:

GXRLQR

GXRLQR

Date Issued: December 15, 2008

Date Revised: June 29, 2009

Manufacturer: GE Appliance

Rated Service Flow: 0.78 gpm

Rated Service Capacity: 750 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Atrazine

Lindane

Toxaphene

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 09- 1953

Model Designation:

Instapure Brands Inc. F5 Complete

System Type

Faucet Mount

Replacement Elements:

R5

Date Issued: March 24, 2009

Manufacturer: Instapure Brands Inc.

Rated Service Flow: 0.45 gpm

Rated Service Capacity: 200 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Inorganic/Radiological:

Lead

Organic:

None

Certificate #: 10- 1954

Model Designation:

*Culligan International Company
Aqua-Clear Advanced Drinking Water
System with RO30*

System Type

Under Counter

Replacement Elements:

RO-30 01020268 - RO Membrane

Date Issued: July 16, 2010

Manufacturer: Culligan International
Company

Rated Service Flow: 11.09 gpd

Rated Service Capacity: N/A

Technology: reverse osmosis

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Arsenic¹ (pentavalent) 50 ppb

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Fluoride

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

None

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 10- 1955

Model Designation:

***Culligan International Company
Aqua-Cleer Advanced Drinking Water
System with RO30***

System Type

Under Counter

Replacement Elements:

RO-30 01020268 - RO Membrane

Date Issued: July 16, 2010

Manufacturer: Culligan International
Company

Rated Service Flow: 11.09 gpd

Rated Service Capacity: N/A

Technology: reverse osmosis

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Arsenic¹ (pentavalent) 50 ppb

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Fluoride

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

None

Certificate #: 10- 1956

Model Designation:

***Culligan International Company
Aqua-Cleer Advanced Drinking Water
System with TD***

System Type

Under Counter

Replacement Elements:

TD- 01020274

Date Issued: July 16, 2010

Manufacturer: Culligan International
Company

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 1000 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Lead

Mercury

Organic:

MTBE

VOCs

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 10- 1957

Model Designation:

*Culligan International Company
Aqua-Clear Advanced Drinking Water
System with TD*

System Type

Under Counter

Replacement Elements:

TD- 01020274

Date Issued: July 16, 2010

Manufacturer: Culligan International
Company

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 1000 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Lead

Mercury

Organic:

MTBE

VOCs

Certificate #: 10- 1958

Model Designation:

*Culligan International Company
Aqua-Clear Advanced Drinking Water
System with RO30 and TD*

System Type

Under Counter

Replacement Elements:

RO-30 01020268 - RO Membrane

TD-01020274 - Post Filter

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: July 16, 2010

Manufacturer: Culligan International
Company

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 1000 gal

Technology: RO w/ carbon

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Arsenic¹ (pentavalent) 50 ppb

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Fluoride

Lead

Mercury

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

MTBE

VOCs

Certificate #: 10-1959

Model Designation:

***Culligan International Company
Aqua-Clear Advanced Drinking Water
System with RO30 and TD***

System Type

Under Counter

Replacement Elements:

RO-30 01020268 - RO Membrane

TD-01020274 - Post Filter

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: July 16, 2010

Manufacturer: Culligan International
Company

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 1000 gal

Technology: RO w/ carbon

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Arsenic¹ (pentavalent) 50 ppb

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Fluoride

Lead

Mercury

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

MTBE

VOCs

Certificate #: 10-1960

Model Designation:

***Culligan International Company
Aqua-Clear Advanced Drinking Water
System with RO30 and AS3***

System Type

Under Counter

Replacement Elements:

RO-30 01020268 - RO Membrane
AS3 - P1020272 - Post Filter

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: July 16, 2010

Manufacturer: Culligan International
Company

Rated Service Flow: 0.035 gpm

Rated Service Capacity: 1000 gal

Technology: RO/Ion Exchange

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Arsenic¹ (pentavalent) 50 ppb

Arsenic¹ (trivalent) 50 ppb

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Fluoride

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

None

Certificate #: 10- 1961

Model Designation:

***Culligan International Company
Aqua-Clear Advanced Drinking Water
System with RO30 and AS3***

System Type

Under Counter

Replacement Elements:

RO-30 01020268 - RO Membrane
AS3 - P1020272 - Post Filter

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: July 16, 2010

Manufacturer: Culligan International
Company

Rated Service Flow: 0.035 gpm

Rated Service Capacity: 1000 gal

Technology: RO/Ion Exchange

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Arsenic¹ (pentavalent) 50 ppb

Arsenic¹ (trivalent) 50 ppb

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Fluoride

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

None

Certificate #: 10- 1962

Model Designation:

***Culligan International Company
Aqua-Clear Advanced Drinking Water
System with RO30, TD and AS3***

System Type

Under Counter

Replacement Elements:

RO-30 01020268 - RO Membrane

TD - 01020274 - Post Filter

AS3 - P1020272 - Post Filter

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: July 16, 2010

Manufacturer: Culligan International
Company

Rated Service Flow: 0.035 gpm

Rated Service Capacity: 1000 gal

Technology: RO/Ion/Carbon

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Arsenic¹ (pentavalent) 50 ppb

Arsenic¹ (trivalent) 50 ppb

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Fluoride

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

MTBE

VOCs

Certificate #: 10- 1963

Model Designation:

***Culligan International Company
Aqua-Clear Advanced Drinking Water
System with RO30, TD and AS3***

System Type

Under Counter

Replacement Elements:

RO-30 01020268 - RO Membrane

TD - 01020274 - Post Filter

AS3 - P1020272 - Post Filter

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: July 16, 2010

Manufacturer: Culligan International
Company

Rated Service Flow: 0.035 gpm

Rated Service Capacity: 1000 gal

Technology: RO/Ion/Carbon

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Turbidity

Inorganic/Radiological:

Arsenic¹ (pentavalent) 50 ppb

Arsenic¹ (trivalent) 50 ppb

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Fluoride

Lead

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

MTBE

VOCs

Certificate #: 08-1972

Model Designation:

GE SmartWater GSWF

System Type

In Line

Replacement Elements:

GSWF

Date Issued: December 18, 2008

Manufacturer: GE Appliance

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 750 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Lead

Organic:

Atrazine

Lindane

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Certificate #: 09- 1973

<u>Model Designation:</u>	<u>System Type</u>	<u>Replacement Elements:</u>
<i>Electrolux Home Products PureSource Ultra(Icemaker Only)</i>	In Line	ULTRAWF

Date Issued: February 11, 2009
Date Revised 4/13/2010
Manufacturer: Electrolux Home Products
Rated Service Flow: 0.65 gpm
Rated Service Capacity: 200 gal (120 gal)
Technology: carbon block
Comments:
 Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:
Microbiological/Turbidity:
 Cysts (protozoan)
 Turbidity
Inorganic/Radiological:
 Asbestos
 Lead
 Mercury
Organic:
 Alachlor
 Atrazine
 Benzene
 Endrin
 Ethylbenzene
 Lindane
 Monochlorobenzene
 VOCs by surrogate
 MTBE
 o-dichlorobenzene
 Styrene
 Tetrachloroethylene
 Toxaphene
 Trihalomethanes
 1,2,4-trichlorobenzene

Certificate #: 09- 1975

<u>Model Designation:</u>	<u>System Type</u>	<u>Replacement Elements:</u>
<i>Mavea Marella XL</i>	Pour Through	Mavea Maxtra 1000894
<i>Mavea Acclaro</i>	Pour Through	Mavea Maxtra 1000894
<i>Mavea Acclaro XL</i>	Pour Through	Mavea Maxtra 1000894
<i>Elemaris Kompakt(Black, White, Ruby Red & Purple)</i>	Pour Through	Mavea Maxtra 1000894
<i>Mavea Elemaris XL (Black, White, Red, Blue, Purple, Smokey Black, Green & Orange)</i>	Pour Through	Mavea Maxtra 1000894

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Date Issued: February 26, 2009

Date Revised: January 12, 2011

Manufacturer: Mavea, LLC

Rated Service Flow: 2 gpd

Rated Service Capacity: 40gal

Technology: GAC/ion exchange

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Cadmium

Copper

Mercury

Organic:

Atrazine

Benzene

Tetrachloroethylene

Simazine

Certificate #: 09- 1976

Model Designation:

Whirlpool WHKF-SUFC

System Type

In Line

Replacement Elements:

WHKF-SRC

Date Issued: December 3, 2009

Manufacturer: Whirlpool

Rated Service Flow: 1.5 gpm

Rated Service Capacity: 2000 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

None

Organic:

None

Certificate #: 09- 1979

Model Designation:

UKF8001AXX-200

System Type

In Line

Replacement Elements:

UKF8001

Kenmore 46 9006-200

In Line

46 9006

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Date Issued: May 8, 2009

Date Revised: 6/22/2010

Manufacturer: 3M Purification

Rated Service Flow: 0.55 gpm

Rated Service Capacity: 200 gal

Technology: mechanical/carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Atrazine

Benzene

Carbofuran

Chlorobenzene

Endrin

Ethylbenzene

Lindane

o-dichlorobenzene

p-dichlorobenzene

Tetrachloroethylene

Toxaphene

2,4-D

Certificate #: 09- 1980

Model Designation:

NGRG-2000

System Type

In Line

Replacement Elements:

RC-900

NGRG-2000

In Line

WFCB

Date Issued: July 27, 2009

Manufacturer: Electrolux Home Products

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 400 gal

Technology: mechanical/carbon block

Comments:

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Lead

Organic:

2, 4-D

Atrazine

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 09- 1981

Model Designation:

H-54 Drinking Water System

System Type

Under Counter

Replacement Elements:

H-54

Date Issued: August 19, 2009

Manufacturer: Everpure, LLC

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 750 gal

Technology: mechanical/GAC

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

Lead

Organic:

None

Certificate #: 09- 1982

Model Designation:

H-104 Drinking Water System

System Type

Under Counter

Replacement Elements:

H-104

Date Issued: August 20, 2009

Manufacturer: Everpure, LLC

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 1000 gal

Technology: mechanical/GAC

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

Lead

Organic:

None

Certificate #: 09- 1983

Model Designation:

H-300+M Drinking Water System

System Type

Under Counter

Replacement Elements:

H-300+M

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Date Issued: August 19, 2009

Manufacturer: Everpure, LLC

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 500 gal

Technology: mechanical/GAC

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

Lead

Organic:

VOCs

Certificate #: 09- 1984

Model Designation:

H-1200 Drinking Water System

System Type

Under Counter

Replacement Elements:

H-1200 #1

H-1200 #2

Date Issued: August 19, 2009

Manufacturer: Everpure, LLC

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 1000 gal

Technology: mechanical/GAC

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

Lead

Organic:

MTBE

VOCs

Certificate #: 09- 1985

Model Designation:

***Culligan International Company Gold
14" Soft-Minder***

System Type

Water Softener

Replacement Elements:

N/A

***Culligan International Company Gold
14" Aqua-Sensor***

Water Softener

N/A

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Date Issued: June 4, 2009

Manufacturer: Culligan International
Company

Rated Service Flow: 10.6 gpm

Rated Service Capacity: N/A

Technology: ion exchange

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Barium

Radium

Organic:

None

Certificate #: 09- 1986

Model Designation:

***Culligan International Company Gold 9”
Soft-Minder***

System Type

Water Softener

Replacement Elements:

N/A

***Culligan International Company Gold 9”
Aqua-Sensor***

Water Softener

N/A

Date Issued: June 4, 2009

Manufacturer: Culligan International
Company

Rated Service Flow: 9 gpm

Rated Service Capacity: N/A

Technology: ion exchange

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Barium

Radium

Organic:

None

Certificate #: 09- 1987

Model Designation:

***Culligan International Company
Medallist 8” Timeclock***

System Type

Water Softener

Replacement Elements:

N/A

***Culligan International Company
Medallist 8” Soft-Minder***

Water Softener

N/A

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Date Issued: June 4, 2009

Manufacturer: Culligan International
Company

Rated Service Flow: 5.9 gpm

Rated Service Capacity: N/A

Technology: ion exchange

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Barium

Radium

Organic:

None

Certificate #: 09- 1988

Model Designation:

*Culligan International Company Gold
12" Soft-Minder*

System Type

Water Softener

Replacement Elements:

N/A

*Culligan International Company Gold
12" Aqua-Sensor*

Water Softener

N/A

Date Issued: June 4, 2009

Manufacturer: Culligan International
Company

Rated Service Flow: 10 gpm

Rated Service Capacity: N/A

Technology: ion exchange

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Barium

Radium

Organic:

None

Certificate #: 10- 1989

Model Designation:

Woongjin Coway Co. LTD NEOS P-07CL

System Type

Counter Top

Replacement Elements:

WJNF8-S (Neo-Sense Filter)

WJIF8-S (Innosense Filter)

WJMF8-20-S (RO Membrane Filter)

WJCC-02 (Ceramic Filter)

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Date Issued: January 13, 2010

Manufacturer: Woongjin Coway Co.
LTD

Rated Service Flow: 0.07 gpm

Rated Service Capacity: 165 gal

Technology: RO/GAC/Adsorptive

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Arsenic(Pentavalent)¹

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Lead

Mercury

Nitrate/Nitrite²

Radium 226/228

Selenium

Organic:

VOCs

Certificate #: 09- 1990

<u>Model Designation:</u>	<u>System Type</u>	<u>Replacement Elements:</u>
<i>The Brita Products Company Classic - Model #OB01/OB04</i>	Pour Through	OB04
<i>The Brita Products Company Slim - Model #OB11/OB04</i>	Pour Through	OB04
<i>The Brita Products Company Space Saver - Model #OB21/OB04</i>	Pour Through	OB04
<i>The Brita Products Company UltraMax - Model #OB24/OB04</i>	Pour Through	OB04
<i>The Brita Products Company Atlantis - Model #OB32/OB04</i>	Pour Through	OB04
<i>The Brita Products Company Riviera - Model #OB35/OB04</i>	Pour Through	OB04
<i>The Brita Products Company Grand - Model #OB36/OB04</i>	Pour Through	OB04
<i>The Brita Products Company Chrome - Model #OB39/OB04</i>	Pour Through	OB04

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

<i>The Brita Products Company Pacifica - Model #OB41/OB04</i>	Pour Through	OB04
<i>The Brita Products Company Vintage - Model #OB43/OB04</i>	Pour Through	OB04
<i>The Brita Products Company Bella - Model #OB44/OB04</i>	Pour Through	OB04

Date Issued: June 18, 2009

Manufacturer: The Brita Products
Company

Rated Service Flow: n/a

Rated Service Capacity: 40 gal

Technology: carbon block

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

Turbidity

Inorganic/Radiological:

Copper

Lead

Organic:

Atrazine

Benzene

Carbon Tetrachloride

Ethylene Dibromide

Lindane

Simazine

Tetrachloroethylene

2,4-D

2,4,5 TP

Certificate #: 09- 1991

Model Designation:

LG 5231JA2006B-S

System Type

In Line
Refrigerator

Replacement Elements:

5231JA2006B

Date Issued: October 20, 2009

Manufacturer: Cuno Inc. a 3M company

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 300 gal

Technology: mechanical/carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Lead

Mercury

Organic:

Atrazine

Benzene

Lindane

2,4-D

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 09- 1993

Model Designation:

US-600A with D-40A

System Type

Under Counter

Replacement Elements:

D-40A

Date Issued: June 22, 2009

Manufacturer: Culligan International
Company

Rated Service Flow: 0.6 gpm

Rated Service Capacity: 600 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Atrazine

Lindane

Certificate #: 09- 1994

Model Designation:

US-600A with D-30A

System Type

Under Counter

Replacement Elements:

D-30A

Date Issued: June 22, 2009

Manufacturer: Culligan International
Company

Rated Service Flow: 0.9 gpm

Rated Service Capacity: 1000 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Organic:

None

Certificate #: 09- 1995

Model Designation:

4158622 with 48167 cartridge

System Type

Under Counter

Replacement Elements:

48167

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: June 22, 2009

Manufacturer: Culligan International
Company

Rated Service Flow: 0.6 gpm

Rated Service Capacity: 600 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Atrazine

Lindane

Certificate #: 09-1996

Model Designation:

4158622 with 4158721 cartridge

System Type

Under Counter

Replacement Elements:

4158721

Date Issued: June 22, 2009

Manufacturer: Culligan International
Company

Rated Service Flow: 0.9 gpm

Rated Service Capacity: 1000 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Organic:

None

Certificate #: 09-1997

Model Designation:

Gold Arsenic 10"

System Type

Point Of Entry

Replacement Elements:

N/A

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: June 16, 2009

Manufacturer: Culligan International
Company

Rated Service Flow: 5.0 gpm

Rated Service Capacity: 75,000 gal

Technology: Adsorption Media

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Arsenic¹

(Reduces both trivalent and pentavalent species)

Organic:

None

Certificate #: 09- 1998

Model Designation:

Gold Arsenic 12"

System Type

Point Of Entry

Replacement Elements:

N/A

Date Issued: June 16, 2009

Manufacturer: Culligan International
Company

Rated Service Flow: 6.0 gpm

Rated Service Capacity: 100,000 gal

Technology: Adsorption Media

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Arsenic¹

(Reduces both trivalent and pentavalent species)

Organic:

None

Certificate #: 09- 1999

Model Designation:

Gold Arsenic 14"

System Type

Point Of Entry

Replacement Elements:

N/A

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Date Issued: June 16, 2009

Manufacturer: Culligan International
Company

Rated Service Flow: 9.5 gpm

Rated Service Capacity: 200,000 gal

Technology: Adsorption Media

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Arsenic¹

(Reduces both trivalent and pentavalent species)

Organic:

None

Certificate #: 09- 2000

Model Designation:

Advanced Platinum Plus 16" Meter

System Type

Water Softener

Replacement Elements:

N/A

Advanced Platinum Plus 16" Aqua-Sensor

Water Softener

N/A

Date Issued: July 27, 2009

Manufacturer: Culligan International

Rated Service Flow: 22.9 gpm

Rated Service Capacity: N/A

Technology: ion exchange

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Barium

Radium 226/228

Organic:

None

Certificate #: 09- 2001

Model Designation:

Advanced Platinum Plus 10" Meter

System Type

Water Softener

Replacement Elements:

N/A

Advanced Platinum Plus 10" Aqua-Sensor

Water Softener

N/A

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: July 27, 2009

Manufacturer: Culligan International

Rated Service Flow: 14.9 gpm

Rated Service Capacity: N/A

Technology: ion exchange

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Barium

Radium 226/228

Organic:

None

Certificate #: 09- 2002

Model Designation:

Advanced Platinum Plus 12" Meter

System Type

Water Softener

Replacement Elements:

N/A

*Advanced Platinum Plus 12"
Aqua-Sensor*

Water Softener

N/A

Date Issued: July 27, 2009

Manufacturer: Culligan International

Rated Service Flow: 19.5 gpm

Rated Service Capacity: N/A

Technology: ion exchange

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Barium

Radium 226/228

Organic:

None

Certificate #: 09- 2003

Model Designation:

Advanced Platinum Plus 14" Meter

System Type

Water Softener

Replacement Elements:

N/A

*Advanced Platinum Plus 14"
Aqua-Sensor*

Water Softener

N/A

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: July 27, 2009

Manufacturer: Culligan International

Rated Service Flow: 20.5 gpm

Rated Service Capacity: N/A

Technology: ion exchange

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Barium

Radium 226/228

Organic:

None

Certificate #: 09- 2004

Model Designation:

PuR Classiclear (FM-3333B)

System Type

Faucet Mount

Replacement Elements:

RF-3375

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Date Issued: September 28, 2009

Revised: 4/15/2010

Manufacturer: The Procter & Gamble
Company

Rated Service Flow: 0.58 gpm

Rated Service Capacity: 100 gal

Technology: mechanical

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

2,4-D

2,4,5-TP

Atrazine

Benzene

Carbofuran

Carbon tetrachloride

Chlordane

Endrin

Ethylbenzene

Heptachlor epoxide

VOCs by chloroform surrogate

Lindane

MTBE

Methoxychlor

Chlorobenzene

o-dichlorobenzene

Simazine

Styrene

Tetrachloroethylene

Toluene

Toxaphene

Trichloroethylene

Trihalomethanes

Certificate #: 09- 2005

Model Designation:

System Type

Replacement Elements:

***PuR Mineralclear Faucet Mount
(FM-3400B)***

Faucet Mount

RF-9999

***PuR Mineralclear Faucet Mount
(FM-3700B)***

Faucet Mount

RF-9999

***PuR Mineralclear Faucet Mount
(FM-3800B)***

Faucet Mount

RF-9999

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

***PuR Mineralclear Faucet Mount
(FM-4100B)***

Faucet Mount

RF-9999

Date Issued: September 28, 2009

Revised: April 20, 2010

Manufacturer: The Procter & Gamble
Company

Rated Service Flow: 0.58 gpm

Rated Service Capacity: 100 gal

Technology: mechanical

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

2,4-D

2,4,5-TP

Atrazine

Benzene

Carbofuran

Carbon Tetrachloride

Chlordane

Chlorobenzene

o-Dichlorobenzene

Endrin

VOCs

Ethylbenzene

Heptachlor Epoxide

Lindane

Methoxychlor

MTBE

Simazine

Styrene

Tetrachloroethylene

Toluene

Toxaphene

Trichloroethylene

Trihalomethanes

Certificate #: 09- 2006

Model Designation:

System Type

Replacement Elements:

***PuR Mineralclear Faucet Mount
(FM-9100B)***

Faucet Mount

RF-9999

***PuR Mineralclear Faucet Mount
(FM-9400B)***

Faucet Mount

RF-9999

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

<i>PuR Mineralclear Faucet Mount (FM-9500B)</i>	Faucet Mount	RF-9999
<i>PuR Mineralclear Faucet Mount (FM-9600B)</i>	Faucet Mount	RF-9999
<i>PuR Mineralclear Faucet Mount (FM-9700B)</i>	Faucet Mount	RF-9999
<i>PuR Mineralclear Faucet Mount (FM-5050B)</i>	Faucet Mount	RF-9999

Date Issued: September 28, 2009

Revised: April 20, 2010

Manufacturer: The Procter & Gamble
Company

Rated Service Flow: 0.58 gpm

Rated Service Capacity: 100 gal

Technology: mechanical

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

2,4-D

2,4,5-TP

Atrazine

Benzene

Carbofuran

Carbon Tetrachloride

Chlordane

Chlorobenzene

o-Dichlorobenzene

Endrin

VOCs

Ethylbenzene

Heptachlor Epoxide

Lindane

Methoxychlor

MTBE

Simazine

Styrene

Tetrachloroethylene

Toluene

Toxaphene

Trichloroethylene

Trihalomethanes

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 09- 2007

Model Designation:

WFDW130009W

System Type

Under Counter

Replacement Elements:

WFDWC50001

Date Issued: October 5, 2009

Manufacturer: Protect Plus, LLC

Rated Service Flow: 0.9 gpm

Rated Service Capacity: 550 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

None

Organic:

Atrazine

Lindane

Certificate #: 09- 2008

Model Designation:

WFQT270005

System Type

Under Counter

Replacement Elements:

WFQTC70001 & WFQTC3001

Date Issued: October 5, 2009

Manufacturer: Protect Plus, LLC

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 400 gal

Technology: mechanical/carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

Lead

Organic:

Atrazine

Lindane

Certificate #: 09- 2009

Model Designation:

WFCHI

System Type

Under Counter

Replacement Elements:

WFPFC5002

WFDWC50001

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: October 5, 2009
Manufacturer: Protect Plus, LLC
Rated Service Flow: 0.9 gpm
Rated Service Capacity: 550 gal
Technology: carbon block
Comments:

Contaminants Reduced:
Microbiological/Turbidity:
Cysts
Inorganic/Radiological:
None
Organic:
Atrazine
Lindane

Certificate #: 10- 2010

Model Designation:
EVOLFLTR10

System Type
In Line
Refrigerator

Replacement Elements:
EVOLFLTR10

Date Issued: January 29, 2010
Manufacturer: Cuno Inc. a 3M Company
Rated Service Flow: 0.5 gpm
Rated Service Capacity: 240 gal
Technology: mechanical/carbon block
Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:
Microbiological/Turbidity:
Cysts
Turbidity
Inorganic/Radiological:
Asbesto
Lead
Mercury
Organic:
2,4-D
Atrazine
Benzene
Toxaphene
p-Dichlorobenzene

Certificate #: 09- 2011

Model Designation:
3MDW301

System Type
Under Counter

Replacement Elements:
3MDW311

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: October 1, 2009

Manufacturer: 3M Brand from 3M

Rated Service Flow: 0.75 gpm

Rated Service Capacity: 1000 gal

Technology: mechanical/carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

Asbestos

Lead

Organic:

MTBE

Trihalomethanes

VOCs

Certificate #: 09- 2012

Model Designation:

3MDW101

System Type

Under Counter

Replacement Elements:

3MDW111

Date Issued: October 1, 2009

Revised October 6, 2010

Manufacturer: 3M Brand from 3M

Rated Service Flow: 0.75 gpm

Rated Service Capacity: 500 gal

Technology: mechanical/carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Atrazine

Benzene

Carbofuran

Lindane

p-Dichlorobenzene

Toxaphene

Certificate #: 09- 2013

Model Designation:

Better Waters XL7000

System Type

Under Counter

Replacement Elements:

XL7000CR

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Date Issued: October 22, 2009

Manufacturer: Cuno, Inc.

Rated Service Flow: 2.5 gpm

Rated Service Capacity: 6000 gal

Technology: mechanical/carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

Lead

Organic:

Benzene

p-Dichlorobenzene

Toxaphene

Certificate #: 10- 2014

Model Designation:

Membrane Elements: TFM-36EB, TFM-24EB, PPCM15EB, TFM-50EB, TFM-18EB, AG1512TBD, AG1809TJD, S1229RS, S1340RS, S1448RS, TFM-18, TFM1809T, TFM 1809T, TFM1809T

System Type

Component

Replacement Elements:

Date Issued: July 16, 2010

Manufacturer: GE Infrastructure

Rated Service Flow: N/A

Rated Service Capacity: N/A

Technology: reverse osmosis

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

Turbidity

Inorganic/Radiological:

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Fluoride

Lead

Radium

Selenium

Organic:

None

Certificate #: 09- 2015

Model Designation:

3MRO401

System Type

Under Counter

Replacement Elements:

Sediment Prefilter 3MROP411

Carbon Prefilter 3MROP412

R.O. Membrane 3MROM413

Carbon Postfilter 3MROP414

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Date Issued: October 23, 2009

Manufacturer: 3M Brand from 3M

Rated Service Flow: 8.28 gpd

Rated Service Capacity: not applicable

Technology: reverse osmosis/carbon

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Arsenic¹

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Fluoride

Lead

Radium 226/228

Selenium

Organic:

None

Certificate #: 09- 2016

Model Designation:

3MDW201

System Type

Under Counter

Replacement Elements:

3MDW211

Date Issued: October 30, 2009

Manufacturer: 3M Brand from 3M

Rated Service Flow: 2.5 gpm

Rated Service Capacity: 6000 gal

Technology: mechanical/carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

Lead

Organic:

Benzene

p-Dichlorobenzene

Toxaphene

Certificate #: 09- 2017

Model Designation:

3MFF100

System Type

Under Counter

Replacement Elements:

3MFF101

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: October 23, 2009

Manufacturer: Cuno Inc.

Rated Service Flow: 2.5 gpm

Rated Service Capacity: 6000 gal

Technology: mechanical/carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

Lead

Organic:

Benzene

p-Dichlorobenzene

Toxaphene

Certificate #: 09- 2018

Model Designation:

ADQ36006101-S

System Type

In Line
Refrigerator

Replacement Elements:

ADQ36006101

Date Issued: December 15, 2009

Manufacturer: Cuno Inc.

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 200 gal

Technology: mechanical/carbon block

Comments:

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

2,4-D Reduction

Atrazine

Benzene

Carbofuran

Lindane

p-Dichlorobenzene

Toxaphene

Certificate #: 09- 2019

Model Designation:

ADQ36006102-S

System Type

In Line
Refrigerator

Replacement Elements:

ADQ36006102

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: December 15, 2009
Manufacturer: Sears Roebuck and Co.
Rated Service Flow: 0.5 gpm
Rated Service Capacity: 200 gal
Technology: mechanical/carbon block
Comments:

Contaminants Reduced:
Microbiological/Turbidity:
Cysts
Inorganic/Radiological:
Asbestos
Lead
Mercury
Organic:
2,4-D Reduction
Atrazine
Benzene
Carbofuran
Lindane
p-Dichlorobenzene
Toxaphene

Certificate #: 10- 2021

Model Designation:

Kenmore DA97-06317A

System Type

In Line
Refrigerator

Replacement Elements:

DA29-00003H

Date Issued: April 27, 2010
Manufacturer: Cuno, Inc.
Rated Service Flow: 0.5 gpm
Rated Service Capacity: 300 gal
Technology: mechanical/carbon block
Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:
Microbiological/Turbidity:
Asbestos
Cysts
Turbidity
Inorganic/Radiological:
Lead
Mercury
Organic:
Benzene
Carbofuran
p-Dichlorobenzene

Certificate #: 09- 2025

Model Designation:

PureSource 3

System Type

In Line
Refrigerator

Replacement Elements:

WF3CB

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: December 15, 2009

Manufacturer: Electrolux

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 200 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Lead

Mercury

Organic:

Atrazine

Chlorobenzene

Lindane

o-Dichlorobenzene

Styrene

Tetrachloroethylene

Toxaphene

2,4 D

Certificate #: 10- 2026

Model Designation:

ROI85011

System Type

In Line
Refrigerator

Replacement Elements:

67003662

Date Issued: April 5, 2010

Manufacturer: Cuno, Inc.

Rated Service Flow: 0.78 gpm

Rated Service Capacity: 750 gal

Technology: mechanical/carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Mercury

Organic:

Atrazine

Benzene

Carbofuran

p-Dichlorobenzene

Lindane

Toxaphene

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 09- 2027

Model Designation:

Gold 10" Aquasensor

Gold 10" Softminder

System Type

Water Softener

Water Softener

Replacement Elements:

Date Issued: June 4, 2009

Manufacturer: Culligan International
Company

Rated Service Flow: 9.4 gpm

Rated Service Capacity: N/A

Technology: ion exchange

Comments:

Do not use with water that is
microbiologically unsafe or of unknown
quality, without adequate disinfection before
or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Barium

Radium 226/228

Organic:

None

Certificate #: 10- 2028

Model Designation:

GEN11053F-08

System Type

In Line

Replacement Elements:

GEN11053FR-08

Date Issued: February 22, 2010

Manufacturer: Microfilter Co., Ltd

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 300 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically
unsafe or with water of unknown quality,
except that systems certified for cyst
reduction may be used on disinfected waters
that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

Lead

Organic:

Atrazine

Benzene

Certificate #: 10- 2029

Model Designation:

DA97-08006A-B

System Type

In Line
Refrigerator

Replacement Elements:

DA29-0020B

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: March 15, 2010

Manufacturer: Microfilter Co. Ltd

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 300 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Inorganic/Radiological:

Asbestos

Lead

Organic:

Atrazine

Benzene

Lindane

Certificate #: 10- 2030

Model Designation:

P5WB2L

System Type

Integrated
Refrigerator

Replacement Elements:

P4RFBW

Date Issued: February 26, 2010

Manufacturer: Whirlpool Corporation

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 200 gal

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

Asbestos

Lead

Organic:

Atrazine

Lindane

Toxaphene

2, 4 - D

Certificate #: 10- 2034

Model Designation:

SQC-VIRO-4

System Type

Under Counter

Replacement Elements:

47-557104G2

66-4710G2

47-227401

47-55730G2

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: December 21, 2010

Manufacturer: 3M Purification Inc.
(formerly Cuno Inc)

Rated Service Flow: <75 gpd

Rated Service Capacity: 3.17 gal

Technology: reverse osmosis

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the reverse osmosis (RO) system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the RO system.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Turbidity

Bacteria

Virus

Inorganic/Radiological:

Arsenic¹

Barium

Cadmium

Chromium (hexavalent)

Chromium (trivalent)

Copper

Fluoride

Lead

Radium 226/228

Selenium

Organic:

Carbofuran

o-Dichlorobenzene

p-Dichlorobenzene

Toxaphene

Certificate #: 10- 2035

Model Designation:

Fresca Pure Ultra (Model WF0600)

System Type

Counter Top

Replacement Elements:

WF0650 (carbon block)

WF0651 (mineralizer)

WF0652 (UF membrane)

WF0653 (UV lamp)

Date Issued: June 14, 2010

Manufacturer: Hy Cite Corporation

Rated Service Flow: 0.6 gpm

Rated Service Capacity: 1250 gallons

Technology: mechanical/carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Turbidity

Inorganic/Radiological:

Lead

Organic:

VOC

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 10- 2039

Model Designation:

*Matrikx Microbiological Barrier -
260-138-53-095*

System Type

Component

Replacement Elements:

Date Issued: November 19, 2010

Manufacturer: KX Technologies LLC

Rated Service Flow: 0.75 gpm

Rated Service Capacity: N/A

Technology: carbon block

Comments:

Do not use for the treatment of water that is visually contaminated (cloudy) or has an obvious contamination source, such as contamination by raw sewage.

Complete candidate systems must pass the Microbiological Interception Protocol for Validation of KX Industries Carbon Treatment Technology - State of California (CA CDPH), version 3-17-05 for health claims of cysts, bacteria and virus.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Bacteria

Virus

Inorganic/Radiological:

None

Organic:

None

Certificate #: 10- 2042

Model Designation:

Eclipse Water Machine CT-45SEW

System Type

Counter Top

Replacement Elements:

RC-45E

Date Issued: August 11, 2010

Manufacturer: Water Safety Corporation

Rated Service Flow: 0.75 gpm

Rated Service Capacity: 800 gals

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

Lead

Organic:

MTBE

VOCs

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 10- 2043

<u>Model Designation:</u>	<u>System Type</u>	<u>Replacement Elements:</u>
<i>High Efficiency: 10" Aqua-Sensor</i>	Water Softener	
<i>10" Soft-Minder Meter</i>	Water Softener	
<i>Upflow 10" Soft-Minder Meter</i>	Water Softener	
<i>Upflow 10" Aqua-Sensor</i>	Water Softener	

Date Issued: August 2, 2010

Manufacturer: Culligan International

Rated Service Flow: 9.4 gpm

Rated Service Capacity:

Technology: ion exchange

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Inorganic/Radiological:

Barium

Radium

Organic:

Certificate #: 10- 2044

<u>Model Designation:</u>	<u>System Type</u>	<u>Replacement Elements:</u>
<i>High Efficiency: 9" Aqua-Sensor</i>	Water Softener	
<i>9" Soft-Minder Meter</i>	Water Softener	
<i>Upflow 9" Soft-Minder Meter</i>	Water Softener	
<i>Upflow 9" Aqua-Sensor</i>	Water Softener	

Date Issued: August 2, 2010

Manufacturer: Culligan International

Rated Service Flow: 9 gpm

Rated Service Capacity:

Technology: ion exchange

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Inorganic/Radiological:

Barium

Radium

Organic:

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 10- 2045

<u>Model Designation:</u>	<u>System Type</u>	<u>Replacement Elements:</u>
<i>High Efficiency 14" Aqua-Sensor</i>	Water Softener	
<i>High Efficiency 14" Soft-Minder Meter</i>	Water Softener	

Date Issued: August 2, 2010

Manufacturer: Culligan International

Rated Service Flow: 10.6 gpm

Rated Service Capacity:

Technology: ion exchange

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Inorganic/Radiological:

Barium

Radium

Organic:

Certificate #: 10- 2046

<u>Model Designation:</u>	<u>System Type</u>	<u>Replacement Elements:</u>
<i>High Efficiency 12" Aqua-Sensor</i>	Water Softener	
<i>High Efficiency 12" Soft-Minder Meter</i>	Water Softener	

Date Issued: August 2, 2010

Manufacturer: Culligan International

Rated Service Flow: 10 gpm

Rated Service Capacity:

Technology: ion exchange

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Inorganic/Radiological:

Barium

Radium

Organic:

Certificate #: 10- 2047

<u>Model Designation:</u>	<u>System Type</u>	<u>Replacement Elements:</u>
<i>Shaklee Pitcher 52114</i>	Pour Through	52117 52115 52116

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: October 22, 2010

Manufacturer: Shaklee Corporation

Rated Service Flow: 2 gpd

Rated Service Capacity: 80 gal

Technology:

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Cadmium

Lead

Mercury

Organic:

VOCs by chloroform surrogate

Certificate #: 10- 2048

Model Designation:

Evolution

System Type

Under Counter

Replacement Elements:

LINX 100 TDS

LINX 100 Sediment

LINX 100 Carbon

Date Issued: October 21, 2010

Manufacturer: Rayne Water Corporation

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 3.17 gal/cycle

Technology: Regenerative Ion Exchange

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

Inorganic/Radiological:

Nitrate/Nitrite

Organic:

Certificate #: 10- 2049

Model Designation:

Eco by Tupperware Water Filter Pitcher

System Type

Pour Through

Replacement Elements:

PAWFPS1

Date Issued: August 4, 2010

Manufacturer: Tupperware Brands Corp.

Rated Service Flow: 5 gpd

Rated Service Capacity: 80 gals

Technology: GAC

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Cadmium

Copper

Mercury

Organic:

None

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Certificate #: 10- 2050

Model Designation:

Essence AHW-45

System Type

Under Counter

Replacement Elements:

A-45

Date Issued: August 12, 2010

Manufacturer: Water Safety Corporation

Rated Service Flow: 0.75 gpm

Rated Service Capacity: 800 gals

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

Lead

Organic:

MTBE

VOCs

Certificate #: 10- 2051

Model Designation:

ESSENCE AHW-35

System Type

Counter Top

Replacement Elements:

A-35

Date Issued: August 12, 2010

Manufacturer: Water Safety Corporation

Rated Service Flow: 0.75 gpm

Rated Service Capacity: 800 gals

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts

Inorganic/Radiological:

Lead

Organic:

MTBE

VOCs

Certificate #: 10- 2052

Model Designation:

Essence HW-35

System Type

Counter Top

Replacement Elements:

H-35

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: August 12, 2010

Manufacturer: Water Safety Corporation

Rated Service Flow: 0.75 gpm

Rated Service Capacity: 480 gals

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

None

Inorganic/Radiological:

Lead

Organic:

MTBE

VOCs

Certificate #: 10-2053

Model Designation:

FF-6000

System Type

Under Counter

Replacement Elements:

FF-6000R

Date Issued: October 18, 2010

Manufacturer: 3M Purification Inc.

Rated Service Flow: 2.5 gpm

Rated Service Capacity: 6000 gals

Technology: carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts(protozoan)

Inorganic/Radiological:

Lead

Organic:

Benzene

p-Dichlorobenzene

Toxaphene

Certificate #: 10-2056

Model Designation:

EP35

System Type

Under Counter

Replacement Elements:

EP35R

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011

Date Issued: October 21, 2010

Manufacturer: 3M Purification

Rated Service Flow: 0.5 gpm

Rated Service Capacity: 350 gals

Technology: mechanical/carbon block

Comments:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Contaminants Reduced:

Microbiological/Turbidity:

Cysts (protozoan)

Inorganic/Radiological:

Asbestos

Lead

Organic:

MTBE

TTHM

VOCs (chloroform surrogate)

Certificate #: 10- 2059

Model Designation:

CHP-06EU

System Type

Counter Top

Replacement Elements:

WJNF14 (Neosense)

WJCF14-POST-carbon

WJ1F14 (Innosense)

WJMF14-UF Membrane

WJCC-03

Date Issued: December 7, 2010

Manufacturer: Woongjin Coway Co., Ltd

Rated Service Flow: 0.07 gpm

Rated Service Capacity: 308 or 419

Technology: Mech Filter/Carbon

Comments:

Do not use with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

Inorganic/Radiological:

Organic:

VOCs (chloroform surrogate)

Certificate #: 10- 2060

Model Designation:

CHP-04AU

System Type

Counter Top

Replacement Elements:

WJCF14-PRE

WJCF14-POST

WJSF14-PLUS

WJIF14 (Innosense)

WJMF14-UF Membrane

**Certified Water Treatment Devices:
By Certificate Number
(4 digits to right of hyphen)**

*California Department of Public Health
Drinking Water Program
Certified Water Treatment Device Directory
February 2011*

Date Issued: December 7, 2010

Manufacturer: Woongjin Coway Co., Ltd

Rated Service Flow: 0.07 gpm

Rated Service Capacity: 381 or 467 gals

Technology: Mech Filter/Carbon

Comments:

Do not use with water that is
microbiologically unsafe or of unknown
quality, without adequate disinfection before
or after the system.

Contaminants Reduced:

Microbiological/Turbidity:

Inorganic/Radiological:

Organic:

VOCs (chloroform surrogate)
