

Use this checklist to ensure all required information is included in the Product Data Sheet and Label submitted with your application for certification for a drinking water treatment system.

The following items are required by regulation to be included in a Product Data Sheet and/or Product Label.

PRODUCT DATA SHEET REQUIREMENTS

- _____ A copy of the certificate by which the Department has granted certification of the water treatment device. The copy may be incorporated in the product data sheet or attached to the sheet.
- _____ Service flow rate in gallons per minute or gallons per day (liters/day) or the production rate in gallons per day (liters/day).
- _____ Rated service life of the water treatment device (where applicable).
- _____ General use conditions and needs, such as maximum turbidity and bacteriological quality of source water.
- _____ Model or part number and estimated cost of components that must be periodically or routinely replaced to maintain the effectiveness of the certified water treatment device.
- _____ Maximum and minimum operating temperature in degrees Fahrenheit and degrees Centigrade.
- _____ Maximum and minimum operating pressure in pounds per square inch and kilograms per square centimeter.
- _____ A reference to the owner's manual for general operation and maintenance requirements, and the manufacturer's warranty.

PRODUCT LABEL REQUIREMENTS

- _____ Equipment name
- _____ Model designation
- _____ Name of manufacturer
- _____ Statement: "For conditions of use, health claims certified by the California Department of Public Health, and replacement parts, see product data sheet."
- _____ "California Department of Public Health Certification Number: XX-XXXX".
(Final certification number will be issued with certificate.)