DISTRICT 58

NAPA COUNTY

DRINKING WATER MONITORING SCHEDULE

THE CALIFORNIA DEPARTMENT OF PUBIC HEALTH (CDPH) MONITORING SCHEDULER LISTS REQUIRED CONTAMINANT TESTING OF DRINKING WATER FOR PUBLIC WATER SYSTEMS IN CALIFORNIA. THE SCHEDULE INCLUDES REQUIRED UPCOMING TESTING, PAST DUE REQUIRED, AND WAIVED TESTING.

THIS INFORMATION IS VALID AS OF MAY 24, 2012.

UPDATES WILL BE REGULARLY PERFORMED REFLECTING CHANGES IN THE WATER QUALITY MONITORING DATABASE. THESE DOCUMENTS SHOULD BE CONSIDERED "DRAFT" IN THAT THEY MAY CHANGE WITH SUBSEQUENT UPDATES AS NEW DATA ARE SUBMITTED, OR AS MONITORING SCHEDULES ARE REVISED. THIS MONITORING SCHEDULE SHOULD NOT BE USED TO DETERMINE IF SYSTEMS ARE IN COMPLETE COMPLIANCE WITH MONITORING REQUIREMENTS. THE PURPOSE IS TO ASSIST SYSTEMS IN THEIR PLANNING FOR SAMPLING EVENTS, AND VERIFICATION OF SCHEDULED MONITORING WITH CDHS RECORDS.

THE TELEPHONE NUMBER FOR THE LOCAL DRINKING WATER OFFICE IS:

(707) 253-4471

Please be aware that the monitoring schedules do not reflect compliance with initial monitoring for newly regulated constituents (such as MTBE), or constituents that require special monitoring frequencies. Specifically, the database is unable to accurately forecast the following for the Monitoring Schedules:

The SOC frequency for large water systems serving over 3,300 people of 2 quarters every 3 years. In addition, if you have been advised of any increased monitoring that is not reflected in the Monitoring Schedule for a particular source, please contact your local Drinking Water office

Some older data may not be present in the database, and these are indicated in the schedule as "DUE." If these samples were taken, have your laboratory submit the data. Since January 1, 2001, data have been required to be submitted directly to CDPH via electronic data transfer (EDT).

If sampled after January 1, 2001, have your lab submit those data (and data prior to 2001 if possible) electronically as required to CDPH via EDT. Your laboratory can contact Anthony Meeks in the CDPH Monitoring and Evaluation Unit at (916) 449-5568 or at edt@cdph.ca.gov for further information. Changes in the monitoring notification documents will be seen in the next update.

System Number: ***2800011***

System Name: ***DANA ESTATES***

PS Code: ***2800011-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/06/20	< .000	2012/06	
NITRITE (AS N)	00620	000				**DUE**
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800011***

System Name: ***DANA ESTATES***

PS Code: ***2800011-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800011***

System Name: ***DANA ESTATES***

PS Code: ***2800011-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800011***

System Name: ***DANA ESTATES***

PS Code: ***2800011-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800011***

System Name: ***DANA ESTATES***

PS Code: ***2800011-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800012***

System Name: ***LONG MEADOW RANCH***

PS Code: ***2800012-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	000				DUE
ANTIMONY	01097	000				DUE
ARSENIC	01002	000				DUE
ASBESTOS	81855	000				DUE
BARIUM	01007	000				DUE
BERYLLIUM	01012	000				DUE
CADMIUM	01027	000				DUE
CHROMIUM (TOTAL)	01034	000				DUE
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				DUE
LEAD	01051	WAIVED				
MERCURY	71900	000				DUE
NICKEL	01067	000				DUE
PERCHLORATE	A-031	006				DUE
SELENIUM	01147	000				DUE
THALLIUM	01059	000				DUE
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/06/08	4.700	2012/06	
NITRITE (AS N)	00620	000				DUE
RADIOLOGICAL						
GROSS ALPHA	01501	108	2011/05/04	3.800	2020/05	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800012***

System Name: ***LONG MEADOW RANCH***

PS Code: ***2800012-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	000			DUE
2,4-D	39730	000			DUE
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	000			DUE
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	000			DUE
CHLORDANE	39350	WAIVED			
DALAPON	38432	000			DUE
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	000			DUE
DIQUAT	78885	000			DUE
ENDOTHALL	38926	000			DUE
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	000			DUE
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	000			DUE
HEPTACHLOR EPOXIDE	39420	000			DUE
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800012***

System Name: ***LONG MEADOW RANCH***

PS Code: ***2800012-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	000			DUE
MOLINATE	82199	WAIVED			
OXAMYL	38865	000			DUE
PENTACHLOROPHENOL	39032	000			DUE
PICLORAM	39720	000			DUE
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	000			DUE
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	000			DUE
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	000			DUE
1,1,2,2-TETRACHLOROETHANE	34516	000			DUE
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	000			DUE
1,1,2-TRICHLOROETHANE	34511	000			DUE
1,1-DICHLOROETHANE	34496	000			DUE
1,1-DICHLOROETHYLENE	34501	000			DUE
1,2,4-TRICHLOROBENZENE	34551	000			DUE
1,2-DICHLOROBENZENE	34536	000			DUE
1,2-DICHLOROETHANE	34531	000			DUE
1,2-DICHLOROPROPANE	34541	000			DUE
1,3-DICHLOROPROPENE (TOTAL)	34561	000			DUE
1,4-DICHLOROBENZENE	34571	000			DUE
BENZENE	34030	000			DUE
CARBON TETRACHLORIDE	32102	000			DUE
CIS-1,2-DICHLOROETHYLENE	77093	000			DUE
DICHLOROMETHANE	34423	000			DUE
ETHYLBENZENE	34371	000			DUE
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	000			DUE
MONOCHLOROBENZENE	34301	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800012***

System Name: ***LONG MEADOW RANCH***

PS Code: ***2800012-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	000			DUE
TETRACHLOROETHYLENE	34475	000			DUE
TOLUENE	34010	000			DUE
TRANS-1,2-DICHLOROETHYLENE	34546	000			DUE
TRICHLOROETHYLENE	39180	000			DUE
TRICHLOROFLUOROMETHANE	34488	000			DUE
VINYL CHLORIDE	39175	000			DUE
XYLENES (TOTAL)	81551	000			DUE
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED	2009/05/19	11.900	
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800012***

System Name: ***LONG MEADOW RANCH***

PS Code: ***2800012-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800012-002***

Source Name: ***CITY OF ST HELENA***

Source Number: ***002***

Source Status: ***PURCHASED TREATED***

Water type: ***SURFACE***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800012***

System Name: ***LONG MEADOW RANCH***

PS Code: ***2800012-002***

Source Name: ***CITY OF ST HELENA***

Source Number: ***002***

Source Status: ***PURCHASED TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800012***

System Name: ***LONG MEADOW RANCH***

PS Code: ***2800012-002***

Source Name: ***CITY OF ST HELENA***

Source Number: ***002***

Source Status: ***PURCHASED TREATED***

Water type: ***SURFACE***

REGULATED SOC

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			

REGULATED VOC

1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800012***

System Name: ***LONG MEADOW RANCH***

PS Code: ***2800012-002***

Source Name: ***CITY OF ST HELENA***

Source Number: ***002***

Source Status: ***PURCHASED TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800012***

System Name: ***LONG MEADOW RANCH***

PS Code: ***2800012-002***

Source Name: ***CITY OF ST HELENA***

Source Number: ***002***

Source Status: ***PURCHASED TREATED***

Water type: ***SURFACE***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800013***

System Name: ***LUNA VINEYARDS***

PS Code: ***2800013-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED	2012/05/02	2.600		
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED	2011/06/15	< 4.000		
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/06/15	< 2.000	2012/06	
NITRITE (AS N)	00620	036	2011/06/15	< 400.000	2014/06	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED	2011/06/15	1.040		
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800013***

System Name: ***LUNA VINEYARDS***

PS Code: ***2800013-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800013***

System Name: ***LUNA VINEYARDS***

PS Code: ***2800013-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800013***

System Name: ***LUNA VINEYARDS***

PS Code: ***2800013-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800013***

System Name: ***LUNA VINEYARDS***

PS Code: ***2800013-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800013-002***

Source Name: ***WELL 002 (50' SEAL)***

Source Number: ***002***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED	2012/05/02	18.000	
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	000			DUE
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800013***

System Name: ***LUNA VINEYARDS***

PS Code: ***2800013-002***

Source Name: ***WELL 002 (50' SEAL)***

Source Number: ***002***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2011/07/28	< 2.000	2012/07
NITRITE (AS N)	00620	036	2011/07/28	< 400.000	2014/07
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800013***

System Name: ***LUNA VINEYARDS***

PS Code: ***2800013-002***

Source Name: ***WELL 002 (50' SEAL)***

Source Number: ***002***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800013***

System Name: ***LUNA VINEYARDS***

PS Code: ***2800013-002***

Source Name: ***WELL 002 (50' SEAL)***

Source Number: ***002***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800013***

System Name: ***LUNA VINEYARDS***

PS Code: ***2800013-002***

Source Name: ***WELL 002 (50' SEAL)***

Source Number: ***002***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
SECONDARY/GP						
MAGNESIUM	00927	000				DUE
MANGANESE	01055	000				DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED				
PH, LABORATORY	00403	000				DUE
SILVER	01077	WAIVED				
SODIUM	00929	000				DUE
SPECIFIC CONDUCTANCE	00095	WAIVED				
SULFATE	00945	WAIVED				
TOTAL DISSOLVED SOLIDS	70300	WAIVED				
TURBIDITY, LABORATORY	82079	WAIVED				
ZINC	01092	WAIVED				

PS Code: ***2800013-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800013***

System Name: ***LUNA VINEYARDS***

PS Code: ***2800013-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800013***

System Name: ***LUNA VINEYARDS***

PS Code: ***2800013-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800013***

System Name: ***LUNA VINEYARDS***

PS Code: ***2800013-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800013***

System Name: ***LUNA VINEYARDS***

PS Code: ***2800013-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800014***

System Name: ***BARREL STOP WINERY***

PS Code: ***2800014-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	000			DUE
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	000			DUE
NITRITE (AS N)	00620	000			DUE
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800014***

System Name: ***BARREL STOP WINERY***

PS Code: ***2800014-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800014***

System Name: ***BARREL STOP WINERY***

PS Code: ***2800014-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800014***

System Name: ***BARREL STOP WINERY***

PS Code: ***2800014-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800014***

System Name: ***BARREL STOP WINERY***

PS Code: ***2800014-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800014-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800014***

System Name: ***BARREL STOP WINERY***

PS Code: ***2800014-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800014***

System Name: ***BARREL STOP WINERY***

PS Code: ***2800014-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800014***

System Name: ***BARREL STOP WINERY***

PS Code: ***2800014-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800014***

System Name: ***BARREL STOP WINERY***

PS Code: ***2800014-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800015***

System Name: ***SOMERSTON WINERY***

PS Code: ***2800015-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2011/01/25	< .200		
INORGANIC						
ALUMINUM	01105	036	2011/01/25	.130	2014/01	
ANTIMONY	01097	000				DUE
ARSENIC	01002	000				DUE
ASBESTOS	81855	108	2011/01/25	.000	2020/01	
BARIUM	01007	000				DUE
BERYLLIUM	01012	000				DUE
CADMIUM	01027	000				DUE
CHROMIUM (TOTAL)	01034	000				DUE
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				DUE
LEAD	01051	WAIVED				
MERCURY	71900	000				DUE
NICKEL	01067	000				DUE
PERCHLORATE	A-031	006	2011/01/25	< 4.000	2011/07	DUE
SELENIUM	01147	000				DUE
THALLIUM	01059	000				DUE
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/01/25	.200	2012/01	DUE
NITRITE (AS N)	00620	036	2011/01/25	< 100.000	2014/01	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2012/02/13	- .730	2021/02	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800015***

System Name: ***SOMERSTON WINERY***

PS Code: ***2800015-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2011/01/25	< .070	
2,4-D	39730	WAIVED	2011/01/25	< .400	
ALACHLOR	77825	WAIVED	2011/01/25	< .200	
ATRAZINE	39033	036	2011/01/25	< .300	2014/01
BENTAZON	38710	WAIVED	2011/01/25	< .800	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	036	2011/01/25	< .000	2014/01
CHLORDANE	39350	WAIVED			
DALAPON	38432	036	2011/01/25	< 5.000	2014/01
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2011/01/25	< .000	
DINOSEB	81287	036	2011/01/25	< .200	2014/01
DIQUAT	78885	036	2011/01/25	< .000	2014/01
ENDOTHALL	38926	036	2011/01/25	< 20.000	2014/01
ENDRIN	39390	WAIVED	2011/01/25	< .005	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2011/01/25	< .000	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2011/01/25	< .005	
HEPTACHLOR EPOXIDE	39420	WAIVED	2011/01/25	< .005	
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED	2011/01/25	< .005	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800015***

System Name: ***SOMERSTON WINERY***

PS Code: ***2800015-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	WAIVED	2011/01/25	< .005		
MOLINATE	82199	WAIVED	2011/01/25	< .500		
OXAMYL	38865	036	2011/01/25	< .000	2014/01	
PENTACHLOROPHENOL	39032	036	2011/01/25	< .050	2014/01	
PICLORAM	39720	036	2011/01/25	< .050	2014/01	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2011/01/25	< .200		
SIMAZINE	39055	036	2011/01/25	< .300	2014/01	
THIOBENCARB	A-001	WAIVED	2011/01/25	< .500		
TOXAPHENE	39400	000				**DUE**
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2011/01/25	< .500	2017/01	
1,1,2,2-TETRACHLOROETHANE	34516	072	2011/01/25	< .500	2017/01	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2011/01/25	< .500	2017/01	
1,1,2-TRICHLOROETHANE	34511	072	2011/01/25	< .500	2017/01	
1,1-DICHLOROETHANE	34496	072	2011/01/25	< .500	2017/01	
1,1-DICHLOROETHYLENE	34501	072	2011/01/25	< .500	2017/01	
1,2,4-TRICHLOROBENZENE	34551	072	2011/01/25	< .500	2017/01	
1,2-DICHLOROBENZENE	34536	072	2011/01/25	< .500	2017/01	
1,2-DICHLOROETHANE	34531	072	2011/01/25	< .500	2017/01	
1,2-DICHLOROPROPANE	34541	072	2011/01/25	< .500	2017/01	
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2011/01/25	< .500	2017/01	
1,4-DICHLOROBENZENE	34571	072	2011/01/25	< .500	2017/01	
BENZENE	34030	072	2011/01/25	< .500	2017/01	
CARBON TETRACHLORIDE	32102	072	2011/01/25	< .500	2017/01	
CIS-1,2-DICHLOROETHYLENE	77093	072	2011/01/25	< .500	2017/01	
DICHLOROMETHANE	34423	072	2011/01/25	< .500	2017/01	
ETHYLBENZENE	34371	072	2011/01/25	< .500	2017/01	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2011/01/25	< .500	2017/01	
MONOCHLOROBENZENE	34301	072	2011/01/25	< .500	2017/01	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800015***

System Name: ***SOMERSTON WINERY***

PS Code: ***2800015-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED VOC						
STYRENE	77128	072	2011/01/25	< .500	2017/01	
TETRACHLOROETHYLENE	34475	072	2011/01/25	< .500	2017/01	
TOLUENE	34010	072	2011/01/25	< .500	2017/01	
TRANS-1,2-DICHLOROETHYLENE	34546	072	2011/01/25	< .500	2017/01	
TRICHLOROETHYLENE	39180	072	2011/01/25	< .500	2017/01	
TRICHLOROFLUOROMETHANE	34488	072	2011/01/25	< .500	2017/01	
VINYL CHLORIDE	39175	072	2011/01/25	< .500	2017/01	
XYLENES (TOTAL)	81551	072	2011/01/25	< 1.000	2017/01	
SECONDARY/GP						
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED				
BICARBONATE ALKALINITY	00440	000				DUE
CALCIUM	00916	000				DUE
CARBONATE ALKALINITY	00445	000				DUE
CHLORIDE	00940	WAIVED				
COLOR	00081	WAIVED				
COPPER	01042	WAIVED				
FOAMING AGENTS (MBAS)	38260	WAIVED				
HARDNESS (TOTAL) AS CACO3	00900	000				DUE
HYDROXIDE ALKALINITY	71830	000				DUE
IRON	01045	000				DUE
MAGNESIUM	00927	000				DUE
MANGANESE	01055	000				DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED				
PH, LABORATORY	00403	000				DUE
SILVER	01077	WAIVED				
SODIUM	00929	000				DUE
SPECIFIC CONDUCTANCE	00095	WAIVED				
SULFATE	00945	WAIVED				
TOTAL DISSOLVED SOLIDS	70300	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800015***

System Name: ***SOMERSTON WINERY***

PS Code: ***2800015-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800015-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800015***

System Name: ***SOMERSTON WINERY***

PS Code: ***2800015-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800015***

System Name: ***SOMERSTON WINERY***

PS Code: ***2800015-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800015***

System Name: ***SOMERSTON WINERY***

PS Code: ***2800015-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800015***

System Name: ***SOMERSTON WINERY***

PS Code: ***2800015-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800017***

System Name: ***STAGLIN FAMILY VINEYARDS***

PS Code: ***2800017-001***

Source Name: ***WELL 3***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2012/03/21	< .000	2013/03	
NITRITE (AS N)	00620	000				**DUE**
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800017***

System Name: ***STAGLIN FAMILY VINEYARDS***

PS Code: ***2800017-001***

Source Name: ***WELL 3***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800017***

System Name: ***STAGLIN FAMILY VINEYARDS***

PS Code: ***2800017-001***

Source Name: ***WELL 3***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800017***

System Name: ***STAGLIN FAMILY VINEYARDS***

PS Code: ***2800017-001***

Source Name: ***WELL 3***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800017***

System Name: ***STAGLIN FAMILY VINEYARDS***

PS Code: ***2800017-001***

Source Name: ***WELL 3***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800021***

System Name: ***KENZO WINERY***

PS Code: ***2800021-001***

Source Name: ***WELL 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	000			DUE
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	000			DUE
NITRITE (AS N)	00620	000			DUE
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800021***

System Name: ***KENZO WINERY***

PS Code: ***2800021-001***

Source Name: ***WELL 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800021***

System Name: ***KENZO WINERY***

PS Code: ***2800021-001***

Source Name: ***WELL 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800021***

System Name: ***KENZO WINERY***

PS Code: ***2800021-001***

Source Name: ***WELL 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800021***

System Name: ***KENZO WINERY***

PS Code: ***2800021-001***

Source Name: ***WELL 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800022***

System Name: ***CADE WINERY***

PS Code: ***2800022-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	000			DUE
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	000			DUE
NITRITE (AS N)	00620	000			DUE
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800022***

System Name: ***CADE WINERY***

PS Code: ***2800022-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800022***

System Name: ***CADE WINERY***

PS Code: ***2800022-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800022***

System Name: ***CADE WINERY***

PS Code: ***2800022-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800022***

System Name: ***CADE WINERY***

PS Code: ***2800022-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800023
System Name: RUTHERFORD HILL MUTUAL WATER

PS Code: 2800023-001
Source Name: WELL 02 OLD WELL
Source Number: 001
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED	2008/10/28	.000	
INORGANIC					
ALUMINUM	01105	036	2011/10/05	< .000	2014/10
ANTIMONY	01097	036	2011/10/05	< .000	2014/10
ARSENIC	01002	036	2011/10/05	2.900	2014/10
ASBESTOS	81855	108	2008/10/28	.000	2017/10
BARIUM	01007	036	2011/10/05	< .000	2014/10
BERYLLIUM	01012	036	2011/10/05	< .000	2014/10
CADMIUM	01027	036	2011/10/05	< .000	2014/10
CHROMIUM (TOTAL)	01034	036	2011/10/05	< .000	2014/10
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2011/08/24	< .000	2014/08
LEAD	01051	WAIVED	2011/10/05	< .000	
MERCURY	71900	036	2011/10/05	< .000	2014/10
NICKEL	01067	036	2011/10/05	< .000	2014/10
PERCHLORATE	A-031	036	2009/08/20	.000	2012/08
SELENIUM	01147	036	2011/10/05	< .000	2014/10
THALLIUM	01059	036	2011/10/05	< .000	2014/10
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2011/05/19	< .000	2012/05
NITRITE (AS N)	00620	036	2011/10/05	< .000	2014/10
RADIOLOGICAL					
GROSS ALPHA	01501	108	2012/01/11	1.090	2021/01
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED	2009/04/17	1.680	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800023***

System Name: ***RUTHERFORD HILL MUTUAL WATER***

PS Code: ***2800023-001***

Source Name: ***WELL 02 OLD WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	108	2011/08/24	< 1.000	2020/08	
2,4-D	39730	108	2011/08/24	< 10.000	2020/08	
ALACHLOR	77825	WAIVED	2008/10/28	.000		
ATRAZINE	39033	036	2011/08/24	< .500	2014/08	
BENTAZON	38710	WAIVED	2011/08/24	< 2.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2011/08/24	< 5.000	2014/08	
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2011/08/24	< 10.000	2014/08	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2008/11/20	.000		
DINOSEB	81287	036	2011/08/24	< 2.000	2014/08	
DIQUAT	78885	036	2011/08/24	< 4.000	2014/08	
ENDOTHALL	38926	036	2011/08/24	< 45.000	2014/08	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	108	2008/11/20	.000	2017/11	
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800023***

System Name: ***RUTHERFORD HILL MUTUAL WATER***

PS Code: ***2800023-001***

Source Name: ***WELL 02 OLD WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	000				DUE
MOLINATE	82199	WAIVED	2008/10/28	.000		
OXAMYL	38865	036	2011/08/24	< 20.000	2014/08	
PENTACHLOROPHENOL	39032	036	2011/08/24	< .200	2014/08	
PICLORAM	39720	036	2011/08/24	< 1.000	2014/08	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2011/08/24	< 1.000	2014/08	
THIOBENCARB	A-001	WAIVED	2008/10/28	.000		
TOXAPHENE	39400	000				DUE
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2008/11/20	.000	2014/11	
1,1,2,2-TETRACHLOROETHANE	34516	072	2008/11/20	.000	2014/11	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2008/11/20	.000	2014/11	
1,1,2-TRICHLOROETHANE	34511	072	2008/11/20	.000	2014/11	
1,1-DICHLOROETHANE	34496	072	2008/11/20	.000	2014/11	
1,1-DICHLOROETHYLENE	34501	072	2008/11/20	.000	2014/11	
1,2,4-TRICHLOROBENZENE	34551	072	2008/11/20	.000	2014/11	
1,2-DICHLOROBENZENE	34536	072	2008/11/20	.000	2014/11	
1,2-DICHLOROETHANE	34531	072	2008/11/20	.000	2014/11	
1,2-DICHLOROPROPANE	34541	072	2008/11/20	.000	2014/11	
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2008/11/20	.000	2014/11	
1,4-DICHLOROBENZENE	34571	072	2008/11/20	.000	2014/11	
BENZENE	34030	072	2008/11/20	.000	2014/11	
CARBON TETRACHLORIDE	32102	072	2008/11/20	.000	2014/11	
CIS-1,2-DICHLOROETHYLENE	77093	072	2008/11/20	.000	2014/11	
DICHLOROMETHANE	34423	072	2008/11/20	.000	2014/11	
ETHYLBENZENE	34371	072	2008/11/20	.000	2014/11	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	036	2008/11/20	.000	2011/11	DUE
MONOCHLOROBENZENE	34301	072	2008/11/20	.000	2014/11	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800023***

System Name: ***RUTHERFORD HILL MUTUAL WATER***

PS Code: ***2800023-001***

Source Name: ***WELL 02 OLD WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED VOC						
STYRENE	77128	072	2008/11/20	.000	2014/11	
TETRACHLOROETHYLENE	34475	072	2008/11/20	.000	2014/11	
TOLUENE	34010	072	2008/11/20	.000	2014/11	
TRANS-1,2-DICHLOROETHYLENE	34546	072	2008/11/20	.000	2014/11	
TRICHLOROETHYLENE	39180	072	2008/11/20	.000	2014/11	
TRICHLOROFLUOROMETHANE	34488	072	2008/11/20	.000	2014/11	
VINYL CHLORIDE	39175	072	2008/11/20	.000	2014/11	
XYLENES (TOTAL)	81551	072	2008/11/20	.000	2014/11	
SECONDARY/GP						
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED				
BICARBONATE ALKALINITY	00440	036	2011/10/05	290.000	2014/10	
CALCIUM	00916	036	2011/10/05	9.500	2014/10	
CARBONATE ALKALINITY	00445	036	2011/10/05	< .000	2014/10	
CHLORIDE	00940	000				**DUE**
COLOR	00081	000				**DUE**
COPPER	01042	000				**DUE**
FOAMING AGENTS (MBAS)	38260	000				**DUE**
HARDNESS (TOTAL) AS CACO3	00900	036	2011/08/24	50.000	2014/08	
HYDROXIDE ALKALINITY	71830	036	2011/10/05	< .000	2014/10	
IRON	01045	036	2011/10/05	< .000	2014/10	
MAGNESIUM	00927	036	2011/10/05	7.100	2014/10	
MANGANESE	01055	036	2011/10/05	36.000	2014/10	
ODOR THRESHOLD @ 60 C	00086	000				**DUE**
PH, LABORATORY	00403	036	2011/10/05	7.900	2014/10	
SILVER	01077	036	2011/10/05	< .000	2014/10	
SODIUM	00929	036	2011/10/05	78.000	2014/10	
SPECIFIC CONDUCTANCE	00095	000				**DUE**
SULFATE	00945	000				**DUE**
TOTAL DISSOLVED SOLIDS	70300	000				**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800023***

System Name: ***RUTHERFORD HILL MUTUAL WATER***

PS Code: ***2800023-001***

Source Name: ***WELL 02 OLD WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
SECONDARY/GP						
TURBIDITY, LABORATORY	**82079**	**000**				**DUE**
ZINC	**01092**	**000**				**DUE**

PS Code: ***2800023-002***

Source Name: ***WELL 3 NEW WELL***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	**39570**	**WAIVED**	2008/10/27	**.000**	
INORGANIC					
ALUMINUM	**01105**	**036**	2009/10/12	**.000**	2012/10
ANTIMONY	**01097**	**036**	2009/10/12	**.000**	2012/10
ARSENIC	**01002**	**036**	2009/10/12	**8.700**	2012/10
ASBESTOS	**81855**	**108**	2008/10/29	**.000**	2017/10
BARIUM	**01007**	**036**	2009/10/12	**100.000**	2012/10
BERYLLIUM	**01012**	**036**	2009/10/12	**.000**	2012/10
CADMIUM	**01027**	**036**	2009/10/12	**.000**	2012/10
CHROMIUM (TOTAL)	**01034**	**036**	2009/10/12	**.000**	2012/10
CYANIDE	**01291**	**WAIVED**			
FLUORIDE (F) (NATURAL-SOURCE)	**00951**	**036**	2009/10/12	**.000**	2012/10
LEAD	**01051**	**WAIVED**	2009/10/12	**.000**	
MERCURY	**71900**	**036**	2009/10/12	**.000**	2012/10
NICKEL	**01067**	**036**	2009/10/12	**22.000**	2012/10
PERCHLORATE	**A-031**	**036**	2009/10/12	**.000**	2012/10
SELENIUM	**01147**	**036**	2009/10/12	**.000**	2012/10
THALLIUM	**01059**	**036**	2009/10/12	**.000**	2012/10

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800023
System Name: RUTHERFORD HILL MUTUAL WATER

PS Code: 2800023-002
Source Name: WELL 3 NEW WELL
Source Number: 002
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2011/05/19	< .000	2012/05
NITRITE (AS N)	00620	036	2009/10/12	.000	2012/10
RADIOLOGICAL					
GROSS ALPHA	01501	108	2010/01/26	4.710	2019/01
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED	2009/04/17	1.680	
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	108	2009/10/12	.000	2018/10
2,4-D	39730	108	2009/10/12	.000	2018/10
ALACHLOR	77825	WAIVED	2008/10/27	.000	
ATRAZINE	39033	036	2011/08/24	< .500	2014/08
BENTAZON	38710	WAIVED	2009/10/12	.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	036	2009/10/12	.000	2012/10
CHLORDANE	39350	WAIVED	2006/08/18	< .100	
DALAPON	38432	036	2009/10/12	.000	2012/10
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2006/08/18	< .010	
DINOSEB	81287	036	2009/10/12	.000	2012/10
DIQUAT	78885	036	2009/10/12	.000	2012/10

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800023***

System Name: ***RUTHERFORD HILL MUTUAL WATER***

PS Code: ***2800023-002***

Source Name: ***WELL 3 NEW WELL***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	036	2009/10/12	.000	2012/10
ENDRIN	39390	WAIVED	2006/08/18	< .100	
ETHYLENE DIBROMIDE (EDB)	77651	108	2006/08/18	< .020	2015/08
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	108	2006/08/18	< .010	2015/08
HEPTACHLOR EPOXIDE	39420	108	2006/08/18	< .010	2015/08
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	108	2006/08/18	< .200	2015/08
METHOXYCHLOR	39480	108	2006/08/18	< 10.000	2015/08
MOLINATE	82199	WAIVED	2008/10/27	.000	
OXAMYL	38865	036	2009/10/12	.000	2012/10
PENTACHLOROPHENOL	39032	036	2009/10/12	.000	2012/10
PICLORAM	39720	036	2009/10/12	.000	2012/10
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2006/08/18	< .500	
SIMAZINE	39055	036	2011/08/24	< 1.000	2014/08
THIOBENCARB	A-001	WAIVED	2008/10/27	.000	
TOXAPHENE	39400	108	2006/08/18	< 1.000	2015/08
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	072	2011/08/24	< .000	2017/08
1,1,2,2-TETRACHLOROETHANE	34516	072	2011/08/24	< .000	2017/08
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2011/08/24	< .000	2017/08
1,1,2-TRICHLOROETHANE	34511	072	2011/08/24	< .000	2017/08
1,1-DICHLOROETHANE	34496	072	2011/08/24	< .000	2017/08
1,1-DICHLOROETHYLENE	34501	072	2011/08/24	< .000	2017/08
1,2,4-TRICHLOROBENZENE	34551	072	2011/08/24	< .000	2017/08
1,2-DICHLOROBENZENE	34536	072	2011/08/24	< .000	2017/08
1,2-DICHLOROETHANE	34531	072	2011/08/24	< .000	2017/08
1,2-DICHLOROPROPANE	34541	072	2011/08/24	< .000	2017/08

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800023***

System Name: ***RUTHERFORD HILL MUTUAL WATER***

PS Code: ***2800023-002***

Source Name: ***WELL 3 NEW WELL***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED VOC						
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2011/08/24	< .000	2017/08	
1,4-DICHLOROBENZENE	34571	072	2011/08/24	< .000	2017/08	
BENZENE	34030	072	2011/08/24	< .000	2017/08	
CARBON TETRACHLORIDE	32102	072	2011/08/24	< .000	2017/08	
CIS-1,2-DICHLOROETHYLENE	77093	072	2011/08/24	< .000	2017/08	
DICHLOROMETHANE	34423	072	2011/08/24	< .000	2017/08	
ETHYLBENZENE	34371	072	2011/08/24	< .000	2017/08	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	036	2011/08/24	< .000	2014/08	
MONOCHLOROBENZENE	34301	072	2011/08/24	< .000	2017/08	
STYRENE	77128	072	2011/08/24	< .000	2017/08	
TETRACHLOROETHYLENE	34475	072	2011/08/24	< .000	2017/08	
TOLUENE	34010	072	2011/08/24	< .000	2017/08	
TRANS-1,2-DICHLOROETHYLENE	34546	072	2011/08/24	< .000	2017/08	
TRICHLOROETHYLENE	39180	072	2011/08/24	< .000	2017/08	
TRICHLOROFLUOROMETHANE	34488	072	2011/08/24	< .000	2017/08	
VINYL CHLORIDE	39175	072	2011/08/24	< .000	2017/08	
XYLENES (TOTAL)	81551	072	2011/08/24	< .000	2017/08	
SECONDARY/GP						
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED				
BICARBONATE ALKALINITY	00440	036	2009/10/12	180.000	2012/10	
CALCIUM	00916	036	2009/10/12	20.000	2012/10	
CARBONATE ALKALINITY	00445	036	2009/10/12	.000	2012/10	
CHLORIDE	00940	000				**DUE**
COLOR	00081	000				**DUE**
COPPER	01042	000				**DUE**
FOAMING AGENTS (MBAS)	38260	000				**DUE**
HARDNESS (TOTAL) AS CACO3	00900	036	2009/10/12	200.000	2012/10	
HYDROXIDE ALKALINITY	71830	036	2009/10/12	.000	2012/10	
IRON	01045	036	2009/10/12	3900.000	2012/10	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800023***

System Name: ***RUTHERFORD HILL MUTUAL WATER***

PS Code: ***2800023-002***

Source Name: ***WELL 3 NEW WELL***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
SECONDARY/GP						
MAGNESIUM	00927	036	2009/10/12	33.000	2012/10	
MANGANESE	01055	036	2009/10/12	200.000	2012/10	
ODOR THRESHOLD @ 60 C	00086	000				DUE
PH, LABORATORY	00403	036	2009/10/12	7.900	2012/10	
SILVER	01077	036	2009/10/12	.000	2012/10	
SODIUM	00929	036	2009/10/12	29.000	2012/10	
SPECIFIC CONDUCTANCE	00095	000				DUE
SULFATE	00945	000				DUE
TOTAL DISSOLVED SOLIDS	70300	000				DUE
TURBIDITY, LABORATORY	82079	000				DUE
ZINC	01092	000				DUE

PS Code: ***2800023-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15		
DIAZINON	39570	WAIVED
INORGANIC		
ALUMINUM	01105	WAIVED
ANTIMONY	01097	WAIVED
ARSENIC	01002	WAIVED
ASBESTOS	81855	WAIVED
BARIUM	01007	WAIVED
BERYLLIUM	01012	WAIVED
CADMIUM	01027	WAIVED
CHROMIUM (TOTAL)	01034	WAIVED
CYANIDE	01291	WAIVED

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800023***

System Name: ***RUTHERFORD HILL MUTUAL WATER***

PS Code: ***2800023-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED	2009/08/21	.000	
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800023***

System Name: ***RUTHERFORD HILL MUTUAL WATER***

PS Code: ***2800023-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800023***

System Name: ***RUTHERFORD HILL MUTUAL WATER***

PS Code: ***2800023-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800023***

System Name: ***RUTHERFORD HILL MUTUAL WATER***

PS Code: ***2800023-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2009/08/21	7.200	
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800024***

System Name: ***DUCKHORN VINEYARDS***

PS Code: ***2800024-001***

Source Name: ***WELL 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED	2008/08/27	.000	
INORGANIC					
ALUMINUM	01105	036	2011/08/22	108.000	2014/08
ANTIMONY	01097	036	2011/08/22	< .000	2014/08
ARSENIC	01002	036	2011/08/22	4.400	2014/08
ASBESTOS	81855	108	2011/05/18	< .200	2020/05
BARIUM	01007	036	2011/08/22	< .000	2014/08
BERYLLIUM	01012	036	2011/08/22	< .000	2014/08
CADMIUM	01027	036	2011/08/22	< .000	2014/08
CHROMIUM (TOTAL)	01034	036	2011/08/22	< .000	2014/08
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2011/08/22	.290	2014/08
LEAD	01051	WAIVED	2011/08/22	< .000	
MERCURY	71900	036	2011/08/22	< .000	2014/08
NICKEL	01067	036	2011/08/22	< .000	2014/08
PERCHLORATE	A-031	036	2010/01/18	.000	2013/01
SELENIUM	01147	036	2011/08/22	< .000	2014/08
THALLIUM	01059	036	2011/08/22	< .000	2014/08
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2011/05/18	< .000	2012/05
NITRITE (AS N)	00620	036	2011/05/18	< .000	2014/05
RADIOLOGICAL					
GROSS ALPHA	01501	108	2007/06/14	.805	2016/06
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED	2006/09/01	.740	
RADIUM 228	11501	WAIVED	2006/09/01	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800024***

System Name: ***DUCKHORN VINEYARDS***

PS Code: ***2800024-001***

Source Name: ***WELL 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2011/08/22	< 1.000	
2,4-D	39730	WAIVED	2011/08/22	< 10.000	
ALACHLOR	77825	WAIVED	2011/08/24	< 1.000	
ATRAZINE	39033	036	2011/08/22	< .500	2014/08
BENTAZON	38710	WAIVED	2011/08/22	< 2.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	036	2011/08/22	< 5.000	2014/08
CHLORDANE	39350	WAIVED	2011/08/24	< .100	
DALAPON	38432	036	2011/08/22	< 10.000	2014/08
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2007/05/24	.000	
DINOSEB	81287	036	2011/08/22	< 2.000	2014/08
DIQUAT	78885	036	2011/08/22	< 4.000	2014/08
ENDOTHALL	38926	036	2011/08/22	< 45.000	2014/08
ENDRIN	39390	WAIVED	2011/08/24	< .100	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2007/05/24	.000	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2011/08/24	< .010	
HEPTACHLOR EPOXIDE	39420	WAIVED	2011/08/24	< .010	
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED	2011/08/24	< .200	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800024***

System Name: ***DUCKHORN VINEYARDS***

PS Code: ***2800024-001***

Source Name: ***WELL 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED	2011/08/24	< 10.000	
MOLINATE	82199	WAIVED	2008/08/27	.000	
OXAMYL	38865	036	2011/08/22	< 20.000	2014/08
PENTACHLOROPHENOL	39032	036	2011/08/22	< .200	2014/08
PICLORAM	39720	036	2011/08/22	< 1.000	2014/08
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2011/08/24	< .500	
SIMAZINE	39055	036	2011/08/22	< 1.000	2014/08
THIOBENCARB	A-001	WAIVED	2008/08/27	.000	
TOXAPHENE	39400	WAIVED	2011/08/24	< 1.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	072	2007/05/24	.000	2013/05
1,1,2,2-TETRACHLOROETHANE	34516	072	2007/05/24	.000	2013/05
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2007/05/24	.000	2013/05
1,1,2-TRICHLOROETHANE	34511	072	2007/05/24	.000	2013/05
1,1-DICHLOROETHANE	34496	072	2007/05/24	.000	2013/05
1,1-DICHLOROETHYLENE	34501	072	2007/05/24	.000	2013/05
1,2,4-TRICHLOROBENZENE	34551	072	2007/05/24	.000	2013/05
1,2-DICHLOROBENZENE	34536	072	2007/05/24	.000	2013/05
1,2-DICHLOROETHANE	34531	072	2007/05/24	.000	2013/05
1,2-DICHLOROPROPANE	34541	072	2007/05/24	.000	2013/05
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2007/05/24	.000	2013/05
1,4-DICHLOROBENZENE	34571	072	2007/05/24	.000	2013/05
BENZENE	34030	072	2007/05/24	.000	2013/05
CARBON TETRACHLORIDE	32102	072	2007/05/24	.000	2013/05
CIS-1,2-DICHLOROETHYLENE	77093	072	2007/05/24	.000	2013/05
DICHLOROMETHANE	34423	072	2007/05/24	.000	2013/05
ETHYLBENZENE	34371	072	2007/05/24	.000	2013/05
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2008/08/27	.000	2014/08
MONOCHLOROBENZENE	34301	072	2007/05/24	.000	2013/05

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800024***

System Name: ***DUCKHORN VINEYARDS***

PS Code: ***2800024-001***

Source Name: ***WELL 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2007/05/24	.000	2013/05
TETRACHLOROETHYLENE	34475	072	2007/05/24	.000	2013/05
TOLUENE	34010	072	2007/05/24	.000	2013/05
TRANS-1,2-DICHLOROETHYLENE	34546	072	2007/05/24	.000	2013/05
TRICHLOROETHYLENE	39180	072	2007/05/24	.000	2013/05
TRICHLOROFLUOROMETHANE	34488	072	2007/05/24	.000	2013/05
VINYL CHLORIDE	39175	072	2007/05/24	.000	2013/05
XYLENES (TOTAL)	81551	072	2007/05/24	.000	2013/05
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2011/08/22	192.000	
CALCIUM	00916	WAIVED	2011/08/22	14.000	
CARBONATE ALKALINITY	00445	WAIVED	2011/08/22	< .000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2011/08/22	68.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2011/08/22	< .000	
IRON	01045	WAIVED	2011/08/22	< .000	
MAGNESIUM	00927	WAIVED	2011/08/22	8.000	
MANGANESE	01055	WAIVED	2011/08/22	80.400	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2011/08/22	7.100	
SILVER	01077	WAIVED	2011/08/22	< .000	
SODIUM	00929	WAIVED	2011/08/22	39.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800024***

System Name: ***DUCKHORN VINEYARDS***

PS Code: ***2800024-001***

Source Name: ***WELL 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800024-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800024***

System Name: ***DUCKHORN VINEYARDS***

PS Code: ***2800024-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800024***

System Name: ***DUCKHORN VINEYARDS***

PS Code: ***2800024-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800024***

System Name: ***DUCKHORN VINEYARDS***

PS Code: ***2800024-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800024***

System Name: ***DUCKHORN VINEYARDS***

PS Code: ***2800024-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800025***

System Name: ***HAGAFEN CELLARS***

PS Code: ***2800025-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2012/04/03	7.800	2013/04	
NITRITE (AS N)	00620	036	2010/04/05	.000	2013/04	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800025***

System Name: ***HAGAFEN CELLARS***

PS Code: ***2800025-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800025***

System Name: ***HAGAFEN CELLARS***

PS Code: ***2800025-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800025***

System Name: ***HAGAFEN CELLARS***

PS Code: ***2800025-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800025***

System Name: ***HAGAFEN CELLARS***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)

PS Code: ***2800025-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800025-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED			

INORGANIC

ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800025***

System Name: ***HAGAFEN CELLARS***

PS Code: ***2800025-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800025***

System Name: ***HAGAFEN CELLARS***

PS Code: ***2800025-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800025***

System Name: ***HAGAFEN CELLARS***

PS Code: ***2800025-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800025***

System Name: ***HAGAFEN CELLARS***

PS Code: ***2800025-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800026***

System Name: ***TRINCHERO WINERY***

PS Code: ***2800026-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED	2008/09/04	.000		
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	**2011/02/14**	.000	**2012/02**	**DUE**
NITRITE (AS N)	00620	036	2011/02/14	.000	2014/02	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800026***

System Name: ***TRINCHERO WINERY***

PS Code: ***2800026-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800026***

System Name: ***TRINCHERO WINERY***

PS Code: ***2800026-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800026***

System Name: ***TRINCHERO WINERY***

PS Code: ***2800026-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	WAIVED	2005/01/17	20.000	
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800026***

System Name: ***TRINCHERO WINERY***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)

PS Code: ***2800026-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800026-002***

Source Name: ***WELL 002***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED	2008/08/20	.000	

INORGANIC

ALUMINUM	01105	WAIVED	2008/08/20	.000	
ANTIMONY	01097	WAIVED	2008/08/20	.000	
ARSENIC	01002	WAIVED	2008/08/20	2.100	
ASBESTOS	81855	WAIVED	2008/08/20	.000	
BARIUM	01007	WAIVED	2008/08/20	.000	
BERYLLIUM	01012	WAIVED	2008/08/20	.000	
CADMIUM	01027	WAIVED	2008/08/20	.000	
CHROMIUM (TOTAL)	01034	WAIVED	2008/08/20	.000	
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2008/08/20	.000	
LEAD	01051	WAIVED	2008/08/20	.000	
MERCURY	71900	WAIVED	2008/08/20	.000	
NICKEL	01067	WAIVED	2008/08/20	.000	
PERCHLORATE	A-031	WAIVED	2008/08/20	.000	
SELENIUM	01147	WAIVED	2008/08/20	.000	
THALLIUM	01059	WAIVED	2008/08/20	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800026***

System Name: ***TRINCHERO WINERY***

PS Code: ***2800026-002***

Source Name: ***WELL 002***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2012/03/21	21.000	2013/03
NITRITE (AS N)	00620	036	2011/02/14	.000	2014/02
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED	2009/05/26	3.080	
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2008/08/20	.000	
2,4-D	39730	WAIVED	2008/08/20	.000	
ALACHLOR	77825	WAIVED	2008/08/20	.000	
ATRAZINE	39033	WAIVED	2008/08/20	.000	
BENTAZON	38710	WAIVED	2008/08/20	.000	
BENZO (A) PYRENE	34247	WAIVED	2008/08/20	.000	
CARBOFURAN	81405	WAIVED	2008/08/20	.000	
CHLORDANE	39350	WAIVED	2008/08/20	.000	
DALAPON	38432	WAIVED	2008/08/20	.000	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED	2008/08/20	.000	
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED	2008/08/20	.000	
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2008/08/20	.000	
DINOSEB	81287	WAIVED	2008/08/20	.000	
DIQUAT	78885	WAIVED	2008/08/20	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800026***

System Name: ***TRINCHERO WINERY***

PS Code: ***2800026-002***

Source Name: ***WELL 002***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED	2008/08/20	.000	
ENDRIN	39390	WAIVED	2008/08/20	.000	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2008/08/20	.000	
GLYPHOSATE	79743	WAIVED	2008/08/20	.000	
HEPTACHLOR	39410	WAIVED	2008/08/20	.000	
HEPTACHLOR EPOXIDE	39420	WAIVED	2008/08/20	.000	
HEXACHLOROBENZENE	39700	WAIVED	2008/08/20	.000	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2008/08/20	.000	
LINDANE	39340	WAIVED	2008/08/20	.000	
METHOXYCHLOR	39480	WAIVED	2008/08/20	.000	
MOLINATE	82199	WAIVED	2008/08/20	.000	
OXAMYL	38865	WAIVED	2008/08/20	.000	
PENTACHLOROPHENOL	39032	WAIVED	2008/08/20	.000	
PICLORAM	39720	WAIVED	2008/08/20	.000	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2008/08/20	.000	
SIMAZINE	39055	WAIVED	2008/08/20	.000	
THIOBENCARB	A-001	WAIVED	2008/08/20	.000	
TOXAPHENE	39400	WAIVED	2008/08/20	.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED	2008/08/20	.000	
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED	2008/08/20	.000	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED	2008/08/20	.000	
1,1,2-TRICHLOROETHANE	34511	WAIVED	2008/08/20	.000	
1,1-DICHLOROETHANE	34496	WAIVED	2008/08/20	.000	
1,1-DICHLOROETHYLENE	34501	WAIVED	2008/08/20	.000	
1,2,4-TRICHLOROBENZENE	34551	WAIVED	2008/08/20	.000	
1,2-DICHLOROBENZENE	34536	WAIVED	2008/08/20	.000	
1,2-DICHLOROETHANE	34531	WAIVED	2008/08/20	.000	
1,2-DICHLOROPROPANE	34541	WAIVED	2008/08/20	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800026***

System Name: ***TRINCHERO WINERY***

PS Code: ***2800026-002***

Source Name: ***WELL 002***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED	2008/08/20	.000	
1,4-DICHLOROBENZENE	34571	WAIVED	2008/08/20	.000	
BENZENE	34030	WAIVED	2008/08/20	.000	
CARBON TETRACHLORIDE	32102	WAIVED	2008/08/20	.000	
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED	2008/08/20	.000	
DICHLOROMETHANE	34423	WAIVED	2008/08/20	.000	
ETHYLBENZENE	34371	WAIVED	2008/08/20	.000	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED	2008/08/20	.000	
MONOCHLOROBENZENE	34301	WAIVED	2008/08/20	.000	
STYRENE	77128	WAIVED	2008/08/20	.000	
TETRACHLOROETHYLENE	34475	WAIVED	2008/08/20	.000	
TOLUENE	34010	WAIVED	2008/08/20	.000	
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED	2008/08/20	.000	
TRICHLOROETHYLENE	39180	WAIVED	2008/08/20	.000	
TRICHLOROFLUOROMETHANE	34488	WAIVED	2008/08/20	.000	
VINYL CHLORIDE	39175	WAIVED	2008/08/20	.000	
XYLENES (TOTAL)	81551	WAIVED	2008/08/20	.000	
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2008/08/20	180.000	
CALCIUM	00916	WAIVED	2008/08/20	25.000	
CARBONATE ALKALINITY	00445	WAIVED	2008/08/20	.000	
CHLORIDE	00940	WAIVED	2008/08/20	160.000	
COLOR	00081	WAIVED	2008/08/20	.000	
COPPER	01042	WAIVED	2008/08/20	.000	
FOAMING AGENTS (MBAS)	38260	WAIVED	2008/08/20	.000	
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2008/08/20	140.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2008/08/20	.000	
IRON	01045	WAIVED	2008/08/20	240.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800026***

System Name: ***TRINCHERO WINERY***

PS Code: ***2800026-002***

Source Name: ***WELL 002***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED	2008/08/20	19.000	
MANGANESE	01055	WAIVED	2008/08/20	42.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED	2008/08/20	1.000	
PH, LABORATORY	00403	WAIVED	2008/08/20	6.800	
SILVER	01077	WAIVED	2008/08/20	.000	
SODIUM	00929	WAIVED	2008/08/20	23.000	
SPECIFIC CONDUCTANCE	00095	WAIVED	2008/08/20	430.000	
SULFATE	00945	WAIVED	2008/08/20	37.000	
TOTAL DISSOLVED SOLIDS	70300	WAIVED	2008/08/20	320.000	
TURBIDITY, LABORATORY	82079	WAIVED	2008/08/20	.730	
ZINC	01092	WAIVED	2008/08/20	1200.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800027***

System Name: ***NICKEL & NICKEL WINERY***

PS Code: ***2800027-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED	2006/06/28	.000	
INORGANIC					
ALUMINUM	01105	WAIVED	2009/05/11	.000	
ANTIMONY	01097	WAIVED	2009/05/11	.000	
ARSENIC	01002	WAIVED	2009/05/11	.000	
ASBESTOS	81855	WAIVED	2011/02/16	.000	
BARIUM	01007	WAIVED	2009/05/11	150.000	
BERYLLIUM	01012	WAIVED	2009/05/11	.000	
CADMIUM	01027	WAIVED	2009/05/11	.000	
CHROMIUM (TOTAL)	01034	WAIVED	2009/05/11	.000	
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2009/05/11	.360	
LEAD	01051	WAIVED	2009/05/11	.000	
MERCURY	71900	WAIVED	2009/05/11	.000	
NICKEL	01067	WAIVED	2009/05/11	.000	
PERCHLORATE	A-031	WAIVED	2011/02/16	< 4.000	
SELENIUM	01147	WAIVED	2009/05/11	.000	
THALLIUM	01059	WAIVED	2009/05/11	.000	
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2012/03/26	1.140	2013/03
NITRITE (AS N)	00620	036	2012/03/26	< 100.000	2015/03
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED	2009/05/11	2.060	
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800027***

System Name: ***NICKEL & NICKEL WINERY***

PS Code: ***2800027-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2008/01/23	< 1.000	
2,4-D	39730	WAIVED	2008/01/23	< 10.000	
ALACHLOR	77825	WAIVED	2009/05/11	.000	
ATRAZINE	39033	WAIVED	2009/05/11	.000	
BENTAZON	38710	WAIVED	2008/01/23	< 2.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED	2011/02/16	< .000	
CHLORDANE	39350	WAIVED	2008/01/23	< .100	
DALAPON	38432	WAIVED	2011/02/16	< 5.000	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2008/01/23	.000	
DINOSEB	81287	WAIVED	2011/02/16	< .200	
DIQUAT	78885	WAIVED	2011/02/16	< 4.000	
ENDOTHALL	38926	WAIVED	2011/02/16	< 20.000	
ENDRIN	39390	WAIVED	2008/01/23	< .100	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2008/01/23	.000	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2008/01/23	< .010	
HEPTACHLOR EPOXIDE	39420	WAIVED	2008/01/23	< .010	
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED	2008/01/23	< .200	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800027***

System Name: ***NICKEL & NICKEL WINERY***

PS Code: ***2800027-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED	2008/01/23	< 10.000	
MOLINATE	82199	WAIVED	2009/05/11	.000	
OXAMYL	38865	WAIVED	2011/02/16	< .000	
PENTACHLOROPHENOL	39032	WAIVED	2011/02/16	< .050	
PICLORAM	39720	WAIVED	2011/02/16	< .050	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2008/01/23	< .500	
SIMAZINE	39055	WAIVED	2009/05/11	.000	
THIOBENCARB	A-001	WAIVED	2009/05/11	.000	
TOXAPHENE	39400	WAIVED	2008/01/23	< 1.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED	2011/02/16	< .500	
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED	2011/02/16	< .500	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED	2011/02/16	< .500	
1,1,2-TRICHLOROETHANE	34511	WAIVED	2011/02/16	< .500	
1,1-DICHLOROETHANE	34496	WAIVED	2011/02/16	< .500	
1,1-DICHLOROETHYLENE	34501	WAIVED	2011/02/16	< .500	
1,2,4-TRICHLOROBENZENE	34551	WAIVED	2011/02/16	< .500	
1,2-DICHLOROBENZENE	34536	WAIVED	2011/02/16	< .500	
1,2-DICHLOROETHANE	34531	WAIVED	2011/02/16	< .500	
1,2-DICHLOROPROPANE	34541	WAIVED	2011/02/16	< .500	
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED	2011/02/16	< .500	
1,4-DICHLOROBENZENE	34571	WAIVED	2011/02/16	< .500	
BENZENE	34030	WAIVED	2011/02/16	< .500	
CARBON TETRACHLORIDE	32102	WAIVED	2011/02/16	< .500	
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED	2011/02/16	< .500	
DICHLOROMETHANE	34423	WAIVED	2011/02/16	< .500	
ETHYLBENZENE	34371	WAIVED	2011/02/16	< .500	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED	2011/02/16	< .500	
MONOCHLOROBENZENE	34301	WAIVED	2011/02/16	< .500	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800027***

System Name: ***NICKEL & NICKEL WINERY***

PS Code: ***2800027-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED	2011/02/16	< .500	
TETRACHLOROETHYLENE	34475	WAIVED	2011/02/16	< .500	
TOLUENE	34010	WAIVED	2011/02/16	< .500	
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED	2011/02/16	< .500	
TRICHLOROETHYLENE	39180	WAIVED	2011/02/16	< .500	
TRICHLOROFLUOROMETHANE	34488	WAIVED	2011/02/16	< .500	
VINYL CHLORIDE	39175	WAIVED	2011/02/16	< .500	
XYLENES (TOTAL)	81551	WAIVED	2011/02/16	< 1.000	
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2009/05/11	380.000	
CALCIUM	00916	WAIVED	2009/05/11	37.000	
CARBONATE ALKALINITY	00445	WAIVED	2009/05/11	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2009/05/11	210.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2009/05/11	.000	
IRON	01045	WAIVED	2009/05/11	.000	
MAGNESIUM	00927	WAIVED	2009/05/11	28.000	
MANGANESE	01055	WAIVED	2009/05/11	790.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2009/05/11	7.600	
SILVER	01077	WAIVED	2009/05/11	.000	
SODIUM	00929	WAIVED	2009/05/11	65.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800027***

System Name: ***NICKEL & NICKEL WINERY***

PS Code: ***2800027-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800027-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800027***

System Name: ***NICKEL & NICKEL WINERY***

PS Code: ***2800027-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800027***

System Name: ***NICKEL & NICKEL WINERY***

PS Code: ***2800027-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800027***

System Name: ***NICKEL & NICKEL WINERY***

PS Code: ***2800027-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800027***

System Name: ***NICKEL & NICKEL WINERY***

PS Code: ***2800027-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800028***

System Name: ***VINEYARD 7 & 8***

PS Code: ***2800028-001***

Source Name: ***WELL 3***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	000			DUE
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	000			DUE
NITRITE (AS N)	00620	000			DUE
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800028***

System Name: ***VINEYARD 7 & 8***

PS Code: ***2800028-001***

Source Name: ***WELL 3***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800028***

System Name: ***VINEYARD 7 & 8***

PS Code: ***2800028-001***

Source Name: ***WELL 3***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800028***

System Name: ***VINEYARD 7 & 8***

PS Code: ***2800028-001***

Source Name: ***WELL 3***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800028***

System Name: ***VINEYARD 7 & 8***

PS Code: ***2800028-001***

Source Name: ***WELL 3***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800029***

System Name: ***AUGUST BRIGGS WINERY***

PS Code: ***2800029-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED	2008/07/15	.000		
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/01/13	1.100	2012/01	**DUE**
NITRITE (AS N)	00620	000				**DUE**
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800029***

System Name: ***AUGUST BRIGGS WINERY***

PS Code: ***2800029-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800029***

System Name: ***AUGUST BRIGGS WINERY***

PS Code: ***2800029-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800029***

System Name: ***AUGUST BRIGGS WINERY***

PS Code: ***2800029-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800029***

System Name: ***AUGUST BRIGGS WINERY***

PS Code: ***2800029-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800029-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800029***

System Name: ***AUGUST BRIGGS WINERY***

PS Code: ***2800029-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800029***

System Name: ***AUGUST BRIGGS WINERY***

PS Code: ***2800029-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800029***

System Name: ***AUGUST BRIGGS WINERY***

PS Code: ***2800029-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800029***

System Name: ***AUGUST BRIGGS WINERY***

PS Code: ***2800029-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800030***

System Name: ***ENVY WINES***

PS Code: ***2800030-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/07/08	< .000	2012/07	
NITRITE (AS N)	00620	036	2011/07/08	< .000	2014/07	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800030***

System Name: ***ENVY WINES***

PS Code: ***2800030-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800030***

System Name: ***ENVY WINES***

PS Code: ***2800030-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800030***

System Name: ***ENVY WINES***

PS Code: ***2800030-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800030***

System Name: ***ENVY WINES***

PS Code: ***2800030-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800031***

System Name: ***SIGNORELLO WINERY***

PS Code: ***2800031-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2010/11/01	.000	2011/11	**DUE**
NITRITE (AS N)	00620	036	2010/11/01	.000	2013/11	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800031***

System Name: ***SIGNORELLO WINERY***

PS Code: ***2800031-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800031***

System Name: ***SIGNORELLO WINERY***

PS Code: ***2800031-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800031***

System Name: ***SIGNORELLO WINERY***

PS Code: ***2800031-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800031***

System Name: ***SIGNORELLO WINERY***

PS Code: ***2800031-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED	2004/05/04	.190	
ZINC	01092	WAIVED			

PS Code: ***2800031-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800031***

System Name: ***SIGNORELLO WINERY***

PS Code: ***2800031-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800031***

System Name: ***SIGNORELLO WINERY***

PS Code: ***2800031-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800031***

System Name: ***SIGNORELLO WINERY***

PS Code: ***2800031-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800031***

System Name: ***SIGNORELLO WINERY***

PS Code: ***2800031-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800032***

System Name: ***TERRA VALENTINE***

PS Code: ***2800032-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/02/28	7.000	2012/02	**DUE**
NITRITE (AS N)	00620	036	2011/02/28	< 400.000	2014/02	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800032***

System Name: ***TERRA VALENTINE***

PS Code: ***2800032-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800032***

System Name: ***TERRA VALENTINE***

PS Code: ***2800032-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800032***

System Name: ***TERRA VALENTINE***

PS Code: ***2800032-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800032***

System Name: ***TERRA VALENTINE***

PS Code: ***2800032-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800032-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800032***

System Name: ***TERRA VALENTINE***

PS Code: ***2800032-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800032***

System Name: ***TERRA VALENTINE***

PS Code: ***2800032-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800032***

System Name: ***TERRA VALENTINE***

PS Code: ***2800032-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800032***

System Name: ***TERRA VALENTINE***

PS Code: ***2800032-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800036***

System Name: ***NAPA VALLEY RESERVE WATER SYSTEM***

PS Code: ***2800036-001***

Source Name: ***WELL 001-EAST WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED	2009/08/20	.000		
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/05/19	< .000	2012/05	
NITRITE (AS N)	00620	036	2010/04/19	.000	2013/04	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED	2007/06/14	.000		
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED	2006/08/31	.200		
RADIUM 228	11501	WAIVED	2006/08/31	.890		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800036***

System Name: ***NAPA VALLEY RESERVE WATER SYSTEM***

PS Code: ***2800036-001***

Source Name: ***WELL 001-EAST WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800036***

System Name: ***NAPA VALLEY RESERVE WATER SYSTEM***

PS Code: ***2800036-001***

Source Name: ***WELL 001-EAST WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800036***

System Name: ***NAPA VALLEY RESERVE WATER SYSTEM***

PS Code: ***2800036-001***

Source Name: ***WELL 001-EAST WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800036***

System Name: ***NAPA VALLEY RESERVE WATER SYSTEM***

PS Code: ***2800036-001***

Source Name: ***WELL 001-EAST WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800036-002***

Source Name: ***WELL 002-WEST WELL***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	000			**DUE**
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED	2009/08/20	.000	
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800036***

System Name: ***NAPA VALLEY RESERVE WATER SYSTEM***

PS Code: ***2800036-002***

Source Name: ***WELL 002-WEST WELL***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2011/05/19	< .000	2012/05
NITRITE (AS N)	00620	036	2010/04/19	.000	2013/04
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED	2007/06/14	.000	
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED	2006/08/31	.460	
RADIUM 228	11501	WAIVED	2006/08/31	.000	
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800036***

System Name: ***NAPA VALLEY RESERVE WATER SYSTEM***

PS Code: ***2800036-002***

Source Name: ***WELL 002-WEST WELL***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800036***

System Name: ***NAPA VALLEY RESERVE WATER SYSTEM***

PS Code: ***2800036-002***

Source Name: ***WELL 002-WEST WELL***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800036***

System Name: ***NAPA VALLEY RESERVE WATER SYSTEM***

PS Code: ***2800036-002***

Source Name: ***WELL 002-WEST WELL***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
MAGNESIUM	00927	000				**DUE**
MANGANESE	01055	000				**DUE**
ODOR THRESHOLD @ 60 C	00086	WAIVED				
PH, LABORATORY	00403	000				**DUE**
SILVER	01077	WAIVED				
SODIUM	00929	000				**DUE**
SPECIFIC CONDUCTANCE	00095	WAIVED				
SULFATE	00945	WAIVED				
TOTAL DISSOLVED SOLIDS	70300	WAIVED				
TURBIDITY, LABORATORY	82079	WAIVED				
ZINC	01092	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800037***

System Name: ***KATHRYN HALL WINERY***

PS Code: ***2800037-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800037***

System Name: ***KATHRYN HALL WINERY***

PS Code: ***2800037-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800037***

System Name: ***KATHRYN HALL WINERY***

PS Code: ***2800037-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800037***

System Name: ***KATHRYN HALL WINERY***

PS Code: ***2800037-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800037***

System Name: ***KATHRYN HALL WINERY***

PS Code: ***2800037-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800038***

System Name: ***VINEYARD 29***

PS Code: ***2800038-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED	2011/02/08	16.000		
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2012/02/07	< .000	2013/02	
NITRITE (AS N)	00620	000				**DUE**
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800038***

System Name: ***VINEYARD 29***

PS Code: ***2800038-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800038***

System Name: ***VINEYARD 29***

PS Code: ***2800038-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800038***

System Name: ***VINEYARD 29***

PS Code: ***2800038-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800038***

System Name: ***VINEYARD 29***

PS Code: ***2800038-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800043***

System Name: ***CASTELLO DI AMOROSA***

PS Code: ***2800043-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED	2008/12/17	.000	
INORGANIC					
ALUMINUM	01105	036	2011/11/21	< .000	2014/11
ANTIMONY	01097	036	2011/11/21	< .000	2014/11
ARSENIC	01002	036	2011/11/21	4.900	2014/11
ASBESTOS	81855	108	2008/12/17	.000	2017/12
BARIUM	01007	036	2011/11/21	< .000	2014/11
BERYLLIUM	01012	036	2011/11/21	< .000	2014/11
CADMIUM	01027	036	2011/11/21	< .000	2014/11
CHROMIUM (TOTAL)	01034	036	2011/11/21	< .000	2014/11
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2011/11/21	< .000	2014/11
LEAD	01051	WAIVED	2011/11/21	< .000	
MERCURY	71900	036	2011/11/21	< .000	2014/11
NICKEL	01067	036	2011/11/21	< .000	2014/11
PERCHLORATE	A-031	036	2010/05/12	.000	2013/05
SELENIUM	01147	036	2011/11/21	< .000	2014/11
THALLIUM	01059	036	2011/11/21	< .000	2014/11
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2011/10/28	< .000	2012/10
NITRITE (AS N)	00620	036	2011/11/21	< .000	2014/11
RADIOLOGICAL					
GROSS ALPHA	01501	108	2010/05/12	1.430	2019/05
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800043***

System Name: ***CASTELLO DI AMOROSA***

PS Code: ***2800043-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2011/11/21	< 1.000		
2,4-D	39730	WAIVED	2011/11/21	< 10.000		
ALACHLOR	77825	WAIVED	2008/12/17	.000		
ATRAZINE	39033	036	2011/11/21	< .500	2014/11	
BENTAZON	38710	WAIVED	2011/11/21	< 2.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2011/11/21	< 5.000	2014/11	
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2011/11/21	< 10.000	2014/11	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2008/12/17	.000		
DINOSEB	81287	036	2011/11/21	< 2.000	2014/11	
DIQUAT	78885	036	2011/11/21	< 4.000	2014/11	
ENDOTHALL	38926	036	2011/11/21	< 45.000	2014/11	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2008/12/17	.000		
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800043***

System Name: ***CASTELLO DI AMOROSA***

PS Code: ***2800043-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	000				**DUE**
MOLINATE	82199	WAIVED	2008/12/17	.000		
OXAMYL	38865	036	2011/11/21	< 20.000	2014/11	
PENTACHLOROPHENOL	39032	036	2011/11/21	< .200	2014/11	
PICLORAM	39720	036	2011/11/21	< 1.000	2014/11	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2011/11/21	< 1.000	2014/11	
THIOBENCARB	A-001	WAIVED	2008/12/17	.000		
TOXAPHENE	39400	000				**DUE**
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2008/12/17	.000	2014/12	
1,1,2,2-TETRACHLOROETHANE	34516	072	2008/12/17	.000	2014/12	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2008/12/17	.000	2014/12	
1,1,2-TRICHLOROETHANE	34511	072	2008/12/17	.000	2014/12	
1,1-DICHLOROETHANE	34496	072	2008/12/17	.000	2014/12	
1,1-DICHLOROETHYLENE	34501	072	2008/12/17	.000	2014/12	
1,2,4-TRICHLOROBENZENE	34551	072	2008/12/17	.000	2014/12	
1,2-DICHLOROBENZENE	34536	072	2008/12/17	.000	2014/12	
1,2-DICHLOROETHANE	34531	072	2008/12/17	.000	2014/12	
1,2-DICHLOROPROPANE	34541	072	2008/12/17	.000	2014/12	
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2008/12/17	.000	2014/12	
1,4-DICHLOROBENZENE	34571	072	2008/12/17	.000	2014/12	
BENZENE	34030	072	2008/12/17	.000	2014/12	
CARBON TETRACHLORIDE	32102	072	2008/12/17	.000	2014/12	
CIS-1,2-DICHLOROETHYLENE	77093	072	2008/12/17	.000	2014/12	
DICHLOROMETHANE	34423	072	2008/12/17	.000	2014/12	
ETHYLBENZENE	34371	072	2008/12/17	.000	2014/12	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2008/12/17	.000	2014/12	
MONOCHLOROBENZENE	34301	072	2008/12/17	.000	2014/12	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800043***

System Name: ***CASTELLO DI AMOROSA***

PS Code: ***2800043-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2008/12/17	.000	2014/12
TETRACHLOROETHYLENE	34475	072	2008/12/17	.000	2014/12
TOLUENE	34010	072	2008/12/17	.000	2014/12
TRANS-1,2-DICHLOROETHYLENE	34546	072	2008/12/17	.000	2014/12
TRICHLOROETHYLENE	39180	072	2008/12/17	.000	2014/12
TRICHLOROFLUOROMETHANE	34488	072	2008/12/17	.000	2014/12
VINYL CHLORIDE	39175	072	2008/12/17	.000	2014/12
XYLENES (TOTAL)	81551	072	2008/12/17	.000	2014/12
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2011/11/21	87.000	
CALCIUM	00916	WAIVED	2011/11/21	8.800	
CARBONATE ALKALINITY	00445	WAIVED	2011/11/21	< .000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2011/11/21	38.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2011/11/21	< .000	
IRON	01045	WAIVED	2011/11/21	< .000	
MAGNESIUM	00927	WAIVED	2011/11/21	3.800	
MANGANESE	01055	WAIVED	2011/11/21	< .000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2011/11/21	6.700	
SILVER	01077	WAIVED	2011/11/21	< .000	
SODIUM	00929	WAIVED	2011/11/21	15.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800043***

System Name: ***CASTELLO DI AMOROSA***

PS Code: ***2800043-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800043-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800043***

System Name: ***CASTELLO DI AMOROSA***

PS Code: ***2800043-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED	2010/02/05	.480	
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800043***

System Name: ***CASTELLO DI AMOROSA***

PS Code: ***2800043-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800043***

System Name: ***CASTELLO DI AMOROSA***

PS Code: ***2800043-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800043***

System Name: ***CASTELLO DI AMOROSA***

PS Code: ***2800043-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800044***

System Name: ***LARKMEAD VINEYARDS***

PS Code: ***2800044-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED	2012/01/11	68.000		
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2009/04/10	7.000	2010/04	**DUE**
NITRITE (AS N)	00620	036	2009/04/10	< 400.000	2012/04	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800044***

System Name: ***LARKMEAD VINEYARDS***

PS Code: ***2800044-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800044***

System Name: ***LARKMEAD VINEYARDS***

PS Code: ***2800044-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800044***

System Name: ***LARKMEAD VINEYARDS***

PS Code: ***2800044-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800044***

System Name: ***LARKMEAD VINEYARDS***

PS Code: ***2800044-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
TURBIDITY, LABORATORY	82079	WAIVED	2009/01/14	6.300	
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800100***

System Name: ***DEL DOTTO WINERY***

PS Code: ***2800100-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2009/08/31	.000	2010/08	**DUE**
NITRITE (AS N)	00620	036	2008/09/18	.000	2011/09	**DUE**
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800100***

System Name: ***DEL DOTTO WINERY***

PS Code: ***2800100-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800100***

System Name: ***DEL DOTTO WINERY***

PS Code: ***2800100-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800100***

System Name: ***DEL DOTTO WINERY***

PS Code: ***2800100-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800100***

System Name: ***DEL DOTTO WINERY***

PS Code: ***2800100-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800100-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800100***

System Name: ***DEL DOTTO WINERY***

PS Code: ***2800100-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800100***

System Name: ***DEL DOTTO WINERY***

PS Code: ***2800100-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800100***

System Name: ***DEL DOTTO WINERY***

PS Code: ***2800100-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800100***

System Name: ***DEL DOTTO WINERY***

PS Code: ***2800100-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800101***

System Name: ***EHLERS ESTATE***

PS Code: ***2800101-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2012/01/05	< .000	2013/01	
NITRITE (AS N)	00620	036	2012/01/05	< .000	2015/01	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800101***

System Name: ***EHLERS ESTATE***

PS Code: ***2800101-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800101***

System Name: ***EHLERS ESTATE***

PS Code: ***2800101-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800101***

System Name: ***EHLERS ESTATE***

PS Code: ***2800101-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800101***

System Name: ***EHLERS ESTATE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)

PS Code: ***2800101-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800101-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED			

INORGANIC

ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800101***

System Name: ***EHLERS ESTATE***

PS Code: ***2800101-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800101***

System Name: ***EHLERS ESTATE***

PS Code: ***2800101-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800101***

System Name: ***EHLERS ESTATE***

PS Code: ***2800101-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800101***

System Name: ***EHLERS ESTATE***

PS Code: ***2800101-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800103***

System Name: ***NAPA L ATTITUDE***

PS Code: ***2800103-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/05/27	< .000	2012/05	
NITRITE (AS N)	00620	036	2011/05/27	< .000	2014/05	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800103***

System Name: ***NAPA L ATTITUDE***

PS Code: ***2800103-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800103***

System Name: ***NAPA L ATTITUDE***

PS Code: ***2800103-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800103***

System Name: ***NAPA L ATTITUDE***

PS Code: ***2800103-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800103***

System Name: ***NAPA L ATTITUDE***

PS Code: ***2800103-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800103-002***

Source Name: ***TREATMENT 002***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800103***

System Name: ***NAPA L ATTITUDE***

PS Code: ***2800103-002***

Source Name: ***TREATMENT 002***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800103***

System Name: ***NAPA L ATTITUDE***

PS Code: ***2800103-002***

Source Name: ***TREATMENT 002***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800103***

System Name: ***NAPA L ATTITUDE***

PS Code: ***2800103-002***

Source Name: ***TREATMENT 002***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800103***

System Name: ***NAPA L ATTITUDE***

PS Code: ***2800103-002***

Source Name: ***TREATMENT 002***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800105***

System Name: ***GROTH VINEYARDS & WINERY***

PS Code: ***2800105-001***

Source Name: ***WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/12/06	< .000	2012/12	
NITRITE (AS N)	00620	036	2011/12/06	< .000	2014/12	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800105***

System Name: ***GROTH VINEYARDS & WINERY***

PS Code: ***2800105-001***

Source Name: ***WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800105***

System Name: ***GROTH VINEYARDS & WINERY***

PS Code: ***2800105-001***

Source Name: ***WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800105***

System Name: ***GROTH VINEYARDS & WINERY***

PS Code: ***2800105-001***

Source Name: ***WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800105***

System Name: ***GROTH VINEYARDS & WINERY***

PS Code: ***2800105-001***

Source Name: ***WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800105-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800105***

System Name: ***GROTH VINEYARDS & WINERY***

PS Code: ***2800105-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800105***

System Name: ***GROTH VINEYARDS & WINERY***

PS Code: ***2800105-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800105***

System Name: ***GROTH VINEYARDS & WINERY***

PS Code: ***2800105-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800105***

System Name: ***GROTH VINEYARDS & WINERY***

PS Code: ***2800105-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800106***

System Name: ***CUVAISON CARNEROS***

PS Code: ***2800106-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	000			DUE
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	000			DUE
NITRITE (AS N)	00620	000			DUE
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800106***

System Name: ***CUVAISON CARNEROS***

PS Code: ***2800106-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800106***

System Name: ***CUVAISON CARNEROS***

PS Code: ***2800106-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800106***

System Name: ***CUVAISON CARNEROS***

PS Code: ***2800106-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800106***

System Name: ***CUVAISON CARNEROS***

PS Code: ***2800106-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800107***

System Name: ***BLACK STALLION WINERY***

PS Code: ***2800107-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/03/03	.000	2012/03	**DUE**
NITRITE (AS N)	00620	036	2009/04/22	.000	2012/04	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800107***

System Name: ***BLACK STALLION WINERY***

PS Code: ***2800107-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800107***

System Name: ***BLACK STALLION WINERY***

PS Code: ***2800107-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800107***

System Name: ***BLACK STALLION WINERY***

PS Code: ***2800107-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800107***

System Name: ***BLACK STALLION WINERY***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)

PS Code: ***2800107-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800107-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED			

INORGANIC

ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800107***

System Name: ***BLACK STALLION WINERY***

PS Code: ***2800107-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800107***

System Name: ***BLACK STALLION WINERY***

PS Code: ***2800107-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800107***

System Name: ***BLACK STALLION WINERY***

PS Code: ***2800107-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800107***

System Name: ***BLACK STALLION WINERY***

PS Code: ***2800107-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800108***

System Name: ***ROUND POND ESTATE WINERY LLC***

PS Code: ***2800108-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/11/16	5.400	2012/11	
NITRITE (AS N)	00620	036	2010/10/14	.000	2013/10	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800108***

System Name: ***ROUND POND ESTATE WINERY LLC***

PS Code: ***2800108-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800108***

System Name: ***ROUND POND ESTATE WINERY LLC***

PS Code: ***2800108-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800108***

System Name: ***ROUND POND ESTATE WINERY LLC***

PS Code: ***2800108-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800108***

System Name: ***ROUND POND ESTATE WINERY LLC***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)

PS Code: ***2800108-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800108-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED			

INORGANIC

ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800108***

System Name: ***ROUND POND ESTATE WINERY LLC***

PS Code: ***2800108-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800108***

System Name: ***ROUND POND ESTATE WINERY LLC***

PS Code: ***2800108-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800108***

System Name: ***ROUND POND ESTATE WINERY LLC***

PS Code: ***2800108-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800108***

System Name: ***ROUND POND ESTATE WINERY LLC***

PS Code: ***2800108-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800109***

System Name: ***PALMAZ VINEYARDS***

PS Code: ***2800109-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	000			DUE
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	000			DUE
NITRITE (AS N)	00620	000			DUE
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800109***

System Name: ***PALMAZ VINEYARDS***

PS Code: ***2800109-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800109***

System Name: ***PALMAZ VINEYARDS***

PS Code: ***2800109-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800109***

System Name: ***PALMAZ VINEYARDS***

PS Code: ***2800109-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800109***

System Name: ***PALMAZ VINEYARDS***

PS Code: ***2800109-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800110***

System Name: ***MARKHAM VINEYARDS***

PS Code: ***2800110-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	000			DUE
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	000			DUE
NITRITE (AS N)	00620	000			DUE
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800110***

System Name: ***MARKHAM VINEYARDS***

PS Code: ***2800110-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800110***

System Name: ***MARKHAM VINEYARDS***

PS Code: ***2800110-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800110***

System Name: ***MARKHAM VINEYARDS***

PS Code: ***2800110-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800110***

System Name: ***MARKHAM VINEYARDS***

PS Code: ***2800110-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800110-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800110***

System Name: ***MARKHAM VINEYARDS***

PS Code: ***2800110-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800110***

System Name: ***MARKHAM VINEYARDS***

PS Code: ***2800110-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800110***

System Name: ***MARKHAM VINEYARDS***

PS Code: ***2800110-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800110***

System Name: ***MARKHAM VINEYARDS***

PS Code: ***2800110-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800110-004***

Source Name: ***CITY OF ST HELENA***

Source Number: ***004***

Source Status: ***PURCHASED TREATED***

Water type: ***SURFACE***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED			

INORGANIC

ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800110***

System Name: ***MARKHAM VINEYARDS***

PS Code: ***2800110-004***

Source Name: ***CITY OF ST HELENA***

Source Number: ***004***

Source Status: ***PURCHASED TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800110***

System Name: ***MARKHAM VINEYARDS***

PS Code: ***2800110-004***

Source Name: ***CITY OF ST HELENA***

Source Number: ***004***

Source Status: ***PURCHASED TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800110***

System Name: ***MARKHAM VINEYARDS***

PS Code: ***2800110-004***

Source Name: ***CITY OF ST HELENA***

Source Number: ***004***

Source Status: ***PURCHASED TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800110***

System Name: ***MARKHAM VINEYARDS***

PS Code: ***2800110-004***

Source Name: ***CITY OF ST HELENA***

Source Number: ***004***

Source Status: ***PURCHASED TREATED***

Water type: ***SURFACE***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800112***

System Name: ***PROFESSIONAL BUILDING OF ST HELENA***

PS Code: ***2800112-002***

Source Name: ***WE;; 002 (NEW WELL)***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	000				DUE
ANTIMONY	01097	000				DUE
ARSENIC	01002	000				DUE
ASBESTOS	81855	000				DUE
BARIUM	01007	000				DUE
BERYLLIUM	01012	000				DUE
CADMIUM	01027	000				DUE
CHROMIUM (TOTAL)	01034	000				DUE
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				DUE
LEAD	01051	WAIVED				
MERCURY	71900	000				DUE
NICKEL	01067	000				DUE
PERCHLORATE	A-031	006	2011/10/12	< 4.000	2012/04	
SELENIUM	01147	000				DUE
THALLIUM	01059	000				DUE
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/10/12	6.400	2012/10	
NITRITE (AS N)	00620	000				DUE
RADIOLOGICAL						
GROSS ALPHA	01501	108	2012/04/04	.772	2021/04	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED	2012/04/04	.000		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800112***

System Name: ***PROFESSIONAL BUILDING OF ST HELENA***

PS Code: ***2800112-002***

Source Name: ***WE;; 002 (NEW WELL)***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	000			DUE
2,4-D	39730	000			DUE
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	000			DUE
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	000			DUE
CHLORDANE	39350	WAIVED			
DALAPON	38432	000			DUE
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	000			DUE
DIQUAT	78885	000			DUE
ENDOTHALL	38926	000			DUE
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	000			DUE
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	000			DUE
HEPTACHLOR EPOXIDE	39420	000			DUE
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800112***

System Name: ***PROFESSIONAL BUILDING OF ST HELENA***

PS Code: ***2800112-002***

Source Name: ***WE;; 002 (NEW WELL)***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	000			DUE
MOLINATE	82199	WAIVED			
OXAMYL	38865	000			DUE
PENTACHLOROPHENOL	39032	000			DUE
PICLORAM	39720	000			DUE
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	000			DUE
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	000			DUE
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	000			DUE
1,1,2,2-TETRACHLOROETHANE	34516	000			DUE
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	000			DUE
1,1,2-TRICHLOROETHANE	34511	000			DUE
1,1-DICHLOROETHANE	34496	000			DUE
1,1-DICHLOROETHYLENE	34501	000			DUE
1,2,4-TRICHLOROBENZENE	34551	000			DUE
1,2-DICHLOROBENZENE	34536	000			DUE
1,2-DICHLOROETHANE	34531	000			DUE
1,2-DICHLOROPROPANE	34541	000			DUE
1,3-DICHLOROPROPENE (TOTAL)	34561	000			DUE
1,4-DICHLOROBENZENE	34571	000			DUE
BENZENE	34030	000			DUE
CARBON TETRACHLORIDE	32102	000			DUE
CIS-1,2-DICHLOROETHYLENE	77093	000			DUE
DICHLOROMETHANE	34423	000			DUE
ETHYLBENZENE	34371	000			DUE
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	000			DUE
MONOCHLOROBENZENE	34301	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800112***

System Name: ***PROFESSIONAL BUILDING OF ST HELENA***

PS Code: ***2800112-002***

Source Name: ***WE;; 002 (NEW WELL)***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	000			DUE
TETRACHLOROETHYLENE	34475	000			DUE
TOLUENE	34010	000			DUE
TRANS-1,2-DICHLOROETHYLENE	34546	000			DUE
TRICHLOROETHYLENE	39180	000			DUE
TRICHLOROFLUOROMETHANE	34488	000			DUE
VINYL CHLORIDE	39175	000			DUE
XYLENES (TOTAL)	81551	000			DUE
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800112***

System Name: ***PROFESSIONAL BUILDING OF ST HELENA***

PS Code: ***2800112-002***

Source Name: ***WE;; 002 (NEW WELL)***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800113***

System Name: ***PICKETT ROAD WINE COMPANY***

PS Code: ***2800113-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	000			DUE
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	000			DUE
NITRITE (AS N)	00620	000			DUE
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800113***

System Name: ***PICKETT ROAD WINE COMPANY***

PS Code: ***2800113-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800113***

System Name: ***PICKETT ROAD WINE COMPANY***

PS Code: ***2800113-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800113***

System Name: ***PICKETT ROAD WINE COMPANY***

PS Code: ***2800113-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800113***

System Name: ***PICKETT ROAD WINE COMPANY***

PS Code: ***2800113-001***

Source Name: ***WELL 001***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800129***

System Name: ***STERLING VINEYARDS***

PS Code: ***2800129-001***

Source Name: ***WELL 01-MARSTON WELL***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	036	2010/06/23	1900.000	2013/06
ANTIMONY	01097	036	2010/06/23	< 6.000	2013/06
ARSENIC	01002	036	2010/06/23	5.600	2013/06
ASBESTOS	81855	108	2011/08/17	.000	2020/08
BARIUM	01007	036	2010/06/23	< 100.000	2013/06
BERYLLIUM	01012	036	2010/06/23	1.800	2013/06
CADMIUM	01027	036	2010/06/23	< 1.000	2013/06
CHROMIUM (TOTAL)	01034	036	2010/06/23	< 1.000	2013/06
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2010/06/23	.250	2013/06
LEAD	01051	WAIVED	2007/02/28	< 5.000	
MERCURY	71900	036	2010/06/23	< 1.000	2013/06
NICKEL	01067	036	2010/06/23	< 10.000	2013/06
PERCHLORATE	A-031	036	2011/06/22	< 4.000	2014/06
SELENIUM	01147	036	2010/06/23	< 5.000	2013/06
THALLIUM	01059	036	2010/06/23	< 1.000	2013/06
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2012/03/21	< 2.000	2013/03
NITRITE (AS N)	00620	036	2010/06/23	< 400.000	2013/06
RADIOLOGICAL					
GROSS ALPHA	01501	108	2009/04/15	1.200	2018/04
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800129***

System Name: ***STERLING VINEYARDS***

PS Code: ***2800129-001***

Source Name: ***WELL 01-MARSTON WELL***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2010/06/23	.000		
2,4-D	39730	WAIVED	2010/06/23	.000		
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	036	2010/06/23	.000	2013/06	
BENTAZON	38710	WAIVED	2010/06/23	.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2010/06/23	.000	2013/06	
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2010/06/23	.000	2013/06	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	036	2010/06/23	.000	2013/06	
DIQUAT	78885	036	2010/06/23	.000	2013/06	
ENDOTHALL	38926	036	2010/06/23	.000	2013/06	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2000/03/15	.000		
GLYPHOSATE	79743	WAIVED	1988/06/29	< 5.000		
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800129***

System Name: ***STERLING VINEYARDS***

PS Code: ***2800129-001***

Source Name: ***WELL 01-MARSTON WELL***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	000				**DUE**
MOLINATE	82199	WAIVED				
OXAMYL	38865	036	2010/06/23	.000	2013/06	
PENTACHLOROPHENOL	39032	036	2010/06/23	.000	2013/06	
PICLORAM	39720	036	2010/06/23	.000	2013/06	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2010/06/23	.000	2013/06	
THIOBENCARB	A-001	WAIVED				
TOXAPHENE	39400	000				**DUE**
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2012/03/21	.000	2018/03	
1,1,2,2-TETRACHLOROETHANE	34516	072	2012/03/21	.000	2018/03	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2012/03/21	.000	2018/03	
1,1,2-TRICHLOROETHANE	34511	072	2012/03/21	.000	2018/03	
1,1-DICHLOROETHANE	34496	072	2012/03/21	.000	2018/03	
1,1-DICHLOROETHYLENE	34501	072	2012/03/21	.000	2018/03	
1,2,4-TRICHLOROBENZENE	34551	072	2012/03/21	.000	2018/03	
1,2-DICHLOROBENZENE	34536	072	2012/03/21	.000	2018/03	
1,2-DICHLOROETHANE	34531	072	2012/03/21	.000	2018/03	
1,2-DICHLOROPROPANE	34541	072	2012/03/21	.000	2018/03	
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2012/03/21	.000	2018/03	
1,4-DICHLOROBENZENE	34571	072	2012/03/21	.000	2018/03	
BENZENE	34030	072	2012/03/21	.000	2018/03	
CARBON TETRACHLORIDE	32102	072	2012/03/21	.000	2018/03	
CIS-1,2-DICHLOROETHYLENE	77093	072	2012/03/21	.000	2018/03	
DICHLOROMETHANE	34423	072	2012/03/21	.000	2018/03	
ETHYLBENZENE	34371	072	2012/03/21	.000	2018/03	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2012/03/21	.000	2018/03	
MONOCHLOROBENZENE	34301	072	2012/03/21	.000	2018/03	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800129
System Name: STERLING VINEYARDS

PS Code: 2800129-001
Source Name: WELL 01-MARSTON WELL
Source Number: 001
Source Status: ACTIVE RAW
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2012/03/21	.000	2018/03
TETRACHLOROETHYLENE	34475	072	2012/03/21	.000	2018/03
TOLUENE	34010	072	2012/03/21	.000	2018/03
TRANS-1,2-DICHLOROETHYLENE	34546	072	2012/03/21	.000	2018/03
TRICHLOROETHYLENE	39180	072	2012/03/21	.000	2018/03
TRICHLOROFLUOROMETHANE	34488	072	2012/03/21	.000	2018/03
VINYL CHLORIDE	39175	072	2012/03/21	.000	2018/03
XYLENES (TOTAL)	81551	072	2012/03/21	.000	2018/03
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2010/06/23	54.000	
CALCIUM	00916	WAIVED	2010/06/23	25.000	
CARBONATE ALKALINITY	00445	WAIVED	2010/06/23	< 1.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED	2003/05/21	< 50.000	
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2010/06/23	71.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2010/06/23	< 1.000	
IRON	01045	WAIVED	2010/06/23	23000.000	
MAGNESIUM	00927	WAIVED	2010/06/23	2.000	
MANGANESE	01055	WAIVED	2010/06/23	1200.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2010/06/23	6.700	
SILVER	01077	WAIVED	2010/06/23	< 10.000	
SODIUM	00929	WAIVED	2010/06/23	26.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800129
System Name: STERLING VINEYARDS

PS Code: 2800129-001
Source Name: WELL 01-MARSTON WELL
Source Number: 001
Source Status: ACTIVE RAW
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED	2003/05/21	89.000	

PS Code: 2800129-002
Source Name: WELL 002-WINERY WELL
Source Number: 002
Source Status: ACTIVE RAW
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	036	2010/06/23	< 50.000	2013/06
ANTIMONY	01097	036	2010/06/23	< 6.000	2013/06
ARSENIC	01002	036	2012/02/22	14.000	2015/02
ASBESTOS	81855	108	2011/08/17	.000	2020/08
BARIUM	01007	036	2010/06/23	< 100.000	2013/06
BERYLLIUM	01012	036	2010/06/23	< 1.000	2013/06
CADMIUM	01027	036	2010/06/23	< 1.000	2013/06
CHROMIUM (TOTAL)	01034	036	2010/06/23	< 1.000	2013/06
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2010/06/23	.490	2013/06
LEAD	01051	WAIVED	2007/02/28	< 5.000	
MERCURY	71900	036	2010/06/23	< 1.000	2013/06
NICKEL	01067	036	2010/06/23	< 10.000	2013/06
PERCHLORATE	A-031	036	2011/06/22	< 4.000	2014/06
SELENIUM	01147	036	2010/06/23	< 5.000	2013/06
THALLIUM	01059	036	2010/06/23	< 1.000	2013/06

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800129***

System Name: ***STERLING VINEYARDS***

PS Code: ***2800129-002***

Source Name: ***WELL 002-WINERY WELL***

Source Number: ***002***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2012/03/21	< 2.000	2013/03
NITRITE (AS N)	00620	036	2010/06/23	< 400.000	2013/06
RADIOLOGICAL					
GROSS ALPHA	01501	108	2009/04/15	.000	2018/04
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2010/06/23	.000	
2,4-D	39730	WAIVED	2010/06/23	.000	
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	036	2010/06/23	.000	2013/06
BENTAZON	38710	WAIVED	2010/06/23	.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	036	2010/06/23	.000	2013/06
CHLORDANE	39350	WAIVED			
DALAPON	38432	036	2010/06/23	.000	2013/06
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	036	2010/06/23	.000	2013/06
DIQUAT	78885	036	2010/06/23	.000	2013/06

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800129***

System Name: ***STERLING VINEYARDS***

PS Code: ***2800129-002***

Source Name: ***WELL 002-WINERY WELL***

Source Number: ***002***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
ENDOTHALL	38926	036	2010/06/23	.000	2013/06	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	000				**DUE**
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**
METHOXYCHLOR	39480	000				**DUE**
MOLINATE	82199	WAIVED				
OXAMYL	38865	036	2010/06/23	.000	2013/06	
PENTACHLOROPHENOL	39032	036	2010/06/23	.000	2013/06	
PICLORAM	39720	036	2010/06/23	.000	2013/06	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2010/06/23	.000	2013/06	
THIOBENCARB	A-001	WAIVED				
TOXAPHENE	39400	000				**DUE**
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2012/03/21	.000	2018/03	
1,1,2,2-TETRACHLOROETHANE	34516	072	2012/03/21	.000	2018/03	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2012/03/21	.000	2018/03	
1,1,2-TRICHLOROETHANE	34511	072	2012/03/21	.000	2018/03	
1,1-DICHLOROETHANE	34496	072	2012/03/21	.000	2018/03	
1,1-DICHLOROETHYLENE	34501	072	2012/03/21	.000	2018/03	
1,2,4-TRICHLOROBENZENE	34551	072	2012/03/21	.000	2018/03	
1,2-DICHLOROBENZENE	34536	072	2012/03/21	.000	2018/03	
1,2-DICHLOROETHANE	34531	072	2012/03/21	.000	2018/03	
1,2-DICHLOROPROPANE	34541	072	2012/03/21	1.600	2018/03	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800129***

System Name: ***STERLING VINEYARDS***

PS Code: ***2800129-002***

Source Name: ***WELL 002-WINERY WELL***

Source Number: ***002***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2012/03/21	.000	2018/03
1,4-DICHLOROBENZENE	34571	072	2012/03/21	.000	2018/03
BENZENE	34030	072	2012/03/21	.000	2018/03
CARBON TETRACHLORIDE	32102	072	2012/03/21	.000	2018/03
CIS-1,2-DICHLOROETHYLENE	77093	072	2012/03/21	.000	2018/03
DICHLOROMETHANE	34423	072	2012/03/21	.000	2018/03
ETHYLBENZENE	34371	072	2012/03/21	.000	2018/03
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2012/03/21	.000	2018/03
MONOCHLOROBENZENE	34301	072	2012/03/21	.000	2018/03
STYRENE	77128	072	2012/03/21	.000	2018/03
TETRACHLOROETHYLENE	34475	072	2012/03/21	.000	2018/03
TOLUENE	34010	072	2012/03/21	.000	2018/03
TRANS-1,2-DICHLOROETHYLENE	34546	072	2012/03/21	.000	2018/03
TRICHLOROETHYLENE	39180	072	2012/03/21	.000	2018/03
TRICHLOROFLUOROMETHANE	34488	072	2012/03/21	.000	2018/03
VINYL CHLORIDE	39175	072	2012/03/21	.000	2018/03
XYLENES (TOTAL)	81551	072	2012/03/21	.000	2018/03
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2010/06/23	110.000	
CALCIUM	00916	WAIVED	2010/06/23	19.000	
CARBONATE ALKALINITY	00445	WAIVED	2010/06/23	< 1.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2010/06/23	73.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2010/06/23	< 1.000	
IRON	01045	WAIVED	2010/06/23	7600.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800129***

System Name: ***STERLING VINEYARDS***

PS Code: ***2800129-002***

Source Name: ***WELL 002-WINERY WELL***

Source Number: ***002***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
MAGNESIUM	00927	WAIVED	2010/06/23	6.200	
MANGANESE	01055	WAIVED	2010/06/23	1400.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2010/06/23	6.700	
SILVER	01077	WAIVED	2010/06/23	< 10.000	
SODIUM	00929	WAIVED	2010/06/23	26.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800129-003***

Source Name: ***WELL 003-OAK TREE WELL***

Source Number: ***003***

Source Status: ***STANDBY RAW***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	108	2008/07/16	< 50.000	2017/07
ANTIMONY	01097	108	2008/07/16	< 6.000	2017/07
ARSENIC	01002	108	2008/07/16	4.800	2017/07
ASBESTOS	81855	108	2008/07/17	.000	2017/07
BARIUM	01007	108	2008/07/16	< 100.000	2017/07
BERYLLIUM	01012	108	2008/07/16	< 1.000	2017/07
CADMIUM	01027	108	2008/07/16	< 1.000	2017/07
CHROMIUM (TOTAL)	01034	108	2008/07/16	< 1.000	2017/07
CYANIDE	01291	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800129***

System Name: ***STERLING VINEYARDS***

PS Code: ***2800129-003***

Source Name: ***WELL 003-OAK TREE WELL***

Source Number: ***003***

Source Status: ***STANDBY RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	108	2008/07/16	.210	2017/07
LEAD	01051	WAIVED			
MERCURY	71900	108	2008/07/16	3.300	2017/07
NICKEL	01067	108	2008/07/16	< 10.000	2017/07
PERCHLORATE	A-031	108	2008/08/27	< 4.000	2017/08
SELENIUM	01147	108	2008/07/16	< 5.000	2017/07
THALLIUM	01059	108	2008/07/16	< 1.000	2017/07
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	108	2010/06/23	< 2.000	2019/06
NITRITE (AS N)	00620	108	2010/06/23	< 400.000	2019/06
RADIOLOGICAL					
GROSS ALPHA	01501	108	2009/04/15	.661	2018/04
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2008/07/16	.000	
2,4-D	39730	WAIVED	2008/07/16	.000	
ALACHLOR	77825	WAIVED	2008/07/16	.000	
ATRAZINE	39033	WAIVED	2008/07/16	.000	
BENTAZON	38710	WAIVED	2008/07/16	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800129***

System Name: ***STERLING VINEYARDS***

PS Code: ***2800129-003***

Source Name: ***WELL 003-OAK TREE WELL***

Source Number: ***003***

Source Status: ***STANDBY RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED	2008/07/16	.000	
CHLORDANE	39350	WAIVED	2008/07/16	.000	
DALAPON	38432	WAIVED	2008/07/16	.000	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED	2008/07/16	.000	
DIQUAT	78885	WAIVED	2008/07/16	.000	
ENDOTHALL	38926	WAIVED	2008/07/16	.000	
ENDRIN	39390	WAIVED	2008/07/16	.000	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2008/07/16	.000	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2008/07/16	.000	
HEPTACHLOR EPOXIDE	39420	WAIVED	2008/07/16	.000	
HEXACHLOROBENZENE	39700	WAIVED	2008/07/16	.000	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2008/07/16	.000	
LINDANE	39340	WAIVED	2008/07/16	.000	
METHOXYCHLOR	39480	WAIVED	2008/07/16	.000	
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED	2008/07/16	.000	
PENTACHLOROPHENOL	39032	WAIVED	2008/07/16	.000	
PICLORAM	39720	WAIVED	2008/07/16	.000	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED	2008/07/16	.000	
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED	2008/07/16	.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED	2008/07/16	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800129***

System Name: ***STERLING VINEYARDS***

PS Code: ***2800129-003***

Source Name: ***WELL 003-OAK TREE WELL***

Source Number: ***003***

Source Status: ***STANDBY RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED	2008/07/16	.000	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED	2008/07/16	.000	
1,1,2-TRICHLOROETHANE	34511	WAIVED	2008/07/16	.000	
1,1-DICHLOROETHANE	34496	WAIVED	2008/07/16	.000	
1,1-DICHLOROETHYLENE	34501	WAIVED	2008/07/16	.000	
1,2,4-TRICHLOROBENZENE	34551	WAIVED	2008/07/16	.000	
1,2-DICHLOROBENZENE	34536	WAIVED	2008/07/16	.000	
1,2-DICHLOROETHANE	34531	WAIVED	2008/07/16	.000	
1,2-DICHLOROPROPANE	34541	WAIVED	2008/07/16	.000	
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED	2008/07/16	.000	
1,4-DICHLOROBENZENE	34571	WAIVED	2008/07/16	.000	
BENZENE	34030	WAIVED	2008/07/16	.000	
CARBON TETRACHLORIDE	32102	WAIVED	2008/07/16	.000	
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED	2008/07/16	.000	
DICHLOROMETHANE	34423	WAIVED	2008/07/16	.000	
ETHYLBENZENE	34371	WAIVED	2008/07/16	.000	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	108	2008/07/16	.000	2017/07
MONOCHLOROBENZENE	34301	WAIVED	2008/07/16	.000	
STYRENE	77128	WAIVED	2008/07/16	.000	
TETRACHLOROETHYLENE	34475	WAIVED	2008/07/16	.000	
TOLUENE	34010	WAIVED	2008/07/16	.000	
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED	2008/07/16	.000	
TRICHLOROETHYLENE	39180	WAIVED	2008/07/16	.000	
TRICHLOROFLUOROMETHANE	34488	WAIVED	2008/07/16	.000	
VINYL CHLORIDE	39175	WAIVED	2008/07/16	.000	
XYLENES (TOTAL)	81551	WAIVED	2008/07/16	.000	
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	108	2008/07/16	170.000	2017/07

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800129***

System Name: ***STERLING VINEYARDS***

PS Code: ***2800129-003***

Source Name: ***WELL 003-OAK TREE WELL***

Source Number: ***003***

Source Status: ***STANDBY RAW***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
CALCIUM	00916	108	2008/07/16	22.000	2017/07	
CARBONATE ALKALINITY	00445	108	2008/07/16	< 1.000	2017/07	
CHLORIDE	00940	000				DUE
COLOR	00081	000				DUE
COPPER	01042	000				DUE
FOAMING AGENTS (MBAS)	38260	000				DUE
HARDNESS (TOTAL) AS CACO3	00900	108	2008/07/16	92.000	2017/07	
HYDROXIDE ALKALINITY	71830	108	2008/07/16	< 1.000	2017/07	
IRON	01045	108	2008/07/16	13000.000	2017/07	
MAGNESIUM	00927	108	2008/07/16	9.100	2017/07	
MANGANESE	01055	108	2008/07/16	1400.000	2017/07	
ODOR THRESHOLD @ 60 C	00086	000				DUE
PH, LABORATORY	00403	108	2008/07/16	6.900	2017/07	
SILVER	01077	000				DUE
SODIUM	00929	108	2008/07/16	46.000	2017/07	
SPECIFIC CONDUCTANCE	00095	000				DUE
SULFATE	00945	000				DUE
TOTAL DISSOLVED SOLIDS	70300	000				DUE
TURBIDITY, LABORATORY	82079	000				DUE
ZINC	01092	000				DUE

PS Code: ***2800129-004***

Source Name: ***TREATMENT PLANT***

Source Number: ***004***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800129***

System Name: ***STERLING VINEYARDS***

PS Code: ***2800129-004***

Source Name: ***TREATMENT PLANT***

Source Number: ***004***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
ALUMINUM	01105	WAIVED	2010/07/27	< 50.000	
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800129***

System Name: ***STERLING VINEYARDS***

PS Code: ***2800129-004***

Source Name: ***TREATMENT PLANT***

Source Number: ***004***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800129***

System Name: ***STERLING VINEYARDS***

PS Code: ***2800129-004***

Source Name: ***TREATMENT PLANT***

Source Number: ***004***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800129***

System Name: ***STERLING VINEYARDS***

PS Code: ***2800129-004***

Source Name: ***TREATMENT PLANT***

Source Number: ***004***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED	2005/06/29	3.200	
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2005/06/29	52.000	
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED	2005/06/29	110.000	
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED	2010/07/27	< 20.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2005/06/29	6.800	
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800186***

System Name: ***TURTLE ROCK***

PS Code: ***2800186-002***

Source Name: ***WELL 002***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				DUE
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2009/06/10	.000	2010/06	DUE
NITRITE (AS N)	00620	000				DUE
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800186***

System Name: ***TURTLE ROCK***

PS Code: ***2800186-002***

Source Name: ***WELL 002***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800186***

System Name: ***TURTLE ROCK***

PS Code: ***2800186-002***

Source Name: ***WELL 002***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800186***

System Name: ***TURTLE ROCK***

PS Code: ***2800186-002***

Source Name: ***WELL 002***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800186***

System Name: ***TURTLE ROCK***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)

PS Code: ***2800186-002***

Source Name: ***WELL 002***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800186-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED			

INORGANIC

ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800186***

System Name: ***TURTLE ROCK***

PS Code: ***2800186-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800186***

System Name: ***TURTLE ROCK***

PS Code: ***2800186-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800186***

System Name: ***TURTLE ROCK***

PS Code: ***2800186-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800186***

System Name: ***TURTLE ROCK***

PS Code: ***2800186-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800297
System Name: CATACULA LAKE WINERY

PS Code: 2800297-001
Source Name: WELL 1
Source Number: 001
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED	2008/09/02	< 50.000		
ANTIMONY	01097	WAIVED	2008/09/02	< 6.000		
ARSENIC	01002	WAIVED	2008/09/02	12.000		
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED	2008/09/02	110.000		
BERYLLIUM	01012	WAIVED	2008/09/02	< 1.000		
CADMIUM	01027	WAIVED	2008/09/02	< 1.000		
CHROMIUM (TOTAL)	01034	WAIVED	2008/09/02	3.100		
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2008/09/02	< .100		
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED	2008/09/02	< 1.000		
NICKEL	01067	WAIVED	2008/09/02	13.000		
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED	2008/09/02	< 5.000		
THALLIUM	01059	WAIVED	2008/09/02	< 1.000		
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/01/11	5.700	2012/01	DUE
NITRITE (AS N)	00620	036	2008/09/02	< 400.000	2011/09	DUE
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800297***

System Name: ***CATACULA LAKE WINERY***

PS Code: ***2800297-001***

Source Name: ***WELL 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800297***

System Name: ***CATACULA LAKE WINERY***

PS Code: ***2800297-001***

Source Name: ***WELL 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800297***

System Name: ***CATACULA LAKE WINERY***

PS Code: ***2800297-001***

Source Name: ***WELL 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2008/09/02	520.000	
CALCIUM	00916	WAIVED	2008/09/02	4.400	
CARBONATE ALKALINITY	00445	WAIVED	2008/09/02	< 1.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2008/09/02	400.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2008/09/02	< 1.000	
IRON	01045	WAIVED	2008/09/02	< 100.000	
MAGNESIUM	00927	WAIVED	2008/09/02	95.000	
MANGANESE	01055	WAIVED	2008/09/02	< 20.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2008/09/02	7.400	
SILVER	01077	WAIVED	2008/09/02	< 10.000	
SODIUM	00929	WAIVED	2008/09/02	4.600	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800297***

System Name: ***CATACULA LAKE WINERY***

PS Code: ***2800297-001***

Source Name: ***WELL 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800298***

System Name: ***DBA SILVER ROSE CELLARS***

PS Code: ***2800298-001***

Source Name: ***WELL 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED	2007/01/29	< .200	
INORGANIC					
ALUMINUM	01105	WAIVED	2011/06/22	< 50.000	
ANTIMONY	01097	WAIVED	2011/06/22	< 6.000	
ARSENIC	01002	WAIVED	2011/06/22	< 2.000	
ASBESTOS	81855	WAIVED	2008/10/15	.000	
BARIUM	01007	WAIVED	2011/06/22	< 100.000	
BERYLLIUM	01012	WAIVED	2011/06/22	< 1.000	
CADMIUM	01027	WAIVED	2011/06/22	< 1.000	
CHROMIUM (TOTAL)	01034	WAIVED	2011/06/22	< 1.000	
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2011/06/22	.440	
LEAD	01051	WAIVED	2008/04/09	< 5.000	
MERCURY	71900	WAIVED	2011/06/22	< 1.000	
NICKEL	01067	WAIVED	2011/06/22	< 10.000	
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED	2011/06/22	< 5.000	
THALLIUM	01059	WAIVED	2011/06/22	< 1.000	
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2011/06/22	8.700	2012/06
NITRITE (AS N)	00620	036	2011/06/22	< 400.000	2014/06
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED	2009/06/10	.000	
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800298***

System Name: ***DBA SILVER ROSE CELLARS***

PS Code: ***2800298-001***

Source Name: ***WELL 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2011/06/22	.000	
2,4-D	39730	WAIVED	2011/06/22	.000	
ALACHLOR	77825	WAIVED	2007/01/29	< .200	
ATRAZINE	39033	WAIVED	2011/06/22	.000	
BENTAZON	38710	WAIVED	2011/06/22	.000	
BENZO (A) PYRENE	34247	WAIVED	2007/01/29	< .100	
CARBOFURAN	81405	WAIVED	2011/06/22	.000	
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED	2011/06/22	.000	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED	2007/01/29	< 1.000	
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED	2007/01/29	< 3.000	
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2006/10/24	< 1.000	
DINOSEB	81287	WAIVED	2011/06/22	.000	
DIQUAT	78885	WAIVED	2011/06/22	.000	
ENDOTHALL	38926	WAIVED	2011/06/22	.000	
ENDRIN	39390	WAIVED	2007/01/29	< 1.000	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2005/12/19	.000	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2007/01/29	< .100	
HEPTACHLOR EPOXIDE	39420	WAIVED	2007/01/29	< .100	
HEXACHLOROBENZENE	39700	WAIVED	2007/01/29	< .100	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2007/01/29	< 3.000	
LINDANE	39340	WAIVED	2007/01/29	< .100	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800298***

System Name: ***DBA SILVER ROSE CELLARS***

PS Code: ***2800298-001***

Source Name: ***WELL 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED	2007/01/29	< .300	
MOLINATE	82199	WAIVED	2007/01/29	< .500	
OXAMYL	38865	WAIVED	2011/06/22	.000	
PENTACHLOROPHENOL	39032	WAIVED	2011/06/22	.000	
PICLORAM	39720	WAIVED	2011/06/22	.000	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED	2011/06/22	.000	
THIOBENCARB	A-001	WAIVED	2007/01/29	< .500	
TOXAPHENE	39400	WAIVED	2007/01/29	< 5.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED	2011/10/19	.000	
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED	2011/10/19	.000	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED	2011/10/19	.000	
1,1,2-TRICHLOROETHANE	34511	WAIVED	2011/10/19	.000	
1,1-DICHLOROETHANE	34496	WAIVED	2011/10/19	.000	
1,1-DICHLOROETHYLENE	34501	WAIVED	2011/10/19	.000	
1,2,4-TRICHLOROBENZENE	34551	WAIVED	2011/10/19	.000	
1,2-DICHLOROBENZENE	34536	WAIVED	2011/10/19	.000	
1,2-DICHLOROETHANE	34531	WAIVED	2011/10/19	.000	
1,2-DICHLOROPROPANE	34541	WAIVED	2011/10/19	.000	
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED	2011/10/19	.000	
1,4-DICHLOROBENZENE	34571	WAIVED	2011/10/19	.000	
BENZENE	34030	WAIVED	2011/10/19	.000	
CARBON TETRACHLORIDE	32102	WAIVED	2011/10/19	.000	
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED	2011/10/19	.000	
DICHLOROMETHANE	34423	WAIVED	2011/10/19	.000	
ETHYLBENZENE	34371	WAIVED	2011/10/19	.000	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED	2011/10/19	.000	
MONOCHLOROBENZENE	34301	WAIVED	2011/10/19	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800298
System Name: DBA SILVER ROSE CELLARS

PS Code: 2800298-001
Source Name: WELL 1
Source Number: 001
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED	2011/10/19	.000	
TETRACHLOROETHYLENE	34475	WAIVED	2011/10/19	.000	
TOLUENE	34010	WAIVED	2011/10/19	.000	
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED	2011/10/19	.000	
TRICHLOROETHYLENE	39180	WAIVED	2011/10/19	.000	
TRICHLOROFLUOROMETHANE	34488	WAIVED	2011/10/19	.000	
VINYL CHLORIDE	39175	WAIVED	2011/10/19	.000	
XYLENES (TOTAL)	81551	WAIVED	2011/10/19	.000	
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2011/06/22	93.000	
CALCIUM	00916	WAIVED	2011/06/22	13.000	
CARBONATE ALKALINITY	00445	WAIVED	2011/06/22	< 1.000	
CHLORIDE	00940	WAIVED	2006/10/24	33.700	
COLOR	00081	WAIVED			
COPPER	01042	WAIVED	2006/10/24	31.100	
FOAMING AGENTS (MBAS)	38260	WAIVED	2006/10/24	< .100	
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2011/06/22	57.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2011/06/22	< 1.000	
IRON	01045	WAIVED	2011/06/22	< 100.000	
MAGNESIUM	00927	WAIVED	2011/06/22	5.900	
MANGANESE	01055	WAIVED	2011/06/22	< 20.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2011/06/22	6.600	
SILVER	01077	WAIVED	2011/06/22	< 10.000	
SODIUM	00929	WAIVED	2011/06/22	20.000	
SPECIFIC CONDUCTANCE	00095	WAIVED	2006/10/24	301.000	
SULFATE	00945	WAIVED	2006/10/24	21.500	
TOTAL DISSOLVED SOLIDS	70300	WAIVED	2006/10/24	205.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800298***

System Name: ***DBA SILVER ROSE CELLARS***

PS Code: ***2800298-001***

Source Name: ***WELL 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED	2006/10/24	83.100	

PS Code: ***2800298-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800298***

System Name: ***DBA SILVER ROSE CELLARS***

PS Code: ***2800298-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800298***

System Name: ***DBA SILVER ROSE CELLARS***

PS Code: ***2800298-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800298***

System Name: ***DBA SILVER ROSE CELLARS***

PS Code: ***2800298-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800298***

System Name: ***DBA SILVER ROSE CELLARS***

PS Code: ***2800298-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800299***

System Name: ***FAR NIENTE WINERY***

PS Code: ***2800299-001***

Source Name: ***WELL 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2007/11/27	.000		
INORGANIC						
ALUMINUM	01105	036	2010/12/14	.000	2013/12	
ANTIMONY	01097	036	2010/12/14	.000	2013/12	
ARSENIC	01002	036	2010/12/14	.000	2013/12	
ASBESTOS	81855	108	2002/04/25	.000	2011/04	DUE
BARIUM	01007	036	2010/12/14	.000	2013/12	
BERYLLIUM	01012	036	2010/12/14	.000	2013/12	
CADMIUM	01027	036	2010/12/14	.000	2013/12	
CHROMIUM (TOTAL)	01034	036	2010/12/14	.000	2013/12	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2010/12/14	.180	2013/12	
LEAD	01051	WAIVED	2010/12/14	.000		
MERCURY	71900	036	2010/12/14	.000	2013/12	
NICKEL	01067	036	2010/12/14	.000	2013/12	
PERCHLORATE	A-031	036	2012/02/09	< .000	2015/02	
SELENIUM	01147	036	2010/12/14	.000	2013/12	
THALLIUM	01059	036	2010/12/14	.000	2013/12	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/08/25	< .000	2012/08	
NITRITE (AS N)	00620	036	2010/08/26	.000	2013/08	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2012/02/09	1.550	2021/02	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800299***

System Name: ***FAR NIENTE WINERY***

PS Code: ***2800299-001***

Source Name: ***WELL 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2010/12/14	< 1.000		
2,4-D	39730	WAIVED	2010/12/14	< 10.000		
ALACHLOR	77825	WAIVED	2007/11/27	.000		
ATRAZINE	39033	036	2010/12/14	< .500	2013/12	
BENTAZON	38710	WAIVED	2010/12/14	< 2.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2010/12/14	< 5.000	2013/12	
CHLORDANE	39350	WAIVED	2002/04/25	.000		
DALAPON	38432	036	2010/12/14	< 10.000	2013/12	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2009/08/10	.000		
DINOSEB	81287	036	2010/12/14	< 2.000	2013/12	
DIQUAT	78885	036	2010/12/14	< 4.000	2013/12	
ENDOTHALL	38926	036	**2007/11/27**	< 45.000	**2010/11**	**DUE**
ENDRIN	39390	WAIVED	2002/04/25	.000		
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2009/08/10	.000		
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	WAIVED	2002/04/25	.000		
HEPTACHLOR EPOXIDE	39420	WAIVED	2002/04/25	.000		
HEXACHLOROBENZENE	39700	WAIVED	2002/04/25	.000		
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2002/04/25	.000		
LINDANE	39340	WAIVED	2002/04/25	.000		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800299***

System Name: ***FAR NIENTE WINERY***

PS Code: ***2800299-001***

Source Name: ***WELL 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED	2002/04/25	.000	
MOLINATE	82199	WAIVED	2007/11/27	.000	
OXAMYL	38865	036	2010/12/14	< 20.000	2013/12
PENTACHLOROPHENOL	39032	036	2010/12/14	< .200	2013/12
PICLORAM	39720	036	2010/12/14	< 1.000	2013/12
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2002/04/25	.000	
SIMAZINE	39055	036	2010/12/14	< 1.000	2013/12
THIOBENCARB	A-001	WAIVED	2007/11/27	.000	
TOXAPHENE	39400	WAIVED	2002/04/25	.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	072	2009/08/10	.000	2015/08
1,1,2,2-TETRACHLOROETHANE	34516	072	2009/08/10	.000	2015/08
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2009/08/10	.000	2015/08
1,1,2-TRICHLOROETHANE	34511	072	2009/08/10	.000	2015/08
1,1-DICHLOROETHANE	34496	072	2009/08/10	.000	2015/08
1,1-DICHLOROETHYLENE	34501	072	2009/08/10	.000	2015/08
1,2,4-TRICHLOROBENZENE	34551	072	2009/08/10	.000	2015/08
1,2-DICHLOROBENZENE	34536	072	2009/08/10	.000	2015/08
1,2-DICHLOROETHANE	34531	072	2009/08/10	.000	2015/08
1,2-DICHLOROPROPANE	34541	072	2009/08/10	.000	2015/08
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2009/08/10	.000	2015/08
1,4-DICHLOROBENZENE	34571	072	2009/08/10	.000	2015/08
BENZENE	34030	072	2009/08/10	.000	2015/08
CARBON TETRACHLORIDE	32102	072	2009/08/10	.000	2015/08
CIS-1,2-DICHLOROETHYLENE	77093	072	2009/08/10	.000	2015/08
DICHLOROMETHANE	34423	072	2009/08/10	.000	2015/08
ETHYLBENZENE	34371	072	2009/08/10	.000	2015/08
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2009/08/10	.000	2015/08
MONOCHLOROBENZENE	34301	072	2009/08/10	.000	2015/08

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800299***

System Name: ***FAR NIENTE WINERY***

PS Code: ***2800299-001***

Source Name: ***WELL 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2009/08/10	.000	2015/08
TETRACHLOROETHYLENE	34475	072	2009/08/10	.000	2015/08
TOLUENE	34010	072	2009/08/10	.000	2015/08
TRANS-1,2-DICHLOROETHYLENE	34546	072	2009/08/10	.000	2015/08
TRICHLOROETHYLENE	39180	072	2009/08/10	.000	2015/08
TRICHLOROFLUOROMETHANE	34488	072	2009/08/10	.000	2015/08
VINYL CHLORIDE	39175	072	2009/08/10	.000	2015/08
XYLENES (TOTAL)	81551	072	2009/08/10	.000	2015/08
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2010/12/14	130.000	
CALCIUM	00916	WAIVED	2010/12/14	21.000	
CARBONATE ALKALINITY	00445	WAIVED	2010/12/14	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2010/12/14	99.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2010/12/14	.000	
IRON	01045	WAIVED	2010/12/14	.000	
MAGNESIUM	00927	WAIVED	2010/12/14	11.000	
MANGANESE	01055	WAIVED	2010/12/14	.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2010/12/14	7.100	
SILVER	01077	WAIVED	2010/12/14	.000	
SODIUM	00929	WAIVED	2010/12/14	11.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800299***

System Name: ***FAR NIENTE WINERY***

PS Code: ***2800299-001***

Source Name: ***WELL 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
SECONDARY/GP						
TURBIDITY, LABORATORY	82079	WAIVED				
ZINC	01092	WAIVED				

PS Code: ***2800299-002***

Source Name: ***WELL 002***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2008/07/07	.000		
INORGANIC						
ALUMINUM	01105	036	2010/12/14	.000	2013/12	
ANTIMONY	01097	036	2010/12/14	.000	2013/12	
ARSENIC	01002	036	2010/12/14	3.000	2013/12	
ASBESTOS	81855	000				**DUE**
BARIUM	01007	036	2010/12/14	.000	2013/12	
BERYLLIUM	01012	036	2010/12/14	.000	2013/12	
CADMIUM	01027	036	2010/12/14	.000	2013/12	
CHROMIUM (TOTAL)	01034	036	2010/12/14	.000	2013/12	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2010/12/14	.320	2013/12	
LEAD	01051	WAIVED	2010/12/14	.000		
MERCURY	71900	036	2010/12/14	.000	2013/12	
NICKEL	01067	036	2010/12/14	.000	2013/12	
PERCHLORATE	A-031	036	2012/02/09	< .000	2015/02	
SELENIUM	01147	036	2010/12/14	.000	2013/12	
THALLIUM	01059	036	2010/12/14	.000	2013/12	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800299***

System Name: ***FAR NIENTE WINERY***

PS Code: ***2800299-002***

Source Name: ***WELL 002***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2011/08/25	< .000	2012/08
NITRITE (AS N)	00620	036	2010/08/26	.000	2013/08
RADIOLOGICAL					
GROSS ALPHA	01501	108	2012/02/09	1.370	2021/02
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2011/08/30	< 1.000	
2,4-D	39730	WAIVED	2011/08/30	< 10.000	
ALACHLOR	77825	WAIVED	2008/07/07	.000	
ATRAZINE	39033	036	2011/08/30	< .500	2014/08
BENTAZON	38710	WAIVED	2011/08/30	< 2.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	036	2011/08/30	< 5.000	2014/08
CHLORDANE	39350	WAIVED			
DALAPON	38432	036	2011/08/30	< 10.000	2014/08
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2007/11/27	.000	
DINOSEB	81287	036	2011/08/30	< 2.000	2014/08
DIQUAT	78885	036	2011/08/30	< 4.000	2014/08

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800299***

System Name: ***FAR NIENTE WINERY***

PS Code: ***2800299-002***

Source Name: ***WELL 002***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
ENDOTHALL	38926	036	2011/08/30	< 45.000	2014/08	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2007/11/27	.000		
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**
METHOXYCHLOR	39480	000				**DUE**
MOLINATE	82199	WAIVED	2008/07/07	.000		
OXAMYL	38865	036	2011/08/30	< 20.000	2014/08	
PENTACHLOROPHENOL	39032	036	2011/08/30	< .200	2014/08	
PICLORAM	39720	036	2011/08/30	< 1.000	2014/08	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2011/08/30	< 1.000	2014/08	
THIOBENCARB	A-001	WAIVED	2008/07/07	.000		
TOXAPHENE	39400	000				**DUE**
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2007/11/27	.000	2013/11	
1,1,2,2-TETRACHLOROETHANE	34516	072	2007/11/27	.000	2013/11	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2007/11/27	.000	2013/11	
1,1,2-TRICHLOROETHANE	34511	072	2007/11/27	.000	2013/11	
1,1-DICHLOROETHANE	34496	072	2007/11/27	.000	2013/11	
1,1-DICHLOROETHYLENE	34501	072	2007/11/27	.000	2013/11	
1,2,4-TRICHLOROBENZENE	34551	072	2007/11/27	.000	2013/11	
1,2-DICHLOROBENZENE	34536	072	2007/11/27	.000	2013/11	
1,2-DICHLOROETHANE	34531	072	2007/11/27	.000	2013/11	
1,2-DICHLOROPROPANE	34541	072	2007/11/27	.000	2013/11	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800299***

System Name: ***FAR NIENTE WINERY***

PS Code: ***2800299-002***

Source Name: ***WELL 002***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2007/11/27	.000	2013/11
1,4-DICHLOROBENZENE	34571	072	2007/11/27	.000	2013/11
BENZENE	34030	072	2007/11/27	.000	2013/11
CARBON TETRACHLORIDE	32102	072	2007/11/27	.000	2013/11
CIS-1,2-DICHLOROETHYLENE	77093	072	2007/11/27	.000	2013/11
DICHLOROMETHANE	34423	072	2007/11/27	.000	2013/11
ETHYLBENZENE	34371	072	2007/11/27	.000	2013/11
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2007/11/27	.000	2013/11
MONOCHLOROBENZENE	34301	072	2007/11/27	.000	2013/11
STYRENE	77128	072	2007/11/27	.000	2013/11
TETRACHLOROETHYLENE	34475	072	2007/11/27	.000	2013/11
TOLUENE	34010	072	2007/11/27	.000	2013/11
TRANS-1,2-DICHLOROETHYLENE	34546	072	2007/11/27	.000	2013/11
TRICHLOROETHYLENE	39180	072	2007/11/27	.000	2013/11
TRICHLOROFLUOROMETHANE	34488	072	2007/11/27	.000	2013/11
VINYL CHLORIDE	39175	072	2007/11/27	.000	2013/11
XYLENES (TOTAL)	81551	072	2007/11/27	.000	2013/11
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2010/12/14	136.000	
CALCIUM	00916	WAIVED	2010/12/14	22.000	
CARBONATE ALKALINITY	00445	WAIVED	2010/12/14	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2010/12/14	110.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2010/12/14	.000	
IRON	01045	WAIVED	2010/12/14	10400.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800299***

System Name: ***FAR NIENTE WINERY***

PS Code: ***2800299-002***

Source Name: ***WELL 002***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
MAGNESIUM	00927	WAIVED	2010/12/14	15.000	
MANGANESE	01055	WAIVED	2010/12/14	104.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2010/12/14	7.000	
SILVER	01077	WAIVED	2010/12/14	.000	
SODIUM	00929	WAIVED	2010/12/14	15.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800299-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800299***

System Name: ***FAR NIENTE WINERY***

PS Code: ***2800299-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800299***

System Name: ***FAR NIENTE WINERY***

PS Code: ***2800299-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800299***

System Name: ***FAR NIENTE WINERY***

PS Code: ***2800299-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800299***

System Name: ***FAR NIENTE WINERY***

PS Code: ***2800299-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800301***

System Name: ***LAIRD FAMILY ESTATE***

PS Code: ***2800301-001***

Source Name: ***WELL #1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED	2008/06/02	.000	
INORGANIC					
ALUMINUM	01105	036	2011/06/01	< .000	2014/06
ANTIMONY	01097	036	2011/06/01	< .000	2014/06
ARSENIC	01002	036	2011/06/01	30.000	2014/06
ASBESTOS	81855	108	2011/06/01	< .200	2020/06
BARIUM	01007	036	2011/06/01	< .000	2014/06
BERYLLIUM	01012	036	2011/06/01	< .000	2014/06
CADMIUM	01027	036	2011/06/01	< .000	2014/06
CHROMIUM (TOTAL)	01034	036	2011/06/01	< .000	2014/06
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2011/06/01	.610	2014/06
LEAD	01051	WAIVED	2011/06/01	< .000	
MERCURY	71900	036	2011/06/01	< .000	2014/06
NICKEL	01067	036	2011/06/01	< .000	2014/06
PERCHLORATE	A-031	036	2009/08/05	.000	2012/08
SELENIUM	01147	036	2011/06/01	< .000	2014/06
THALLIUM	01059	036	2011/06/01	< .000	2014/06
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2011/06/01	< .000	2012/06
NITRITE (AS N)	00620	036	2009/04/13	.000	2012/04
RADIOLOGICAL					
GROSS ALPHA	01501	108	2011/03/03	.640	2020/03
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800301***

System Name: ***LAIRD FAMILY ESTATE***

PS Code: ***2800301-001***

Source Name: ***WELL #1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2011/06/01	< 1.000	
2,4-D	39730	WAIVED	2011/06/01	< 10.000	
ALACHLOR	77825	WAIVED	2008/06/02	.000	
ATRAZINE	39033	036	2011/06/01	< .500	2014/06
BENTAZON	38710	WAIVED	2011/06/01	< 2.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	036	2011/06/01	< 5.000	2014/06
CHLORDANE	39350	WAIVED	2002/05/01	.000	
DALAPON	38432	036	2011/06/01	< 10.000	2014/06
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2008/06/02	.000	
DINOSEB	81287	036	2011/06/01	< 2.000	2014/06
DIQUAT	78885	036	2011/06/01	< 4.000	2014/06
ENDOTHALL	38926	036	2011/06/01	< 45.000	2014/06
ENDRIN	39390	WAIVED	2002/05/01	.000	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2008/06/02	.000	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2002/05/01	.000	
HEPTACHLOR EPOXIDE	39420	WAIVED	2002/05/01	.000	
HEXACHLOROBENZENE	39700	WAIVED	2002/05/01	.000	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2002/05/01	.000	
LINDANE	39340	WAIVED	2002/05/01	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800301***

System Name: ***LAIRD FAMILY ESTATE***

PS Code: ***2800301-001***

Source Name: ***WELL #1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED	2002/05/01	.000	
MOLINATE	82199	WAIVED	2008/06/02	.000	
OXAMYL	38865	036	2011/06/01	< 20.000	2014/06
PENTACHLOROPHENOL	39032	036	2011/06/01	< .200	2014/06
PICLORAM	39720	036	2011/06/01	< 1.000	2014/06
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2002/05/01	.000	
SIMAZINE	39055	036	2011/06/01	< 1.000	2014/06
THIOBENCARB	A-001	WAIVED	2008/06/02	.000	
TOXAPHENE	39400	WAIVED	2002/05/01	.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	072	2008/06/02	.000	2014/06
1,1,2,2-TETRACHLOROETHANE	34516	072	2008/06/02	.000	2014/06
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2008/06/02	.000	2014/06
1,1,2-TRICHLOROETHANE	34511	072	2008/06/02	.000	2014/06
1,1-DICHLOROETHANE	34496	072	2008/06/02	.000	2014/06
1,1-DICHLOROETHYLENE	34501	072	2008/06/02	.000	2014/06
1,2,4-TRICHLOROBENZENE	34551	072	2008/06/02	.000	2014/06
1,2-DICHLOROBENZENE	34536	072	2008/06/02	.000	2014/06
1,2-DICHLOROETHANE	34531	072	2008/06/02	.000	2014/06
1,2-DICHLOROPROPANE	34541	072	2008/06/02	.000	2014/06
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2008/06/02	.000	2014/06
1,4-DICHLOROBENZENE	34571	072	2008/06/02	.000	2014/06
BENZENE	34030	072	2008/06/02	.000	2014/06
CARBON TETRACHLORIDE	32102	072	2008/06/02	.000	2014/06
CIS-1,2-DICHLOROETHYLENE	77093	072	2008/06/02	.000	2014/06
DICHLOROMETHANE	34423	072	2008/06/02	.000	2014/06
ETHYLBENZENE	34371	072	2008/06/02	.000	2014/06
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2008/06/02	.000	2014/06
MONOCHLOROBENZENE	34301	072	2008/06/02	.000	2014/06

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800301***

System Name: ***LAIRD FAMILY ESTATE***

PS Code: ***2800301-001***

Source Name: ***WELL #1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2008/06/02	.000	2014/06
TETRACHLOROETHYLENE	34475	072	2008/06/02	.000	2014/06
TOLUENE	34010	072	2008/06/02	.000	2014/06
TRANS-1,2-DICHLOROETHYLENE	34546	072	2008/06/02	.000	2014/06
TRICHLOROETHYLENE	39180	072	2008/06/02	.000	2014/06
TRICHLOROFLUOROMETHANE	34488	072	2008/06/02	.000	2014/06
VINYL CHLORIDE	39175	072	2008/06/02	.000	2014/06
XYLENES (TOTAL)	81551	072	2008/06/02	.000	2014/06
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2009/04/13	290.000	
CALCIUM	00916	WAIVED	2009/04/13	15.000	
CARBONATE ALKALINITY	00445	WAIVED	2009/04/13	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED	2011/06/01	< .000	
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2009/04/13	66.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2009/04/13	.000	
IRON	01045	WAIVED	2009/04/13	160.000	
MAGNESIUM	00927	WAIVED	2009/04/13	5.900	
MANGANESE	01055	WAIVED	2009/04/13	44.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2009/04/13	7.800	
SILVER	01077	WAIVED	2011/06/01	< .000	
SODIUM	00929	WAIVED	2009/04/13	77.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800301***

System Name: ***LAIRD FAMILY ESTATE***

PS Code: ***2800301-001***

Source Name: ***WELL #1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800301-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800301***

System Name: ***LAIRD FAMILY ESTATE***

PS Code: ***2800301-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800301***

System Name: ***LAIRD FAMILY ESTATE***

PS Code: ***2800301-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800301***

System Name: ***LAIRD FAMILY ESTATE***

PS Code: ***2800301-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800301***

System Name: ***LAIRD FAMILY ESTATE***

PS Code: ***2800301-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800302***

System Name: ***HARTWELL WINERY***

PS Code: ***2800302-001***

Source Name: ***WELL#4***

Source Number: ***001***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED	2002/04/18	.000	
ANTIMONY	01097	WAIVED	2002/07/19	22.000	
ARSENIC	01002	WAIVED	2002/07/19	690.000	
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED	2002/04/18	.000	
BERYLLIUM	01012	WAIVED	2002/04/18	.000	
CADMIUM	01027	WAIVED	2002/04/18	.000	
CHROMIUM (TOTAL)	01034	WAIVED	2002/04/18	.000	
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2002/04/18	2.400	
LEAD	01051	WAIVED	2002/04/18	.000	
MERCURY	71900	WAIVED	2002/04/18	.000	
NICKEL	01067	WAIVED	2002/04/18	.000	
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED	2002/05/22	8.000	
THALLIUM	01059	WAIVED	2002/04/18	.000	
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	108	2012/02/06	< .000	2021/02
NITRITE (AS N)	00620	108	2011/02/03	.000	2020/02
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800302***

System Name: ***HARTWELL WINERY***

PS Code: ***2800302-001***

Source Name: ***WELL#4***

Source Number: ***001***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800302***

System Name: ***HARTWELL WINERY***

PS Code: ***2800302-001***

Source Name: ***WELL#4***

Source Number: ***001***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800302***

System Name: ***HARTWELL WINERY***

PS Code: ***2800302-001***

Source Name: ***WELL#4***

Source Number: ***001***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2002/04/18	410.000	
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED	2002/04/18	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED	2002/04/18	.000	
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED	2002/04/18	.000	
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800302***

System Name: ***HARTWELL WINERY***

PS Code: ***2800302-001***

Source Name: ***WELL#4***

Source Number: ***001***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800302-002***

Source Name: ***WELL#5***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
DIAZINON	39570	WAIVED			

INORGANIC

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
ALUMINUM	01105	WAIVED	2002/04/18	100.000	
ANTIMONY	01097	WAIVED	2002/07/19	.000	
ARSENIC	01002	WAIVED	2002/07/19	830.000	
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED	2002/04/18	.000	
BERYLLIUM	01012	WAIVED	2002/04/18	.000	
CADMIUM	01027	WAIVED	2002/04/18	.000	
CHROMIUM (TOTAL)	01034	WAIVED	2002/04/18	.000	
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2002/04/18	2.100	
LEAD	01051	WAIVED	2002/04/18	.000	
MERCURY	71900	WAIVED	2002/04/18	.000	
NICKEL	01067	WAIVED	2002/04/18	.000	
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED	2002/05/22	12.000	
THALLIUM	01059	WAIVED	2002/04/18	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800302***

System Name: ***HARTWELL WINERY***

PS Code: ***2800302-002***

Source Name: ***WELL#5***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
NITRATE/NITRITE						
NITRATE (AS NO3)	**71850**	**108**	**2002/04/18**	**.000**	**2011/04**	**DUE**
NITRITE (AS N)	**00620**	**000**				**DUE**
RADIOLOGICAL						
GROSS ALPHA	**01501**	**WAIVED**				
GROSS BETA	**03501**	**WAIVED**				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	**A-080**	**WAIVED**				
RA-226 OR TOTAL RA BY 903.0 C.E.	**A-081**	**WAIVED**				
RADIUM 226	**09501**	**WAIVED**				
RADIUM 228	**11501**	**WAIVED**				
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	**A-082**	**WAIVED**				
STRONTIUM-90	**13501**	**WAIVED**				
TRITIUM	**07000**	**WAIVED**				
URANIUM (PCI/L)	**28012**	**WAIVED**				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	**34676**	**WAIVED**				
2,4,5-TP (SILVEX)	**39045**	**WAIVED**				
2,4-D	**39730**	**WAIVED**				
ALACHLOR	**77825**	**WAIVED**				
ATRAZINE	**39033**	**WAIVED**				
BENTAZON	**38710**	**WAIVED**				
BENZO (A) PYRENE	**34247**	**WAIVED**				
CARBOFURAN	**81405**	**WAIVED**				
CHLORDANE	**39350**	**WAIVED**				
DALAPON	**38432**	**WAIVED**				
DI(2-ETHYLHEXYL)ADIPATE	**A-026**	**WAIVED**				
DI(2-ETHYLHEXYL)PHTHALATE	**39100**	**WAIVED**				
DIBROMOCHLOROPROPANE (DBCP)	**38761**	**WAIVED**				
DINOSEB	**81287**	**WAIVED**				
DIQUAT	**78885**	**WAIVED**				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800302***

System Name: ***HARTWELL WINERY***

PS Code: ***2800302-002***

Source Name: ***WELL#5***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800302***

System Name: ***HARTWELL WINERY***

PS Code: ***2800302-002***

Source Name: ***WELL#5***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2002/04/18	310.000	
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED	2002/04/18	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED	2002/04/18	.000	
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800302***

System Name: ***HARTWELL WINERY***

PS Code: ***2800302-002***

Source Name: ***WELL#5***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED	2002/04/18	.000	
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800302-003***

Source Name: ***WELL 001***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED			

INORGANIC

ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800302***

System Name: ***HARTWELL WINERY***

PS Code: ***2800302-003***

Source Name: ***WELL 001***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
INORGANIC						
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				DUE
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2009/04/02	.000	2010/04	DUE
NITRITE (AS N)	00620	000				DUE
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED				
2,4-D	39730	WAIVED				
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	WAIVED				
BENTAZON	38710	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800302***

System Name: ***HARTWELL WINERY***

PS Code: ***2800302-003***

Source Name: ***WELL 001***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800302***

System Name: ***HARTWELL WINERY***

PS Code: ***2800302-003***

Source Name: ***WELL 001***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800302***

System Name: ***HARTWELL WINERY***

PS Code: ***2800302-003***

Source Name: ***WELL 001***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800302-004***

Source Name: ***TREATMENT PLANT***

Source Number: ***004***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800302***

System Name: ***HARTWELL WINERY***

PS Code: ***2800302-004***

Source Name: ***TREATMENT PLANT***

Source Number: ***004***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800302***

System Name: ***HARTWELL WINERY***

PS Code: ***2800302-004***

Source Name: ***TREATMENT PLANT***

Source Number: ***004***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800302***

System Name: ***HARTWELL WINERY***

PS Code: ***2800302-004***

Source Name: ***TREATMENT PLANT***

Source Number: ***004***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800302***

System Name: ***HARTWELL WINERY***

PS Code: ***2800302-004***

Source Name: ***TREATMENT PLANT***

Source Number: ***004***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800508***

System Name: ***CUVAISON VINEYARD***

PS Code: ***2800508-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE-LOWER WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED	2007/08/15	.000		
ANTIMONY	01097	WAIVED	2007/08/15	.000		
ARSENIC	01002	WAIVED	2007/08/15	15.000		
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED	2007/08/15	.000		
BERYLLIUM	01012	WAIVED	2007/08/15	.000		
CADMIUM	01027	WAIVED	2007/08/15	.000		
CHROMIUM (TOTAL)	01034	WAIVED	2007/08/15	.000		
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2007/08/15	.000		
LEAD	01051	WAIVED	2007/08/15	34.000		
MERCURY	71900	WAIVED	2007/08/15	.000		
NICKEL	01067	WAIVED	2007/08/15	.000		
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED	2007/08/15	.000		
THALLIUM	01059	WAIVED	2007/08/15	.000		
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2009/02/11	.000	2010/02	DUE
NITRITE (AS N)	00620	036	2009/02/11	.000	2012/02	DUE
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800508***

System Name: ***CUVAISON VINEYARD***

PS Code: ***2800508-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE-LOWER WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800508***

System Name: ***CUVAISON VINEYARD***

PS Code: ***2800508-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE-LOWER WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800508***

System Name: ***CUVAISON VINEYARD***

PS Code: ***2800508-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE-LOWER WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2007/08/15	380.000	
CALCIUM	00916	WAIVED	2007/08/15	9.000	
CARBONATE ALKALINITY	00445	WAIVED	2007/08/15	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2007/08/15	43.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2007/08/15	.000	
IRON	01045	WAIVED	2007/08/15	.000	
MAGNESIUM	00927	WAIVED	2007/08/15	4.900	
MANGANESE	01055	WAIVED	2007/08/15	23.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2007/08/15	8.300	
SILVER	01077	WAIVED	2007/08/15	.000	
SODIUM	00929	WAIVED	2007/08/15	220.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800508***

System Name: ***CUVAISON VINEYARD***

PS Code: ***2800508-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE-LOWER WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800508-002***

Source Name: ***WELL #2 UPPER WELL***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
DIAZINON	39570	WAIVED			

INORGANIC

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
ALUMINUM	01105	WAIVED	2009/02/11	.000	
ANTIMONY	01097	WAIVED	2009/02/11	.000	
ARSENIC	01002	WAIVED	2009/02/11	.000	
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED	2009/02/11	.000	
BERYLLIUM	01012	WAIVED	2009/02/11	.000	
CADMIUM	01027	WAIVED	2009/02/11	.000	
CHROMIUM (TOTAL)	01034	WAIVED	2009/02/11	.000	
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2009/02/11	.320	
LEAD	01051	WAIVED	2009/02/11	18.000	
MERCURY	71900	WAIVED	2009/02/11	.000	
NICKEL	01067	WAIVED	2009/02/11	.000	
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED	2009/02/11	.000	
THALLIUM	01059	WAIVED	2009/02/11	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800508***

System Name: ***CUVAISON VINEYARD***

PS Code: ***2800508-002***

Source Name: ***WELL #2 UPPER WELL***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2009/02/11	.000	2010/02	DUE
NITRITE (AS N)	00620	036	2009/02/11	.000	2012/02	DUE
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED				
2,4-D	39730	WAIVED				
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	WAIVED				
BENTAZON	38710	WAIVED				
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	WAIVED				
CHLORDANE	39350	WAIVED				
DALAPON	38432	WAIVED				
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	WAIVED				
DIQUAT	78885	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800508***

System Name: ***CUVAISON VINEYARD***

PS Code: ***2800508-002***

Source Name: ***WELL #2 UPPER WELL***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800508***

System Name: ***CUVAISON VINEYARD***

PS Code: ***2800508-002***

Source Name: ***WELL #2 UPPER WELL***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2009/02/11	410.000	
CALCIUM	00916	WAIVED	2009/02/11	350.000	
CARBONATE ALKALINITY	00445	WAIVED	2009/02/11	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2009/02/11	1400.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2009/02/11	.000	
IRON	01045	WAIVED	2009/02/11	2700.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800508***

System Name: ***CUVAISON VINEYARD***

PS Code: ***2800508-002***

Source Name: ***WELL #2 UPPER WELL***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED	2009/02/11	120.000	
MANGANESE	01055	WAIVED	2009/02/11	880.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2009/02/11	6.800	
SILVER	01077	WAIVED	2009/02/11	.000	
SODIUM	00929	WAIVED	2009/02/11	36.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800516***

System Name: ***TUCKER ACRES MUTUAL WATER CO.***

PS Code: ***2800516-001***

Source Name: ***BACK UP WELL***

Source Number: ***001***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED	2007/02/13	.000	
INORGANIC					
ALUMINUM	01105	108	2007/02/13	.000	2016/02
ANTIMONY	01097	108	2007/02/13	.000	2016/02
ARSENIC	01002	108	2012/04/04	10.000	2021/04
ASBESTOS	81855	108	2009/03/31	.000	2018/03
BARIUM	01007	108	2007/02/13	.000	2016/02
BERYLLIUM	01012	108	2007/02/13	.000	2016/02
CADMIUM	01027	108	2007/02/13	.000	2016/02
CHROMIUM (TOTAL)	01034	108	2007/02/13	.000	2016/02
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	108	2007/02/13	.150	2016/02
LEAD	01051	WAIVED	2007/02/13	.000	
MERCURY	71900	108	2007/02/13	.000	2016/02
NICKEL	01067	108	2007/02/13	.000	2016/02
PERCHLORATE	A-031	108	2010/01/19	.000	2019/01
SELENIUM	01147	108	2007/02/13	.000	2016/02
THALLIUM	01059	108	2007/02/13	.000	2016/02
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	108	2009/03/31	.000	2018/03
NITRITE (AS N)	00620	108	2009/03/31	.000	2018/03
RADIOLOGICAL					
GROSS ALPHA	01501	108	2011/10/05	.310	2020/10
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED	2011/10/05	.010	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800516
System Name: TUCKER ACRES MUTUAL WATER CO.

PS Code: 2800516-001
Source Name: BACK UP WELL
Source Number: 001
Source Status: STANDBY UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	108	2007/02/13	< 1.000	2016/02	
2,4-D	39730	WAIVED	2007/02/13	< 10.000		
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	108	2007/02/13	.000	2016/02	
BENTAZON	38710	WAIVED	2007/02/13	< 2.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	WAIVED	2007/02/13	< 5.000		
CHLORDANE	39350	WAIVED				
DALAPON	38432	108	2007/02/13	< 10.000	2016/02	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2007/02/13	< .010		
DINOSEB	81287	WAIVED	2007/02/13	< 2.000		
DIQUAT	78885	108	2007/02/13	< 4.000	2016/02	
ENDOTHALL	38926	108	2007/02/13	< 45.000	2016/02	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	108	2007/02/13	< .020	2016/02	
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800516***

System Name: ***TUCKER ACRES MUTUAL WATER CO.***

PS Code: ***2800516-001***

Source Name: ***BACK UP WELL***

Source Number: ***001***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	000				**DUE**
MOLINATE	82199	WAIVED	2007/02/13	.000		
OXAMYL	38865	108	2007/02/13	< 20.000	2016/02	
PENTACHLOROPHENOL	39032	108	2007/02/13	< .200	2016/02	
PICLORAM	39720	108	2007/02/13	< 1.000	2016/02	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	108	2007/02/13	.000	2016/02	
THIOBENCARB	A-001	WAIVED	2007/02/13	.000		
TOXAPHENE	39400	WAIVED				
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	108	2007/02/13	.000	2016/02	
1,1,2,2-TETRACHLOROETHANE	34516	108	2007/02/13	.000	2016/02	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	108	2007/02/13	.000	2016/02	
1,1,2-TRICHLOROETHANE	34511	108	2007/02/13	.000	2016/02	
1,1-DICHLOROETHANE	34496	108	2007/02/13	.000	2016/02	
1,1-DICHLOROETHYLENE	34501	108	2007/02/13	.000	2016/02	
1,2,4-TRICHLOROBENZENE	34551	108	2007/02/13	.000	2016/02	
1,2-DICHLOROBENZENE	34536	108	2007/02/13	.000	2016/02	
1,2-DICHLOROETHANE	34531	108	2007/02/13	.000	2016/02	
1,2-DICHLOROPROPANE	34541	108	2007/02/13	.000	2016/02	
1,3-DICHLOROPROPENE (TOTAL)	34561	108	2007/02/13	.000	2016/02	
1,4-DICHLOROBENZENE	34571	108	2007/02/13	.000	2016/02	
BENZENE	34030	108	2007/02/13	.000	2016/02	
CARBON TETRACHLORIDE	32102	108	2007/02/13	.000	2016/02	
CIS-1,2-DICHLOROETHYLENE	77093	108	2007/02/13	.000	2016/02	
DICHLOROMETHANE	34423	108	2007/02/13	.000	2016/02	
ETHYLBENZENE	34371	108	2007/02/13	.000	2016/02	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	108	2007/02/13	.000	2016/02	
MONOCHLOROBENZENE	34301	108	2007/02/13	.000	2016/02	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800516***

System Name: ***TUCKER ACRES MUTUAL WATER CO.***

PS Code: ***2800516-001***

Source Name: ***BACK UP WELL***

Source Number: ***001***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	108	2007/02/13	.000	2016/02
TETRACHLOROETHYLENE	34475	108	2007/02/13	.000	2016/02
TOLUENE	34010	108	2007/02/13	.000	2016/02
TRANS-1,2-DICHLOROETHYLENE	34546	108	2007/02/13	.000	2016/02
TRICHLOROETHYLENE	39180	108	2007/02/13	.000	2016/02
TRICHLOROFLUOROMETHANE	34488	108	2007/02/13	.000	2016/02
VINYL CHLORIDE	39175	108	2007/02/13	.000	2016/02
XYLENES (TOTAL)	81551	108	2007/02/13	.000	2016/02
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED	2007/02/13	10.200	
BICARBONATE ALKALINITY	00440	108	2007/02/13	120.000	2016/02
CALCIUM	00916	108	2007/02/13	11.000	2016/02
CARBONATE ALKALINITY	00445	108	2007/02/13	.000	2016/02
CHLORIDE	00940	108	2007/02/13	4.300	2016/02
COLOR	00081	108	2012/04/04	40.000	2021/04
COPPER	01042	108	2007/02/13	.000	2016/02
FOAMING AGENTS (MBAS)	38260	108	2007/02/13	.000	2016/02
HARDNESS (TOTAL) AS CACO3	00900	108	2007/02/13	48.000	2016/02
HYDROXIDE ALKALINITY	71830	108	2007/02/13	.000	2016/02
IRON	01045	108	2012/04/04	1750.000	2021/04
MAGNESIUM	00927	108	2007/02/13	4.900	2016/02
MANGANESE	01055	108	2012/04/04	372.000	2021/04
ODOR THRESHOLD @ 60 C	00086	108	2012/04/04	2.000	2021/04
PH, LABORATORY	00403	108	2007/02/13	6.800	2016/02
SILVER	01077	108	2007/02/13	.000	2016/02
SODIUM	00929	108	2007/02/13	28.000	2016/02
SPECIFIC CONDUCTANCE	00095	108	2007/02/13	230.000	2016/02
SULFATE	00945	108	2007/02/13	11.000	2016/02
TOTAL DISSOLVED SOLIDS	70300	108	2007/02/13	240.000	2016/02

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800516***

System Name: ***TUCKER ACRES MUTUAL WATER CO.***

PS Code: ***2800516-001***

Source Name: ***BACK UP WELL***

Source Number: ***001***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
SECONDARY/GP						
TURBIDITY, LABORATORY	82079	108	2012/04/04	19.000	2021/04	
ZINC	01092	108	2007/02/13	.000	2016/02	

PS Code: ***2800516-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2010/04/15	< .000		
INORGANIC						
ALUMINUM	01105	036	2010/04/15	.000	2013/04	
ANTIMONY	01097	036	2010/04/15	.000	2013/04	
ARSENIC	01002	036	2011/10/06	10.000	2014/10	
ASBESTOS	81855	000				**DUE**
BARIUM	01007	036	2010/04/15	.000	2013/04	
BERYLLIUM	01012	036	2010/04/15	.000	2013/04	
CADMIUM	01027	036	2010/04/15	.000	2013/04	
CHROMIUM (TOTAL)	01034	036	2010/04/15	.000	2013/04	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2010/04/15	.130	2013/04	
LEAD	01051	WAIVED	2010/04/15	.000		
MERCURY	71900	036	2010/04/15	.000	2013/04	
NICKEL	01067	036	2010/04/15	.000	2013/04	
PERCHLORATE	A-031	036	2010/01/19	.000	2013/01	
SELENIUM	01147	036	2010/04/15	.000	2013/04	
THALLIUM	01059	036	2010/04/15	.000	2013/04	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800516***

System Name: ***TUCKER ACRES MUTUAL WATER CO.***

PS Code: ***2800516-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2011/05/04	< .000	2012/05
NITRITE (AS N)	00620	036	2010/04/15	.000	2013/04
RADIOLOGICAL					
GROSS ALPHA	01501	108	2009/12/02	.930	2018/12
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED	2009/12/02	.030	
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	108	2010/04/15	< .000	2019/04
2,4-D	39730	WAIVED	2010/04/15	< .000	
ALACHLOR	77825	WAIVED	2010/04/15	< .000	
ATRAZINE	39033	036	2010/04/15	< .000	2013/04
BENTAZON	38710	WAIVED	2010/04/15	< .000	
BENZO (A) PYRENE	34247	WAIVED	2010/04/15	< .000	
CARBOFURAN	81405	WAIVED	2010/04/15	< .000	
CHLORDANE	39350	WAIVED			
DALAPON	38432	036	2010/04/15	< .000	2013/04
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED	2010/04/15	< .000	
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED	2010/04/15	< .000	
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2007/02/13	< .010	
DINOSEB	81287	WAIVED	2010/04/15	< .000	
DIQUAT	78885	036	2010/04/15	< .000	2013/04

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800516***

System Name: ***TUCKER ACRES MUTUAL WATER CO.***

PS Code: ***2800516-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
ENDOTHALL	38926	036	2010/04/15	< .000	2013/04	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	108	2007/02/13	< .020	2016/02	
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**
METHOXYCHLOR	39480	000				**DUE**
MOLINATE	82199	WAIVED	2010/04/15	< .000		
OXAMYL	38865	036	2010/04/15	< .000	2013/04	
PENTACHLOROPHENOL	39032	036	2010/04/15	< .000	2013/04	
PICLORAM	39720	036	2010/04/15	< .000	2013/04	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2010/04/15	< .000	2013/04	
THIOBENCARB	A-001	WAIVED	2010/04/15	< .000		
TOXAPHENE	39400	WAIVED				
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2007/02/13	.000	2013/02	
1,1,2,2-TETRACHLOROETHANE	34516	072	2007/02/13	.000	2013/02	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2007/02/13	.000	2013/02	
1,1,2-TRICHLOROETHANE	34511	072	2007/02/13	.000	2013/02	
1,1-DICHLOROETHANE	34496	072	2007/02/13	.000	2013/02	
1,1-DICHLOROETHYLENE	34501	072	2007/02/13	.000	2013/02	
1,2,4-TRICHLOROBENZENE	34551	072	2007/02/13	.000	2013/02	
1,2-DICHLOROBENZENE	34536	072	2007/02/13	.000	2013/02	
1,2-DICHLOROETHANE	34531	072	2007/02/13	.000	2013/02	
1,2-DICHLOROPROPANE	34541	072	2007/02/13	.000	2013/02	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800516***

System Name: ***TUCKER ACRES MUTUAL WATER CO.***

PS Code: ***2800516-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2007/02/13	.000	2013/02
1,4-DICHLOROBENZENE	34571	072	2007/02/13	.000	2013/02
BENZENE	34030	072	2007/02/13	.000	2013/02
CARBON TETRACHLORIDE	32102	072	2007/02/13	.000	2013/02
CIS-1,2-DICHLOROETHYLENE	77093	072	2007/02/13	.000	2013/02
DICHLOROMETHANE	34423	072	2007/02/13	.000	2013/02
ETHYLBENZENE	34371	072	2007/02/13	.000	2013/02
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	036	2010/04/15	.000	2013/04
MONOCHLOROBENZENE	34301	072	2007/02/13	.000	2013/02
STYRENE	77128	072	2007/02/13	.000	2013/02
TETRACHLOROETHYLENE	34475	072	2007/02/13	.000	2013/02
TOLUENE	34010	072	2007/02/13	.000	2013/02
TRANS-1,2-DICHLOROETHYLENE	34546	072	2007/02/13	.000	2013/02
TRICHLOROETHYLENE	39180	072	2007/02/13	.000	2013/02
TRICHLOROFLUOROMETHANE	34488	072	2007/02/13	.000	2013/02
VINYL CHLORIDE	39175	072	2007/02/13	.000	2013/02
XYLENES (TOTAL)	81551	072	2007/02/13	.000	2013/02
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED	2010/04/15	10.600	
BICARBONATE ALKALINITY	00440	036	2010/04/15	120.000	2013/04
CALCIUM	00916	036	2010/04/15	12.000	2013/04
CARBONATE ALKALINITY	00445	036	2010/04/15	.000	2013/04
CHLORIDE	00940	036	2010/04/15	3.900	2013/04
COLOR	00081	036	2011/10/06	8.000	2014/10
COPPER	01042	036	2010/04/15	.000	2013/04
FOAMING AGENTS (MBAS)	38260	036	2010/04/15	.000	2013/04
HARDNESS (TOTAL) AS CACO3	00900	036	2010/04/15	54.000	2013/04
HYDROXIDE ALKALINITY	71830	036	2010/04/15	.000	2013/04
IRON	01045	036	2011/10/06	1190.000	2014/10

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800516***

System Name: ***TUCKER ACRES MUTUAL WATER CO.***

PS Code: ***2800516-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	036	2010/04/15	4.900	2013/04
MANGANESE	01055	036	2011/10/06	356.000	2014/10
ODOR THRESHOLD @ 60 C	00086	036	2011/10/06	8.000	2014/10
PH, LABORATORY	00403	036	2010/04/15	7.200	2013/04
SILVER	01077	036	2010/04/15	.000	2013/04
SODIUM	00929	036	2010/04/15	28.000	2013/04
SPECIFIC CONDUCTANCE	00095	036	2010/04/15	240.000	2013/04
SULFATE	00945	036	2010/04/15	9.900	2013/04
TOTAL DISSOLVED SOLIDS	70300	036	2010/04/15	230.000	2013/04
TURBIDITY, LABORATORY	82079	036	2011/10/06	1.900	2014/10
ZINC	01092	036	2010/04/15	.000	2013/04

PS Code: ***2800516-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED		

INORGANIC

ALUMINUM	01105	WAIVED		
ANTIMONY	01097	WAIVED		
ARSENIC	01002	WAIVED	2007/09/27	13.000
ASBESTOS	81855	WAIVED		
BARIUM	01007	WAIVED		
BERYLLIUM	01012	WAIVED		
CADMIUM	01027	WAIVED		
CHROMIUM (TOTAL)	01034	WAIVED		
CYANIDE	01291	WAIVED		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800516***

System Name: ***TUCKER ACRES MUTUAL WATER CO.***

PS Code: ***2800516-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800516***

System Name: ***TUCKER ACRES MUTUAL WATER CO.***

PS Code: ***2800516-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800516***

System Name: ***TUCKER ACRES MUTUAL WATER CO.***

PS Code: ***2800516-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800516***

System Name: ***TUCKER ACRES MUTUAL WATER CO.***

PS Code: ***2800516-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800521***

System Name: ***CIRCLE WATER DISTRICT***

PS Code: ***2800521-001***

Source Name: ***WELL 001-END OF DOGWOOD COURT***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2006/08/16	.000		
INORGANIC						
ALUMINUM	01105	036	2011/10/04	< .000	2014/10	
ANTIMONY	01097	036	2011/10/04	< .000	2014/10	
ARSENIC	01002	036	2011/10/04	2.900	2014/10	
ASBESTOS	81855	108	2006/08/16	.000	2015/08	
BARIUM	01007	036	2011/10/04	< .000	2014/10	
BERYLLIUM	01012	036	2011/10/04	< .000	2014/10	
CADMIUM	01027	036	2011/10/04	< .000	2014/10	
CHROMIUM (TOTAL)	01034	036	2011/10/04	< .000	2014/10	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2011/10/04	.170	2014/10	
LEAD	01051	WAIVED	2011/10/04	< .000		
MERCURY	71900	036	2011/10/04	< .000	2014/10	
NICKEL	01067	036	2011/10/04	< .000	2014/10	
PERCHLORATE	A-031	036	**2008/08/18**	.000	**2011/08**	**DUE**
SELENIUM	01147	036	2011/10/04	< .000	2014/10	
THALLIUM	01059	036	2011/10/04	< .000	2014/10	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/10/04	< .000	2012/10	
NITRITE (AS N)	00620	036	2010/06/01	.000	2013/06	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2007/06/17	.928	2016/06	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED	2007/06/17	.078		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800521***

System Name: ***CIRCLE WATER DISTRICT***

PS Code: ***2800521-001***

Source Name: ***WELL 001-END OF DOGWOOD COURT***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	108	2009/08/27	.000	2018/08	
2,4-D	39730	WAIVED	2009/08/27	.000		
ALACHLOR	77825	WAIVED	2009/08/27	.000		
ATRAZINE	39033	036	2009/08/27	.000	2012/08	
BENTAZON	38710	WAIVED	2009/08/27	.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	WAIVED	2009/08/27	.000		
CHLORDANE	39350	WAIVED	2002/07/23	.000		
DALAPON	38432	036	2009/08/27	.000	2012/08	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2006/08/16	.000		
DINOSEB	81287	WAIVED	2009/08/27	.000		
DIQUAT	78885	036	2009/08/27	.000	2012/08	
ENDOTHALL	38926	036	2009/08/27	.000	2012/08	
ENDRIN	39390	WAIVED	2002/07/23	.000		
ETHYLENE DIBROMIDE (EDB)	77651	108	2006/08/16	.000	2015/08	
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	108	**2002/07/23**	.000	**2011/07**	**DUE**
HEPTACHLOR EPOXIDE	39420	108	**2002/07/23**	.000	**2011/07**	**DUE**
HEXACHLOROBENZENE	39700	WAIVED	2002/07/23	.000		
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2002/07/23	.000		
LINDANE	39340	108	**2002/07/23**	.000	**2011/07**	**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800521***

System Name: ***CIRCLE WATER DISTRICT***

PS Code: ***2800521-001***

Source Name: ***WELL 001-END OF DOGWOOD COURT***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	**39480**	**108**	**2002/07/23**	**.000**	**2011/07**	**DUE**
MOLINATE	**82199**	**WAIVED**	2006/08/16	**.000**		
OXAMYL	**38865**	**036**	2009/08/27	**.000**	2012/08	
PENTACHLOROPHENOL	**39032**	**036**	2009/08/27	**.000**	2012/08	
PICLORAM	**39720**	**036**	2009/08/27	**.000**	2012/08	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	**39516**	**WAIVED**				
SIMAZINE	**39055**	**036**	2009/08/27	**.000**	2012/08	
THIOBENCARB	**A-001**	**WAIVED**	2006/08/16	**.000**		
TOXAPHENE	**39400**	**WAIVED**	2002/07/23	**.000**		
REGULATED VOC						
1,1,1-TRICHLOROETHANE	**34506**	**072**	2006/08/16	**.000**	2012/08	
1,1,2,2-TETRACHLOROETHANE	**34516**	**072**	2006/08/16	**.000**	2012/08	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	**81611**	**072**	2006/08/16	**.000**	2012/08	
1,1,2-TRICHLOROETHANE	**34511**	**072**	2006/08/16	**.000**	2012/08	
1,1-DICHLOROETHANE	**34496**	**072**	2006/08/16	**.000**	2012/08	
1,1-DICHLOROETHYLENE	**34501**	**072**	2006/08/16	**.000**	2012/08	
1,2,4-TRICHLOROBENZENE	**34551**	**072**	2006/08/16	**.000**	2012/08	
1,2-DICHLOROBENZENE	**34536**	**072**	2006/08/16	**.000**	2012/08	
1,2-DICHLOROETHANE	**34531**	**072**	2006/08/16	**.000**	2012/08	
1,2-DICHLOROPROPANE	**34541**	**072**	2006/08/16	**.000**	2012/08	
1,3-DICHLOROPROPENE (TOTAL)	**34561**	**072**	2006/08/16	**.000**	2012/08	
1,4-DICHLOROBENZENE	**34571**	**072**	2006/08/16	**.000**	2012/08	
BENZENE	**34030**	**072**	2006/08/16	**.000**	2012/08	
CARBON TETRACHLORIDE	**32102**	**072**	2006/08/16	**.000**	2012/08	
CIS-1,2-DICHLOROETHYLENE	**77093**	**072**	2006/08/16	**.000**	2012/08	
DICHLOROMETHANE	**34423**	**072**	2006/08/16	**.000**	2012/08	
ETHYLBENZENE	**34371**	**072**	2006/08/16	**.000**	2012/08	
METHYL-TERT-BUTYL-ETHER (MTBE)	**46491**	**036**	2011/10/04	**< .000**	2014/10	
MONOCHLOROBENZENE	**34301**	**072**	2006/08/16	**.000**	2012/08	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800521***

System Name: ***CIRCLE WATER DISTRICT***

PS Code: ***2800521-001***

Source Name: ***WELL 001-END OF DOGWOOD COURT***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2006/08/16	.000	2012/08
TETRACHLOROETHYLENE	34475	072	2006/08/16	.000	2012/08
TOLUENE	34010	072	2006/08/16	.000	2012/08
TRANS-1,2-DICHLOROETHYLENE	34546	072	2006/08/16	.000	2012/08
TRICHLOROETHYLENE	39180	072	2006/08/16	.000	2012/08
TRICHLOROFLUOROMETHANE	34488	072	2006/08/16	.000	2012/08
VINYL CHLORIDE	39175	072	2006/08/16	.000	2012/08
XYLENES (TOTAL)	81551	072	2006/08/16	.000	2012/08
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED	2002/07/23	9.900	
BICARBONATE ALKALINITY	00440	036	2011/10/04	80.000	2014/10
CALCIUM	00916	036	2011/10/04	11.000	2014/10
CARBONATE ALKALINITY	00445	036	2011/10/04	< .000	2014/10
CHLORIDE	00940	036	2011/10/04	4.500	2014/10
COLOR	00081	036	2011/10/04	20.000	2014/10
COPPER	01042	036	2011/10/04	< .000	2014/10
FOAMING AGENTS (MBAS)	38260	036	2011/10/04	< .050	2014/10
HARDNESS (TOTAL) AS CACO3	00900	036	2011/10/04	57.000	2014/10
HYDROXIDE ALKALINITY	71830	036	2011/10/04	< .000	2014/10
IRON	01045	036	2011/10/04	6000.000	2014/10
MAGNESIUM	00927	036	2011/10/04	7.300	2014/10
MANGANESE	01055	036	2011/10/04	472.000	2014/10
ODOR THRESHOLD @ 60 C	00086	036	2011/10/04	2.000	2014/10
PH, LABORATORY	00403	036	2011/10/04	6.800	2014/10
SILVER	01077	036	2011/10/04	< .000	2014/10
SODIUM	00929	036	2011/10/04	9.100	2014/10
SPECIFIC CONDUCTANCE	00095	036	2011/10/04	180.000	2014/10
SULFATE	00945	036	2011/10/04	22.000	2014/10
TOTAL DISSOLVED SOLIDS	70300	036	2011/10/04	190.000	2014/10

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800521
System Name: CIRCLE WATER DISTRICT

PS Code: 2800521-001
Source Name: WELL 001-END OF DOGWOOD COURT
Source Number: 001
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
SECONDARY/GP						
TURBIDITY, LABORATORY	82079	036	2011/10/04	5.800	2014/10	
ZINC	01092	036	2011/10/04	< .000	2014/10	

PS Code: 2800521-003
Source Name: WELL 003-END OF COLUMBINE
Source Number: 003
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2006/08/16	.000		
INORGANIC						
ALUMINUM	01105	036	2006/08/16	.000	2009/08	DUE
ANTIMONY	01097	036	2006/08/16	.000	2009/08	DUE
ARSENIC	01002	036	2006/08/16	.000	2009/08	DUE
ASBESTOS	81855	108	2006/08/16	.000	2015/08	
BARIUM	01007	036	2006/08/16	.000	2009/08	DUE
BERYLLIUM	01012	036	2006/08/16	.000	2009/08	DUE
CADMIUM	01027	036	2006/08/16	.000	2009/08	DUE
CHROMIUM (TOTAL)	01034	036	2006/08/16	.000	2009/08	DUE
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2006/08/16	.180	2009/08	DUE
LEAD	01051	WAIVED	2006/08/16	.000		
MERCURY	71900	036	2006/08/16	.000	2009/08	DUE
NICKEL	01067	036	2006/08/16	.000	2009/08	DUE
PERCHLORATE	A-031	006				DUE
SELENIUM	01147	036	2006/08/16	.000	2009/08	DUE
THALLIUM	01059	036	2006/08/16	.000	2009/08	DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800521
System Name: CIRCLE WATER DISTRICT

PS Code: 2800521-003
Source Name: WELL 003-END OF COLUMBINE
Source Number: 003
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2007/07/19	.000	2008/07	DUE
NITRITE (AS N)	00620	036	2006/08/16	.000	2009/08	DUE
RADIOLOGICAL						
GROSS ALPHA	01501	108	2007/06/17	.039	2016/06	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED	2007/06/17	.000		
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	108	2006/08/16	< 1.000	2015/08	
2,4-D	39730	WAIVED	2006/08/16	< 10.000		
ALACHLOR	77825	WAIVED	2006/08/16	< 1.000		
ATRAZINE	39033	036	2006/08/16	.000	2009/08	DUE
BENTAZON	38710	WAIVED	2006/08/16	< 2.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	WAIVED	2006/08/16	< 5.000		
CHLORDANE	39350	WAIVED	2006/08/16	< .100		
DALAPON	38432	036	2006/08/16	< 10.000	2009/08	DUE
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2006/08/16	< .010		
DINOSEB	81287	WAIVED	2006/08/16	< 2.000		
DIQUAT	78885	036	2006/08/16	< 4.000	2009/08	DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800521
System Name: CIRCLE WATER DISTRICT

PS Code: 2800521-003
Source Name: WELL 003-END OF COLUMBINE
Source Number: 003
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
ENDOTHALL	38926	036	2006/08/16	< 45.000	2009/08	DUE
ENDRIN	39390	WAIVED	2006/08/16	< .100		
ETHYLENE DIBROMIDE (EDB)	77651	108	2006/08/16	< .020	2015/08	
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	108	2006/08/16	< .010	2015/08	
HEPTACHLOR EPOXIDE	39420	108	2006/08/16	< .010	2015/08	
HEXACHLOROBENZENE	39700	WAIVED	2004/07/29	.000		
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2004/07/29	.000		
LINDANE	39340	108	2006/08/16	< .200	2015/08	
METHOXYCHLOR	39480	108	2006/08/16	< 10.000	2015/08	
MOLINATE	82199	WAIVED	2006/08/16	.000		
OXAMYL	38865	036	2006/08/16	< 20.000	2009/08	DUE
PENTACHLOROPHENOL	39032	036	2006/08/16	< .200	2009/08	DUE
PICLORAM	39720	036	2006/08/16	< 1.000	2009/08	DUE
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2006/08/16	< .500		
SIMAZINE	39055	036	2006/08/16	.000	2009/08	DUE
THIOBENCARB	A-001	WAIVED	2006/08/16	.000		
TOXAPHENE	39400	WAIVED	2006/08/16	< 1.000		
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2006/08/16	.000	2012/08	
1,1,2,2-TETRACHLOROETHANE	34516	072	2006/08/16	.000	2012/08	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2006/08/16	.000	2012/08	
1,1,2-TRICHLOROETHANE	34511	072	2006/08/16	.000	2012/08	
1,1-DICHLOROETHANE	34496	072	2006/08/16	.000	2012/08	
1,1-DICHLOROETHYLENE	34501	072	2006/08/16	.000	2012/08	
1,2,4-TRICHLOROBENZENE	34551	072	2006/08/16	.000	2012/08	
1,2-DICHLOROBENZENE	34536	072	2006/08/16	.000	2012/08	
1,2-DICHLOROETHANE	34531	072	2006/08/16	.000	2012/08	
1,2-DICHLOROPROPANE	34541	072	2006/08/16	.000	2012/08	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800521***

System Name: ***CIRCLE WATER DISTRICT***

PS Code: ***2800521-003***

Source Name: ***WELL 003-END OF COLUMBINE***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED VOC						
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2006/08/16	.000	2012/08	
1,4-DICHLOROBENZENE	34571	072	2006/08/16	.000	2012/08	
BENZENE	34030	072	2006/08/16	.000	2012/08	
CARBON TETRACHLORIDE	32102	072	2006/08/16	.000	2012/08	
CIS-1,2-DICHLOROETHYLENE	77093	072	2006/08/16	.000	2012/08	
DICHLOROMETHANE	34423	072	2006/08/16	.000	2012/08	
ETHYLBENZENE	34371	072	2006/08/16	.000	2012/08	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	036	**2006/08/16**	.000	**2009/08**	**DUE**
MONOCHLOROBENZENE	34301	072	2006/08/16	.000	2012/08	
STYRENE	77128	072	2006/08/16	.000	2012/08	
TETRACHLOROETHYLENE	34475	072	2006/08/16	.000	2012/08	
TOLUENE	34010	072	2006/08/16	.000	2012/08	
TRANS-1,2-DICHLOROETHYLENE	34546	072	2006/08/16	.000	2012/08	
TRICHLOROETHYLENE	39180	072	2006/08/16	.000	2012/08	
TRICHLOROFLUOROMETHANE	34488	072	2006/08/16	.000	2012/08	
VINYL CHLORIDE	39175	072	2006/08/16	.000	2012/08	
XYLENES (TOTAL)	81551	072	2006/08/16	.000	2012/08	
SECONDARY/GP						
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED	2004/07/29	10.700		
BICARBONATE ALKALINITY	00440	036	**2006/08/16**	350.000	**2009/08**	**DUE**
CALCIUM	00916	036	**2006/08/16**	39.000	**2009/08**	**DUE**
CARBONATE ALKALINITY	00445	036	**2006/08/16**	.000	**2009/08**	**DUE**
CHLORIDE	00940	036	**2006/08/16**	15.000	**2009/08**	**DUE**
COLOR	00081	036	**2006/08/16**	.000	**2009/08**	**DUE**
COPPER	01042	036	**2006/08/16**	.000	**2009/08**	**DUE**
FOAMING AGENTS (MBAS)	38260	036	**2006/08/16**	.000	**2009/08**	**DUE**
HARDNESS (TOTAL) AS CACO3	00900	036	**2006/08/16**	140.000	**2009/08**	**DUE**
HYDROXIDE ALKALINITY	71830	036	**2006/08/16**	.000	**2009/08**	**DUE**
IRON	01045	036	**2006/08/16**	.000	**2009/08**	**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800521
System Name: CIRCLE WATER DISTRICT

PS Code: 2800521-003
Source Name: WELL 003-END OF COLUMBINE
Source Number: 003
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
MAGNESIUM	00927	036	2006/08/16	11.000	2009/08	DUE
MANGANESE	01055	036	2006/08/16	.000	2009/08	DUE
ODOR THRESHOLD @ 60 C	00086	036	2006/08/16	.000	2009/08	DUE
PH, LABORATORY	00403	036	2006/08/16	7.800	2009/08	DUE
SILVER	01077	036	2006/08/16	.000	2009/08	DUE
SODIUM	00929	036	2006/08/16	98.000	2009/08	DUE
SPECIFIC CONDUCTANCE	00095	036	2006/08/16	700.000	2009/08	DUE
SULFATE	00945	036	2006/08/16	77.000	2009/08	DUE
TOTAL DISSOLVED SOLIDS	70300	036	2006/08/16	460.000	2009/08	DUE
TURBIDITY, LABORATORY	82079	036	2006/08/16	.460	2009/08	DUE
ZINC	01092	036	2006/08/16	.000	2009/08	DUE

PS Code: 2800521-004
Source Name: WELL #4 SURFACE SOURCES
Source Number: 004
Source Status: COMBINATION OR BLEND RAW
Water type: SURFACE

GENERAL NON CHAP 15				
DIAZINON	39570	WAIVED		

INORGANIC				
ALUMINUM	01105	WAIVED	2010/05/24	.000
ANTIMONY	01097	WAIVED	2010/05/24	.000
ARSENIC	01002	WAIVED	2010/05/24	.000
ASBESTOS	81855	WAIVED		
BARIUM	01007	WAIVED	2010/05/24	.000
BERYLLIUM	01012	WAIVED	2010/05/24	.000
CADMIUM	01027	WAIVED	2010/05/24	.000
CHROMIUM (TOTAL)	01034	WAIVED	2010/05/24	.000
CYANIDE	01291	WAIVED		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800521***

System Name: ***CIRCLE WATER DISTRICT***

PS Code: ***2800521-004***

Source Name: ***WELL #4 SURFACE SOURCES***

Source Number: ***004***

Source Status: ***COMBINATION OR BLEND RAW***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2009/08/27	.000	
LEAD	01051	WAIVED	2010/05/24	.000	
MERCURY	71900	WAIVED	2010/05/24	.000	
NICKEL	01067	WAIVED	2010/05/24	.000	
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED	2010/05/24	.000	
THALLIUM	01059	WAIVED	2010/05/24	.000	
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED	2010/05/24	.000	
NITRITE (AS N)	00620	WAIVED	2010/05/24	.000	
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED	2006/12/29	.689	
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2009/08/27	.000	
2,4-D	39730	WAIVED	2009/08/27	.000	
ALACHLOR	77825	WAIVED	2009/08/27	.000	
ATRAZINE	39033	WAIVED	2009/08/27	.000	
BENTAZON	38710	WAIVED	2009/08/27	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800521***

System Name: ***CIRCLE WATER DISTRICT***

PS Code: ***2800521-004***

Source Name: ***WELL #4 SURFACE SOURCES***

Source Number: ***004***

Source Status: ***COMBINATION OR BLEND RAW***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED	2009/08/27	.000	
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED	2009/08/27	.000	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED	2009/08/27	.000	
DIQUAT	78885	WAIVED	2009/08/27	.000	
ENDOTHALL	38926	WAIVED	2009/08/27	.000	
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED	2009/08/27	.000	
PENTACHLOROPHENOL	39032	WAIVED	2009/08/27	.000	
PICLORAM	39720	WAIVED	2009/08/27	.000	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED	2009/08/27	.000	
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800521
System Name: CIRCLE WATER DISTRICT

PS Code: 2800521-004
Source Name: WELL #4 SURFACE SOURCES
Source Number: 004
Source Status: COMBINATION OR BLEND RAW
Water type: SURFACE

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED	2010/06/01	.000	
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2010/05/24	65.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800521
System Name: CIRCLE WATER DISTRICT

PS Code: 2800521-004
Source Name: WELL #4 SURFACE SOURCES
Source Number: 004
Source Status: COMBINATION OR BLEND RAW
Water type: SURFACE

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED	2010/05/24	11.000	
CARBONATE ALKALINITY	00445	WAIVED	2010/05/24	.000	
CHLORIDE	00940	WAIVED	2010/05/24	4.300	
COLOR	00081	WAIVED	2010/05/24	22.000	
COPPER	01042	WAIVED	2010/05/24	.000	
FOAMING AGENTS (MBAS)	38260	WAIVED	2010/05/24	.000	
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2010/05/24	40.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2010/05/24	.000	
IRON	01045	WAIVED	2010/05/24	1300.000	
MAGNESIUM	00927	WAIVED	2010/05/24	7.400	
MANGANESE	01055	WAIVED	2010/05/24	190.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED	2010/05/24	2.000	
PH, LABORATORY	00403	WAIVED	2010/05/24	6.900	
SILVER	01077	WAIVED	2010/05/24	.000	
SODIUM	00929	WAIVED	2010/05/24	8.200	
SPECIFIC CONDUCTANCE	00095	WAIVED	2010/05/24	170.000	
SULFATE	00945	WAIVED	2010/05/24	23.000	
TOTAL DISSOLVED SOLIDS	70300	WAIVED	2010/05/24	160.000	
TURBIDITY, LABORATORY	82079	WAIVED	2010/05/24	9.100	
ZINC	01092	WAIVED	2010/05/24	.000	

PS Code: 2800521-008
Source Name: TREATMENT PLANT
Source Number: 008
Source Status: ACTIVE TREATED
Water type: SURFACE

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800521***

System Name: ***CIRCLE WATER DISTRICT***

PS Code: ***2800521-008***

Source Name: ***TREATMENT PLANT***

Source Number: ***008***

Source Status: ***ACTIVE TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800521***

System Name: ***CIRCLE WATER DISTRICT***

PS Code: ***2800521-008***

Source Name: ***TREATMENT PLANT***

Source Number: ***008***

Source Status: ***ACTIVE TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800521***

System Name: ***CIRCLE WATER DISTRICT***

PS Code: ***2800521-008***

Source Name: ***TREATMENT PLANT***

Source Number: ***008***

Source Status: ***ACTIVE TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800521***

System Name: ***CIRCLE WATER DISTRICT***

PS Code: ***2800521-008***

Source Name: ***TREATMENT PLANT***

Source Number: ***008***

Source Status: ***ACTIVE TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800525***

System Name: ***LA TIERRA HEIGHTS MUTUAL***

PS Code: ***2800525-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	036	2009/04/20	< 50.000	2012/04	
ANTIMONY	01097	036	2009/04/20	< 6.000	2012/04	
ARSENIC	01002	036	2009/04/20	< 2.000	2012/04	
ASBESTOS	81855	108	2009/04/20	.000	2018/04	
BARIUM	01007	036	2009/04/20	< 100.000	2012/04	
BERYLLIUM	01012	036	2009/04/20	< 1.000	2012/04	
CADMIUM	01027	036	2009/04/20	< 1.000	2012/04	
CHROMIUM (TOTAL)	01034	036	2009/04/20	< 1.000	2012/04	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2009/04/20	.180	2012/04	
LEAD	01051	WAIVED	2004/11/01	< 5.000		
MERCURY	71900	036	2009/04/20	< 1.000	2012/04	
NICKEL	01067	036	2009/04/20	< 10.000	2012/04	
PERCHLORATE	A-031	006				**DUE**
SELENIUM	01147	036	2009/04/20	< 5.000	2012/04	
THALLIUM	01059	036	2009/04/20	< 1.000	2012/04	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/05/09	11.000	2012/05	
NITRITE (AS N)	00620	036	2009/04/20	< 400.000	2012/04	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2012/02/13	.020	2021/02	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED	2012/02/13	.000		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800525***

System Name: ***LA TIERRA HEIGHTS MUTUAL***

PS Code: ***2800525-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	108	2011/05/09	.000	2020/05	
2,4-D	39730	108	2011/05/09	.000	2020/05	
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	036	2011/05/09	.000	2014/05	
BENTAZON	38710	WAIVED	2011/05/09	.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2011/05/09	.000	2014/05	
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2011/05/09	.000	2014/05	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	036	2011/05/09	.000	2014/05	
DIQUAT	78885	036	2011/05/09	.000	2014/05	
ENDOTHALL	38926	036	2011/05/09	.000	2014/05	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	000				**DUE**
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800525***

System Name: ***LA TIERRA HEIGHTS MUTUAL***

PS Code: ***2800525-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	**39480**	**000**				**DUE**
MOLINATE	**82199**	**WAIVED**				
OXAMYL	**38865**	**036**	2011/05/09	**.000**	2014/05	
PENTACHLOROPHENOL	**39032**	**036**	2011/05/09	**.000**	2014/05	
PICLORAM	**39720**	**036**	2011/05/09	**.000**	2014/05	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	**39516**	**WAIVED**				
SIMAZINE	**39055**	**036**	2011/05/09	**.000**	2014/05	
THIOBENCARB	**A-001**	**WAIVED**				
TOXAPHENE	**39400**	**000**				**DUE**
REGULATED VOC						
1,1,1-TRICHLOROETHANE	**34506**	**072**	2009/04/20	**.000**	2015/04	
1,1,2,2-TETRACHLOROETHANE	**34516**	**072**	2009/04/20	**.000**	2015/04	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	**81611**	**072**	2009/04/20	**.000**	2015/04	
1,1,2-TRICHLOROETHANE	**34511**	**072**	2009/04/20	**.000**	2015/04	
1,1-DICHLOROETHANE	**34496**	**072**	2009/04/20	**.000**	2015/04	
1,1-DICHLOROETHYLENE	**34501**	**072**	2009/04/20	**.000**	2015/04	
1,2,4-TRICHLOROBENZENE	**34551**	**072**	2009/04/20	**.000**	2015/04	
1,2-DICHLOROBENZENE	**34536**	**072**	2009/04/20	**.000**	2015/04	
1,2-DICHLOROETHANE	**34531**	**072**	2009/04/20	**.000**	2015/04	
1,2-DICHLOROPROPANE	**34541**	**072**	2009/04/20	**.000**	2015/04	
1,3-DICHLOROPROPENE (TOTAL)	**34561**	**072**	2009/04/20	**.000**	2015/04	
1,4-DICHLOROBENZENE	**34571**	**072**	2009/04/20	**.000**	2015/04	
BENZENE	**34030**	**072**	2009/04/20	**.000**	2015/04	
CARBON TETRACHLORIDE	**32102**	**072**	2009/04/20	**.000**	2015/04	
CIS-1,2-DICHLOROETHYLENE	**77093**	**072**	2009/04/20	**.000**	2015/04	
DICHLOROMETHANE	**34423**	**072**	2009/04/20	**.000**	2015/04	
ETHYLBENZENE	**34371**	**072**	2009/04/20	**.000**	2015/04	
METHYL-TERT-BUTYL-ETHER (MTBE)	**46491**	**036**	2009/04/20	**.000**	2012/04	
MONOCHLOROBENZENE	**34301**	**072**	2009/04/20	**.000**	2015/04	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800525***

System Name: ***LA TIERRA HEIGHTS MUTUAL***

PS Code: ***2800525-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2009/04/20	.000	2015/04
TETRACHLOROETHYLENE	34475	072	2009/04/20	.000	2015/04
TOLUENE	34010	072	2009/04/20	.000	2015/04
TRANS-1,2-DICHLOROETHYLENE	34546	072	2009/04/20	.000	2015/04
TRICHLOROETHYLENE	39180	072	2009/04/20	.000	2015/04
TRICHLOROFLUOROMETHANE	34488	072	2009/04/20	.000	2015/04
VINYL CHLORIDE	39175	072	2009/04/20	.000	2015/04
XYLENES (TOTAL)	81551	072	2009/04/20	.000	2015/04
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED	2009/04/20	9.300	
BICARBONATE ALKALINITY	00440	036	2009/04/20	68.000	2012/04
CALCIUM	00916	036	2009/04/20	12.000	2012/04
CARBONATE ALKALINITY	00445	036	2009/04/20	< 1.000	2012/04
CHLORIDE	00940	036	2009/04/20	11.000	2012/04
COLOR	00081	036	2009/04/20	5.000	2012/04
COPPER	01042	036	2009/04/20	< 50.000	2012/04
FOAMING AGENTS (MBAS)	38260	036	2009/04/20	< .050	2012/04
HARDNESS (TOTAL) AS CACO3	00900	036	2009/04/20	50.000	2012/04
HYDROXIDE ALKALINITY	71830	036	2009/04/20	< 1.000	2012/04
IRON	01045	036	2009/04/20	< 100.000	2012/04
MAGNESIUM	00927	036	2009/04/20	4.900	2012/04
MANGANESE	01055	036	2009/04/20	< 20.000	2012/04
ODOR THRESHOLD @ 60 C	00086	036	2009/04/20	< 1.000	2012/04
PH, LABORATORY	00403	036	2009/04/20	6.100	2012/04
SILVER	01077	036	2009/04/20	< 10.000	2012/04
SODIUM	00929	036	2009/04/20	11.000	2012/04
SPECIFIC CONDUCTANCE	00095	036	2009/04/20	170.000	2012/04
SULFATE	00945	036	2009/04/20	3.500	2012/04
TOTAL DISSOLVED SOLIDS	70300	036	2009/04/20	180.000	2012/04

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800525***

System Name: ***LA TIERRA HEIGHTS MUTUAL***

PS Code: ***2800525-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
SECONDARY/GP						
TURBIDITY, LABORATORY	82079	036	2009/04/20	.710	2012/04	
ZINC	01092	036	2009/04/20	< 50.000	2012/04	

PS Code: ***2800525-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	036	2011/05/09	< 50.000	2014/05	
ANTIMONY	01097	036	2011/05/09	< 6.000	2014/05	
ARSENIC	01002	036	2011/05/09	< 2.000	2014/05	
ASBESTOS	81855	108	2004/11/01	< 2.000	2013/11	
BARIUM	01007	036	2011/05/09	< 100.000	2014/05	
BERYLLIUM	01012	036	2011/05/09	< 1.000	2014/05	
CADMIUM	01027	036	2011/05/09	< 1.000	2014/05	
CHROMIUM (TOTAL)	01034	036	2011/05/09	< 1.000	2014/05	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2011/05/09	.220	2014/05	
LEAD	01051	WAIVED	2004/11/01	< 5.000		
MERCURY	71900	036	2011/05/09	< 1.000	2014/05	
NICKEL	01067	036	2011/05/09	< 10.000	2014/05	
PERCHLORATE	A-031	006				**DUE**
SELENIUM	01147	036	2011/05/09	< 5.000	2014/05	
THALLIUM	01059	036	2011/05/09	< 1.000	2014/05	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800525
System Name: LA TIERRA HEIGHTS MUTUAL

PS Code: 2800525-002
Source Name: WELL #2
Source Number: 002
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2011/05/09	7.200	2012/05
NITRITE (AS N)	00620	036	2011/05/09	< 400.000	2014/05
RADIOLOGICAL					
GROSS ALPHA	01501	108	2012/02/13	.146	2021/02
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED	2012/02/13	.000	
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	108	2011/05/09	.000	2020/05
2,4-D	39730	108	2011/05/09	.000	2020/05
ALACHLOR	77825	WAIVED	2004/11/01	.000	
ATRAZINE	39033	036	2011/05/09	.000	2014/05
BENTAZON	38710	WAIVED	2011/05/09	.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	036	2011/05/09	.000	2014/05
CHLORDANE	39350	WAIVED	2004/11/01	.000	
DALAPON	38432	036	2011/05/09	.000	2014/05
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	036	2011/05/09	.000	2014/05
DIQUAT	78885	036	2011/05/09	.000	2014/05

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800525
System Name: LA TIERRA HEIGHTS MUTUAL

PS Code: 2800525-002
Source Name: WELL #2
Source Number: 002
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	036	2011/05/09	.000	2014/05
ENDRIN	39390	WAIVED	2004/11/01	.000	
ETHYLENE DIBROMIDE (EDB)	77651	108	2004/11/01	.000	2013/11
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	108	2004/11/01	.000	2013/11
HEPTACHLOR EPOXIDE	39420	108	2004/11/01	.000	2013/11
HEXACHLOROBENZENE	39700	WAIVED	2004/11/01	.000	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2004/11/01	.000	
LINDANE	39340	108	2004/11/01	.000	2013/11
METHOXYCHLOR	39480	108	2004/11/01	.000	2013/11
MOLINATE	82199	WAIVED			
OXAMYL	38865	036	2011/05/09	.000	2014/05
PENTACHLOROPHENOL	39032	036	2011/05/09	.000	2014/05
PICLORAM	39720	036	2011/05/09	.000	2014/05
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	036	2011/05/09	.000	2014/05
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	108	2004/11/01	.000	2013/11
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	072	2011/05/09	.000	2017/05
1,1,2,2-TETRACHLOROETHANE	34516	072	2011/05/09	.000	2017/05
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2011/05/09	.000	2017/05
1,1,2-TRICHLOROETHANE	34511	072	2011/05/09	.000	2017/05
1,1-DICHLOROETHANE	34496	072	2011/05/09	.000	2017/05
1,1-DICHLOROETHYLENE	34501	072	2011/05/09	.000	2017/05
1,2,4-TRICHLOROBENZENE	34551	072	2011/05/09	.000	2017/05
1,2-DICHLOROBENZENE	34536	072	2011/05/09	.000	2017/05
1,2-DICHLOROETHANE	34531	072	2011/05/09	.000	2017/05
1,2-DICHLOROPROPANE	34541	072	2011/05/09	.000	2017/05

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800525***

System Name: ***LA TIERRA HEIGHTS MUTUAL***

PS Code: ***2800525-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2011/05/09	.000	2017/05
1,4-DICHLOROBENZENE	34571	072	2011/05/09	.000	2017/05
BENZENE	34030	072	2011/05/09	.000	2017/05
CARBON TETRACHLORIDE	32102	072	2011/05/09	.000	2017/05
CIS-1,2-DICHLOROETHYLENE	77093	072	2011/05/09	.000	2017/05
DICHLOROMETHANE	34423	072	2011/05/09	.000	2017/05
ETHYLBENZENE	34371	072	2011/05/09	.000	2017/05
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	036	2011/05/09	.000	2014/05
MONOCHLOROBENZENE	34301	072	2011/05/09	.000	2017/05
STYRENE	77128	072	2011/05/09	.000	2017/05
TETRACHLOROETHYLENE	34475	072	2011/05/09	.000	2017/05
TOLUENE	34010	072	2011/05/09	.000	2017/05
TRANS-1,2-DICHLOROETHYLENE	34546	072	2011/05/09	.000	2017/05
TRICHLOROETHYLENE	39180	072	2011/05/09	.000	2017/05
TRICHLOROFLUOROMETHANE	34488	072	2011/05/09	.000	2017/05
VINYL CHLORIDE	39175	072	2011/05/09	.000	2017/05
XYLENES (TOTAL)	81551	072	2011/05/09	.000	2017/05
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED	2011/05/09	8.750	
BICARBONATE ALKALINITY	00440	036	2011/05/09	37.000	2014/05
CALCIUM	00916	036	2011/05/09	3.800	2014/05
CARBONATE ALKALINITY	00445	036	2011/05/09	< 1.000	2014/05
CHLORIDE	00940	036	2011/05/09	6.200	2014/05
COLOR	00081	036	2011/05/09	5.000	2014/05
COPPER	01042	036	2011/05/09	< 50.000	2014/05
FOAMING AGENTS (MBAS)	38260	036	2011/05/09	< .050	2014/05
HARDNESS (TOTAL) AS CACO3	00900	036	2011/05/09	17.000	2014/05
HYDROXIDE ALKALINITY	71830	036	2011/05/09	< 1.000	2014/05
IRON	01045	036	2011/05/09	< 100.000	2014/05

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800525***

System Name: ***LA TIERRA HEIGHTS MUTUAL***

PS Code: ***2800525-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	036	2011/05/09	1.800	2014/05
MANGANESE	01055	036	2011/05/09	< 20.000	2014/05
ODOR THRESHOLD @ 60 C	00086	036	2011/05/09	< 1.000	2014/05
PH, LABORATORY	00403	036	2011/05/09	6.300	2014/05
SILVER	01077	036	2011/05/09	< 10.000	2014/05
SODIUM	00929	036	2011/05/09	11.000	2014/05
SPECIFIC CONDUCTANCE	00095	036	2011/05/09	100.000	2014/05
SULFATE	00945	036	2011/05/09	3.000	2014/05
TOTAL DISSOLVED SOLIDS	70300	036	2011/05/09	140.000	2014/05
TURBIDITY, LABORATORY	82079	036	2011/05/09	.900	2014/05
ZINC	01092	036	2011/05/09	< 50.000	2014/05

PS Code: ***2800525-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED

INORGANIC

ALUMINUM	01105	WAIVED
ANTIMONY	01097	WAIVED
ARSENIC	01002	WAIVED
ASBESTOS	81855	WAIVED
BARIUM	01007	WAIVED
BERYLLIUM	01012	WAIVED
CADMIUM	01027	WAIVED
CHROMIUM (TOTAL)	01034	WAIVED
CYANIDE	01291	WAIVED

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800525***

System Name: ***LA TIERRA HEIGHTS MUTUAL***

PS Code: ***2800525-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800525***

System Name: ***LA TIERRA HEIGHTS MUTUAL***

PS Code: ***2800525-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800525***

System Name: ***LA TIERRA HEIGHTS MUTUAL***

PS Code: ***2800525-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800525***

System Name: ***LA TIERRA HEIGHTS MUTUAL***

PS Code: ***2800525-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800527***

System Name: ***LINDA FALLS TERRACE MUTUAL***

PS Code: ***2800527-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	036	2010/06/14	< 50.000	2013/06
ANTIMONY	01097	036	2010/06/14	< 6.000	2013/06
ARSENIC	01002	036	2010/06/14	< 2.000	2013/06
ASBESTOS	81855	108	2011/06/20	.000	2020/06
BARIUM	01007	036	2010/06/14	< 100.000	2013/06
BERYLLIUM	01012	036	2010/06/14	< 1.000	2013/06
CADMIUM	01027	036	2010/06/14	< 1.000	2013/06
CHROMIUM (TOTAL)	01034	036	2010/06/14	< 1.000	2013/06
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2010/06/14	.320	2013/06
LEAD	01051	WAIVED	2003/06/02	< 5.000	
MERCURY	71900	036	2010/06/14	< 1.000	2013/06
NICKEL	01067	036	2010/06/14	< 10.000	2013/06
PERCHLORATE	A-031	036	2010/12/06	< 4.000	2013/12
SELENIUM	01147	036	2010/06/14	< 5.000	2013/06
THALLIUM	01059	036	2010/06/14	< 1.000	2013/06
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2011/06/20	7.000	2012/06
NITRITE (AS N)	00620	036	2010/06/14	< 400.000	2013/06
RADIOLOGICAL					
GROSS ALPHA	01501	108	2010/01/11	10.400	2019/01
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED	2011/03/14	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800527***

System Name: ***LINDA FALLS TERRACE MUTUAL***

PS Code: ***2800527-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED	2011/07/05	.391		
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	108	2009/04/20	.000	2018/04	
2,4-D	39730	108	2009/04/20	.000	2018/04	
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	036	2009/04/20	.000	2012/04	
BENTAZON	38710	WAIVED	2009/04/20	.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2009/04/20	.000	2012/04	
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2009/04/20	< 20.000	2012/04	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	036	2009/04/20	.000	2012/04	
DIQUAT	78885	036	2009/04/20	.000	2012/04	
ENDOTHALL	38926	036	2009/04/20	.000	2012/04	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	000				**DUE**
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800527***

System Name: ***LINDA FALLS TERRACE MUTUAL***

PS Code: ***2800527-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	000				**DUE**
MOLINATE	82199	WAIVED				
OXAMYL	38865	036	2009/04/20	.000	2012/04	
PENTACHLOROPHENOL	39032	036	2009/04/20	.000	2012/04	
PICLORAM	39720	036	2009/04/20	.000	2012/04	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2009/04/20	.000	2012/04	
THIOBENCARB	A-001	WAIVED				
TOXAPHENE	39400	000				**DUE**
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2009/04/20	.000	2015/04	
1,1,2,2-TETRACHLOROETHANE	34516	072	2009/04/20	.000	2015/04	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2009/04/20	.000	2015/04	
1,1,2-TRICHLOROETHANE	34511	072	2009/04/20	.000	2015/04	
1,1-DICHLOROETHANE	34496	072	2009/04/20	.000	2015/04	
1,1-DICHLOROETHYLENE	34501	072	2009/04/20	.000	2015/04	
1,2,4-TRICHLOROBENZENE	34551	072	2009/04/20	.000	2015/04	
1,2-DICHLOROBENZENE	34536	072	2009/04/20	.000	2015/04	
1,2-DICHLOROETHANE	34531	072	2009/04/20	.000	2015/04	
1,2-DICHLOROPROPANE	34541	072	2009/04/20	.000	2015/04	
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2009/04/20	.000	2015/04	
1,4-DICHLOROBENZENE	34571	072	2009/04/20	.000	2015/04	
BENZENE	34030	072	2009/04/20	.000	2015/04	
CARBON TETRACHLORIDE	32102	072	2009/04/20	.000	2015/04	
CIS-1,2-DICHLOROETHYLENE	77093	072	2009/04/20	.000	2015/04	
DICHLOROMETHANE	34423	072	2009/04/20	.000	2015/04	
ETHYLBENZENE	34371	072	2009/04/20	.000	2015/04	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	036	2009/04/20	.000	2012/04	
MONOCHLOROBENZENE	34301	072	2009/04/20	.000	2015/04	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800527***

System Name: ***LINDA FALLS TERRACE MUTUAL***

PS Code: ***2800527-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2009/04/20	.000	2015/04
TETRACHLOROETHYLENE	34475	072	2009/04/20	.000	2015/04
TOLUENE	34010	072	2009/04/20	.000	2015/04
TRANS-1,2-DICHLOROETHYLENE	34546	072	2009/04/20	.000	2015/04
TRICHLOROETHYLENE	39180	072	2009/04/20	.000	2015/04
TRICHLOROFLUOROMETHANE	34488	072	2009/04/20	.000	2015/04
VINYL CHLORIDE	39175	072	2009/04/20	.000	2015/04
XYLENES (TOTAL)	81551	072	2009/04/20	.000	2015/04
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED	2010/06/14	10.400	
BICARBONATE ALKALINITY	00440	036	2010/06/14	68.000	2013/06
CALCIUM	00916	036	2010/06/14	11.000	2013/06
CARBONATE ALKALINITY	00445	036	2010/06/14	< 1.000	2013/06
CHLORIDE	00940	036	2010/06/14	5.500	2013/06
COLOR	00081	036	2010/06/14	< 3.000	2013/06
COPPER	01042	036	2010/06/14	< 50.000	2013/06
FOAMING AGENTS (MBAS)	38260	036	2010/06/14	< .050	2013/06
HARDNESS (TOTAL) AS CACO3	00900	036	2010/06/14	46.000	2013/06
HYDROXIDE ALKALINITY	71830	036	2010/06/14	< 1.000	2013/06
IRON	01045	036	2010/06/14	< 100.000	2013/06
MAGNESIUM	00927	036	2010/06/14	4.400	2013/06
MANGANESE	01055	036	2010/06/14	< 20.000	2013/06
ODOR THRESHOLD @ 60 C	00086	036	2010/06/14	< 1.000	2013/06
PH, LABORATORY	00403	036	2010/06/14	6.500	2013/06
SILVER	01077	036	2010/06/14	< 10.000	2013/06
SODIUM	00929	036	2010/06/14	10.000	2013/06
SPECIFIC CONDUCTANCE	00095	036	2010/06/14	140.000	2013/06
SULFATE	00945	036	2010/06/14	4.100	2013/06
TOTAL DISSOLVED SOLIDS	70300	036	2010/06/14	170.000	2013/06

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800527***

System Name: ***LINDA FALLS TERRACE MUTUAL***

PS Code: ***2800527-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	036	2010/06/14	.300	2013/06
ZINC	01092	036	2010/06/14	< 50.000	2013/06

PS Code: ***2800527-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	000			DUE
ANTIMONY	01097	000			DUE
ARSENIC	01002	000			DUE
ASBESTOS	81855	000			DUE
BARIUM	01007	000			DUE
BERYLLIUM	01012	000			DUE
CADMIUM	01027	000			DUE
CHROMIUM (TOTAL)	01034	000			DUE
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	000			DUE
LEAD	01051	WAIVED			
MERCURY	71900	000			DUE
NICKEL	01067	000			DUE
PERCHLORATE	A-031	006			DUE
SELENIUM	01147	000			DUE
THALLIUM	01059	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800527***

System Name: ***LINDA FALLS TERRACE MUTUAL***

PS Code: ***2800527-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	000			DUE
NITRITE (AS N)	00620	000			DUE
RADIOLOGICAL					
GROSS ALPHA	01501	000			DUE
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	000			DUE
2,4-D	39730	000			DUE
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	000			DUE
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	000			DUE
CHLORDANE	39350	WAIVED			
DALAPON	38432	000			DUE
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	000			DUE
DIQUAT	78885	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800527***

System Name: ***LINDA FALLS TERRACE MUTUAL***

PS Code: ***2800527-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	000			DUE
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	000			DUE
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	000			DUE
HEPTACHLOR EPOXIDE	39420	000			DUE
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	000			DUE
METHOXYCHLOR	39480	000			DUE
MOLINATE	82199	WAIVED			
OXAMYL	38865	000			DUE
PENTACHLOROPHENOL	39032	000			DUE
PICLORAM	39720	000			DUE
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	000			DUE
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	000			DUE
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	000			DUE
1,1,2,2-TETRACHLOROETHANE	34516	000			DUE
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	000			DUE
1,1,2-TRICHLOROETHANE	34511	000			DUE
1,1-DICHLOROETHANE	34496	000			DUE
1,1-DICHLOROETHYLENE	34501	000			DUE
1,2,4-TRICHLOROBENZENE	34551	000			DUE
1,2-DICHLOROBENZENE	34536	000			DUE
1,2-DICHLOROETHANE	34531	000			DUE
1,2-DICHLOROPROPANE	34541	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800527
System Name: LINDA FALLS TERRACE MUTUAL

PS Code: 2800527-002
Source Name: WELL #2
Source Number: 002
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	000			DUE
1,4-DICHLOROBENZENE	34571	000			DUE
BENZENE	34030	000			DUE
CARBON TETRACHLORIDE	32102	000			DUE
CIS-1,2-DICHLOROETHYLENE	77093	000			DUE
DICHLOROMETHANE	34423	000			DUE
ETHYLBENZENE	34371	000			DUE
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	000			DUE
MONOCHLOROBENZENE	34301	000			DUE
STYRENE	77128	000			DUE
TETRACHLOROETHYLENE	34475	000			DUE
TOLUENE	34010	000			DUE
TRANS-1,2-DICHLOROETHYLENE	34546	000			DUE
TRICHLOROETHYLENE	39180	000			DUE
TRICHLOROFLUOROMETHANE	34488	000			DUE
VINYL CHLORIDE	39175	000			DUE
XYLENES (TOTAL)	81551	000			DUE
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	000			DUE
COLOR	00081	000			DUE
COPPER	01042	000			DUE
FOAMING AGENTS (MBAS)	38260	000			DUE
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800527***

System Name: ***LINDA FALLS TERRACE MUTUAL***

PS Code: ***2800527-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	000			DUE
PH, LABORATORY	00403	000			DUE
SILVER	01077	000			DUE
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	000			DUE
SULFATE	00945	000			DUE
TOTAL DISSOLVED SOLIDS	70300	000			DUE
TURBIDITY, LABORATORY	82079	000			DUE
ZINC	01092	000			DUE

PS Code: ***2800527-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED

INORGANIC

ALUMINUM	01105	WAIVED
ANTIMONY	01097	WAIVED
ARSENIC	01002	WAIVED
ASBESTOS	81855	WAIVED
BARIUM	01007	WAIVED
BERYLLIUM	01012	WAIVED
CADMIUM	01027	WAIVED
CHROMIUM (TOTAL)	01034	WAIVED
CYANIDE	01291	WAIVED

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800527***

System Name: ***LINDA FALLS TERRACE MUTUAL***

PS Code: ***2800527-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800527***

System Name: ***LINDA FALLS TERRACE MUTUAL***

PS Code: ***2800527-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800527***

System Name: ***LINDA FALLS TERRACE MUTUAL***

PS Code: ***2800527-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800527***

System Name: ***LINDA FALLS TERRACE MUTUAL***

PS Code: ***2800527-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800528***

System Name: ***LINDA VISTA MUTUAL WATER CO***

PS Code: ***2800528-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	036	2011/09/26	< 50.000	2014/09	
ANTIMONY	01097	036	2011/09/26	< 6.000	2014/09	
ARSENIC	01002	036	2011/09/26	< 2.000	2014/09	
ASBESTOS	81855	000				**DUE**
BARIUM	01007	036	2011/09/26	< 100.000	2014/09	
BERYLLIUM	01012	036	2011/09/26	< 1.000	2014/09	
CADMIUM	01027	036	2011/09/26	< 1.000	2014/09	
CHROMIUM (TOTAL)	01034	036	2011/09/26	< 1.000	2014/09	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2011/09/26	.180	2014/09	
LEAD	01051	WAIVED	2005/10/03	< 5.000		
MERCURY	71900	036	2011/09/26	< 1.000	2014/09	
NICKEL	01067	036	2011/09/26	< 10.000	2014/09	
PERCHLORATE	A-031	036	2011/12/19	< 4.000	2014/12	
SELENIUM	01147	036	2011/09/26	< 5.000	2014/09	
THALLIUM	01059	036	2011/09/26	< 1.000	2014/09	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/05/23	5.700	2012/05	
NITRITE (AS N)	00620	036	2011/09/26	< 400.000	2014/09	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2009/03/09	.000	2018/03	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED	2009/06/15	.055		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800528***

System Name: ***LINDA VISTA MUTUAL WATER CO***

PS Code: ***2800528-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	108	2011/09/26	.000	2020/09
2,4-D	39730	108	2011/09/26	.000	2020/09
ALACHLOR	77825	WAIVED	2005/10/03	.000	
ATRAZINE	39033	036	2011/09/26	.000	2014/09
BENTAZON	38710	WAIVED	2011/09/26	.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	036	2011/09/26	.000	2014/09
CHLORDANE	39350	WAIVED	2005/10/03	.000	
DALAPON	38432	036	2011/09/26	.000	2014/09
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	036	2011/09/26	.000	2014/09
DIQUAT	78885	036	2011/09/26	.000	2014/09
ENDOTHALL	38926	036	2011/09/26	.000	2014/09
ENDRIN	39390	WAIVED	2005/10/03	.000	
ETHYLENE DIBROMIDE (EDB)	77651	108	2005/10/03	.000	2014/10
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	108	2005/10/03	.000	2014/10
HEPTACHLOR EPOXIDE	39420	108	2005/10/03	.000	2014/10
HEXACHLOROBENZENE	39700	WAIVED	2005/10/03	.000	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2005/10/03	.000	
LINDANE	39340	108	2005/10/03	.000	2014/10

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800528***

System Name: ***LINDA VISTA MUTUAL WATER CO***

PS Code: ***2800528-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	108	2005/10/03	.000	2014/10	
MOLINATE	82199	WAIVED				
OXAMYL	38865	036	2011/09/26	.000	2014/09	
PENTACHLOROPHENOL	39032	036	2011/09/26	.000	2014/09	
PICLORAM	39720	036	2011/09/26	.000	2014/09	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2011/09/26	.000	2014/09	
THIOBENCARB	A-001	WAIVED				
TOXAPHENE	39400	108	2005/10/03	.000	2014/10	
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2005/10/03	.000	2011/10	DUE
1,1,2,2-TETRACHLOROETHANE	34516	072	2005/10/03	.000	2011/10	DUE
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2008/11/03	.000	2014/11	
1,1,2-TRICHLOROETHANE	34511	072	2005/10/03	.000	2011/10	DUE
1,1-DICHLOROETHANE	34496	072	2005/10/03	.000	2011/10	DUE
1,1-DICHLOROETHYLENE	34501	072	2005/10/03	.000	2011/10	DUE
1,2,4-TRICHLOROBENZENE	34551	072	2005/10/03	.000	2011/10	DUE
1,2-DICHLOROBENZENE	34536	072	2005/10/03	.000	2011/10	DUE
1,2-DICHLOROETHANE	34531	072	2005/10/03	.000	2011/10	DUE
1,2-DICHLOROPROPANE	34541	072	2005/10/03	.000	2011/10	DUE
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2005/10/03	.000	2011/10	DUE
1,4-DICHLOROBENZENE	34571	072	2005/10/03	.000	2011/10	DUE
BENZENE	34030	072	2005/10/03	.000	2011/10	DUE
CARBON TETRACHLORIDE	32102	072	2005/10/03	.000	2011/10	DUE
CIS-1,2-DICHLOROETHYLENE	77093	072	2005/10/03	.000	2011/10	DUE
DICHLOROMETHANE	34423	072	2005/10/03	.000	2011/10	DUE
ETHYLBENZENE	34371	072	2005/10/03	.000	2011/10	DUE
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	036	2011/09/26	.000	2014/09	
MONOCHLOROBENZENE	34301	072	2005/10/03	.000	2011/10	DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800528***

System Name: ***LINDA VISTA MUTUAL WATER CO***

PS Code: ***2800528-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED VOC						
STYRENE	77128	072	2005/10/03	.000	2011/10	DUE
TETRACHLOROETHYLENE	34475	072	2005/10/03	.000	2011/10	DUE
TOLUENE	34010	072	2005/10/03	.000	2011/10	DUE
TRANS-1,2-DICHLOROETHYLENE	34546	072	2005/10/03	.000	2011/10	DUE
TRICHLOROETHYLENE	39180	072	2005/10/03	.000	2011/10	DUE
TRICHLOROFLUOROMETHANE	34488	072	2005/10/03	.000	2011/10	DUE
VINYL CHLORIDE	39175	072	2005/10/03	.000	2011/10	DUE
XYLENES (TOTAL)	81551	072	2005/10/03	.000	2011/10	DUE
SECONDARY/GP						
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED	2011/09/26	10.000		
BICARBONATE ALKALINITY	00440	036	2011/09/26	68.000	2014/09	
CALCIUM	00916	036	2011/09/26	6.900	2014/09	
CARBONATE ALKALINITY	00445	036	2011/09/26	< 1.000	2014/09	
CHLORIDE	00940	036	2011/09/26	5.400	2014/09	
COLOR	00081	036	2011/09/26	10.000	2014/09	
COPPER	01042	036	2011/09/26	< 50.000	2014/09	
FOAMING AGENTS (MBAS)	38260	036	2011/09/26	< .050	2014/09	
HARDNESS (TOTAL) AS CACO3	00900	036	2011/09/26	37.000	2014/09	
HYDROXIDE ALKALINITY	71830	036	2011/09/26	< 1.000	2014/09	
IRON	01045	036	2011/09/26	< 100.000	2014/09	
MAGNESIUM	00927	036	2011/09/26	4.700	2014/09	
MANGANESE	01055	036	2011/09/26	< 20.000	2014/09	
ODOR THRESHOLD @ 60 C	00086	036	2011/09/26	< 1.000	2014/09	
PH, LABORATORY	00403	036	2011/09/26	6.300	2014/09	
SILVER	01077	036	2011/09/26	< 10.000	2014/09	
SODIUM	00929	036	2011/09/26	12.000	2014/09	
SPECIFIC CONDUCTANCE	00095	036	2011/09/26	140.000	2014/09	
SULFATE	00945	036	2011/09/26	3.800	2014/09	
TOTAL DISSOLVED SOLIDS	70300	036	2011/09/26	170.000	2014/09	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800528***

System Name: ***LINDA VISTA MUTUAL WATER CO***

PS Code: ***2800528-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	036	2011/09/26	.250	2014/09
ZINC	01092	036	2011/09/26	< 50.000	2014/09

PS Code: ***2800528-002***

Source Name: ***WELL 2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	036	2011/06/20	< 50.000	2014/06
ANTIMONY	01097	036	2011/06/20	< 6.000	2014/06
ARSENIC	01002	036	2011/06/20	< 2.000	2014/06
ASBESTOS	81855	108	2007/02/26	.000	2016/02
BARIUM	01007	036	2011/06/20	< 100.000	2014/06
BERYLLIUM	01012	036	2011/06/20	< 1.000	2014/06
CADMIUM	01027	036	2011/06/20	< 1.000	2014/06
CHROMIUM (TOTAL)	01034	036	2011/06/20	< 1.000	2014/06
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2011/06/20	.220	2014/06
LEAD	01051	WAIVED	2004/10/04	< 5.000	
MERCURY	71900	036	2011/06/20	< 1.000	2014/06
NICKEL	01067	036	2011/06/20	< 10.000	2014/06
PERCHLORATE	A-031	036	2011/12/19	< 4.000	2014/12
SELENIUM	01147	036	2011/06/20	< 5.000	2014/06
THALLIUM	01059	036	2011/06/20	< 1.000	2014/06

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800528***

System Name: ***LINDA VISTA MUTUAL WATER CO***

PS Code: ***2800528-002***

Source Name: ***WELL 2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2011/06/20	7.000	2012/06
NITRITE (AS N)	00620	036	2011/06/20	< 400.000	2014/06
RADIOLOGICAL					
GROSS ALPHA	01501	108	2009/06/15	.292	2018/06
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED	2009/06/15	.000	
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	108	2011/06/20	.000	2020/06
2,4-D	39730	108	2011/06/20	.000	2020/06
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	036	2011/06/20	.000	2014/06
BENTAZON	38710	WAIVED	2011/06/20	.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	036	2011/06/20	.000	2014/06
CHLORDANE	39350	WAIVED			
DALAPON	38432	036	2011/06/20	.000	2014/06
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	036	2011/06/20	.000	2014/06
DIQUAT	78885	036	2011/06/20	.000	2014/06

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800528***

System Name: ***LINDA VISTA MUTUAL WATER CO***

PS Code: ***2800528-002***

Source Name: ***WELL 2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
ENDOTHALL	38926	036	2011/06/20	.000	2014/06	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	000				**DUE**
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**
METHOXYCHLOR	39480	000				**DUE**
MOLINATE	82199	WAIVED				
OXAMYL	38865	036	2011/06/20	.000	2014/06	
PENTACHLOROPHENOL	39032	036	2011/06/20	.000	2014/06	
PICLORAM	39720	036	2011/06/20	.000	2014/06	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2011/06/20	.000	2014/06	
THIOBENCARB	A-001	WAIVED				
TOXAPHENE	39400	000				**DUE**
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2008/09/08	.000	2014/09	
1,1,2,2-TETRACHLOROETHANE	34516	072	2008/09/08	.000	2014/09	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2008/09/08	.000	2014/09	
1,1,2-TRICHLOROETHANE	34511	072	2008/09/08	.000	2014/09	
1,1-DICHLOROETHANE	34496	072	2008/09/08	.000	2014/09	
1,1-DICHLOROETHYLENE	34501	072	2008/09/08	.000	2014/09	
1,2,4-TRICHLOROBENZENE	34551	072	2008/09/08	.000	2014/09	
1,2-DICHLOROBENZENE	34536	072	2008/09/08	.000	2014/09	
1,2-DICHLOROETHANE	34531	072	2008/09/08	.000	2014/09	
1,2-DICHLOROPROPANE	34541	072	2008/09/08	.000	2014/09	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800528***

System Name: ***LINDA VISTA MUTUAL WATER CO***

PS Code: ***2800528-002***

Source Name: ***WELL 2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2008/09/08	.000	2014/09
1,4-DICHLOROBENZENE	34571	072	2008/09/08	.000	2014/09
BENZENE	34030	072	2008/09/08	.000	2014/09
CARBON TETRACHLORIDE	32102	072	2008/09/08	.000	2014/09
CIS-1,2-DICHLOROETHYLENE	77093	072	2008/09/08	.000	2014/09
DICHLOROMETHANE	34423	072	2008/09/08	.000	2014/09
ETHYLBENZENE	34371	072	2008/09/08	.000	2014/09
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	036	2011/06/20	.000	2014/06
MONOCHLOROBENZENE	34301	072	2008/09/08	.000	2014/09
STYRENE	77128	072	2008/09/08	.000	2014/09
TETRACHLOROETHYLENE	34475	072	2008/09/08	.000	2014/09
TOLUENE	34010	072	2008/09/08	.000	2014/09
TRANS-1,2-DICHLOROETHYLENE	34546	072	2008/09/08	.000	2014/09
TRICHLOROETHYLENE	39180	072	2008/09/08	.000	2014/09
TRICHLOROFLUOROMETHANE	34488	072	2008/09/08	.000	2014/09
VINYL CHLORIDE	39175	072	2008/09/08	.000	2014/09
XYLENES (TOTAL)	81551	072	2008/09/08	.000	2014/09
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED	2008/06/16	10.000	
BICARBONATE ALKALINITY	00440	036	2011/06/20	68.000	2014/06
CALCIUM	00916	036	2011/06/20	8.200	2014/06
CARBONATE ALKALINITY	00445	036	2011/06/20	< 1.000	2014/06
CHLORIDE	00940	036	2011/06/20	7.100	2014/06
COLOR	00081	036	2011/06/20	10.000	2014/06
COPPER	01042	036	2011/06/20	< 50.000	2014/06
FOAMING AGENTS (MBAS)	38260	036	2011/06/20	< .050	2014/06
HARDNESS (TOTAL) AS CACO3	00900	036	2011/06/20	39.000	2014/06
HYDROXIDE ALKALINITY	71830	036	2011/06/20	< 1.000	2014/06
IRON	01045	036	2011/06/20	450.000	2014/06

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800528***

System Name: ***LINDA VISTA MUTUAL WATER CO***

PS Code: ***2800528-002***

Source Name: ***WELL 2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	036	2011/06/20	4.400	2014/06
MANGANESE	01055	036	2011/06/20	< 20.000	2014/06
ODOR THRESHOLD @ 60 C	00086	036	2011/06/20	< 1.000	2014/06
PH, LABORATORY	00403	036	2011/06/20	6.400	2014/06
SILVER	01077	036	2011/06/20	< 10.000	2014/06
SODIUM	00929	036	2011/06/20	11.000	2014/06
SPECIFIC CONDUCTANCE	00095	036	2011/06/20	150.000	2014/06
SULFATE	00945	036	2011/06/20	6.700	2014/06
TOTAL DISSOLVED SOLIDS	70300	036	2011/06/20	170.000	2014/06
TURBIDITY, LABORATORY	82079	036	2011/06/20	2.400	2014/06
ZINC	01092	036	2011/06/20	< 50.000	2014/06

PS Code: ***2800528-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED

INORGANIC

ALUMINUM	01105	WAIVED
ANTIMONY	01097	WAIVED
ARSENIC	01002	WAIVED
ASBESTOS	81855	WAIVED
BARIUM	01007	WAIVED
BERYLLIUM	01012	WAIVED
CADMIUM	01027	WAIVED
CHROMIUM (TOTAL)	01034	WAIVED
CYANIDE	01291	WAIVED

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800528***

System Name: ***LINDA VISTA MUTUAL WATER CO***

PS Code: ***2800528-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800528***

System Name: ***LINDA VISTA MUTUAL WATER CO***

PS Code: ***2800528-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800528***

System Name: ***LINDA VISTA MUTUAL WATER CO***

PS Code: ***2800528-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800528***

System Name: ***LINDA VISTA MUTUAL WATER CO***

PS Code: ***2800528-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800530***

System Name: ***MEYERS WATER CO.***

PS Code: ***2800530-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2007/01/29	.000		
INORGANIC						
ALUMINUM	01105	036	2010/07/26	.000	2013/07	
ANTIMONY	01097	036	2010/07/26	.000	2013/07	
ARSENIC	01002	036	2010/07/26	6.600	2013/07	
ASBESTOS	81855	000				**DUE**
BARIUM	01007	036	2010/07/26	520.000	2013/07	
BERYLLIUM	01012	036	2010/07/26	.000	2013/07	
CADMIUM	01027	036	2010/07/26	.000	2013/07	
CHROMIUM (TOTAL)	01034	036	2010/07/26	.000	2013/07	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2010/07/26	.000	2013/07	
LEAD	01051	WAIVED	2010/07/26	.000		
MERCURY	71900	036	2010/07/26	.000	2013/07	
NICKEL	01067	036	2010/07/26	.000	2013/07	
PERCHLORATE	A-031	006				**DUE**
SELENIUM	01147	036	2010/07/26	.000	2013/07	
THALLIUM	01059	036	2010/07/26	.000	2013/07	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	**2010/07/26**	.000	**2011/07**	**DUE**
NITRITE (AS N)	00620	036	2010/07/26	.000	2013/07	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2010/07/26	.000	2019/07	
GROSS BETA	03501	WAIVED	1996/06/11	2.580		
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED	2010/07/26	1.940		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800530***

System Name: ***MEYERS WATER CO.***

PS Code: ***2800530-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED	2007/01/29	.890		
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	108	2007/01/29	< 1.000	2016/01	
2,4-D	39730	108	2007/01/29	< 10.000	2016/01	
ALACHLOR	77825	WAIVED	2010/07/26	< .000		
ATRAZINE	39033	036	2010/07/26	< .000	2013/07	
BENTAZON	38710	WAIVED	2007/01/29	< 2.000		
BENZO (A) PYRENE	34247	WAIVED	1997/07/21	.000		
CARBOFURAN	81405	036	2010/07/26	< .000	2013/07	
CHLORDANE	39350	WAIVED	1997/07/21	.000		
DALAPON	38432	036	**2007/01/29**	< 10.000	**2010/01**	**DUE**
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED	1997/07/21	.000		
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED	1997/07/21	.000		
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2006/02/20	.000		
DINOSEB	81287	036	**2007/01/29**	< 2.000	**2010/01**	**DUE**
DIQUAT	78885	036	2010/07/26	< .000	2013/07	
ENDOTHALL	38926	036	2010/07/26	< .000	2013/07	
ENDRIN	39390	WAIVED	1997/07/21	.000		
ETHYLENE DIBROMIDE (EDB)	77651	108	2006/02/20	.000	2015/02	
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	108	**1997/07/21**	.000	**2006/07**	**DUE**
HEPTACHLOR EPOXIDE	39420	108	**1997/07/21**	.000	**2006/07**	**DUE**
HEXACHLOROBENZENE	39700	WAIVED	1997/07/21	.000		
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	1997/07/21	.000		
LINDANE	39340	108	**1997/07/21**	.000	**2006/07**	**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800530***

System Name: ***MEYERS WATER CO.***

PS Code: ***2800530-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	108	1997/07/21	.000	2006/07	DUE
MOLINATE	82199	WAIVED	2010/07/26	< .000		
OXAMYL	38865	036	2010/07/26	< .000	2013/07	
PENTACHLOROPHENOL	39032	036	2007/01/29	< .200	2010/01	DUE
PICLORAM	39720	036	2007/01/29	< 1.000	2010/01	DUE
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	1997/07/21	.000		
SIMAZINE	39055	036	2010/07/26	< .000	2013/07	
THIOBENCARB	A-001	WAIVED	2010/07/26	< .000		
TOXAPHENE	39400	108	1997/07/21	.000	2006/07	DUE
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2006/02/20	.000	2012/02	DUE
1,1,2,2-TETRACHLOROETHANE	34516	072	2006/02/20	.000	2012/02	DUE
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2006/02/20	.000	2012/02	DUE
1,1,2-TRICHLOROETHANE	34511	072	2006/02/20	.000	2012/02	DUE
1,1-DICHLOROETHANE	34496	072	2006/02/20	.000	2012/02	DUE
1,1-DICHLOROETHYLENE	34501	072	2006/02/20	.000	2012/02	DUE
1,2,4-TRICHLOROBENZENE	34551	072	2006/02/20	.000	2012/02	DUE
1,2-DICHLOROBENZENE	34536	072	2006/02/20	.000	2012/02	DUE
1,2-DICHLOROETHANE	34531	072	2006/02/20	.000	2012/02	DUE
1,2-DICHLOROPROPANE	34541	072	2006/02/20	.000	2012/02	DUE
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2006/02/20	.000	2012/02	DUE
1,4-DICHLOROBENZENE	34571	072	2006/02/20	.000	2012/02	DUE
BENZENE	34030	072	2006/02/20	.000	2012/02	DUE
CARBON TETRACHLORIDE	32102	072	2006/02/20	.000	2012/02	DUE
CIS-1,2-DICHLOROETHYLENE	77093	072	2006/02/20	.000	2012/02	DUE
DICHLOROMETHANE	34423	072	2006/02/20	.000	2012/02	DUE
ETHYLBENZENE	34371	072	2006/02/20	.000	2012/02	DUE
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	036	2007/09/23	.000	2010/09	DUE
MONOCHLOROBENZENE	34301	072	2006/02/20	.000	2012/02	DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800530***

System Name: ***MEYERS WATER CO.***

PS Code: ***2800530-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED VOC						
STYRENE	77128	072	2006/02/20	.000	2012/02	DUE
TETRACHLOROETHYLENE	34475	072	2006/02/20	.000	2012/02	DUE
TOLUENE	34010	072	2006/02/20	.000	2012/02	DUE
TRANS-1,2-DICHLOROETHYLENE	34546	072	2006/02/20	.000	2012/02	DUE
TRICHLOROETHYLENE	39180	072	2006/02/20	.000	2012/02	DUE
TRICHLOROFLUOROMETHANE	34488	072	2006/02/20	.000	2012/02	DUE
VINYL CHLORIDE	39175	072	2006/02/20	.000	2012/02	DUE
XYLENES (TOTAL)	81551	072	2006/02/20	.000	2012/02	DUE
SECONDARY/GP						
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED	2010/07/26	12.500		
BICARBONATE ALKALINITY	00440	036	2010/07/26	308.000	2013/07	
CALCIUM	00916	036	2010/07/26	52.000	2013/07	
CARBONATE ALKALINITY	00445	036	2010/07/26	.000	2013/07	
CHLORIDE	00940	036	2010/07/26	310.000	2013/07	
COLOR	00081	036	2010/07/26	15.000	2013/07	
COPPER	01042	036	2010/07/26	.000	2013/07	
FOAMING AGENTS (MBAS)	38260	036	2010/07/26	.000	2013/07	
HARDNESS (TOTAL) AS CACO3	00900	036	2010/07/26	350.000	2013/07	
HYDROXIDE ALKALINITY	71830	036	2010/07/26	.000	2013/07	
IRON	01045	036	2010/07/26	620.000	2013/07	
MAGNESIUM	00927	036	2010/07/26	55.000	2013/07	
MANGANESE	01055	036	2010/07/26	1400.000	2013/07	
ODOR THRESHOLD @ 60 C	00086	036	2010/07/26	4.000	2013/07	
PH, LABORATORY	00403	036	2010/07/26	7.500	2013/07	
SILVER	01077	036	2010/07/26	.000	2013/07	
SODIUM	00929	036	2010/07/26	155.000	2013/07	
SPECIFIC CONDUCTANCE	00095	036	2010/07/26	1500.000	2013/07	
SULFATE	00945	036	2010/07/26	11.000	2013/07	
TOTAL DISSOLVED SOLIDS	70300	036	2010/07/26	830.000	2013/07	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800530***

System Name: ***MEYERS WATER CO.***

PS Code: ***2800530-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
TURBIDITY, LABORATORY	**82079**	**036**	2010/07/26	**6.300**	2013/07
ZINC	**01092**	**036**	2010/07/26	**.000**	2013/07

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800531***

System Name: ***MOORE S RESORT***

PS Code: ***2800531-001***

Source Name: ***WELL 02***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	036	2011/03/31	< 50.000	2014/03	
ANTIMONY	01097	036	2011/03/31	< 6.000	2014/03	
ARSENIC	01002	036	2011/03/31	9.900	2014/03	
ASBESTOS	81855	108	2011/03/31	.000	2020/03	
BARIUM	01007	036	2011/03/31	2600.000	2014/03	
BERYLLIUM	01012	036	2011/03/31	< 1.000	2014/03	
CADMIUM	01027	036	2011/03/31	< 1.000	2014/03	
CHROMIUM (TOTAL)	01034	036	2011/03/31	< 1.000	2014/03	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2011/03/31	< .100	2014/03	
LEAD	01051	WAIVED				
MERCURY	71900	036	2011/03/31	< 1.000	2014/03	
NICKEL	01067	036	2011/03/31	< 10.000	2014/03	
PERCHLORATE	A-031	036	2011/09/28	< 4.000	2014/09	
SELENIUM	01147	036	2011/03/31	5.500	2014/03	
THALLIUM	01059	036	2011/03/31	< 1.000	2014/03	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	**2011/03/31**	12.000	**2012/03**	**DUE**
NITRITE (AS N)	00620	036	2011/03/31	< 400.000	2014/03	
RADIOLOGICAL						
GROSS ALPHA	01501	000				**DUE**
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800531***

System Name: ***MOORE S RESORT***

PS Code: ***2800531-001***

Source Name: ***WELL 02***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	108	2011/03/31	.000	2020/03	
2,4-D	39730	108	2011/03/31	.000	2020/03	
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	036	2011/03/31	.000	2014/03	
BENTAZON	38710	WAIVED	2011/03/31	.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2011/03/31	.000	2014/03	
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2011/03/31	.000	2014/03	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	036	2011/03/31	.000	2014/03	
DIQUAT	78885	036	2011/03/31	.000	2014/03	
ENDOTHALL	38926	036	2011/03/31	.000	2014/03	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	000				**DUE**
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800531***

System Name: ***MOORE S RESORT***

PS Code: ***2800531-001***

Source Name: ***WELL 02***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	000				**DUE**
MOLINATE	82199	WAIVED				
OXAMYL	38865	036	2004/04/14	.000	2007/04	**DUE**
PENTACHLOROPHENOL	39032	036	2011/03/31	.000	2014/03	
PICLORAM	39720	036	2011/03/31	.000	2014/03	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2011/03/31	.000	2014/03	
THIOBENCARB	A-001	WAIVED				
TOXAPHENE	39400	000				**DUE**
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2011/03/31	.000	2017/03	
1,1,2,2-TETRACHLOROETHANE	34516	072	2011/03/31	.000	2017/03	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2011/03/31	.000	2017/03	
1,1,2-TRICHLOROETHANE	34511	072	2011/03/31	.000	2017/03	
1,1-DICHLOROETHANE	34496	072	2011/03/31	.000	2017/03	
1,1-DICHLOROETHYLENE	34501	072	2011/03/31	.000	2017/03	
1,2,4-TRICHLOROBENZENE	34551	072	2011/03/31	.000	2017/03	
1,2-DICHLOROBENZENE	34536	072	2011/03/31	.000	2017/03	
1,2-DICHLOROETHANE	34531	072	2011/03/31	.000	2017/03	
1,2-DICHLOROPROPANE	34541	072	2011/03/31	.000	2017/03	
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2011/03/31	.000	2017/03	
1,4-DICHLOROBENZENE	34571	072	2011/03/31	.000	2017/03	
BENZENE	34030	072	2011/03/31	.000	2017/03	
CARBON TETRACHLORIDE	32102	072	2011/03/31	.000	2017/03	
CIS-1,2-DICHLOROETHYLENE	77093	072	2011/03/31	.000	2017/03	
DICHLOROMETHANE	34423	072	2011/03/31	.000	2017/03	
ETHYLBENZENE	34371	072	2011/03/31	.000	2017/03	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	036	2011/03/31	.000	2014/03	
MONOCHLOROBENZENE	34301	072	2011/03/31	.000	2017/03	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800531***

System Name: ***MOORE S RESORT***

PS Code: ***2800531-001***

Source Name: ***WELL 02***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2011/03/31	.000	2017/03
TETRACHLOROETHYLENE	34475	072	2011/03/31	.000	2017/03
TOLUENE	34010	072	2011/03/31	.000	2017/03
TRANS-1,2-DICHLOROETHYLENE	34546	072	2011/03/31	.000	2017/03
TRICHLOROETHYLENE	39180	072	2011/03/31	.000	2017/03
TRICHLOROFLUOROMETHANE	34488	072	2011/03/31	.000	2017/03
VINYL CHLORIDE	39175	072	2011/03/31	.000	2017/03
XYLENES (TOTAL)	81551	072	2011/03/31	.000	2017/03
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED	2011/03/31	12.100	
BICARBONATE ALKALINITY	00440	036	2011/03/31	180.000	2014/03
CALCIUM	00916	036	2011/03/31	210.000	2014/03
CARBONATE ALKALINITY	00445	036	2011/03/31	< 1.000	2014/03
CHLORIDE	00940	036	2011/03/31	1000.000	2014/03
COLOR	00081	036	2011/03/31	10.000	2014/03
COPPER	01042	036	2011/03/31	< 50.000	2014/03
FOAMING AGENTS (MBAS)	38260	036	2011/03/31	< .050	2014/03
HARDNESS (TOTAL) AS CACO3	00900	036	2011/03/31	1600.000	2014/03
HYDROXIDE ALKALINITY	71830	036	2011/03/31	< 1.000	2014/03
IRON	01045	036	2011/03/31	6400.000	2014/03
MAGNESIUM	00927	036	2011/03/31	260.000	2014/03
MANGANESE	01055	036	2011/03/31	2600.000	2014/03
ODOR THRESHOLD @ 60 C	00086	036	2011/03/31	2.000	2014/03
PH, LABORATORY	00403	036	2011/03/31	7.200	2014/03
SILVER	01077	036	2011/03/31	< 10.000	2014/03
SODIUM	00929	036	2011/03/31	260.000	2014/03
SPECIFIC CONDUCTANCE	00095	036	2011/03/31	5300.000	2014/03
SULFATE	00945	036	2011/03/31	44.000	2014/03
TOTAL DISSOLVED SOLIDS	70300	036	2011/03/31	3800.000	2014/03

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800531***

System Name: ***MOORE S RESORT***

PS Code: ***2800531-001***

Source Name: ***WELL 02***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	036	2011/03/31	7.200	2014/03
ZINC	01092	036	2011/03/31	< 50.000	2014/03

PS Code: ***2800531-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15		
DIAZINON	39570	WAIVED
INORGANIC		
ALUMINUM	01105	WAIVED
ANTIMONY	01097	WAIVED
ARSENIC	01002	WAIVED
ASBESTOS	81855	WAIVED
BARIUM	01007	WAIVED
BERYLLIUM	01012	WAIVED
CADMIUM	01027	WAIVED
CHROMIUM (TOTAL)	01034	WAIVED
CYANIDE	01291	WAIVED
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED
LEAD	01051	WAIVED
MERCURY	71900	WAIVED
NICKEL	01067	WAIVED
PERCHLORATE	A-031	WAIVED
SELENIUM	01147	WAIVED
THALLIUM	01059	WAIVED

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800531***

System Name: ***MOORE S RESORT***

PS Code: ***2800531-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800531***

System Name: ***MOORE S RESORT***

PS Code: ***2800531-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800531***

System Name: ***MOORE S RESORT***

PS Code: ***2800531-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800531***

System Name: ***MOORE S RESORT***

PS Code: ***2800531-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800532***

System Name: ***VAILIMA ESTATES MUTUAL WATER***

PS Code: ***2800532-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	036	2009/08/19	< 50.000	2012/08
ANTIMONY	01097	036	2009/08/19	< 6.000	2012/08
ARSENIC	01002	036	2009/08/19	< 2.000	2012/08
ASBESTOS	81855	108	2006/07/19	.000	2015/07
BARIUM	01007	036	2009/08/19	< 100.000	2012/08
BERYLLIUM	01012	036	2009/08/19	< 1.000	2012/08
CADMIUM	01027	036	2009/08/19	< 1.000	2012/08
CHROMIUM (TOTAL)	01034	036	2009/08/19	1.100	2012/08
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2009/08/19	.470	2012/08
LEAD	01051	WAIVED			
MERCURY	71900	036	2009/08/19	< 1.000	2012/08
NICKEL	01067	036	2009/08/19	< 10.000	2012/08
PERCHLORATE	A-031	036	2010/01/20	< 4.000	2013/01
SELENIUM	01147	036	2009/08/19	< 5.000	2012/08
THALLIUM	01059	036	2009/08/19	< 1.000	2012/08
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2011/08/17	4.600	2012/08
NITRITE (AS N)	00620	036	2009/08/19	< 400.000	2012/08
RADIOLOGICAL					
GROSS ALPHA	01501	108	2009/04/15	.125	2018/04
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED	2009/04/15	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800532***

System Name: ***VAILIMA ESTATES MUTUAL WATER***

PS Code: ***2800532-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	108	2009/08/19	.000	2018/08	
2,4-D	39730	108	2009/08/19	.000	2018/08	
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	036	2009/08/19	.000	2012/08	
BENTAZON	38710	WAIVED	2009/08/19	.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2009/08/19	.000	2012/08	
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2009/08/19	.000	2012/08	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	036	2009/08/19	.000	2012/08	
DIQUAT	78885	036	2009/08/19	.000	2012/08	
ENDOTHALL	38926	036	2009/08/19	.000	2012/08	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	000				**DUE**
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800532***

System Name: ***VAILIMA ESTATES MUTUAL WATER***

PS Code: ***2800532-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	000				**DUE**
MOLINATE	82199	WAIVED				
OXAMYL	38865	036	2010/06/02	.000	2013/06	
PENTACHLOROPHENOL	39032	036	2009/08/19	.000	2012/08	
PICLORAM	39720	036	2009/08/19	.000	2012/08	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2009/08/19	.000	2012/08	
THIOBENCARB	A-001	WAIVED				
TOXAPHENE	39400	000				**DUE**
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2009/08/19	.000	2015/08	
1,1,2,2-TETRACHLOROETHANE	34516	072	2009/08/19	.000	2015/08	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2009/08/19	.000	2015/08	
1,1,2-TRICHLOROETHANE	34511	072	2009/08/19	.000	2015/08	
1,1-DICHLOROETHANE	34496	072	2009/08/19	.000	2015/08	
1,1-DICHLOROETHYLENE	34501	072	2009/08/19	.000	2015/08	
1,2,4-TRICHLOROBENZENE	34551	072	2009/08/19	.000	2015/08	
1,2-DICHLOROBENZENE	34536	072	2009/08/19	.000	2015/08	
1,2-DICHLOROETHANE	34531	072	2009/08/19	.000	2015/08	
1,2-DICHLOROPROPANE	34541	072	2009/08/19	.000	2015/08	
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2009/08/19	.000	2015/08	
1,4-DICHLOROBENZENE	34571	072	2009/08/19	.000	2015/08	
BENZENE	34030	072	2009/08/19	.000	2015/08	
CARBON TETRACHLORIDE	32102	072	2009/08/19	.000	2015/08	
CIS-1,2-DICHLOROETHYLENE	77093	072	2009/08/19	.000	2015/08	
DICHLOROMETHANE	34423	072	2009/08/19	.000	2015/08	
ETHYLBENZENE	34371	072	2009/08/19	.000	2015/08	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	036	2009/08/19	.000	2012/08	
MONOCHLOROBENZENE	34301	072	2009/08/19	.000	2015/08	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800532***

System Name: ***VAILIMA ESTATES MUTUAL WATER***

PS Code: ***2800532-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2009/08/19	.000	2015/08
TETRACHLOROETHYLENE	34475	072	2009/08/19	.000	2015/08
TOLUENE	34010	072	2009/08/19	.000	2015/08
TRANS-1,2-DICHLOROETHYLENE	34546	072	2009/08/19	.000	2015/08
TRICHLOROETHYLENE	39180	072	2009/08/19	.000	2015/08
TRICHLOROFLUOROMETHANE	34488	072	2009/08/19	.000	2015/08
VINYL CHLORIDE	39175	072	2009/08/19	.000	2015/08
XYLENES (TOTAL)	81551	072	2009/08/19	.000	2015/08
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED	2009/08/19	10.300	
BICARBONATE ALKALINITY	00440	036	2009/08/19	120.000	2012/08
CALCIUM	00916	036	2009/08/19	10.000	2012/08
CARBONATE ALKALINITY	00445	036	2009/08/19	< 1.000	2012/08
CHLORIDE	00940	036	2009/08/19	6.000	2012/08
COLOR	00081	036	2009/08/19	5.000	2012/08
COPPER	01042	036	2009/08/19	< 50.000	2012/08
FOAMING AGENTS (MBAS)	38260	036	2009/08/19	< .050	2012/08
HARDNESS (TOTAL) AS CACO3	00900	036	2009/08/19	52.000	2012/08
HYDROXIDE ALKALINITY	71830	036	2009/08/19	< 1.000	2012/08
IRON	01045	036	2009/08/19	< 100.000	2012/08
MAGNESIUM	00927	036	2009/08/19	6.600	2012/08
MANGANESE	01055	036	2009/08/19	< 20.000	2012/08
ODOR THRESHOLD @ 60 C	00086	036	2009/08/19	< 1.000	2012/08
PH, LABORATORY	00403	036	2009/08/19	6.900	2012/08
SILVER	01077	036	2009/08/19	< 10.000	2012/08
SODIUM	00929	036	2009/08/19	21.000	2012/08
SPECIFIC CONDUCTANCE	00095	036	2009/08/19	200.000	2012/08
SULFATE	00945	036	2009/08/19	3.100	2012/08
TOTAL DISSOLVED SOLIDS	70300	036	2009/08/19	210.000	2012/08

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800532***

System Name: ***VAILIMA ESTATES MUTUAL WATER***

PS Code: ***2800532-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
TURBIDITY, LABORATORY	**82079**	**036**	2009/08/19	**.340**	2012/08
ZINC	**01092**	**036**	2009/08/19	**< 50.000**	2012/08

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800536***

System Name: ***GRGICH HILLS***

PS Code: ***2800536-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	036	2009/09/02	< 50.000	2012/09	
ANTIMONY	01097	036	2009/09/02	< 6.000	2012/09	
ARSENIC	01002	036	2009/09/02	2.200	2012/09	
ASBESTOS	81855	000				**DUE**
BARIUM	01007	036	2009/09/02	100.000	2012/09	
BERYLLIUM	01012	036	2009/09/02	< 1.000	2012/09	
CADMIUM	01027	036	2009/09/02	< 1.000	2012/09	
CHROMIUM (TOTAL)	01034	036	2009/09/02	< 10.000	2012/09	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2009/09/02	.330	2012/09	
LEAD	01051	WAIVED	2002/04/09	31.000		
MERCURY	71900	036	2009/09/02	< 1.000	2012/09	
NICKEL	01067	036	2009/09/02	< 10.000	2012/09	
PERCHLORATE	A-031	036	2012/02/22	< 4.000	2015/02	
SELENIUM	01147	036	2009/09/02	< 5.000	2012/09	
THALLIUM	01059	036	2009/09/02	< 1.000	2012/09	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/09/07	< 2.000	2012/09	
NITRITE (AS N)	00620	036	2009/09/02	< 400.000	2012/09	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2012/02/22	.810	2021/02	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800536***

System Name: ***GRGICH HILLS***

PS Code: ***2800536-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2009/09/02	.000		
2,4-D	39730	WAIVED	2009/09/02	.000		
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	036	2009/09/02	.000	2012/09	
BENTAZON	38710	WAIVED	2009/09/02	.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2009/09/02	.000	2012/09	
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2009/09/02	.000	2012/09	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	036	2009/09/02	.000	2012/09	
DIQUAT	78885	036	2009/09/02	.000	2012/09	
ENDOTHALL	38926	036	2009/09/02	.000	2012/09	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	000				**DUE**
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800536***

System Name: ***GRGICH HILLS***

PS Code: ***2800536-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	000				**DUE**
MOLINATE	82199	WAIVED				
OXAMYL	38865	036	2009/09/02	.000	2012/09	
PENTACHLOROPHENOL	39032	036	2009/09/02	.000	2012/09	
PICLORAM	39720	036	2009/09/02	.000	2012/09	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2009/09/02	.000	2012/09	
THIOBENCARB	A-001	WAIVED				
TOXAPHENE	39400	000				**DUE**
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2011/09/07	.000	2017/09	
1,1,2,2-TETRACHLOROETHANE	34516	072	2011/09/07	.000	2017/09	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2011/09/07	.000	2017/09	
1,1,2-TRICHLOROETHANE	34511	072	2011/09/07	.000	2017/09	
1,1-DICHLOROETHANE	34496	072	2011/09/07	.000	2017/09	
1,1-DICHLOROETHYLENE	34501	072	2011/09/07	.000	2017/09	
1,2,4-TRICHLOROBENZENE	34551	072	2011/09/07	.000	2017/09	
1,2-DICHLOROBENZENE	34536	072	2011/09/07	.000	2017/09	
1,2-DICHLOROETHANE	34531	072	2011/09/07	.000	2017/09	
1,2-DICHLOROPROPANE	34541	072	2011/09/07	.000	2017/09	
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2011/09/07	.000	2017/09	
1,4-DICHLOROBENZENE	34571	072	2011/09/07	.000	2017/09	
BENZENE	34030	072	2011/09/07	.000	2017/09	
CARBON TETRACHLORIDE	32102	072	2011/09/07	.000	2017/09	
CIS-1,2-DICHLOROETHYLENE	77093	072	2011/09/07	.000	2017/09	
DICHLOROMETHANE	34423	072	2011/09/07	.000	2017/09	
ETHYLBENZENE	34371	072	2011/09/07	.000	2017/09	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2011/09/07	.000	2017/09	
MONOCHLOROBENZENE	34301	072	2011/09/07	.000	2017/09	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800536***

System Name: ***GRGICH HILLS***

PS Code: ***2800536-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2011/09/07	.000	2017/09
TETRACHLOROETHYLENE	34475	072	2011/09/07	.000	2017/09
TOLUENE	34010	072	2011/09/07	.000	2017/09
TRANS-1,2-DICHLOROETHYLENE	34546	072	2011/09/07	.000	2017/09
TRICHLOROETHYLENE	39180	072	2011/09/07	.000	2017/09
TRICHLOROFLUOROMETHANE	34488	072	2011/09/07	.000	2017/09
VINYL CHLORIDE	39175	072	2011/09/07	.000	2017/09
XYLENES (TOTAL)	81551	072	2011/09/07	.000	2017/09
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2009/09/02	300.000	
CALCIUM	00916	WAIVED	2009/09/02	29.000	
CARBONATE ALKALINITY	00445	WAIVED	2009/09/02	< 1.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2009/09/02	220.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2009/09/02	< 1.000	
IRON	01045	WAIVED	2009/09/02	210.000	
MAGNESIUM	00927	WAIVED	2009/09/02	35.000	
MANGANESE	01055	WAIVED	2009/09/02	510.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2009/09/02	7.400	
SILVER	01077	WAIVED	2009/09/02	< 10.000	
SODIUM	00929	WAIVED	2009/09/02	27.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800536***

System Name: ***GRGICH HILLS***

PS Code: ***2800536-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800536-002***

Source Name: ***WELL 2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type:

		000			DUE
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	036			DUE
ANTIMONY	01097	036			DUE
ARSENIC	01002	036			DUE
ASBESTOS	81855	WAIVED			
BARIUM	01007	036			DUE
BERYLLIUM	01012	036			DUE
CADMIUM	01027	036			DUE
CHROMIUM (TOTAL)	01034	036			DUE
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	036			DUE
LEAD	01051	WAIVED			
MERCURY	71900	036			DUE
NICKEL	01067	036			DUE
PERCHLORATE	A-031	006			DUE
SELENIUM	01147	036			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800536***

System Name: ***GRGICH HILLS***

PS Code: ***2800536-002***

Source Name: ***WELL 2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type:

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
INORGANIC						
THALLIUM	01059	036				DUE
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	000				DUE
NITRITE (AS N)	00620	000				DUE
RADIOLOGICAL						
GROSS ALPHA	01501	108				DUE
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED				
2,4-D	39730	000				DUE
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	000				DUE
BENTAZON	38710	WAIVED				
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	WAIVED				
CHLORDANE	39350	WAIVED				
DALAPON	38432	WAIVED				
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800536***

System Name: ***GRGICH HILLS***

PS Code: ***2800536-002***

Source Name: ***WELL 2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type:

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	000			DUE
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	000			DUE
1,1,2,2-TETRACHLOROETHANE	34516	000			DUE
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	000			DUE
1,1,2-TRICHLOROETHANE	34511	000			DUE
1,1-DICHLOROETHANE	34496	000			DUE
1,1-DICHLOROETHYLENE	34501	000			DUE
1,2,4-TRICHLOROBENZENE	34551	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800536***

System Name: ***GRGICH HILLS***

PS Code: ***2800536-002***

Source Name: ***WELL 2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type:

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,2-DICHLOROBENZENE	34536	000			DUE
1,2-DICHLOROETHANE	34531	000			DUE
1,2-DICHLOROPROPANE	34541	000			DUE
1,3-DICHLOROPROPENE (TOTAL)	34561	000			DUE
1,4-DICHLOROBENZENE	34571	000			DUE
BENZENE	34030	000			DUE
CARBON TETRACHLORIDE	32102	000			DUE
CIS-1,2-DICHLOROETHYLENE	77093	000			DUE
DICHLOROMETHANE	34423	000			DUE
ETHYLBENZENE	34371	000			DUE
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	000			DUE
MONOCHLOROBENZENE	34301	000			DUE
STYRENE	77128	000			DUE
TETRACHLOROETHYLENE	34475	000			DUE
TOLUENE	34010	000			DUE
TRANS-1,2-DICHLOROETHYLENE	34546	000			DUE
TRICHLOROETHYLENE	39180	000			DUE
TRICHLOROFLUOROMETHANE	34488	000			DUE
VINYL CHLORIDE	39175	000			DUE
XYLENES (TOTAL)	81551	000			DUE
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	000			DUE
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	036			DUE
COLOR	00081	036			DUE
COPPER	01042	036			DUE
FOAMING AGENTS (MBAS)	38260	036			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800536***

System Name: ***GRGICH HILLS***

PS Code: ***2800536-002***

Source Name: ***WELL 2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type:

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
HARDNESS (TOTAL) AS CACO3	00900	000				DUE
HYDROXIDE ALKALINITY	71830	000				DUE
IRON	01045	036				DUE
MAGNESIUM	00927	000				DUE
MANGANESE	01055	036				DUE
ODOR THRESHOLD @ 60 C	00086	036				DUE
PH, LABORATORY	00403	036				DUE
SILVER	01077	036				DUE
SODIUM	00929	000				DUE
SPECIFIC CONDUCTANCE	00095	036				DUE
SULFATE	00945	036				DUE
TOTAL DISSOLVED SOLIDS	70300	036				DUE
TURBIDITY, LABORATORY	82079	036				DUE
ZINC	01092	036				DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800538***

System Name: ***CARNEROS INN***

PS Code: ***2800538-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2003/10/20	.000		
INORGANIC						
ALUMINUM	01105	036	2009/07/22	94.000	2012/07	
ANTIMONY	01097	036	2009/07/22	< .500	2012/07	
ARSENIC	01002	036	2009/07/22	.950	2012/07	
ASBESTOS	81855	108	2009/07/22	.000	2018/07	
BARIUM	01007	036	2009/07/22	130.000	2012/07	
BERYLLIUM	01012	036	2009/07/22	< .100	2012/07	
CADMIUM	01027	036	2009/07/22	< .100	2012/07	
CHROMIUM (TOTAL)	01034	036	2009/07/22	< .500	2012/07	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2009/07/22	.130	2012/07	
LEAD	01051	WAIVED	2003/10/20	.000		
MERCURY	71900	036	2009/07/22	< 1.000	2012/07	
NICKEL	01067	036	2009/07/22	.880	2012/07	
PERCHLORATE	A-031	006				**DUE**
SELENIUM	01147	036	2009/07/22	< 1.000	2012/07	
THALLIUM	01059	036	2009/07/22	< .100	2012/07	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	**2005/02/11**	.000	**2006/02**	**DUE**
NITRITE (AS N)	00620	036	**2003/10/20**	.000	**2006/10**	**DUE**
RADIOLOGICAL						
GROSS ALPHA	01501	000				**DUE**
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800538***

System Name: ***CARNEROS INN***

PS Code: ***2800538-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	108	2009/07/22	< .500	2018/07	
2,4-D	39730	108	2009/07/22	< 1.000	2018/07	
ALACHLOR	77825	WAIVED	2009/07/22	< .500		
ATRAZINE	39033	036	2009/07/22	< .500	2012/07	
BENTAZON	38710	WAIVED	2009/07/22	< .400		
BENZO (A) PYRENE	34247	WAIVED	2009/07/22	< .000		
CARBOFURAN	81405	036	2009/07/22	< 5.000	2012/07	
CHLORDANE	39350	WAIVED	2009/07/22	< .050		
DALAPON	38432	036	2009/07/22	< 6.000	2012/07	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED	2009/07/22	< .000		
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED	2009/07/22	4.100		
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	1998/02/05	.000		
DINOSEB	81287	036	2009/07/22	< 1.000	2012/07	
DIQUAT	78885	036	2009/07/22	< 2.000	2012/07	
ENDOTHALL	38926	036	2009/07/22	< 90.000	2012/07	
ENDRIN	39390	WAIVED	2009/07/22	< .010		
ETHYLENE DIBROMIDE (EDB)	77651	108	1998/02/05	.000	2007/02	DUE
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	108	2009/07/22	< .010	2018/07	
HEPTACHLOR EPOXIDE	39420	108	2009/07/22	< .010	2018/07	
HEXACHLOROBENZENE	39700	WAIVED	2009/07/22	< .040		
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2009/07/22	< .400		
LINDANE	39340	108	2009/07/22	< .010	2018/07	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800538***

System Name: ***CARNEROS INN***

PS Code: ***2800538-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	108	2009/07/22	< .020	2018/07
MOLINATE	82199	WAIVED	2009/07/22	< .500	
OXAMYL	38865	036	2009/07/22	< 20.000	2012/07
PENTACHLOROPHENOL	39032	036	2009/07/22	< .200	2012/07
PICLORAM	39720	036	2009/07/22	< .200	2012/07
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2009/07/22	< .500	
SIMAZINE	39055	036	2009/07/22	< .500	2012/07
THIOBENCARB	A-001	WAIVED	2009/07/22	< 1.000	
TOXAPHENE	39400	108	2009/07/22	< .500	2018/07
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	072	2009/07/22	< .500	2015/07
1,1,2,2-TETRACHLOROETHANE	34516	072	2009/07/22	< .500	2015/07
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2009/07/22	< .500	2015/07
1,1,2-TRICHLOROETHANE	34511	072	2009/07/22	< .500	2015/07
1,1-DICHLOROETHANE	34496	072	2009/07/22	< .500	2015/07
1,1-DICHLOROETHYLENE	34501	072	2009/07/22	< .300	2015/07
1,2,4-TRICHLOROBENZENE	34551	072	2009/07/22	< .500	2015/07
1,2-DICHLOROBENZENE	34536	072	2009/07/22	< .500	2015/07
1,2-DICHLOROETHANE	34531	072	2009/07/22	< .500	2015/07
1,2-DICHLOROPROPANE	34541	072	2009/07/22	< .500	2015/07
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2009/07/22	< .500	2015/07
1,4-DICHLOROBENZENE	34571	072	2009/07/22	< .500	2015/07
BENZENE	34030	072	2009/07/22	< .300	2015/07
CARBON TETRACHLORIDE	32102	072	2009/07/22	< .500	2015/07
CIS-1,2-DICHLOROETHYLENE	77093	072	2009/07/22	< .500	2015/07
DICHLOROMETHANE	34423	072	2009/07/22	< .500	2015/07
ETHYLBENZENE	34371	072	2009/07/22	< .500	2015/07
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	036	2009/07/22	< .500	2012/07
MONOCHLOROBENZENE	34301	072	2009/07/22	< .500	2015/07

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800538***

System Name: ***CARNEROS INN***

PS Code: ***2800538-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2009/07/22	< .500	2015/07
TETRACHLOROETHYLENE	34475	072	2009/07/22	< .500	2015/07
TOLUENE	34010	072	2009/07/22	.730	2015/07
TRANS-1,2-DICHLOROETHYLENE	34546	072	2009/07/22	< .500	2015/07
TRICHLOROETHYLENE	39180	072	2009/07/22	< .500	2015/07
TRICHLOROFLUOROMETHANE	34488	072	2009/07/22	< .500	2015/07
VINYL CHLORIDE	39175	072	2009/07/22	< .500	2015/07
XYLENES (TOTAL)	81551	072	2009/07/22	< .500	2015/07
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED	2009/07/22	12.320	
BICARBONATE ALKALINITY	00440	036	2009/07/22	590.000	2012/07
CALCIUM	00916	036	2009/07/22	32.000	2012/07
CARBONATE ALKALINITY	00445	036	2009/07/22	< 5.000	2012/07
CHLORIDE	00940	036	2009/07/22	300.000	2012/07
COLOR	00081	036	2009/07/22	< 5.000	2012/07
COPPER	01042	036	2009/07/22	.950	2012/07
FOAMING AGENTS (MBAS)	38260	036	2009/07/22	.150	2012/07
HARDNESS (TOTAL) AS CACO3	00900	036	2009/07/22	181.000	2012/07
HYDROXIDE ALKALINITY	71830	036	2009/07/22	< 1.000	2012/07
IRON	01045	036	2009/07/22	220.000	2012/07
MAGNESIUM	00927	036	2009/07/22	25.000	2012/07
MANGANESE	01055	036	2009/07/22	60.000	2012/07
ODOR THRESHOLD @ 60 C	00086	036	2009/07/22	< 1.000	2012/07
PH, LABORATORY	00403	036	2009/07/22	7.730	2012/07
SILVER	01077	036	2009/07/22	< .100	2012/07
SODIUM	00929	036	2009/07/22	300.000	2012/07
SPECIFIC CONDUCTANCE	00095	036	2009/07/22	1800.000	2012/07
SULFATE	00945	036	2009/07/22	.540	2012/07
TOTAL DISSOLVED SOLIDS	70300	036	2009/07/22	960.000	2012/07

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800538***

System Name: ***CARNEROS INN***

PS Code: ***2800538-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	**82079**	**036**	2009/07/22	**1.200**	2012/07
ZINC	**01092**	**036**	2009/07/22	**200.000**	2012/07

PS Code: ***2800538-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15		
DIAZINON	**39570**	**WAIVED**
INORGANIC		
ALUMINUM	**01105**	**WAIVED**
ANTIMONY	**01097**	**WAIVED**
ARSENIC	**01002**	**WAIVED**
ASBESTOS	**81855**	**WAIVED**
BARIUM	**01007**	**WAIVED**
BERYLLIUM	**01012**	**WAIVED**
CADMIUM	**01027**	**WAIVED**
CHROMIUM (TOTAL)	**01034**	**WAIVED**
CYANIDE	**01291**	**WAIVED**
FLUORIDE (F) (NATURAL-SOURCE)	**00951**	**WAIVED**
LEAD	**01051**	**WAIVED**
MERCURY	**71900**	**WAIVED**
NICKEL	**01067**	**WAIVED**
PERCHLORATE	**A-031**	**WAIVED**
SELENIUM	**01147**	**WAIVED**
THALLIUM	**01059**	**WAIVED**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800538***

System Name: ***CARNEROS INN***

PS Code: ***2800538-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800538***

System Name: ***CARNEROS INN***

PS Code: ***2800538-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800538***

System Name: ***CARNEROS INN***

PS Code: ***2800538-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800538***

System Name: ***CARNEROS INN***

PS Code: ***2800538-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800543
System Name: CAPELL VALLEY ESTATES

PS Code: 2800543-001
Source Name: LPA REPORTED PRIMARY SOURCE
Source Number: 001
Source Status: ACTIVE RAW
Water type: SURFACE

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2008/07/01	.000		
INORGANIC						
ALUMINUM	01105	012	2011/05/25	< .000	2012/05	
ANTIMONY	01097	012	2011/05/25	< .000	2012/05	
ARSENIC	01002	012	2011/05/25	< .000	2012/05	
ASBESTOS	81855	108	2008/12/01	.000	2017/12	
BARIUM	01007	012	2011/05/25	< .000	2012/05	
BERYLLIUM	01012	012	2011/05/25	< .000	2012/05	
CADMIUM	01027	012	2011/05/25	< .000	2012/05	
CHROMIUM (TOTAL)	01034	012	2011/05/25	< .000	2012/05	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	012	2011/05/25	< .000	2012/05	
LEAD	01051	WAIVED	2011/05/25	< .000		
MERCURY	71900	012	2011/05/25	< .000	2012/05	
NICKEL	01067	012	2011/05/25	< .000	2012/05	
PERCHLORATE	A-031	012	2010/01/26	.000	2011/01	DUE
SELENIUM	01147	012	2011/05/25	< .000	2012/05	
THALLIUM	01059	012	2011/05/25	< .000	2012/05	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/05/25	< .000	2012/05	
NITRITE (AS N)	00620	036	2011/05/25	< .000	2014/05	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2010/07/02	1.580	2019/07	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED	2008/12/01	.220		
RADIUM 228	11501	WAIVED	2010/07/02	1.670		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800543***

System Name: ***CAPELL VALLEY ESTATES***

PS Code: ***2800543-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	108	2011/05/25	< 1.000	2020/05	
2,4-D	39730	108	2011/05/25	< 10.000	2020/05	
ALACHLOR	77825	WAIVED	2008/07/01	.000		
ATRAZINE	39033	036	2011/05/25	< .500	2014/05	
BENTAZON	38710	WAIVED	2011/05/25	< 2.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2011/05/25	< 5.000	2014/05	
CHLORDANE	39350	WAIVED	2002/10/22	.000		
DALAPON	38432	036	2011/05/25	< 10.000	2014/05	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2011/05/25	< .010		
DINOSEB	81287	036	2011/05/25	< 2.000	2014/05	
DIQUAT	78885	036	2011/05/25	< 4.000	2014/05	
ENDOTHALL	38926	036	2011/05/25	< 45.000	2014/05	
ENDRIN	39390	WAIVED	2002/10/22	.000		
ETHYLENE DIBROMIDE (EDB)	77651	108	2011/05/25	< .020	2020/05	
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	108	2002/10/22	.000	2011/10	DUE
HEPTACHLOR EPOXIDE	39420	108	2002/10/22	.000	2011/10	DUE
HEXACHLOROBENZENE	39700	WAIVED	2002/10/22	.000		
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2002/10/22	.000		
LINDANE	39340	108	2002/10/22	.000	2011/10	DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800543***

System Name: ***CAPELL VALLEY ESTATES***

PS Code: ***2800543-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	108	2002/10/22	.000	2011/10	DUE
MOLINATE	82199	WAIVED	2008/07/01	.000		
OXAMYL	38865	036	2011/05/25	< 20.000	2014/05	
PENTACHLOROPHENOL	39032	036	2011/05/25	< .200	2014/05	
PICLORAM	39720	036	2011/05/25	< 1.000	2014/05	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2002/10/22	.000		
SIMAZINE	39055	036	2011/05/25	< 1.000	2014/05	
THIOBENCARB	A-001	WAIVED	2008/07/01	.000		
TOXAPHENE	39400	108	2002/10/22	.000	2011/10	DUE
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2008/07/01	.000	2014/07	
1,1,2,2-TETRACHLOROETHANE	34516	072	2008/07/01	.000	2014/07	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2008/07/01	.000	2014/07	
1,1,2-TRICHLOROETHANE	34511	072	2008/07/01	.000	2014/07	
1,1-DICHLOROETHANE	34496	072	2008/07/01	.000	2014/07	
1,1-DICHLOROETHYLENE	34501	072	2008/07/01	.000	2014/07	
1,2,4-TRICHLOROBENZENE	34551	072	2008/07/01	.000	2014/07	
1,2-DICHLOROBENZENE	34536	072	2008/07/01	.000	2014/07	
1,2-DICHLOROETHANE	34531	072	2008/07/01	.000	2014/07	
1,2-DICHLOROPROPANE	34541	072	2008/07/01	.000	2014/07	
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2008/07/01	.000	2014/07	
1,4-DICHLOROBENZENE	34571	072	2008/07/01	.000	2014/07	
BENZENE	34030	072	2008/07/01	.000	2014/07	
CARBON TETRACHLORIDE	32102	072	2008/07/01	.000	2014/07	
CIS-1,2-DICHLOROETHYLENE	77093	072	2008/07/01	.000	2014/07	
DICHLOROMETHANE	34423	072	2008/07/01	.000	2014/07	
ETHYLBENZENE	34371	072	2008/07/01	.000	2014/07	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	036	2011/05/25	< .000	2014/05	
MONOCHLOROBENZENE	34301	072	2008/07/01	.000	2014/07	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800543***

System Name: ***CAPELL VALLEY ESTATES***

PS Code: ***2800543-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2008/07/01	.000	2014/07
TETRACHLOROETHYLENE	34475	072	2008/07/01	.000	2014/07
TOLUENE	34010	072	2008/07/01	.000	2014/07
TRANS-1,2-DICHLOROETHYLENE	34546	072	2008/07/01	.000	2014/07
TRICHLOROETHYLENE	39180	072	2008/07/01	.000	2014/07
TRICHLOROFLUOROMETHANE	34488	072	2008/07/01	.000	2014/07
VINYL CHLORIDE	39175	072	2008/07/01	.000	2014/07
XYLENES (TOTAL)	81551	072	2008/07/01	.000	2014/07
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED	2011/05/25	11.500	
BICARBONATE ALKALINITY	00440	012	2011/05/25	118.000	2012/05
CALCIUM	00916	012	2011/05/25	23.000	2012/05
CARBONATE ALKALINITY	00445	012	2011/05/25	< .000	2012/05
CHLORIDE	00940	012	2011/05/25	6.100	2012/05
COLOR	00081	012	2011/05/25	15.000	2012/05
COPPER	01042	012	2011/05/25	< .000	2012/05
FOAMING AGENTS (MBAS)	38260	012	2011/05/25	< .000	2012/05
HARDNESS (TOTAL) AS CACO3	00900	012	2011/05/25	95.000	2012/05
HYDROXIDE ALKALINITY	71830	012	2011/05/25	< .000	2012/05
IRON	01045	012	2011/05/25	< .000	2012/05
MAGNESIUM	00927	012	2011/05/25	9.300	2012/05
MANGANESE	01055	012	2011/05/25	33.400	2012/05
ODOR THRESHOLD @ 60 C	00086	012	2011/06/08	8.000	2012/06
PH, LABORATORY	00403	012	2011/05/25	7.800	2012/05
SILVER	01077	012	2011/05/25	< .000	2012/05
SODIUM	00929	012	2011/05/25	12.000	2012/05
SPECIFIC CONDUCTANCE	00095	012	2011/05/25	220.000	2012/05
SULFATE	00945	012	2011/05/25	15.000	2012/05
TOTAL DISSOLVED SOLIDS	70300	012	2011/05/25	130.000	2012/05

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800543***

System Name: ***CAPELL VALLEY ESTATES***

PS Code: ***2800543-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	012	2011/05/25	.930	2012/05
ZINC	01092	012	2011/05/25	< .000	2012/05

PS Code: ***2800543-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***SURFACE***

GENERAL NON CHAP 15		
DIAZINON	39570	WAIVED
INORGANIC		
ALUMINUM	01105	WAIVED
ANTIMONY	01097	WAIVED
ARSENIC	01002	WAIVED
ASBESTOS	81855	WAIVED
BARIUM	01007	WAIVED
BERYLLIUM	01012	WAIVED
CADMIUM	01027	WAIVED
CHROMIUM (TOTAL)	01034	WAIVED
CYANIDE	01291	WAIVED
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED
LEAD	01051	WAIVED
MERCURY	71900	WAIVED
NICKEL	01067	WAIVED
PERCHLORATE	A-031	WAIVED
SELENIUM	01147	WAIVED
THALLIUM	01059	WAIVED

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800543***

System Name: ***CAPELL VALLEY ESTATES***

PS Code: ***2800543-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800543***

System Name: ***CAPELL VALLEY ESTATES***

PS Code: ***2800543-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800543***

System Name: ***CAPELL VALLEY ESTATES***

PS Code: ***2800543-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800543***

System Name: ***CAPELL VALLEY ESTATES***

PS Code: ***2800543-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***SURFACE***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800548***

System Name: ***SILVERADO PINES MOBILE HOME***

PS Code: ***2800548-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2010/05/18	< .025		
INORGANIC						
ALUMINUM	01105	036	2010/05/18	< 50.000	2013/05	
ANTIMONY	01097	036	2010/05/18	< 6.000	2013/05	
ARSENIC	01002	036	2010/05/18	< 2.000	2013/05	
ASBESTOS	81855	108	2006/09/28	.000	2015/09	
BARIUM	01007	036	2010/05/18	< 100.000	2013/05	
BERYLLIUM	01012	036	2010/05/18	< 1.000	2013/05	
CADMIUM	01027	036	2010/05/18	< 1.000	2013/05	
CHROMIUM (TOTAL)	01034	036	2010/05/18	< 1.000	2013/05	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2010/05/18	.810	2013/05	
LEAD	01051	WAIVED	2003/10/29	< 5.000		
MERCURY	71900	036	2010/05/18	< 1.000	2013/05	
NICKEL	01067	036	2010/05/18	< 10.000	2013/05	
PERCHLORATE	A-031	036	2010/11/30	< 4.000	2013/11	
SELENIUM	01147	036	2010/05/18	< 5.000	2013/05	
THALLIUM	01059	036	2010/05/18	< 1.000	2013/05	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	**2010/05/18**	< 2.000	**2011/05**	**DUE**
NITRITE (AS N)	00620	036	2010/05/18	< 400.000	2013/05	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2011/02/28	.000	2020/02	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800548***

System Name: ***SILVERADO PINES MOBILE HOME***

PS Code: ***2800548-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	108	2010/05/18	.000	2019/05	
2,4-D	39730	108	2010/05/18	.000	2019/05	
ALACHLOR	77825	WAIVED	2010/05/18	.000		
ATRAZINE	39033	036	2010/05/18	.000	2013/05	
BENTAZON	38710	WAIVED	2010/05/18	.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2010/05/18	.000	2013/05	
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2010/05/18	.000	2013/05	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED	1999/06/30	.000		
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED	1999/06/30	.000		
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	036	2010/05/18	.000	2013/05	
DIQUAT	78885	036	2010/05/18	.000	2013/05	
ENDOTHALL	38926	036	2010/05/18	.000	2013/05	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	108	1999/06/30	.000	2008/06	DUE
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				DUE
HEPTACHLOR EPOXIDE	39420	000				DUE
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800548***

System Name: ***SILVERADO PINES MOBILE HOME***

PS Code: ***2800548-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	000				**DUE**
MOLINATE	82199	WAIVED	2010/05/18	.000		
OXAMYL	38865	036	2010/05/18	.000	2013/05	
PENTACHLOROPHENOL	39032	036	2010/05/18	.000	2013/05	
PICLORAM	39720	036	2010/05/18	.000	2013/05	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2010/05/18	.000	2013/05	
THIOBENCARB	A-001	WAIVED	2010/05/18	.000		
TOXAPHENE	39400	000				**DUE**
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2010/05/18	.000	2016/05	
1,1,2,2-TETRACHLOROETHANE	34516	072	2010/05/18	.000	2016/05	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2010/05/18	.000	2016/05	
1,1,2-TRICHLOROETHANE	34511	072	2010/05/18	.000	2016/05	
1,1-DICHLOROETHANE	34496	072	2010/05/18	.000	2016/05	
1,1-DICHLOROETHYLENE	34501	072	2010/05/18	.000	2016/05	
1,2,4-TRICHLOROBENZENE	34551	072	2010/05/18	.000	2016/05	
1,2-DICHLOROBENZENE	34536	072	2010/05/18	.000	2016/05	
1,2-DICHLOROETHANE	34531	072	2010/05/18	.000	2016/05	
1,2-DICHLOROPROPANE	34541	072	2010/05/18	.000	2016/05	
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2010/05/18	.000	2016/05	
1,4-DICHLOROBENZENE	34571	072	2010/05/18	.000	2016/05	
BENZENE	34030	072	2010/05/18	.000	2016/05	
CARBON TETRACHLORIDE	32102	072	2010/05/18	.000	2016/05	
CIS-1,2-DICHLOROETHYLENE	77093	072	2010/05/18	.000	2016/05	
DICHLOROMETHANE	34423	072	2010/05/18	.000	2016/05	
ETHYLBENZENE	34371	072	2010/05/18	.000	2016/05	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	036	2010/05/18	.000	2013/05	
MONOCHLOROBENZENE	34301	072	2010/05/18	.000	2016/05	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800548***

System Name: ***SILVERADO PINES MOBILE HOME***

PS Code: ***2800548-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2010/05/18	.000	2016/05
TETRACHLOROETHYLENE	34475	072	2010/05/18	.000	2016/05
TOLUENE	34010	072	2010/05/18	.000	2016/05
TRANS-1,2-DICHLOROETHYLENE	34546	072	2010/05/18	.000	2016/05
TRICHLOROETHYLENE	39180	072	2010/05/18	.000	2016/05
TRICHLOROFLUOROMETHANE	34488	072	2010/05/18	.000	2016/05
VINYL CHLORIDE	39175	072	2010/05/18	.000	2016/05
XYLENES (TOTAL)	81551	072	2010/05/18	.000	2016/05
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED	2010/05/18	11.800	
BICARBONATE ALKALINITY	00440	036	2010/05/18	260.000	2013/05
CALCIUM	00916	036	2010/05/18	8.600	2013/05
CARBONATE ALKALINITY	00445	036	2010/05/18	< 1.000	2013/05
CHLORIDE	00940	036	2010/05/18	37.000	2013/05
COLOR	00081	036	2010/05/18	< 3.000	2013/05
COPPER	01042	036	2010/05/18	< 50.000	2013/05
FOAMING AGENTS (MBAS)	38260	036	2010/05/18	< .050	2013/05
HARDNESS (TOTAL) AS CACO3	00900	036	2010/05/18	31.000	2013/05
HYDROXIDE ALKALINITY	71830	036	2010/05/18	< 1.000	2013/05
IRON	01045	036	2010/05/18	< 100.000	2013/05
MAGNESIUM	00927	036	2010/05/18	2.300	2013/05
MANGANESE	01055	036	2010/05/18	< 20.000	2013/05
ODOR THRESHOLD @ 60 C	00086	036	2010/05/18	8.000	2013/05
PH, LABORATORY	00403	036	2010/05/18	8.100	2013/05
SILVER	01077	036	2010/05/18	< 10.000	2013/05
SODIUM	00929	036	2010/05/18	95.000	2013/05
SPECIFIC CONDUCTANCE	00095	036	2010/05/18	530.000	2013/05
SULFATE	00945	036	2010/05/18	3.100	2013/05
TOTAL DISSOLVED SOLIDS	70300	036	2010/05/18	370.000	2013/05

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800548***

System Name: ***SILVERADO PINES MOBILE HOME***

PS Code: ***2800548-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	036	2010/05/18	.420	2013/05
ZINC	01092	036	2010/05/18	< 50.000	2013/05

PS Code: ***2800548-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	000			DUE
ANTIMONY	01097	000			DUE
ARSENIC	01002	000			DUE
ASBESTOS	81855	000			DUE
BARIUM	01007	000			DUE
BERYLLIUM	01012	000			DUE
CADMIUM	01027	000			DUE
CHROMIUM (TOTAL)	01034	000			DUE
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	000			DUE
LEAD	01051	WAIVED			
MERCURY	71900	000			DUE
NICKEL	01067	000			DUE
PERCHLORATE	A-031	000			DUE
SELENIUM	01147	000			DUE
THALLIUM	01059	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800548
System Name: SILVERADO PINES MOBILE HOME

PS Code: 2800548-002
Source Name: WELL #2
Source Number: 002
Source Status: STANDBY UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	000			DUE
NITRITE (AS N)	00620	000			DUE
RADIOLOGICAL					
GROSS ALPHA	01501	000			DUE
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	000			DUE
2,4-D	39730	000			DUE
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	000			DUE
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	000			DUE
CHLORDANE	39350	WAIVED			
DALAPON	38432	000			DUE
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	000			DUE
DIQUAT	78885	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800548***

System Name: ***SILVERADO PINES MOBILE HOME***

PS Code: ***2800548-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	000			DUE
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	000			DUE
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	000			DUE
HEPTACHLOR EPOXIDE	39420	000			DUE
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	000			DUE
METHOXYCHLOR	39480	000			DUE
MOLINATE	82199	WAIVED			
OXAMYL	38865	000			DUE
PENTACHLOROPHENOL	39032	000			DUE
PICLORAM	39720	000			DUE
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	000			DUE
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	000			DUE
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	000			DUE
1,1,2,2-TETRACHLOROETHANE	34516	000			DUE
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	000			DUE
1,1,2-TRICHLOROETHANE	34511	000			DUE
1,1-DICHLOROETHANE	34496	000			DUE
1,1-DICHLOROETHYLENE	34501	000			DUE
1,2,4-TRICHLOROBENZENE	34551	000			DUE
1,2-DICHLOROBENZENE	34536	000			DUE
1,2-DICHLOROETHANE	34531	000			DUE
1,2-DICHLOROPROPANE	34541	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800548***

System Name: ***SILVERADO PINES MOBILE HOME***

PS Code: ***2800548-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	000			DUE
1,4-DICHLOROBENZENE	34571	000			DUE
BENZENE	34030	000			DUE
CARBON TETRACHLORIDE	32102	000			DUE
CIS-1,2-DICHLOROETHYLENE	77093	000			DUE
DICHLOROMETHANE	34423	000			DUE
ETHYLBENZENE	34371	000			DUE
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	000			DUE
MONOCHLOROBENZENE	34301	000			DUE
STYRENE	77128	000			DUE
TETRACHLOROETHYLENE	34475	000			DUE
TOLUENE	34010	000			DUE
TRANS-1,2-DICHLOROETHYLENE	34546	000			DUE
TRICHLOROETHYLENE	39180	000			DUE
TRICHLOROFLUOROMETHANE	34488	000			DUE
VINYL CHLORIDE	39175	000			DUE
XYLENES (TOTAL)	81551	000			DUE
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	000			DUE
COLOR	00081	000			DUE
COPPER	01042	000			DUE
FOAMING AGENTS (MBAS)	38260	000			DUE
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800548***

System Name: ***SILVERADO PINES MOBILE HOME***

PS Code: ***2800548-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	000			DUE
PH, LABORATORY	00403	000			DUE
SILVER	01077	000			DUE
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	000			DUE
SULFATE	00945	000			DUE
TOTAL DISSOLVED SOLIDS	70300	000			DUE
TURBIDITY, LABORATORY	82079	000			DUE
ZINC	01092	000			DUE

PS Code: ***2800548-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED

INORGANIC

ALUMINUM	01105	WAIVED
ANTIMONY	01097	WAIVED
ARSENIC	01002	WAIVED
ASBESTOS	81855	WAIVED
BARIUM	01007	WAIVED
BERYLLIUM	01012	WAIVED
CADMIUM	01027	WAIVED
CHROMIUM (TOTAL)	01034	WAIVED
CYANIDE	01291	WAIVED

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800548***

System Name: ***SILVERADO PINES MOBILE HOME***

PS Code: ***2800548-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800548***

System Name: ***SILVERADO PINES MOBILE HOME***

PS Code: ***2800548-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800548***

System Name: ***SILVERADO PINES MOBILE HOME***

PS Code: ***2800548-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800548***

System Name: ***SILVERADO PINES MOBILE HOME***

PS Code: ***2800548-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800554***

System Name: ***GENE NORRIS PLAZA***

PS Code: ***2800554-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED	2003/02/13	.000	
ANTIMONY	01097	WAIVED	2003/02/13	.000	
ARSENIC	01002	WAIVED	2003/02/13	3.000	
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED	2003/02/13	100.000	
BERYLLIUM	01012	WAIVED	2003/02/13	.000	
CADMIUM	01027	WAIVED	2003/02/13	.000	
CHROMIUM (TOTAL)	01034	WAIVED	2003/02/13	.000	
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2003/02/13	.300	
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED	2003/02/13	.000	
NICKEL	01067	WAIVED	2003/02/13	.000	
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED	2003/02/13	.000	
THALLIUM	01059	WAIVED	2003/02/13	.000	
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2012/04/17	< .000	2013/04
NITRITE (AS N)	00620	036	2011/04/21	< .000	2014/04
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800554***

System Name: ***GENE NORRIS PLAZA***

PS Code: ***2800554-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800554***

System Name: ***GENE NORRIS PLAZA***

PS Code: ***2800554-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800554***

System Name: ***GENE NORRIS PLAZA***

PS Code: ***2800554-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800554***

System Name: ***GENE NORRIS PLAZA***

PS Code: ***2800554-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800555***

System Name: ***TWOMEY CELLARS***

PS Code: ***2800555-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED	2009/02/18	.000		
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2012/01/05	< .000	2013/01	
NITRITE (AS N)	00620	036	2011/01/10	.000	2014/01	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800555***

System Name: ***TWOMEY CELLARS***

PS Code: ***2800555-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800555***

System Name: ***TWOMEY CELLARS***

PS Code: ***2800555-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800555***

System Name: ***TWOMEY CELLARS***

PS Code: ***2800555-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800555***

System Name: ***TWOMEY CELLARS***

PS Code: ***2800555-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800555-004***

Source Name: ***TREATMENT PLANT***

Source Number: ***004***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800555***

System Name: ***TWOMEY CELLARS***

PS Code: ***2800555-004***

Source Name: ***TREATMENT PLANT***

Source Number: ***004***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800555***

System Name: ***TWOMEY CELLARS***

PS Code: ***2800555-004***

Source Name: ***TREATMENT PLANT***

Source Number: ***004***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800555***

System Name: ***TWOMEY CELLARS***

PS Code: ***2800555-004***

Source Name: ***TREATMENT PLANT***

Source Number: ***004***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800555***

System Name: ***TWOMEY CELLARS***

PS Code: ***2800555-004***

Source Name: ***TREATMENT PLANT***

Source Number: ***004***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800556***

System Name: ***BROKEN HILL 1 LLC***

PS Code: ***2800556-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2010/06/09	< .025		
INORGANIC						
ALUMINUM	01105	036	2007/03/16	< 50.000	2010/03	DUE
ANTIMONY	01097	036	2007/03/16	< 6.000	2010/03	DUE
ARSENIC	01002	036	2007/03/16	< 2.000	2010/03	DUE
ASBESTOS	81855	108	2006/10/17	.000	2015/10	
BARIUM	01007	036	2007/03/16	< 100.000	2010/03	DUE
BERYLLIUM	01012	036	2007/03/16	< 1.000	2010/03	DUE
CADMIUM	01027	036	2007/03/16	< 1.000	2010/03	DUE
CHROMIUM (TOTAL)	01034	036	2007/03/16	< 1.000	2010/03	DUE
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2007/03/16	.390	2010/03	DUE
LEAD	01051	WAIVED	2007/03/16	< 5.000		
MERCURY	71900	036	2007/03/16	< 1.000	2010/03	DUE
NICKEL	01067	036	2007/03/16	< 5.000	2010/03	DUE
PERCHLORATE	A-031	036	2011/10/12	< 4.000	2014/10	
SELENIUM	01147	036	2007/03/16	< 5.000	2010/03	DUE
THALLIUM	01059	036	2007/03/16	< 1.000	2010/03	DUE
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/10/12	4.700	2012/10	
NITRITE (AS N)	00620	036	2007/03/16	< 400.000	2010/03	DUE
RADIOLOGICAL						
GROSS ALPHA	01501	108	2008/12/03	.596	2017/12	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800556***

System Name: ***BROKEN HILL 1 LLC***

PS Code: ***2800556-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2010/06/09	.000	
2,4-D	39730	WAIVED	2010/06/09	.000	
ALACHLOR	77825	WAIVED	2010/06/09	.000	
ATRAZINE	39033	036	2010/06/09	.000	2013/06
BENTAZON	38710	WAIVED	2010/06/09	.000	
BENZO (A) PYRENE	34247	WAIVED	2006/10/17	< .100	
CARBOFURAN	81405	036	2010/06/09	.000	2013/06
CHLORDANE	39350	WAIVED	2002/10/03	.000	
DALAPON	38432	036	2010/06/09	.000	2013/06
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED	2006/10/17	< 1.000	
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED	2006/10/17	< 3.000	
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2002/10/03	.000	
DINOSEB	81287	036	2010/06/09	.000	2013/06
DIQUAT	78885	036	2010/06/09	.000	2013/06
ENDOTHALL	38926	036	2010/06/09	.000	2013/06
ENDRIN	39390	WAIVED	2006/10/17	< 1.000	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2002/10/03	.000	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2006/10/17	< .100	
HEPTACHLOR EPOXIDE	39420	WAIVED	2006/10/17	< .100	
HEXACHLOROBENZENE	39700	WAIVED	2006/10/17	< .100	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2006/10/17	< 3.000	
LINDANE	39340	WAIVED	2006/10/17	< .100	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800556***

System Name: ***BROKEN HILL 1 LLC***

PS Code: ***2800556-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED	2006/10/17	< .300	
MOLINATE	82199	WAIVED	2010/06/09	.000	
OXAMYL	38865	036	2010/06/09	.000	2013/06
PENTACHLOROPHENOL	39032	036	2010/06/09	.000	2013/06
PICLORAM	39720	036	2010/06/09	.000	2013/06
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2002/10/03	.000	
SIMAZINE	39055	036	2010/06/09	.000	2013/06
THIOBENCARB	A-001	WAIVED	2010/06/09	.000	
TOXAPHENE	39400	WAIVED	2006/10/17	< 5.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	072	2009/01/07	.000	2015/01
1,1,2,2-TETRACHLOROETHANE	34516	072	2009/01/07	.000	2015/01
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2009/01/07	.000	2015/01
1,1,2-TRICHLOROETHANE	34511	072	2009/01/07	.000	2015/01
1,1-DICHLOROETHANE	34496	072	2009/01/07	.000	2015/01
1,1-DICHLOROETHYLENE	34501	072	2009/01/07	.000	2015/01
1,2,4-TRICHLOROBENZENE	34551	072	2009/01/07	.000	2015/01
1,2-DICHLOROBENZENE	34536	072	2009/01/07	.000	2015/01
1,2-DICHLOROETHANE	34531	072	2009/01/07	.000	2015/01
1,2-DICHLOROPROPANE	34541	072	2009/01/07	.000	2015/01
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2009/01/07	.000	2015/01
1,4-DICHLOROBENZENE	34571	072	2009/01/07	.000	2015/01
BENZENE	34030	072	2009/01/07	.000	2015/01
CARBON TETRACHLORIDE	32102	072	2009/01/07	.000	2015/01
CIS-1,2-DICHLOROETHYLENE	77093	072	2009/01/07	.000	2015/01
DICHLOROMETHANE	34423	072	2009/01/07	.000	2015/01
ETHYLBENZENE	34371	072	2009/01/07	.000	2015/01
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2009/01/07	.000	2015/01
MONOCHLOROBENZENE	34301	072	2009/01/07	.000	2015/01

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800556***

System Name: ***BROKEN HILL 1 LLC***

PS Code: ***2800556-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2009/01/07	.000	2015/01
TETRACHLOROETHYLENE	34475	072	2009/01/07	.000	2015/01
TOLUENE	34010	072	2009/01/07	.000	2015/01
TRANS-1,2-DICHLOROETHYLENE	34546	072	2009/01/07	.000	2015/01
TRICHLOROETHYLENE	39180	072	2009/01/07	.000	2015/01
TRICHLOROFLUOROMETHANE	34488	072	2009/01/07	.000	2015/01
VINYL CHLORIDE	39175	072	2009/01/07	.000	2015/01
XYLENES (TOTAL)	81551	072	2009/01/07	.000	2015/01
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2007/03/16	250.000	
CALCIUM	00916	WAIVED	2007/03/16	31.000	
CARBONATE ALKALINITY	00445	WAIVED	2007/03/16	< 1.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2007/03/16	160.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2007/03/16	< 1.000	
IRON	01045	WAIVED	2007/03/16	< 100.000	
MAGNESIUM	00927	WAIVED	2007/03/16	21.000	
MANGANESE	01055	WAIVED	2007/03/16	< 20.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2007/03/16	8.100	
SILVER	01077	WAIVED	2007/03/16	< 10.000	
SODIUM	00929	WAIVED	2007/03/16	45.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800556***

System Name: ***BROKEN HILL 1 LLC***

PS Code: ***2800556-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800556-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800556***

System Name: ***BROKEN HILL 1 LLC***

PS Code: ***2800556-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800556***

System Name: ***BROKEN HILL 1 LLC***

PS Code: ***2800556-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800556***

System Name: ***BROKEN HILL 1 LLC***

PS Code: ***2800556-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800556***

System Name: ***BROKEN HILL 1 LLC***

PS Code: ***2800556-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800557***

System Name: ***CASTLE TROVE, INC.***

PS Code: ***2800557-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2009/01/16	.000	2010/01	**DUE**
NITRITE (AS N)	00620	036	2008/02/27	.000	2011/02	**DUE**
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800557***

System Name: ***CASTLE TROVE, INC.***

PS Code: ***2800557-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800557***

System Name: ***CASTLE TROVE, INC.***

PS Code: ***2800557-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800557***

System Name: ***CASTLE TROVE, INC.***

PS Code: ***2800557-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800557***

System Name: ***CASTLE TROVE, INC.***

PS Code: ***2800557-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED	2004/09/20	1.500	
ZINC	01092	WAIVED			

PS Code: ***2800557-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800557***

System Name: ***CASTLE TROVE, INC.***

PS Code: ***2800557-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800557***

System Name: ***CASTLE TROVE, INC.***

PS Code: ***2800557-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800557***

System Name: ***CASTLE TROVE, INC.***

PS Code: ***2800557-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800557***

System Name: ***CASTLE TROVE, INC.***

PS Code: ***2800557-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800561***

System Name: ***FREEMARK ABBEY PROPERTIES***

PS Code: ***2800561-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED	2008/06/19	.000	
INORGANIC					
ALUMINUM	01105	036	2011/04/26	< .000	2014/04
ANTIMONY	01097	036	2011/04/26	< .000	2014/04
ARSENIC	01002	036	2011/04/26	36.000	2014/04
ASBESTOS	81855	108	2008/06/19	.000	2017/06
BARIUM	01007	036	2011/04/26	< .000	2014/04
BERYLLIUM	01012	036	2011/04/26	< .000	2014/04
CADMIUM	01027	036	2011/04/26	< .000	2014/04
CHROMIUM (TOTAL)	01034	036	2011/04/26	< .000	2014/04
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2011/04/26	.110	2014/04
LEAD	01051	WAIVED	2011/04/26	< .000	
MERCURY	71900	036	2011/04/26	< .000	2014/04
NICKEL	01067	036	2011/04/26	< .000	2014/04
PERCHLORATE	A-031	036	2009/05/21	.000	2012/05
SELENIUM	01147	036	2011/04/26	< .000	2014/04
THALLIUM	01059	036	2011/04/26	< .000	2014/04
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2012/04/19	2.600	2013/04
NITRITE (AS N)	00620	036	2012/04/19	< .000	2015/04
RADIOLOGICAL					
GROSS ALPHA	01501	108	2009/07/16	2.820	2018/07
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800561***

System Name: ***FREEMARK ABBEY PROPERTIES***

PS Code: ***2800561-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2011/04/26	< 1.000	
2,4-D	39730	WAIVED	2011/04/26	< 10.000	
ALACHLOR	77825	WAIVED	2008/06/19	.000	
ATRAZINE	39033	036	2011/04/26	< .500	2014/04
BENTAZON	38710	WAIVED	2011/04/26	< 2.000	
BENZO (A) PYRENE	34247	WAIVED	2002/02/07	.000	
CARBOFURAN	81405	036	2011/04/26	< 5.000	2014/04
CHLORDANE	39350	WAIVED	2002/02/07	.000	
DALAPON	38432	036	2011/04/26	< 10.000	2014/04
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED	2002/02/07	.000	
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED	2002/02/07	.000	
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2008/06/19	.000	
DINOSEB	81287	036	2011/04/26	< 2.000	2014/04
DIQUAT	78885	036	2011/04/26	< 4.000	2014/04
ENDOTHALL	38926	036	2011/04/26	< 45.000	2014/04
ENDRIN	39390	WAIVED	2002/02/07	.000	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2008/06/19	.000	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2002/02/07	.000	
HEPTACHLOR EPOXIDE	39420	WAIVED	2002/02/07	.000	
HEXACHLOROBENZENE	39700	WAIVED	2002/02/07	.000	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2002/02/07	.000	
LINDANE	39340	WAIVED	2002/02/07	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800561***

System Name: ***FREEMARK ABBEY PROPERTIES***

PS Code: ***2800561-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED	2002/02/07	.000	
MOLINATE	82199	WAIVED	2008/06/19	.000	
OXAMYL	38865	036	2011/04/26	< 20.000	2014/04
PENTACHLOROPHENOL	39032	036	2011/04/26	< .200	2014/04
PICLORAM	39720	036	2011/04/26	< 1.000	2014/04
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2002/02/07	.000	
SIMAZINE	39055	036	2011/04/26	< 1.000	2014/04
THIOBENCARB	A-001	WAIVED	2008/06/19	.000	
TOXAPHENE	39400	WAIVED	2002/02/07	.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	072	2008/06/19	.000	2014/06
1,1,2,2-TETRACHLOROETHANE	34516	072	2008/06/19	.000	2014/06
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2008/06/19	.000	2014/06
1,1,2-TRICHLOROETHANE	34511	072	2008/06/19	.000	2014/06
1,1-DICHLOROETHANE	34496	072	2008/06/19	.000	2014/06
1,1-DICHLOROETHYLENE	34501	072	2008/06/19	.000	2014/06
1,2,4-TRICHLOROBENZENE	34551	072	2008/06/19	.000	2014/06
1,2-DICHLOROBENZENE	34536	072	2008/06/19	.000	2014/06
1,2-DICHLOROETHANE	34531	072	2008/06/19	.000	2014/06
1,2-DICHLOROPROPANE	34541	072	2008/06/19	.000	2014/06
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2008/06/19	.000	2014/06
1,4-DICHLOROBENZENE	34571	072	2008/06/19	.000	2014/06
BENZENE	34030	072	2008/06/19	.000	2014/06
CARBON TETRACHLORIDE	32102	072	2008/06/19	.000	2014/06
CIS-1,2-DICHLOROETHYLENE	77093	072	2008/06/19	.000	2014/06
DICHLOROMETHANE	34423	072	2008/06/19	.000	2014/06
ETHYLBENZENE	34371	072	2008/06/19	.000	2014/06
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2008/06/19	.000	2014/06
MONOCHLOROBENZENE	34301	072	2008/06/19	.000	2014/06

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800561***

System Name: ***FREEMARK ABBEY PROPERTIES***

PS Code: ***2800561-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2008/06/19	.000	2014/06
TETRACHLOROETHYLENE	34475	072	2008/06/19	.000	2014/06
TOLUENE	34010	072	2008/06/19	.000	2014/06
TRANS-1,2-DICHLOROETHYLENE	34546	072	2008/06/19	.000	2014/06
TRICHLOROETHYLENE	39180	072	2008/06/19	.000	2014/06
TRICHLOROFLUOROMETHANE	34488	072	2008/06/19	.000	2014/06
VINYL CHLORIDE	39175	072	2008/06/19	.000	2014/06
XYLENES (TOTAL)	81551	072	2008/06/19	.000	2014/06
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2009/05/21	160.000	
CALCIUM	00916	WAIVED	2009/05/21	14.000	
CARBONATE ALKALINITY	00445	WAIVED	2009/05/21	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2009/05/21	80.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2009/05/21	.000	
IRON	01045	WAIVED	2009/05/21	.000	
MAGNESIUM	00927	WAIVED	2009/05/21	9.500	
MANGANESE	01055	WAIVED	2009/05/21	100.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2009/05/21	7.300	
SILVER	01077	WAIVED	2011/04/26	< .000	
SODIUM	00929	WAIVED	2009/05/21	30.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800561***

System Name: ***FREEMARK ABBEY PROPERTIES***

PS Code: ***2800561-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
SECONDARY/GP						
TURBIDITY, LABORATORY	82079	WAIVED				
ZINC	01092	WAIVED				

PS Code: ***2800561-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2008/06/19	.000		
INORGANIC						
ALUMINUM	01105	036	2011/04/26	< .000	2014/04	
ANTIMONY	01097	036	2011/04/26	< .000	2014/04	
ARSENIC	01002	036	2011/04/26	3.000	2014/04	
ASBESTOS	81855	000				**DUE**
BARIUM	01007	036	2011/04/26	< .000	2014/04	
BERYLLIUM	01012	036	2011/04/26	< .000	2014/04	
CADMIUM	01027	036	2011/04/26	< .000	2014/04	
CHROMIUM (TOTAL)	01034	036	2011/04/26	< .000	2014/04	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2011/04/26	< .000	2014/04	
LEAD	01051	WAIVED	2011/04/26	< .000		
MERCURY	71900	036	2011/04/26	< .000	2014/04	
NICKEL	01067	036	2011/04/26	< .000	2014/04	
PERCHLORATE	A-031	036	2009/05/21	.000	2012/05	
SELENIUM	01147	036	2011/04/26	< .000	2014/04	
THALLIUM	01059	036	2011/04/26	< .000	2014/04	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800561
System Name: FREEMARK ABBEY PROPERTIES

PS Code: 2800561-002
Source Name: WELL #2
Source Number: 002
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2012/04/19	< .000	2013/04
NITRITE (AS N)	00620	036	2012/04/19	< .000	2015/04
RADIOLOGICAL					
GROSS ALPHA	01501	108	2011/04/26	1.270	2020/04
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2011/04/26	< 1.000	
2,4-D	39730	WAIVED	2011/04/26	< 10.000	
ALACHLOR	77825	WAIVED	2008/06/19	.000	
ATRAZINE	39033	036	2011/04/26	< .500	2014/04
BENTAZON	38710	WAIVED	2011/04/26	< 2.000	
BENZO (A) PYRENE	34247	WAIVED	2002/02/07	.000	
CARBOFURAN	81405	036	2011/04/26	< 5.000	2014/04
CHLORDANE	39350	WAIVED	2002/02/07	.000	
DALAPON	38432	036	2011/04/26	< 10.000	2014/04
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED	2002/02/07	.000	
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED	2002/02/07	.000	
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2008/06/19	.000	
DINOSEB	81287	036	2011/04/26	< 2.000	2014/04
DIQUAT	78885	036	2011/04/26	< 4.000	2014/04

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800561
System Name: FREEMARK ABBEY PROPERTIES

PS Code: 2800561-002
Source Name: WELL #2
Source Number: 002
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	036	2011/04/26	< 45.000	2014/04
ENDRIN	39390	WAIVED	2002/02/07	.000	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2008/06/19	.000	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2002/02/07	.000	
HEPTACHLOR EPOXIDE	39420	WAIVED	2002/02/07	.000	
HEXACHLOROBENZENE	39700	WAIVED	2002/02/07	.000	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2002/02/07	.000	
LINDANE	39340	WAIVED	2002/02/07	.000	
METHOXYCHLOR	39480	WAIVED	2002/02/07	.000	
MOLINATE	82199	WAIVED	2008/06/19	.000	
OXAMYL	38865	036	2011/04/26	< 20.000	2014/04
PENTACHLOROPHENOL	39032	036	2011/04/26	< .200	2014/04
PICLORAM	39720	036	2011/04/26	< 1.000	2014/04
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2002/02/07	.000	
SIMAZINE	39055	036	2011/04/26	< 1.000	2014/04
THIOBENCARB	A-001	WAIVED	2008/06/19	.000	
TOXAPHENE	39400	WAIVED	2002/02/07	.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	072	2008/06/19	.000	2014/06
1,1,2,2-TETRACHLOROETHANE	34516	072	2008/06/19	.000	2014/06
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2008/06/19	.000	2014/06
1,1,2-TRICHLOROETHANE	34511	072	2008/06/19	.000	2014/06
1,1-DICHLOROETHANE	34496	072	2008/06/19	.000	2014/06
1,1-DICHLOROETHYLENE	34501	072	2008/06/19	.000	2014/06
1,2,4-TRICHLOROBENZENE	34551	072	2008/06/19	.000	2014/06
1,2-DICHLOROBENZENE	34536	072	2008/06/19	.000	2014/06
1,2-DICHLOROETHANE	34531	072	2008/06/19	.000	2014/06
1,2-DICHLOROPROPANE	34541	072	2008/06/19	.000	2014/06

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800561***

System Name: ***FREEMARK ABBEY PROPERTIES***

PS Code: ***2800561-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2008/06/19	.000	2014/06
1,4-DICHLOROBENZENE	34571	072	2008/06/19	.000	2014/06
BENZENE	34030	072	2008/06/19	.000	2014/06
CARBON TETRACHLORIDE	32102	072	2008/06/19	.000	2014/06
CIS-1,2-DICHLOROETHYLENE	77093	072	2008/06/19	.000	2014/06
DICHLOROMETHANE	34423	072	2008/06/19	.000	2014/06
ETHYLBENZENE	34371	072	2008/06/19	.000	2014/06
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2008/06/19	.000	2014/06
MONOCHLOROBENZENE	34301	072	2008/06/19	.000	2014/06
STYRENE	77128	072	2008/06/19	.000	2014/06
TETRACHLOROETHYLENE	34475	072	2008/06/19	.000	2014/06
TOLUENE	34010	072	2008/06/19	.000	2014/06
TRANS-1,2-DICHLOROETHYLENE	34546	072	2008/06/19	.000	2014/06
TRICHLOROETHYLENE	39180	072	2008/06/19	.000	2014/06
TRICHLOROFLUOROMETHANE	34488	072	2008/06/19	.000	2014/06
VINYL CHLORIDE	39175	072	2008/06/19	.000	2014/06
XYLENES (TOTAL)	81551	072	2008/06/19	.000	2014/06
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2009/05/21	150.000	
CALCIUM	00916	WAIVED	2011/04/26	22.000	
CARBONATE ALKALINITY	00445	WAIVED	2009/05/21	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2009/05/21	100.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2009/05/21	.000	
IRON	01045	WAIVED	2009/05/21	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800561***

System Name: ***FREEMARK ABBEY PROPERTIES***

PS Code: ***2800561-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
MAGNESIUM	00927	WAIVED	2011/04/26	12.000	
MANGANESE	01055	WAIVED	2009/05/21	.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2011/04/26	6.600	
SILVER	01077	WAIVED	2011/04/26	< .000	
SODIUM	00929	WAIVED	2011/04/26	16.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800561-003***

Source Name: ***WELL #3***

Source Number: ***003***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED	2008/06/19	.000	
INORGANIC					
ALUMINUM	01105	108	2008/06/19	.000	2017/06
ANTIMONY	01097	108	2008/06/19	.000	2017/06
ARSENIC	01002	108	2008/06/19	30.000	2017/06
ASBESTOS	81855	108	2008/06/19	.000	2017/06
BARIUM	01007	108	2008/06/19	.000	2017/06
BERYLLIUM	01012	108	2008/06/19	.000	2017/06
CADMIUM	01027	108	2008/06/19	.000	2017/06
CHROMIUM (TOTAL)	01034	108	2008/06/19	.000	2017/06
CYANIDE	01291	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800561***

System Name: ***FREEMARK ABBEY PROPERTIES***

PS Code: ***2800561-003***

Source Name: ***WELL #3***

Source Number: ***003***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	108	2008/06/19	.000	2017/06
LEAD	01051	WAIVED	2008/06/19	.000	
MERCURY	71900	108	2008/06/19	.000	2017/06
NICKEL	01067	108	2008/06/19	.000	2017/06
PERCHLORATE	A-031	108	2011/04/26	< .000	2020/04
SELENIUM	01147	108	2008/06/19	.000	2017/06
THALLIUM	01059	108	2008/06/19	.000	2017/06
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	108	2008/06/19	.000	2017/06
NITRITE (AS N)	00620	108	2008/06/19	.000	2017/06
RADIOLOGICAL					
GROSS ALPHA	01501	108	2008/11/19	1.180	2017/11
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2008/06/19	.000	
2,4-D	39730	WAIVED	2008/06/19	.000	
ALACHLOR	77825	WAIVED	2008/06/19	.000	
ATRAZINE	39033	WAIVED	2008/06/19	.000	
BENTAZON	38710	WAIVED	2008/06/19	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800561
System Name: FREEMARK ABBEY PROPERTIES

PS Code: 2800561-003
Source Name: WELL #3
Source Number: 003
Source Status: STANDBY UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED	2002/02/07	.000	
CARBOFURAN	81405	WAIVED	2008/06/19	.000	
CHLORDANE	39350	WAIVED	2004/11/16	.000	
DALAPON	38432	WAIVED	2008/06/19	.000	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED	2002/02/07	.000	
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED	2002/02/07	.000	
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2008/06/19	.000	
DINOSEB	81287	WAIVED	2008/06/19	.000	
DIQUAT	78885	WAIVED	2008/06/19	.000	
ENDOTHALL	38926	WAIVED	2008/06/19	.000	
ENDRIN	39390	WAIVED	2004/11/16	.000	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2008/06/19	.000	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2004/11/16	.000	
HEPTACHLOR EPOXIDE	39420	WAIVED	2004/11/16	.000	
HEXACHLOROBENZENE	39700	WAIVED	2004/11/16	.000	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2004/11/16	.000	
LINDANE	39340	WAIVED	2004/11/16	.000	
METHOXYCHLOR	39480	WAIVED	2004/11/16	.000	
MOLINATE	82199	WAIVED	2008/06/19	.000	
OXAMYL	38865	WAIVED	2008/06/19	.000	
PENTACHLOROPHENOL	39032	WAIVED	2008/06/19	.000	
PICLORAM	39720	WAIVED	2008/06/19	.000	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2004/11/16	.000	
SIMAZINE	39055	WAIVED	2008/06/19	.000	
THIOBENCARB	A-001	WAIVED	2008/06/19	.000	
TOXAPHENE	39400	WAIVED	2004/11/16	.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED	2008/06/19	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800561
System Name: FREEMARK ABBEY PROPERTIES

PS Code: 2800561-003
Source Name: WELL #3
Source Number: 003
Source Status: STANDBY UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED	2008/06/19	.000	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED	2008/06/19	.000	
1,1,2-TRICHLOROETHANE	34511	WAIVED	2008/06/19	.000	
1,1-DICHLOROETHANE	34496	WAIVED	2008/06/19	.000	
1,1-DICHLOROETHYLENE	34501	WAIVED	2008/06/19	.000	
1,2,4-TRICHLOROBENZENE	34551	WAIVED	2008/06/19	.000	
1,2-DICHLOROBENZENE	34536	WAIVED	2008/06/19	.000	
1,2-DICHLOROETHANE	34531	WAIVED	2008/06/19	.000	
1,2-DICHLOROPROPANE	34541	WAIVED	2008/06/19	.000	
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED	2008/06/19	.000	
1,4-DICHLOROBENZENE	34571	WAIVED	2008/06/19	.000	
BENZENE	34030	WAIVED	2008/06/19	.000	
CARBON TETRACHLORIDE	32102	WAIVED	2008/06/19	.000	
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED	2008/06/19	.000	
DICHLOROMETHANE	34423	WAIVED	2008/06/19	.000	
ETHYLBENZENE	34371	WAIVED	2008/06/19	.000	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	108	2008/06/19	.000	2017/06
MONOCHLOROBENZENE	34301	WAIVED	2008/06/19	.000	
STYRENE	77128	WAIVED	2008/06/19	.000	
TETRACHLOROETHYLENE	34475	WAIVED	2008/06/19	.000	
TOLUENE	34010	WAIVED	2008/06/19	.000	
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED	2008/06/19	.000	
TRICHLOROETHYLENE	39180	WAIVED	2008/06/19	.000	
TRICHLOROFLUOROMETHANE	34488	WAIVED	2008/06/19	.000	
VINYL CHLORIDE	39175	WAIVED	2008/06/19	.000	
XYLENES (TOTAL)	81551	WAIVED	2008/06/19	.000	
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	108	2008/06/19	270.000	2017/06

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800561***

System Name: ***FREEMARK ABBEY PROPERTIES***

PS Code: ***2800561-003***

Source Name: ***WELL #3***

Source Number: ***003***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
CALCIUM	00916	108	2008/06/19	38.000	2017/06	
CARBONATE ALKALINITY	00445	108	2008/06/19	.000	2017/06	
CHLORIDE	00940	000				DUE
COLOR	00081	000				DUE
COPPER	01042	000				DUE
FOAMING AGENTS (MBAS)	38260	000				DUE
HARDNESS (TOTAL) AS CACO3	00900	108	2008/06/19	210.000	2017/06	
HYDROXIDE ALKALINITY	71830	108	2008/06/19	.000	2017/06	
IRON	01045	108	2008/06/19	9600.000	2017/06	
MAGNESIUM	00927	108	2008/06/19	27.000	2017/06	
MANGANESE	01055	108	2008/06/19	1200.000	2017/06	
ODOR THRESHOLD @ 60 C	00086	000				DUE
PH, LABORATORY	00403	108	2008/06/19	7.000	2017/06	
SILVER	01077	108	2008/06/19	.000	2017/06	
SODIUM	00929	108	2008/06/19	34.000	2017/06	
SPECIFIC CONDUCTANCE	00095	000				DUE
SULFATE	00945	000				DUE
TOTAL DISSOLVED SOLIDS	70300	000				DUE
TURBIDITY, LABORATORY	82079	000				DUE
ZINC	01092	000				DUE

PS Code: ***2800561-004***

Source Name: ***TREATMENT PLANT***

Source Number: ***004***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800561***

System Name: ***FREEMARK ABBEY PROPERTIES***

PS Code: ***2800561-004***

Source Name: ***TREATMENT PLANT***

Source Number: ***004***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800561***

System Name: ***FREEMARK ABBEY PROPERTIES***

PS Code: ***2800561-004***

Source Name: ***TREATMENT PLANT***

Source Number: ***004***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800561***

System Name: ***FREEMARK ABBEY PROPERTIES***

PS Code: ***2800561-004***

Source Name: ***TREATMENT PLANT***

Source Number: ***004***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800561***

System Name: ***FREEMARK ABBEY PROPERTIES***

PS Code: ***2800561-004***

Source Name: ***TREATMENT PLANT***

Source Number: ***004***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800561***

System Name: ***FREEMARK ABBEY PROPERTIES***

PS Code: ***2800561-005***

Source Name: ***CITY OF ST. HELENA***

Source Number: ***005***

Source Status: ***PURCHASED TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800561***

System Name: ***FREEMARK ABBEY PROPERTIES***

PS Code: ***2800561-005***

Source Name: ***CITY OF ST. HELENA***

Source Number: ***005***

Source Status: ***PURCHASED TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800561***

System Name: ***FREEMARK ABBEY PROPERTIES***

PS Code: ***2800561-005***

Source Name: ***CITY OF ST. HELENA***

Source Number: ***005***

Source Status: ***PURCHASED TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800561***

System Name: ***FREEMARK ABBEY PROPERTIES***

PS Code: ***2800561-005***

Source Name: ***CITY OF ST. HELENA***

Source Number: ***005***

Source Status: ***PURCHASED TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800561***

System Name: ***FREEMARK ABBEY PROPERTIES***

PS Code: ***2800561-005***

Source Name: ***CITY OF ST. HELENA***

Source Number: ***005***

Source Status: ***PURCHASED TREATED***

Water type: ***SURFACE***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800562***

System Name: ***FRANCISCAN WINERY***

PS Code: ***2800562-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2007/04/24	.000		
INORGANIC						
ALUMINUM	01105	036	2007/04/24	.000	2010/04	DUE
ANTIMONY	01097	036	2007/04/24	.000	2010/04	DUE
ARSENIC	01002	036	2007/04/24	.000	2010/04	DUE
ASBESTOS	81855	000				DUE
BARIUM	01007	036	2007/04/24	.000	2010/04	DUE
BERYLLIUM	01012	036	2007/04/24	.000	2010/04	DUE
CADMIUM	01027	036	2007/04/24	.000	2010/04	DUE
CHROMIUM (TOTAL)	01034	036	2007/04/24	.000	2010/04	DUE
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2007/04/24	.330	2010/04	DUE
LEAD	01051	WAIVED	2007/04/24	.000		
MERCURY	71900	036	2007/04/24	.000	2010/04	DUE
NICKEL	01067	036	2007/04/24	.000	2010/04	DUE
PERCHLORATE	A-031	036	2008/08/19	.000	2011/08	DUE
SELENIUM	01147	036	2007/04/24	.000	2010/04	DUE
THALLIUM	01059	036	2007/04/24	.000	2010/04	DUE
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/05/18	< .000	2012/05	
NITRITE (AS N)	00620	036	2010/04/30	.000	2013/04	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2007/06/14	1.870	2016/06	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800562***

System Name: ***FRANCISCAN WINERY***

PS Code: ***2800562-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2011/10/31	< 1.000		
2,4-D	39730	WAIVED	2011/10/31	< 10.000		
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	036	2011/11/28	< .500	2014/11	
BENTAZON	38710	WAIVED	2011/10/31	< 2.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2011/10/31	< 5.000	2014/10	
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2011/10/31	< 10.000	2014/10	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2009/02/11	.000		
DINOSEB	81287	036	2011/10/31	< 2.000	2014/10	
DIQUAT	78885	036	2011/10/31	< 4.000	2014/10	
ENDOTHALL	38926	036	2011/10/31	< 45.000	2014/10	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2009/02/11	.000		
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800562***

System Name: ***FRANCISCAN WINERY***

PS Code: ***2800562-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	000				DUE
MOLINATE	82199	WAIVED	2007/04/24	.000		
OXAMYL	38865	036	2011/10/31	< 20.000	2014/10	
PENTACHLOROPHENOL	39032	036	2011/10/31	< .200	2014/10	
PICLORAM	39720	036	2011/10/31	< 1.000	2014/10	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2011/11/28	< 1.000	2014/11	
THIOBENCARB	A-001	WAIVED	2007/04/24	.000		
TOXAPHENE	39400	000				DUE
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2009/02/11	.000	2015/02	
1,1,2,2-TETRACHLOROETHANE	34516	072	2009/02/11	.000	2015/02	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2009/02/11	.000	2015/02	
1,1,2-TRICHLOROETHANE	34511	072	2009/02/11	.000	2015/02	
1,1-DICHLOROETHANE	34496	072	2009/02/11	.000	2015/02	
1,1-DICHLOROETHYLENE	34501	072	2009/02/11	.000	2015/02	
1,2,4-TRICHLOROBENZENE	34551	072	2009/02/11	.000	2015/02	
1,2-DICHLOROBENZENE	34536	072	2009/02/11	.000	2015/02	
1,2-DICHLOROETHANE	34531	072	2009/02/11	.000	2015/02	
1,2-DICHLOROPROPANE	34541	072	2009/02/11	.000	2015/02	
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2009/02/11	.000	2015/02	
1,4-DICHLOROBENZENE	34571	072	2009/02/11	.000	2015/02	
BENZENE	34030	072	2009/02/11	.000	2015/02	
CARBON TETRACHLORIDE	32102	072	2009/02/11	.000	2015/02	
CIS-1,2-DICHLOROETHYLENE	77093	072	2009/02/11	.000	2015/02	
DICHLOROMETHANE	34423	072	2009/02/11	.000	2015/02	
ETHYLBENZENE	34371	072	2009/02/11	.000	2015/02	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2009/02/11	.000	2015/02	
MONOCHLOROBENZENE	34301	072	2009/02/11	.000	2015/02	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800562***

System Name: ***FRANCISCAN WINERY***

PS Code: ***2800562-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2009/02/11	.000	2015/02
TETRACHLOROETHYLENE	34475	072	2009/02/11	.000	2015/02
TOLUENE	34010	072	2009/02/11	.000	2015/02
TRANS-1,2-DICHLOROETHYLENE	34546	072	2009/02/11	.000	2015/02
TRICHLOROETHYLENE	39180	072	2009/02/11	.000	2015/02
TRICHLOROFLUOROMETHANE	34488	072	2009/02/11	.000	2015/02
VINYL CHLORIDE	39175	072	2009/02/11	.000	2015/02
XYLENES (TOTAL)	81551	072	2009/02/11	.000	2015/02
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED	2004/02/25	11.300	
BICARBONATE ALKALINITY	00440	WAIVED	2007/04/24	210.000	
CALCIUM	00916	WAIVED	2009/02/11	17.000	
CARBONATE ALKALINITY	00445	WAIVED	2007/04/24	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2007/04/24	130.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2007/04/24	.000	
IRON	01045	WAIVED	2007/04/24	.000	
MAGNESIUM	00927	WAIVED	2007/04/24	19.000	
MANGANESE	01055	WAIVED	2007/04/24	170.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2007/04/24	7.400	
SILVER	01077	WAIVED	2007/04/24	.000	
SODIUM	00929	WAIVED	2007/04/24	31.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800562***

System Name: ***FRANCISCAN WINERY***

PS Code: ***2800562-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800562-002***

Source Name: ***TREATEMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800562***

System Name: ***FRANCISCAN WINERY***

PS Code: ***2800562-002***

Source Name: ***TREATEMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800562***

System Name: ***FRANCISCAN WINERY***

PS Code: ***2800562-002***

Source Name: ***TREATEMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800562***

System Name: ***FRANCISCAN WINERY***

PS Code: ***2800562-002***

Source Name: ***TREATEMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800562***

System Name: ***FRANCISCAN WINERY***

PS Code: ***2800562-002***

Source Name: ***TREATEMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800564***

System Name: ***SODA CANYON STORE***

PS Code: ***2800564-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED	2002/04/25	.000	
ANTIMONY	01097	WAIVED	2002/04/25	.000	
ARSENIC	01002	WAIVED	2002/04/25	28.000	
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED	2002/04/25	.000	
BERYLLIUM	01012	WAIVED	2002/04/25	.000	
CADMIUM	01027	WAIVED	2002/04/25	.000	
CHROMIUM (TOTAL)	01034	WAIVED	2002/04/25	.000	
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2002/04/25	.600	
LEAD	01051	WAIVED	2002/04/25	.000	
MERCURY	71900	WAIVED	2002/04/25	.000	
NICKEL	01067	WAIVED	2002/04/25	.000	
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED	2002/04/25	.000	
THALLIUM	01059	WAIVED	2002/04/25	.000	
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2012/04/27	< .000	2013/04
NITRITE (AS N)	00620	036	2012/04/27	< .000	2015/04
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800564***

System Name: ***SODA CANYON STORE***

PS Code: ***2800564-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800564***

System Name: ***SODA CANYON STORE***

PS Code: ***2800564-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800564***

System Name: ***SODA CANYON STORE***

PS Code: ***2800564-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED	2002/04/25	.000	
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800564***

System Name: ***SODA CANYON STORE***

PS Code: ***2800564-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800569***

System Name: ***AETNA SPRINGS GOLF COURSE***

PS Code: ***2800569-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	036	2009/07/13	120.000	2012/07	
ANTIMONY	01097	036	2009/07/13	.000	2012/07	
ARSENIC	01002	036	2009/07/13	.000	2012/07	
ASBESTOS	81855	000				**DUE**
BARIUM	01007	036	2009/07/13	.000	2012/07	
BERYLLIUM	01012	036	2009/07/13	.000	2012/07	
CADMIUM	01027	036	2009/07/13	.000	2012/07	
CHROMIUM (TOTAL)	01034	036	2009/07/13	.000	2012/07	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2009/07/13	.000	2012/07	
LEAD	01051	WAIVED	2009/07/13	.000		
MERCURY	71900	036	2009/07/13	.000	2012/07	
NICKEL	01067	036	2009/07/13	.000	2012/07	
PERCHLORATE	A-031	036	2011/12/08	< .000	2014/12	
SELENIUM	01147	036	2009/07/13	.000	2012/07	
THALLIUM	01059	036	2009/07/13	.000	2012/07	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/08/03	< .000	2012/08	
NITRITE (AS N)	00620	036	2009/07/13	.000	2012/07	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2009/09/24	.610	2018/09	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800569***

System Name: ***AETNA SPRINGS GOLF COURSE***

PS Code: ***2800569-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2011/08/03	< 1.000		
2,4-D	39730	WAIVED	2011/08/03	< 10.000		
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	036	2009/07/13	.000	2012/07	
BENTAZON	38710	WAIVED	2011/08/03	< 2.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2009/07/13	.000	2012/07	
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2011/08/03	< 10.000	2014/08	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	036	2011/08/03	< 2.000	2014/08	
DIQUAT	78885	036	2011/08/03	< 4.000	2014/08	
ENDOTHALL	38926	036	2009/07/13	.000	2012/07	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	000				**DUE**
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	WAIVED	2006/06/21	.000		
HEPTACHLOR EPOXIDE	39420	WAIVED	2006/06/21	.000		
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	WAIVED	2006/06/21	.000		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800569***

System Name: ***AETNA SPRINGS GOLF COURSE***

PS Code: ***2800569-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED	2006/06/21	.000	
MOLINATE	82199	WAIVED			
OXAMYL	38865	036	2009/07/13	.000	2012/07
PENTACHLOROPHENOL	39032	036	2011/08/03	< .200	2014/08
PICLORAM	39720	036	2011/08/03	< 1.000	2014/08
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	036	2009/07/13	.000	2012/07
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED	2006/06/21	.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	072	2011/08/03	< .000	2017/08
1,1,2,2-TETRACHLOROETHANE	34516	072	2011/08/03	< .000	2017/08
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2011/08/03	< .000	2017/08
1,1,2-TRICHLOROETHANE	34511	072	2011/08/03	< .000	2017/08
1,1-DICHLOROETHANE	34496	072	2011/08/03	< .000	2017/08
1,1-DICHLOROETHYLENE	34501	072	2011/08/03	< .000	2017/08
1,2,4-TRICHLOROBENZENE	34551	072	2011/08/03	< .000	2017/08
1,2-DICHLOROBENZENE	34536	072	2011/08/03	< .000	2017/08
1,2-DICHLOROETHANE	34531	072	2011/08/03	< .000	2017/08
1,2-DICHLOROPROPANE	34541	072	2011/08/03	< .000	2017/08
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2011/08/03	< .000	2017/08
1,4-DICHLOROBENZENE	34571	072	2011/08/03	< .000	2017/08
BENZENE	34030	072	2011/08/03	< .000	2017/08
CARBON TETRACHLORIDE	32102	072	2011/08/03	< .000	2017/08
CIS-1,2-DICHLOROETHYLENE	77093	072	2011/08/03	< .000	2017/08
DICHLOROMETHANE	34423	072	2011/08/03	< .000	2017/08
ETHYLBENZENE	34371	072	2011/08/03	< .000	2017/08
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2011/08/03	< .000	2017/08
MONOCHLOROBENZENE	34301	072	2011/08/03	< .000	2017/08

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800569***

System Name: ***AETNA SPRINGS GOLF COURSE***

PS Code: ***2800569-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2011/08/03	< .000	2017/08
TETRACHLOROETHYLENE	34475	072	2011/08/03	< .000	2017/08
TOLUENE	34010	072	2011/08/03	< .000	2017/08
TRANS-1,2-DICHLOROETHYLENE	34546	072	2011/08/03	< .000	2017/08
TRICHLOROETHYLENE	39180	072	2011/08/03	< .000	2017/08
TRICHLOROFLUOROMETHANE	34488	072	2011/08/03	< .000	2017/08
VINYL CHLORIDE	39175	072	2011/08/03	< .000	2017/08
XYLENES (TOTAL)	81551	072	2011/08/03	< .000	2017/08
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2009/07/13	61.000	
CALCIUM	00916	WAIVED	2009/07/13	5.700	
CARBONATE ALKALINITY	00445	WAIVED	2009/07/13	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED	2008/05/21	59.000	
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2009/07/13	25.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2009/07/13	.000	
IRON	01045	WAIVED	2009/07/13	.000	
MAGNESIUM	00927	WAIVED	2009/07/13	2.800	
MANGANESE	01055	WAIVED	2009/07/13	.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2009/07/13	7.300	
SILVER	01077	WAIVED	2009/07/13	.000	
SODIUM	00929	WAIVED	2009/07/13	10.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800569***

System Name: ***AETNA SPRINGS GOLF COURSE***

PS Code: ***2800569-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED	2006/06/21	.000	

PS Code: ***2800569-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800569***

System Name: ***AETNA SPRINGS GOLF COURSE***

PS Code: ***2800569-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800569***

System Name: ***AETNA SPRINGS GOLF COURSE***

PS Code: ***2800569-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800569***

System Name: ***AETNA SPRINGS GOLF COURSE***

PS Code: ***2800569-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800569***

System Name: ***AETNA SPRINGS GOLF COURSE***

PS Code: ***2800569-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800575***

System Name: ***CALISTOGA RANCH***

PS Code: ***2800575-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2008/02/20	.000		
INORGANIC						
ALUMINUM	01105	036	2008/02/20	.000	2011/02	DUE
ANTIMONY	01097	036	2008/02/20	.000	2011/02	DUE
ARSENIC	01002	036	2008/02/20	.000	2011/02	DUE
ASBESTOS	81855	108	2011/02/22	.000	2020/02	
BARIUM	01007	036	2008/02/20	.000	2011/02	DUE
BERYLLIUM	01012	036	2008/02/20	.000	2011/02	DUE
CADMIUM	01027	036	2008/02/20	.000	2011/02	DUE
CHROMIUM (TOTAL)	01034	036	2008/02/20	.000	2011/02	DUE
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2008/02/20	.180	2011/02	DUE
LEAD	01051	WAIVED	2008/02/20	.000		
MERCURY	71900	036	2008/02/20	.000	2011/02	DUE
NICKEL	01067	036	2008/02/20	.000	2011/02	DUE
PERCHLORATE	A-031	036	2010/03/31	.000	2013/03	
SELENIUM	01147	036	2008/02/20	.000	2011/02	DUE
THALLIUM	01059	036	2008/02/20	.000	2011/02	DUE
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2009/02/26	.000	2010/02	DUE
NITRITE (AS N)	00620	036	2008/02/20	.000	2011/02	DUE
RADIOLOGICAL						
GROSS ALPHA	01501	108	2009/02/26	2.880	2018/02	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED	2006/09/13	.000		
RADIUM 228	11501	WAIVED	2007/03/29	.000		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800575***

System Name: ***CALISTOGA RANCH***

PS Code: ***2800575-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2008/02/20	< 1.000		
2,4-D	39730	WAIVED	2008/02/20	< 10.000		
ALACHLOR	77825	WAIVED	2008/02/20	< 1.000		
ATRAZINE	39033	036	**2008/02/20**	.000	**2011/02**	**DUE**
BENTAZON	38710	WAIVED	2008/02/20	< 2.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	**2008/02/20**	< 5.000	**2011/02**	**DUE**
CHLORDANE	39350	WAIVED	2008/02/20	< .100		
DALAPON	38432	036	**2008/02/20**	< 10.000	**2011/02**	**DUE**
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2008/02/20	< .010		
DINOSEB	81287	036	**2008/02/20**	< 2.000	**2011/02**	**DUE**
DIQUAT	78885	036	**2008/02/20**	< 4.000	**2011/02**	**DUE**
ENDOTHALL	38926	036	**2008/02/20**	< 45.000	**2011/02**	**DUE**
ENDRIN	39390	WAIVED	2008/02/20	< .100		
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2008/02/20	< .020		
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	WAIVED	2008/02/20	< .010		
HEPTACHLOR EPOXIDE	39420	WAIVED	2008/02/20	< .010		
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	WAIVED	2008/02/20	< .200		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800575***

System Name: ***CALISTOGA RANCH***

PS Code: ***2800575-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	WAIVED	2008/02/20	< 10.000		
MOLINATE	82199	WAIVED	2008/02/20	.000		
OXAMYL	38865	036	2008/02/20	< 20.000	2011/02	DUE
PENTACHLOROPHENOL	39032	036	2008/02/20	< .200	2011/02	DUE
PICLORAM	39720	036	2008/02/20	< 1.000	2011/02	DUE
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2008/02/20	< .500		
SIMAZINE	39055	036	2008/02/20	.000	2011/02	DUE
THIOBENCARB	A-001	WAIVED	2008/02/20	.000		
TOXAPHENE	39400	WAIVED	2008/02/20	< 1.000		
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2008/02/20	.000	2014/02	
1,1,2,2-TETRACHLOROETHANE	34516	072	2008/02/20	.000	2014/02	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2008/02/20	.000	2014/02	
1,1,2-TRICHLOROETHANE	34511	072	2008/02/20	.000	2014/02	
1,1-DICHLOROETHANE	34496	072	2008/02/20	.000	2014/02	
1,1-DICHLOROETHYLENE	34501	072	2008/02/20	.000	2014/02	
1,2,4-TRICHLOROBENZENE	34551	072	2008/02/20	.000	2014/02	
1,2-DICHLOROBENZENE	34536	072	2008/02/20	.000	2014/02	
1,2-DICHLOROETHANE	34531	072	2008/02/20	.000	2014/02	
1,2-DICHLOROPROPANE	34541	072	2008/02/20	.000	2014/02	
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2008/02/20	.000	2014/02	
1,4-DICHLOROBENZENE	34571	072	2008/02/20	.000	2014/02	
BENZENE	34030	072	2008/02/20	.000	2014/02	
CARBON TETRACHLORIDE	32102	072	2008/02/20	.000	2014/02	
CIS-1,2-DICHLOROETHYLENE	77093	072	2008/02/20	.000	2014/02	
DICHLOROMETHANE	34423	072	2008/02/20	.000	2014/02	
ETHYLBENZENE	34371	072	2008/02/20	.000	2014/02	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2008/02/20	.000	2014/02	
MONOCHLOROBENZENE	34301	072	2008/02/20	.000	2014/02	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800575***

System Name: ***CALISTOGA RANCH***

PS Code: ***2800575-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED VOC						
STYRENE	77128	072	2008/02/20	.000	2014/02	
TETRACHLOROETHYLENE	34475	072	2008/02/20	.000	2014/02	
TOLUENE	34010	072	2008/02/20	.000	2014/02	
TRANS-1,2-DICHLOROETHYLENE	34546	072	2008/02/20	.000	2014/02	
TRICHLOROETHYLENE	39180	072	2008/02/20	.000	2014/02	
TRICHLOROFLUOROMETHANE	34488	072	2008/02/20	.000	2014/02	
VINYL CHLORIDE	39175	072	2008/02/20	.000	2014/02	
XYLENES (TOTAL)	81551	072	2008/02/20	.000	2014/02	
SECONDARY/GP						
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED				
BICARBONATE ALKALINITY	00440	WAIVED	2008/02/20	230.000		
CALCIUM	00916	000				**DUE**
CARBONATE ALKALINITY	00445	WAIVED	2008/02/20	.000		
CHLORIDE	00940	WAIVED				
COLOR	00081	WAIVED				
COPPER	01042	WAIVED				
FOAMING AGENTS (MBAS)	38260	WAIVED				
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2008/02/20	160.000		
HYDROXIDE ALKALINITY	71830	WAIVED	2008/02/20	.000		
IRON	01045	WAIVED	2008/02/20	400.000		
MAGNESIUM	00927	000				**DUE**
MANGANESE	01055	WAIVED	2008/02/20	110.000		
ODOR THRESHOLD @ 60 C	00086	WAIVED				
PH, LABORATORY	00403	WAIVED	2008/02/20	7.700		
SILVER	01077	WAIVED	2008/02/20	.000		
SODIUM	00929	WAIVED	2008/02/20	35.000		
SPECIFIC CONDUCTANCE	00095	WAIVED				
SULFATE	00945	WAIVED				
TOTAL DISSOLVED SOLIDS	70300	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800575***

System Name: ***CALISTOGA RANCH***

PS Code: ***2800575-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800575-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED	2011/02/22	.000	
ANTIMONY	01097	WAIVED	2011/02/22	.000	
ARSENIC	01002	WAIVED	2011/02/22	.000	
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED	2011/02/22	.000	
BERYLLIUM	01012	WAIVED	2011/02/22	.000	
CADMIUM	01027	WAIVED	2011/02/22	.000	
CHROMIUM (TOTAL)	01034	WAIVED	2011/02/22	.000	
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2011/02/22	.190	
LEAD	01051	WAIVED	2011/02/22	.000	
MERCURY	71900	WAIVED	2011/02/22	.000	
NICKEL	01067	WAIVED	2011/02/22	.000	
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED	2011/02/22	.000	
THALLIUM	01059	WAIVED	2011/02/22	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800575***

System Name: ***CALISTOGA RANCH***

PS Code: ***2800575-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED	2011/02/22	.000	
NITRITE (AS N)	00620	WAIVED	2011/02/22	.000	
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2011/02/22	< 1.000	
2,4-D	39730	WAIVED	2011/02/22	< 10.000	
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED	2011/02/22	< .500	
BENTAZON	38710	WAIVED	2011/02/22	< 2.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED	2011/02/22	< 5.000	
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED	2011/02/22	< 10.000	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED	2011/02/22	< 2.000	
DIQUAT	78885	WAIVED	2011/02/22	< 4.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800575***

System Name: ***CALISTOGA RANCH***

PS Code: ***2800575-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED	2011/02/22	< 45.000	
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED	2011/02/22	< 20.000	
PENTACHLOROPHENOL	39032	WAIVED	2011/02/22	< .200	
PICLORAM	39720	WAIVED	2011/02/22	< 1.000	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED	2011/02/22	< 1.000	
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800575***

System Name: ***CALISTOGA RANCH***

PS Code: ***2800575-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2011/02/22	246.000	
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED	2011/02/22	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2011/02/22	130.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2011/02/22	.000	
IRON	01045	WAIVED	2011/02/22	970.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800575***

System Name: ***CALISTOGA RANCH***

PS Code: ***2800575-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED	2011/02/22	11.000	
MANGANESE	01055	WAIVED	2011/02/22	89.800	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2011/02/22	7.900	
SILVER	01077	WAIVED	2011/02/22	.000	
SODIUM	00929	WAIVED	2011/02/22	35.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800575-005***

Source Name: ***WELL 5***

Source Number: ***005***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED			

INORGANIC

ALUMINUM	01105	000			DUE
ANTIMONY	01097	000			DUE
ARSENIC	01002	000			DUE
ASBESTOS	81855	000			DUE
BARIUM	01007	000			DUE
BERYLLIUM	01012	000			DUE
CADMIUM	01027	000			DUE
CHROMIUM (TOTAL)	01034	000			DUE
CYANIDE	01291	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800575***

System Name: ***CALISTOGA RANCH***

PS Code: ***2800575-005***

Source Name: ***WELL 5***

Source Number: ***005***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	000			DUE
LEAD	01051	WAIVED			
MERCURY	71900	000			DUE
NICKEL	01067	000			DUE
PERCHLORATE	A-031	006			DUE
SELENIUM	01147	000			DUE
THALLIUM	01059	000			DUE
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	000			DUE
NITRITE (AS N)	00620	000			DUE
RADIOLOGICAL					
GROSS ALPHA	01501	000			DUE
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	000			DUE
2,4-D	39730	000			DUE
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	000			DUE
BENTAZON	38710	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800575***

System Name: ***CALISTOGA RANCH***

PS Code: ***2800575-005***

Source Name: ***WELL 5***

Source Number: ***005***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	000			DUE
CHLORDANE	39350	WAIVED			
DALAPON	38432	000			DUE
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	000			DUE
DIQUAT	78885	000			DUE
ENDOTHALL	38926	000			DUE
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	000			DUE
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	000			DUE
HEPTACHLOR EPOXIDE	39420	000			DUE
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	000			DUE
METHOXYCHLOR	39480	000			DUE
MOLINATE	82199	WAIVED			
OXAMYL	38865	000			DUE
PENTACHLOROPHENOL	39032	000			DUE
PICLORAM	39720	000			DUE
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	000			DUE
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	000			DUE
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800575
System Name: CALISTOGA RANCH

PS Code: 2800575-005
Source Name: WELL 5
Source Number: 005
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	000			DUE
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	000			DUE
1,1,2-TRICHLOROETHANE	34511	000			DUE
1,1-DICHLOROETHANE	34496	000			DUE
1,1-DICHLOROETHYLENE	34501	000			DUE
1,2,4-TRICHLOROBENZENE	34551	000			DUE
1,2-DICHLOROBENZENE	34536	000			DUE
1,2-DICHLOROETHANE	34531	000			DUE
1,2-DICHLOROPROPANE	34541	000			DUE
1,3-DICHLOROPROPENE (TOTAL)	34561	000			DUE
1,4-DICHLOROBENZENE	34571	000			DUE
BENZENE	34030	000			DUE
CARBON TETRACHLORIDE	32102	000			DUE
CIS-1,2-DICHLOROETHYLENE	77093	000			DUE
DICHLOROMETHANE	34423	000			DUE
ETHYLBENZENE	34371	000			DUE
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	000			DUE
MONOCHLOROBENZENE	34301	000			DUE
STYRENE	77128	000			DUE
TETRACHLOROETHYLENE	34475	000			DUE
TOLUENE	34010	000			DUE
TRANS-1,2-DICHLOROETHYLENE	34546	000			DUE
TRICHLOROETHYLENE	39180	000			DUE
TRICHLOROFLUOROMETHANE	34488	000			DUE
VINYL CHLORIDE	39175	000			DUE
XYLENES (TOTAL)	81551	000			DUE
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800575***

System Name: ***CALISTOGA RANCH***

PS Code: ***2800575-005***

Source Name: ***WELL 5***

Source Number: ***005***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800578***

System Name: ***ENCHANTED HILLS***

PS Code: ***2800578-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED	2007/04/12	520.000		
ANTIMONY	01097	WAIVED	2007/04/12	< 6.000		
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED	2007/04/12	< 1.000		
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED	2007/04/12	< 10.000		
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED	2007/04/12	< 1.000		
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/06/29	5.900	2012/06	
NITRITE (AS N)	00620	036	2011/11/08	< 400.000	2014/11	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800578***

System Name: ***ENCHANTED HILLS***

PS Code: ***2800578-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800578***

System Name: ***ENCHANTED HILLS***

PS Code: ***2800578-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800578***

System Name: ***ENCHANTED HILLS***

PS Code: ***2800578-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	WAIVED	2009/04/15	< 100.000	
MAGNESIUM	00927	000			DUE
MANGANESE	01055	WAIVED	2009/04/15	< 20.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800578***

System Name: ***ENCHANTED HILLS***

PS Code: ***2800578-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED	2006/08/17	1.200	
ZINC	01092	WAIVED			

PS Code: ***2800578-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***SURFACE***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800578***

System Name: ***ENCHANTED HILLS***

PS Code: ***2800578-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800578***

System Name: ***ENCHANTED HILLS***

PS Code: ***2800578-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800578***

System Name: ***ENCHANTED HILLS***

PS Code: ***2800578-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800578***

System Name: ***ENCHANTED HILLS***

PS Code: ***2800578-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***SURFACE***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED	2005/02/28	3.800	
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800579***

System Name: ***NAPA-SOLANO GIRL SCOUTS***

PS Code: ***2800579-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED	2002/06/10	100.000	
ANTIMONY	01097	WAIVED	2002/06/10	.000	
ARSENIC	01002	WAIVED	2002/06/10	5.000	
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED	2002/06/10	.000	
BERYLLIUM	01012	WAIVED	2002/06/10	.000	
CADMIUM	01027	WAIVED	2002/06/10	.000	
CHROMIUM (TOTAL)	01034	WAIVED	2002/06/10	.000	
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2002/06/10	.300	
LEAD	01051	WAIVED	2002/06/10	.000	
MERCURY	71900	WAIVED	2002/06/10	.000	
NICKEL	01067	WAIVED	2002/06/10	.000	
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED	2002/06/10	.000	
THALLIUM	01059	WAIVED	2002/06/10	.000	
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	000			DUE
NITRITE (AS N)	00620	000			DUE
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800579***

System Name: ***NAPA-SOLANO GIRL SCOUTS***

PS Code: ***2800579-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800579***

System Name: ***NAPA-SOLANO GIRL SCOUTS***

PS Code: ***2800579-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800579***

System Name: ***NAPA-SOLANO GIRL SCOUTS***

PS Code: ***2800579-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED	2002/06/10	.000	
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800579***

System Name: ***NAPA-SOLANO GIRL SCOUTS***

PS Code: ***2800579-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800579-002***

Source Name: ***SPRING #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	000			DUE
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800579***

System Name: ***NAPA-SOLANO GIRL SCOUTS***

PS Code: ***2800579-002***

Source Name: ***SPRING #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2007/08/08	.000	2008/08	DUE
NITRITE (AS N)	00620	036	2007/08/08	.000	2010/08	DUE
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED				
2,4-D	39730	WAIVED				
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	WAIVED				
BENTAZON	38710	WAIVED				
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	WAIVED				
CHLORDANE	39350	WAIVED				
DALAPON	38432	WAIVED				
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	WAIVED				
DIQUAT	78885	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800579***

System Name: ***NAPA-SOLANO GIRL SCOUTS***

PS Code: ***2800579-002***

Source Name: ***SPRING #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800579***

System Name: ***NAPA-SOLANO GIRL SCOUTS***

PS Code: ***2800579-002***

Source Name: ***SPRING #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800579***

System Name: ***NAPA-SOLANO GIRL SCOUTS***

PS Code: ***2800579-002***

Source Name: ***SPRING #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
SECONDARY/GP						
MAGNESIUM	00927	000				DUE
MANGANESE	01055	000				DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED				
PH, LABORATORY	00403	000				DUE
SILVER	01077	WAIVED				
SODIUM	00929	000				DUE
SPECIFIC CONDUCTANCE	00095	WAIVED				
SULFATE	00945	WAIVED				
TOTAL DISSOLVED SOLIDS	70300	WAIVED				
TURBIDITY, LABORATORY	82079	WAIVED				
ZINC	01092	WAIVED				

PS Code: ***2800579-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800579***

System Name: ***NAPA-SOLANO GIRL SCOUTS***

PS Code: ***2800579-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800579***

System Name: ***NAPA-SOLANO GIRL SCOUTS***

PS Code: ***2800579-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800579***

System Name: ***NAPA-SOLANO GIRL SCOUTS***

PS Code: ***2800579-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800579***

System Name: ***NAPA-SOLANO GIRL SCOUTS***

PS Code: ***2800579-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800580***

System Name: ***SYAR INDUSTRIES***

PS Code: ***2800580-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED	2011/06/22	< .000	
INORGANIC					
ALUMINUM	01105	036	2010/06/28	54.000	2013/06
ANTIMONY	01097	036	2010/06/28	.000	2013/06
ARSENIC	01002	036	2010/06/28	.000	2013/06
ASBESTOS	81855	108	2008/08/28	.000	2017/08
BARIUM	01007	036	2010/06/28	.000	2013/06
BERYLLIUM	01012	036	2010/06/28	.000	2013/06
CADMIUM	01027	036	2010/06/28	.000	2013/06
CHROMIUM (TOTAL)	01034	036	2010/06/28	.000	2013/06
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2010/06/28	.170	2013/06
LEAD	01051	WAIVED	2007/06/07	.000	
MERCURY	71900	036	2010/06/28	.000	2013/06
NICKEL	01067	036	2010/06/28	.000	2013/06
PERCHLORATE	A-031	036	2011/06/22	.000	2014/06
SELENIUM	01147	036	2010/06/28	.000	2013/06
THALLIUM	01059	036	2010/06/28	.000	2013/06
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2011/06/22	.000	2012/06
NITRITE (AS N)	00620	036	2010/06/28	.000	2013/06
RADIOLOGICAL					
GROSS ALPHA	01501	108	2009/06/25	.542	2018/06
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800580***

System Name: ***SYAR INDUSTRIES***

PS Code: ***2800580-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2011/06/22	< .000		
2,4-D	39730	WAIVED	2011/06/22	< .000		
ALACHLOR	77825	WAIVED	2011/06/22	< .000		
ATRAZINE	39033	036	2011/06/22	< .000	2014/06	
BENTAZON	38710	WAIVED	2011/06/22	< .000		
BENZO (A) PYRENE	34247	WAIVED	2011/06/22	< .000		
CARBOFURAN	81405	036	2011/06/22	< .000	2014/06	
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2011/06/22	< .000	2014/06	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED	2011/06/22	< .000		
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED	2011/06/22	< .000		
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	036	2011/06/22	< .000	2014/06	
DIQUAT	78885	036	2011/06/22	< .000	2014/06	
ENDOTHALL	38926	036	2011/06/22	< .000	2014/06	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	000				**DUE**
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800580***

System Name: ***SYAR INDUSTRIES***

PS Code: ***2800580-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	000				DUE
MOLINATE	82199	WAIVED	2011/06/22	< .000		
OXAMYL	38865	036	2011/06/22	< .000	2014/06	
PENTACHLOROPHENOL	39032	036	2011/06/22	< .000	2014/06	
PICLORAM	39720	036	2011/06/22	< .000	2014/06	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2011/06/22	< .000	2014/06	
THIOBENCARB	A-001	WAIVED	2011/06/22	< .000		
TOXAPHENE	39400	000				DUE
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2004/01/23	.000	2010/01	DUE
1,1,2,2-TETRACHLOROETHANE	34516	072	2004/01/23	.000	2010/01	DUE
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2004/01/23	.000	2010/01	DUE
1,1,2-TRICHLOROETHANE	34511	072	2004/01/23	.000	2010/01	DUE
1,1-DICHLOROETHANE	34496	072	2004/01/23	.000	2010/01	DUE
1,1-DICHLOROETHYLENE	34501	072	2004/01/23	.000	2010/01	DUE
1,2,4-TRICHLOROBENZENE	34551	072	2004/01/23	.000	2010/01	DUE
1,2-DICHLOROBENZENE	34536	072	2004/01/23	.000	2010/01	DUE
1,2-DICHLOROETHANE	34531	072	2004/01/23	.000	2010/01	DUE
1,2-DICHLOROPROPANE	34541	072	2004/01/23	.000	2010/01	DUE
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2004/01/23	.000	2010/01	DUE
1,4-DICHLOROBENZENE	34571	072	2004/01/23	.000	2010/01	DUE
BENZENE	34030	072	2004/01/23	.000	2010/01	DUE
CARBON TETRACHLORIDE	32102	072	2004/01/23	.000	2010/01	DUE
CIS-1,2-DICHLOROETHYLENE	77093	072	2004/01/23	.000	2010/01	DUE
DICHLOROMETHANE	34423	072	2004/01/23	.000	2010/01	DUE
ETHYLBENZENE	34371	072	2004/01/23	.000	2010/01	DUE
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2004/01/23	.000	2010/01	DUE
MONOCHLOROBENZENE	34301	072	2004/01/23	.000	2010/01	DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800580***

System Name: ***SYAR INDUSTRIES***

PS Code: ***2800580-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED VOC						
STYRENE	77128	072	2004/01/23	.000	2010/01	DUE
TETRACHLOROETHYLENE	34475	072	2004/01/23	.000	2010/01	DUE
TOLUENE	34010	072	2004/01/23	.000	2010/01	DUE
TRANS-1,2-DICHLOROETHYLENE	34546	072	2004/01/23	.000	2010/01	DUE
TRICHLOROETHYLENE	39180	072	2004/01/23	.000	2010/01	DUE
TRICHLOROFLUOROMETHANE	34488	072	2004/01/23	.000	2010/01	DUE
VINYL CHLORIDE	39175	072	2004/01/23	.000	2010/01	DUE
XYLENES (TOTAL)	81551	072	2004/01/23	.000	2010/01	DUE
SECONDARY/GP						
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED				
BICARBONATE ALKALINITY	00440	WAIVED	2010/06/28	150.000		
CALCIUM	00916	WAIVED	2010/06/28	18.000		
CARBONATE ALKALINITY	00445	WAIVED	2010/06/28	.000		
CHLORIDE	00940	WAIVED	2003/08/18	15.000		
COLOR	00081	WAIVED				
COPPER	01042	WAIVED				
FOAMING AGENTS (MBAS)	38260	WAIVED				
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2010/06/28	96.000		
HYDROXIDE ALKALINITY	71830	WAIVED	2010/06/28	.000		
IRON	01045	WAIVED	2010/06/28	200.000		
MAGNESIUM	00927	WAIVED	2010/06/28	12.000		
MANGANESE	01055	WAIVED	2010/06/28	41.000		
ODOR THRESHOLD @ 60 C	00086	WAIVED				
PH, LABORATORY	00403	WAIVED	2010/06/28	7.410		
SILVER	01077	WAIVED	2007/06/07	.000		
SODIUM	00929	WAIVED	2010/06/28	36.000		
SPECIFIC CONDUCTANCE	00095	WAIVED				
SULFATE	00945	WAIVED				
TOTAL DISSOLVED SOLIDS	70300	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800580***

System Name: ***SYAR INDUSTRIES***

PS Code: ***2800580-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800580-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	000			DUE
ANTIMONY	01097	000			DUE
ARSENIC	01002	000			DUE
ASBESTOS	81855	000			DUE
BARIUM	01007	000			DUE
BERYLLIUM	01012	000			DUE
CADMIUM	01027	000			DUE
CHROMIUM (TOTAL)	01034	000			DUE
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	000			DUE
LEAD	01051	WAIVED			
MERCURY	71900	000			DUE
NICKEL	01067	000			DUE
PERCHLORATE	A-031	000			DUE
SELENIUM	01147	000			DUE
THALLIUM	01059	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800580***

System Name: ***SYAR INDUSTRIES***

PS Code: ***2800580-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	000			DUE
NITRITE (AS N)	00620	000			DUE
RADIOLOGICAL					
GROSS ALPHA	01501	000			DUE
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	000			DUE
2,4-D	39730	000			DUE
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	000			DUE
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	000			DUE
CHLORDANE	39350	WAIVED			
DALAPON	38432	000			DUE
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	000			DUE
DIQUAT	78885	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800580***

System Name: ***SYAR INDUSTRIES***

PS Code: ***2800580-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	000			DUE
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	000			DUE
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	000			DUE
HEPTACHLOR EPOXIDE	39420	000			DUE
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	000			DUE
METHOXYCHLOR	39480	000			DUE
MOLINATE	82199	WAIVED			
OXAMYL	38865	000			DUE
PENTACHLOROPHENOL	39032	000			DUE
PICLORAM	39720	000			DUE
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	000			DUE
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	000			DUE
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	000			DUE
1,1,2,2-TETRACHLOROETHANE	34516	000			DUE
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	000			DUE
1,1,2-TRICHLOROETHANE	34511	000			DUE
1,1-DICHLOROETHANE	34496	000			DUE
1,1-DICHLOROETHYLENE	34501	000			DUE
1,2,4-TRICHLOROBENZENE	34551	000			DUE
1,2-DICHLOROBENZENE	34536	000			DUE
1,2-DICHLOROETHANE	34531	000			DUE
1,2-DICHLOROPROPANE	34541	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800580***

System Name: ***SYAR INDUSTRIES***

PS Code: ***2800580-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	000			DUE
1,4-DICHLOROBENZENE	34571	000			DUE
BENZENE	34030	000			DUE
CARBON TETRACHLORIDE	32102	000			DUE
CIS-1,2-DICHLOROETHYLENE	77093	000			DUE
DICHLOROMETHANE	34423	000			DUE
ETHYLBENZENE	34371	000			DUE
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	000			DUE
MONOCHLOROBENZENE	34301	000			DUE
STYRENE	77128	000			DUE
TETRACHLOROETHYLENE	34475	000			DUE
TOLUENE	34010	000			DUE
TRANS-1,2-DICHLOROETHYLENE	34546	000			DUE
TRICHLOROETHYLENE	39180	000			DUE
TRICHLOROFLUOROMETHANE	34488	000			DUE
VINYL CHLORIDE	39175	000			DUE
XYLENES (TOTAL)	81551	000			DUE
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	000			DUE
COLOR	00081	000			DUE
COPPER	01042	000			DUE
FOAMING AGENTS (MBAS)	38260	000			DUE
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800580***

System Name: ***SYAR INDUSTRIES***

PS Code: ***2800580-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	000			DUE
PH, LABORATORY	00403	000			DUE
SILVER	01077	000			DUE
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	000			DUE
SULFATE	00945	000			DUE
TOTAL DISSOLVED SOLIDS	70300	000			DUE
TURBIDITY, LABORATORY	82079	000			DUE
ZINC	01092	000			DUE

PS Code: ***2800580-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15		
DIAZINON	39570	WAIVED
INORGANIC		
ALUMINUM	01105	WAIVED
ANTIMONY	01097	WAIVED
ARSENIC	01002	WAIVED
ASBESTOS	81855	WAIVED
BARIUM	01007	WAIVED
BERYLLIUM	01012	WAIVED
CADMIUM	01027	WAIVED
CHROMIUM (TOTAL)	01034	WAIVED
CYANIDE	01291	WAIVED

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800580***

System Name: ***SYAR INDUSTRIES***

PS Code: ***2800580-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800580***

System Name: ***SYAR INDUSTRIES***

PS Code: ***2800580-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800580***

System Name: ***SYAR INDUSTRIES***

PS Code: ***2800580-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800580***

System Name: ***SYAR INDUSTRIES***

PS Code: ***2800580-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800583
System Name: WELCOME GRANGE HALL

PS Code: 2800583-001
Source Name: WELL 01
Source Number: 001
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED	2005/02/11	.000		
ANTIMONY	01097	WAIVED	2005/02/11	.000		
ARSENIC	01002	WAIVED	2005/02/11	3.800		
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED	2005/02/11	.000		
BERYLLIUM	01012	WAIVED	2005/02/11	.000		
CADMIUM	01027	WAIVED	2005/02/11	.000		
CHROMIUM (TOTAL)	01034	WAIVED	2005/02/11	.000		
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2005/02/11	.170		
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED	2005/02/11	.000		
NICKEL	01067	WAIVED	2005/02/11	.000		
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED	2005/02/11	.000		
THALLIUM	01059	WAIVED	2005/02/11	.000		
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2010/07/15	.000	2011/07	DUE
NITRITE (AS N)	00620	036	2010/07/15	.000	2013/07	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800583***

System Name: ***WELCOME GRANGE HALL***

PS Code: ***2800583-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800583***

System Name: ***WELCOME GRANGE HALL***

PS Code: ***2800583-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800583***

System Name: ***WELCOME GRANGE HALL***

PS Code: ***2800583-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	WAIVED	2005/02/11	320.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800583***

System Name: ***WELCOME GRANGE HALL***

PS Code: ***2800583-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800583-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800583***

System Name: ***WELCOME GRANGE HALL***

PS Code: ***2800583-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800583***

System Name: ***WELCOME GRANGE HALL***

PS Code: ***2800583-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800583***

System Name: ***WELCOME GRANGE HALL***

PS Code: ***2800583-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800583***

System Name: ***WELCOME GRANGE HALL***

PS Code: ***2800583-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800584***

System Name: ***LAS POSADAS 4-H CAMP***

PS Code: ***2800584-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2009/05/27	.000	2010/05	**DUE**
NITRITE (AS N)	00620	000				**DUE**
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800584***

System Name: ***LAS POSADAS 4-H CAMP***

PS Code: ***2800584-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800584***

System Name: ***LAS POSADAS 4-H CAMP***

PS Code: ***2800584-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800584***

System Name: ***LAS POSADAS 4-H CAMP***

PS Code: ***2800584-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800584***

System Name: ***LAS POSADAS 4-H CAMP***

PS Code: ***2800584-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800584-002***

Source Name: ***SPRING 2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED	2003/06/06	140.000	
ANTIMONY	01097	WAIVED	2003/06/06	.000	
ARSENIC	01002	WAIVED	2003/06/06	.000	
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED	2003/06/06	.000	
BERYLLIUM	01012	WAIVED	2003/06/06	.000	
CADMIUM	01027	WAIVED	2003/06/06	.000	
CHROMIUM (TOTAL)	01034	WAIVED	2003/06/06	.000	
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	000			**DUE**
LEAD	01051	WAIVED	2003/06/06	.000	
MERCURY	71900	WAIVED	2003/06/06	.000	
NICKEL	01067	WAIVED	2003/06/06	.000	
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED	2003/06/06	.000	
THALLIUM	01059	WAIVED	2003/06/06	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800584***

System Name: ***LAS POSADAS 4-H CAMP***

PS Code: ***2800584-002***

Source Name: ***SPRING 2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2003/06/06	4.000	2004/06	DUE
NITRITE (AS N)	00620	036	2003/06/06	.000	2006/06	DUE
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED				
2,4-D	39730	WAIVED				
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	WAIVED				
BENTAZON	38710	WAIVED				
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	WAIVED				
CHLORDANE	39350	WAIVED				
DALAPON	38432	WAIVED				
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	WAIVED				
DIQUAT	78885	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800584***

System Name: ***LAS POSADAS 4-H CAMP***

PS Code: ***2800584-002***

Source Name: ***SPRING 2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800584***

System Name: ***LAS POSADAS 4-H CAMP***

PS Code: ***2800584-002***

Source Name: ***SPRING 2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800584***

System Name: ***LAS POSADAS 4-H CAMP***

PS Code: ***2800584-002***

Source Name: ***SPRING 2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED	2003/06/06	.000	
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800584-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15		
DIAZINON	39570	WAIVED
INORGANIC		
ALUMINUM	01105	WAIVED
ANTIMONY	01097	WAIVED
ARSENIC	01002	WAIVED
ASBESTOS	81855	WAIVED
BARIUM	01007	WAIVED
BERYLLIUM	01012	WAIVED
CADMIUM	01027	WAIVED
CHROMIUM (TOTAL)	01034	WAIVED
CYANIDE	01291	WAIVED

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800584***

System Name: ***LAS POSADAS 4-H CAMP***

PS Code: ***2800584-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800584***

System Name: ***LAS POSADAS 4-H CAMP***

PS Code: ***2800584-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800584***

System Name: ***LAS POSADAS 4-H CAMP***

PS Code: ***2800584-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800584***

System Name: ***LAS POSADAS 4-H CAMP***

PS Code: ***2800584-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800585***

System Name: ***MARKLEY COVE RESORT***

PS Code: ***2800585-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED	2009/07/13	330.000		
ANTIMONY	01097	WAIVED	2009/07/13	< 6.000		
ARSENIC	01002	WAIVED	2009/07/13	< 2.000		
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED	2009/07/13	< 100.000		
BERYLLIUM	01012	WAIVED	2009/07/13	< 1.000		
CADMIUM	01027	WAIVED	2009/07/13	< 1.000		
CHROMIUM (TOTAL)	01034	WAIVED	2009/07/13	1.700		
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2009/07/13	.220		
LEAD	01051	WAIVED	2005/09/06	< 5.000		
MERCURY	71900	WAIVED	2009/07/13	< 1.000		
NICKEL	01067	WAIVED	2009/07/13	< 10.000		
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED	2009/07/13	< 5.000		
THALLIUM	01059	WAIVED	2009/07/13	< 1.000		
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	**2009/07/13**	< 2.000	**2010/07**	**DUE**
NITRITE (AS N)	00620	036	2009/07/13	< 400.000	2012/07	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800585***

System Name: ***MARKLEY COVE RESORT***

PS Code: ***2800585-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2009/07/13	.000	
2,4-D	39730	WAIVED	2009/07/13	.000	
ALACHLOR	77825	WAIVED	2009/07/13	.000	
ATRAZINE	39033	WAIVED	2009/07/13	.000	
BENTAZON	38710	WAIVED	2009/07/13	.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED	2009/07/13	.000	
CHLORDANE	39350	WAIVED	2009/07/13	.000	
DALAPON	38432	WAIVED	2009/07/13	.000	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED	2009/07/13	.000	
DIQUAT	78885	WAIVED	2009/07/13	.000	
ENDOTHALL	38926	WAIVED	2009/07/13	.000	
ENDRIN	39390	WAIVED	2009/07/13	.000	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2009/07/13	.000	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2009/07/13	.000	
HEPTACHLOR EPOXIDE	39420	WAIVED	2009/07/13	.000	
HEXACHLOROBENZENE	39700	WAIVED	2009/07/13	.000	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2009/07/13	.000	
LINDANE	39340	WAIVED	2009/07/13	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800585***

System Name: ***MARKLEY COVE RESORT***

PS Code: ***2800585-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED	2009/07/13	.000	
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED	2009/07/13	.000	
PENTACHLOROPHENOL	39032	WAIVED	2009/07/13	.000	
PICLORAM	39720	WAIVED	2009/07/13	.000	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED	2009/07/13	.000	
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED	2009/07/13	.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED	2009/07/13	.000	
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED	2009/07/13	.000	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED	2009/07/13	.000	
1,1,2-TRICHLOROETHANE	34511	WAIVED	2009/07/13	.000	
1,1-DICHLOROETHANE	34496	WAIVED	2009/07/13	.000	
1,1-DICHLOROETHYLENE	34501	WAIVED	2009/07/13	.000	
1,2,4-TRICHLOROBENZENE	34551	WAIVED	2009/07/13	.000	
1,2-DICHLOROBENZENE	34536	WAIVED	2009/07/13	.000	
1,2-DICHLOROETHANE	34531	WAIVED	2009/07/13	.000	
1,2-DICHLOROPROPANE	34541	WAIVED	2009/07/13	.000	
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED	2009/07/13	.000	
1,4-DICHLOROBENZENE	34571	WAIVED	2009/07/13	.000	
BENZENE	34030	WAIVED	2009/07/13	.000	
CARBON TETRACHLORIDE	32102	WAIVED	2009/07/13	.000	
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED	2009/07/13	.000	
DICHLOROMETHANE	34423	WAIVED	2009/07/13	.000	
ETHYLBENZENE	34371	WAIVED	2009/07/13	.000	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED	2009/07/13	.000	
MONOCHLOROBENZENE	34301	WAIVED	2009/07/13	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800585
System Name: MARKLEY COVE RESORT

PS Code: 2800585-001
Source Name: LPA REPORTED PRIMARY SOURCE
Source Number: 001
Source Status: ACTIVE RAW
Water type: SURFACE

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED	2009/07/13	.000	
TETRACHLOROETHYLENE	34475	WAIVED	2009/07/13	.000	
TOLUENE	34010	WAIVED	2009/07/13	.000	
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED	2009/07/13	.000	
TRICHLOROETHYLENE	39180	WAIVED	2009/07/13	.000	
TRICHLOROFLUOROMETHANE	34488	WAIVED	2009/07/13	.000	
VINYL CHLORIDE	39175	WAIVED	2009/07/13	.000	
XYLENES (TOTAL)	81551	WAIVED	2009/07/13	.000	
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2009/07/13	200.000	
CALCIUM	00916	WAIVED	2009/07/13	20.000	
CARBONATE ALKALINITY	00445	WAIVED	2009/07/13	8.000	
CHLORIDE	00940	WAIVED	2009/07/13	6.400	
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2009/07/13	190.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2009/07/13	< 1.000	
IRON	01045	WAIVED	2009/07/13	400.000	
MAGNESIUM	00927	WAIVED	2009/07/13	34.000	
MANGANESE	01055	WAIVED	2009/07/13	< 20.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2009/07/13	8.500	
SILVER	01077	WAIVED	2009/07/13	< 10.000	
SODIUM	00929	WAIVED	2009/07/13	12.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED	2009/07/13	23.000	
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800585***

System Name: ***MARKLEY COVE RESORT***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)

PS Code: ***2800585-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE RAW***

Water type: ***SURFACE***

SECONDARY/GP

TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800585-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***SURFACE***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED			

INORGANIC

ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800585***

System Name: ***MARKLEY COVE RESORT***

PS Code: ***2800585-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800585***

System Name: ***MARKLEY COVE RESORT***

PS Code: ***2800585-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800585***

System Name: ***MARKLEY COVE RESORT***

PS Code: ***2800585-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800585***

System Name: ***MARKLEY COVE RESORT***

PS Code: ***2800585-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***SURFACE***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800587
System Name: DUFFY S MYRTLEDALE RESORT

PS Code: 2800587-001
Source Name: LPA REPORTED PRIMARY SOURCE
Source Number: 001
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED	2003/03/06	.000	
ANTIMONY	01097	WAIVED	2005/04/04	65.000	
ARSENIC	01002	WAIVED	2005/04/04	93.000	
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED	2003/03/06	.000	
BERYLLIUM	01012	WAIVED	2003/03/06	.000	
CADMIUM	01027	WAIVED	2003/03/06	.000	
CHROMIUM (TOTAL)	01034	WAIVED	2003/03/06	.000	
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2005/04/04	8.300	
LEAD	01051	WAIVED	2003/03/06	.000	
MERCURY	71900	WAIVED	2003/03/06	.000	
NICKEL	01067	WAIVED	2003/03/06	.000	
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED	2003/03/06	.000	
THALLIUM	01059	WAIVED	2003/03/06	.000	
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2012/01/13	< .000	2013/01
NITRITE (AS N)	00620	036	2011/01/13	.000	2014/01
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800587***

System Name: ***DUFFY S MYRTLEDALE RESORT***

PS Code: ***2800587-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800587***

System Name: ***DUFFY S MYRTLEDALE RESORT***

PS Code: ***2800587-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800587***

System Name: ***DUFFY S MYRTLEDALE RESORT***

PS Code: ***2800587-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED	2003/03/06	.000	
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800587***

System Name: ***DUFFY S MYRTLEDALE RESORT***

PS Code: ***2800587-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800587-002***

Source Name: ***CALIST CITY WATER***

Source Number: ***002***

Source Status: ***PURCHASED TREATED***

Water type: ***SURFACE***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800587***

System Name: ***DUFFY S MYRTLEDALE RESORT***

PS Code: ***2800587-002***

Source Name: ***CALIST CITY WATER***

Source Number: ***002***

Source Status: ***PURCHASED TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800587***

System Name: ***DUFFY S MYRTLEDALE RESORT***

PS Code: ***2800587-002***

Source Name: ***CALIST CITY WATER***

Source Number: ***002***

Source Status: ***PURCHASED TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800587***

System Name: ***DUFFY S MYRTLEDALE RESORT***

PS Code: ***2800587-002***

Source Name: ***CALIST CITY WATER***

Source Number: ***002***

Source Status: ***PURCHASED TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800587***

System Name: ***DUFFY S MYRTLEDALE RESORT***

PS Code: ***2800587-002***

Source Name: ***CALIST CITY WATER***

Source Number: ***002***

Source Status: ***PURCHASED TREATED***

Water type: ***SURFACE***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800587-003***

Source Name: ***TREATMENT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED			

INORGANIC

ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800587***

System Name: ***DUFFY S MYRTLEDALE RESORT***

PS Code: ***2800587-003***

Source Name: ***TREATMENT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800587***

System Name: ***DUFFY S MYRTLEDALE RESORT***

PS Code: ***2800587-003***

Source Name: ***TREATMENT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800587***

System Name: ***DUFFY S MYRTLEDALE RESORT***

PS Code: ***2800587-003***

Source Name: ***TREATMENT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800587***

System Name: ***DUFFY S MYRTLEDALE RESORT***

PS Code: ***2800587-003***

Source Name: ***TREATMENT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800588***

System Name: ***NAPA VALLEY COUNTRY CLUB***

PS Code: ***2800588-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2006/11/14	.000		
INORGANIC						
ALUMINUM	01105	036	2009/08/13	.000	2012/08	
ANTIMONY	01097	036	2009/08/13	.000	2012/08	
ARSENIC	01002	036	2009/08/13	2.900	2012/08	
ASBESTOS	81855	000				**DUE**
BARIUM	01007	036	2009/08/13	.000	2012/08	
BERYLLIUM	01012	036	2009/08/13	.000	2012/08	
CADMIUM	01027	036	2009/08/13	.000	2012/08	
CHROMIUM (TOTAL)	01034	036	2009/08/13	.000	2012/08	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2009/08/13	.120	2012/08	
LEAD	01051	WAIVED	2009/08/13	.000		
MERCURY	71900	036	2009/08/13	.000	2012/08	
NICKEL	01067	036	2009/08/13	.000	2012/08	
PERCHLORATE	A-031	036	**2008/08/20**	.000	**2011/08**	**DUE**
SELENIUM	01147	036	2009/08/13	.000	2012/08	
THALLIUM	01059	036	2009/08/13	.000	2012/08	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/05/05	< .000	2012/05	
NITRITE (AS N)	00620	036	2010/07/14	.000	2013/07	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2007/06/14	1.030	2016/06	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800588***

System Name: ***NAPA VALLEY COUNTRY CLUB***

PS Code: ***2800588-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2009/08/13	.000		
2,4-D	39730	WAIVED	2009/08/13	.000		
ALACHLOR	77825	WAIVED	2009/08/13	.000		
ATRAZINE	39033	036	2009/08/13	.000	2012/08	
BENTAZON	38710	WAIVED	2009/08/13	.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2009/08/13	.000	2012/08	
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2009/08/13	.000	2012/08	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	036	2009/08/13	.000	2012/08	
DIQUAT	78885	036	2009/08/13	.000	2012/08	
ENDOTHALL	38926	036	2009/08/13	.000	2012/08	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	000				**DUE**
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800588***

System Name: ***NAPA VALLEY COUNTRY CLUB***

PS Code: ***2800588-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	000				DUE
MOLINATE	82199	WAIVED	2009/08/13	.000		
OXAMYL	38865	036	2009/08/13	.000	2012/08	
PENTACHLOROPHENOL	39032	036	2009/08/13	.000	2012/08	
PICLORAM	39720	036	2009/08/13	.000	2012/08	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2009/08/13	.000	2012/08	
THIOBENCARB	A-001	WAIVED	2009/08/13	.000		
TOXAPHENE	39400	000				DUE
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	000				DUE
1,1,2,2-TETRACHLOROETHANE	34516	000				DUE
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	000				DUE
1,1,2-TRICHLOROETHANE	34511	000				DUE
1,1-DICHLOROETHANE	34496	000				DUE
1,1-DICHLOROETHYLENE	34501	000				DUE
1,2,4-TRICHLOROBENZENE	34551	000				DUE
1,2-DICHLOROBENZENE	34536	000				DUE
1,2-DICHLOROETHANE	34531	000				DUE
1,2-DICHLOROPROPANE	34541	000				DUE
1,3-DICHLOROPROPENE (TOTAL)	34561	000				DUE
1,4-DICHLOROBENZENE	34571	000				DUE
BENZENE	34030	000				DUE
CARBON TETRACHLORIDE	32102	000				DUE
CIS-1,2-DICHLOROETHYLENE	77093	000				DUE
DICHLOROMETHANE	34423	000				DUE
ETHYLBENZENE	34371	000				DUE
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	000				DUE
MONOCHLOROBENZENE	34301	000				DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800588***

System Name: ***NAPA VALLEY COUNTRY CLUB***

PS Code: ***2800588-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	000			DUE
TETRACHLOROETHYLENE	34475	000			DUE
TOLUENE	34010	000			DUE
TRANS-1,2-DICHLOROETHYLENE	34546	000			DUE
TRICHLOROETHYLENE	39180	000			DUE
TRICHLOROFLUOROMETHANE	34488	000			DUE
VINYL CHLORIDE	39175	000			DUE
XYLENES (TOTAL)	81551	000			DUE
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2009/08/13	155.000	
CALCIUM	00916	WAIVED	2009/08/13	19.000	
CARBONATE ALKALINITY	00445	WAIVED	2009/08/13	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2009/08/13	75.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2009/08/13	.000	
IRON	01045	WAIVED	2009/08/13	.000	
MAGNESIUM	00927	WAIVED	2009/08/13	5.000	
MANGANESE	01055	WAIVED	2009/08/13	87.200	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2009/08/13	7.900	
SILVER	01077	WAIVED	2009/08/13	.000	
SODIUM	00929	WAIVED	2009/08/13	36.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800588***

System Name: ***NAPA VALLEY COUNTRY CLUB***

PS Code: ***2800588-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800588-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800588***

System Name: ***NAPA VALLEY COUNTRY CLUB***

PS Code: ***2800588-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800588***

System Name: ***NAPA VALLEY COUNTRY CLUB***

PS Code: ***2800588-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800588***

System Name: ***NAPA VALLEY COUNTRY CLUB***

PS Code: ***2800588-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800588***

System Name: ***NAPA VALLEY COUNTRY CLUB***

PS Code: ***2800588-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800589
System Name: WHITEHALL LANE WINERY

PS Code: 2800589-001
Source Name: LPA REPORTED PRIMARY SOURCE
Source Number: 001
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED	2002/10/04	.000		
ANTIMONY	01097	WAIVED	2006/12/29	.000		
ARSENIC	01002	WAIVED	2006/12/29	.000		
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED	2006/12/29	.000		
BERYLLIUM	01012	WAIVED	2006/12/29	.000		
CADMIUM	01027	WAIVED	2006/12/29	.000		
CHROMIUM (TOTAL)	01034	WAIVED	2006/12/29	.000		
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2006/12/29	.170		
LEAD	01051	WAIVED	2006/12/29	.000		
MERCURY	71900	WAIVED	2006/12/29	.000		
NICKEL	01067	WAIVED	2006/12/29	.000		
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED	2002/10/04	.000		
THALLIUM	01059	WAIVED	2006/12/29	.000		
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/02/24	.000	2012/02	DUE
NITRITE (AS N)	00620	036	2006/12/29	.000	2009/12	DUE
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800589***

System Name: ***WHITEHALL LANE WINERY***

PS Code: ***2800589-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800589***

System Name: ***WHITEHALL LANE WINERY***

PS Code: ***2800589-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800589***

System Name: ***WHITEHALL LANE WINERY***

PS Code: ***2800589-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2006/12/29	300.000	
CALCIUM	00916	WAIVED	2006/12/29	22.000	
CARBONATE ALKALINITY	00445	WAIVED	2006/12/29	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2006/12/29	140.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2006/12/29	.000	
IRON	01045	WAIVED	2006/12/29	.000	
MAGNESIUM	00927	WAIVED	2006/12/29	20.000	
MANGANESE	01055	WAIVED	2006/12/29	550.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2006/12/29	7.800	
SILVER	01077	WAIVED	2006/12/29	.000	
SODIUM	00929	WAIVED	2006/12/29	55.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800589***

System Name: ***WHITEHALL LANE WINERY***

PS Code: ***2800589-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800589-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800589***

System Name: ***WHITEHALL LANE WINERY***

PS Code: ***2800589-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED	2009/04/10	.000	
NITRITE (AS N)	00620	WAIVED	2009/04/10	.000	
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800589***

System Name: ***WHITEHALL LANE WINERY***

PS Code: ***2800589-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800589***

System Name: ***WHITEHALL LANE WINERY***

PS Code: ***2800589-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800589***

System Name: ***WHITEHALL LANE WINERY***

PS Code: ***2800589-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800589-003***

Source Name: ***WELL 002***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800589***

System Name: ***WHITEHALL LANE WINERY***

PS Code: ***2800589-003***

Source Name: ***WELL 002***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
INORGANIC						
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2012/03/09	< .000	2013/03	
NITRITE (AS N)	00620	000				**DUE**
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED				
2,4-D	39730	WAIVED				
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	WAIVED				
BENTAZON	38710	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800589***

System Name: ***WHITEHALL LANE WINERY***

PS Code: ***2800589-003***

Source Name: ***WELL 002***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800589***

System Name: ***WHITEHALL LANE WINERY***

PS Code: ***2800589-003***

Source Name: ***WELL 002***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800589***

System Name: ***WHITEHALL LANE WINERY***

PS Code: ***2800589-003***

Source Name: ***WELL 002***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800592***

System Name: ***NAPA VALLEY MARINA***

PS Code: ***2800592-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED	2003/08/05	.000	
ANTIMONY	01097	WAIVED	2003/08/05	.000	
ARSENIC	01002	WAIVED	2003/08/05	2.000	
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED	2003/08/05	.000	
BERYLLIUM	01012	WAIVED	2003/08/05	.000	
CADMIUM	01027	WAIVED	2003/08/05	.000	
CHROMIUM (TOTAL)	01034	WAIVED	2003/08/05	.000	
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2003/08/05	.400	
LEAD	01051	WAIVED	2003/08/05	.000	
MERCURY	71900	WAIVED	2003/08/05	.000	
NICKEL	01067	WAIVED	2003/08/05	.000	
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED	2003/08/05	.000	
THALLIUM	01059	WAIVED	2003/08/05	.000	
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2012/04/19	< .000	2013/04
NITRITE (AS N)	00620	036	2012/04/19	< .000	2015/04
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800592***

System Name: ***NAPA VALLEY MARINA***

PS Code: ***2800592-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800592***

System Name: ***NAPA VALLEY MARINA***

PS Code: ***2800592-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800592***

System Name: ***NAPA VALLEY MARINA***

PS Code: ***2800592-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2012/04/19	198.000	
CALCIUM	00916	WAIVED	2012/04/19	< .000	
CARBONATE ALKALINITY	00445	WAIVED	2012/04/19	< .000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2012/04/19	< .000	
HYDROXIDE ALKALINITY	71830	WAIVED	2012/04/19	< .000	
IRON	01045	WAIVED	2012/04/19	< .000	
MAGNESIUM	00927	WAIVED	2012/04/19	< .000	
MANGANESE	01055	WAIVED	2012/04/19	< .000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2012/04/19	7.700	
SILVER	01077	WAIVED	2003/08/05	.000	
SODIUM	00929	WAIVED	2012/04/19	677.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800592***

System Name: ***NAPA VALLEY MARINA***

PS Code: ***2800592-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800592-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800592***

System Name: ***NAPA VALLEY MARINA***

PS Code: ***2800592-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800592***

System Name: ***NAPA VALLEY MARINA***

PS Code: ***2800592-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800592***

System Name: ***NAPA VALLEY MARINA***

PS Code: ***2800592-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800592***

System Name: ***NAPA VALLEY MARINA***

PS Code: ***2800592-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800593***

System Name: ***R RANCH AT THE LAKE***

PS Code: ***2800593-001***

Source Name: ***WELL # 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	036	2010/07/08	.000	2013/07
ANTIMONY	01097	036	2010/07/08	.000	2013/07
ARSENIC	01002	036	2010/07/08	.000	2013/07
ASBESTOS	81855	108	2005/06/09	< 2.200	2014/06
BARIUM	01007	036	2010/07/08	120.000	2013/07
BERYLLIUM	01012	036	2010/07/08	.000	2013/07
CADMIUM	01027	036	2010/07/08	.000	2013/07
CHROMIUM (TOTAL)	01034	036	2010/07/08	.000	2013/07
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2010/07/08	.000	2013/07
LEAD	01051	WAIVED	2010/07/08	.000	
MERCURY	71900	036	2010/07/08	.000	2013/07
NICKEL	01067	036	2010/07/08	.000	2013/07
PERCHLORATE	A-031	036	2010/06/25	.000	2013/06
SELENIUM	01147	036	2010/07/08	.000	2013/07
THALLIUM	01059	036	2010/07/08	.000	2013/07
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2011/04/07	< .000	2012/04
NITRITE (AS N)	00620	036	2011/04/07	< .000	2014/04
RADIOLOGICAL					
GROSS ALPHA	01501	108	2010/06/24	1.370	2019/06
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED	2008/05/29	.082	
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED	2008/05/29	.226	
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED	2010/06/24	1.790	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800593***

System Name: ***R RANCH AT THE LAKE***

PS Code: ***2800593-001***

Source Name: ***WELL # 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED	2008/05/29	.479		
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED	2008/05/29	.000		
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	108	2010/06/28	< .000	2019/06	
2,4-D	39730	108	2010/06/28	< .000	2019/06	
ALACHLOR	77825	WAIVED	2010/06/28	< .000		
ATRAZINE	39033	036	2010/06/28	< .000	2013/06	
BENTAZON	38710	WAIVED	2010/06/28	< .000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2010/06/28	< .000	2013/06	
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2010/06/28	< .000	2013/06	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	036	2010/06/28	< .000	2013/06	
DIQUAT	78885	036	2010/06/28	< .000	2013/06	
ENDOTHALL	38926	036	2010/06/28	< .000	2013/06	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	000				**DUE**
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800593***

System Name: ***R RANCH AT THE LAKE***

PS Code: ***2800593-001***

Source Name: ***WELL # 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	000				**DUE**
MOLINATE	82199	WAIVED	2010/06/28	< .000		
OXAMYL	38865	036	2010/06/28	< .000	2013/06	
PENTACHLOROPHENOL	39032	036	2010/06/28	< .000	2013/06	
PICLORAM	39720	036	2010/06/28	< .000	2013/06	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2010/06/28	< .000	2013/06	
THIOBENCARB	A-001	WAIVED	2010/06/28	< .000		
TOXAPHENE	39400	000				**DUE**
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2007/06/18	.000	2013/06	
1,1,2,2-TETRACHLOROETHANE	34516	072	2007/06/18	.000	2013/06	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2007/06/18	.000	2013/06	
1,1,2-TRICHLOROETHANE	34511	072	2007/06/18	.000	2013/06	
1,1-DICHLOROETHANE	34496	072	2007/06/18	.000	2013/06	
1,1-DICHLOROETHYLENE	34501	072	2007/06/18	.000	2013/06	
1,2,4-TRICHLOROBENZENE	34551	072	2007/06/18	.000	2013/06	
1,2-DICHLOROBENZENE	34536	072	2007/06/18	.000	2013/06	
1,2-DICHLOROETHANE	34531	072	2007/06/18	.000	2013/06	
1,2-DICHLOROPROPANE	34541	072	2007/06/18	.000	2013/06	
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2007/06/18	.000	2013/06	
1,4-DICHLOROBENZENE	34571	072	2007/06/18	.000	2013/06	
BENZENE	34030	072	2007/06/18	.000	2013/06	
CARBON TETRACHLORIDE	32102	072	2007/06/18	.000	2013/06	
CIS-1,2-DICHLOROETHYLENE	77093	072	2007/06/18	.000	2013/06	
DICHLOROMETHANE	34423	072	2007/06/18	.000	2013/06	
ETHYLBENZENE	34371	072	2007/06/18	.000	2013/06	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	036	**2007/06/18**	.000	**2010/06**	**DUE**
MONOCHLOROBENZENE	34301	072	2007/06/18	.000	2013/06	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800593***

System Name: ***R RANCH AT THE LAKE***

PS Code: ***2800593-001***

Source Name: ***WELL # 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED VOC						
STYRENE	77128	072	2007/06/18	.000	2013/06	
TETRACHLOROETHYLENE	34475	072	2007/06/18	.000	2013/06	
TOLUENE	34010	072	2007/06/18	.000	2013/06	
TRANS-1,2-DICHLOROETHYLENE	34546	072	2007/06/18	.000	2013/06	
TRICHLOROETHYLENE	39180	072	2007/06/18	.000	2013/06	
TRICHLOROFLUOROMETHANE	34488	072	2007/06/18	.000	2013/06	
VINYL CHLORIDE	39175	072	2007/06/18	.000	2013/06	
XYLENES (TOTAL)	81551	072	2007/06/18	.000	2013/06	
SECONDARY/GP						
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED	2010/07/08	12.600		
BICARBONATE ALKALINITY	00440	036	2010/07/08	430.000	2013/07	
CALCIUM	00916	036	2010/07/08	79.000	2013/07	
CARBONATE ALKALINITY	00445	036	2010/07/08	.000	2013/07	
CHLORIDE	00940	036	2010/07/08	6.400	2013/07	
COLOR	00081	036	2010/07/08	.000	2013/07	
COPPER	01042	036	2010/07/08	.000	2013/07	
FOAMING AGENTS (MBAS)	38260	036	2010/07/08	.000	2013/07	
HARDNESS (TOTAL) AS CACO3	00900	036	2010/07/08	340.000	2013/07	
HYDROXIDE ALKALINITY	71830	036	2010/07/08	.000	2013/07	
IRON	01045	036	**2007/06/18**	< 100.000	**2010/06**	**DUE**
MAGNESIUM	00927	036	2010/07/08	35.000	2013/07	
MANGANESE	01055	036	2010/07/08	140.000	2013/07	
ODOR THRESHOLD @ 60 C	00086	036	2010/07/08	1.000	2013/07	
PH, LABORATORY	00403	036	2010/07/08	7.500	2013/07	
SILVER	01077	036	2010/07/08	.000	2013/07	
SODIUM	00929	036	2010/07/08	21.000	2013/07	
SPECIFIC CONDUCTANCE	00095	036	2010/07/08	690.000	2013/07	
SULFATE	00945	036	2010/07/08	25.000	2013/07	
TOTAL DISSOLVED SOLIDS	70300	036	2010/07/08	400.000	2013/07	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800593***

System Name: ***R RANCH AT THE LAKE***

PS Code: ***2800593-001***

Source Name: ***WELL # 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	036	2010/07/08	.320	2013/07
ZINC	01092	036	2010/07/08	.000	2013/07

PS Code: ***2800593-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	036	2010/07/08	.000	2013/07
ANTIMONY	01097	036	2010/07/08	.000	2013/07
ARSENIC	01002	036	2010/07/08	.000	2013/07
ASBESTOS	81855	108	2005/06/09	< .200	2014/06
BARIUM	01007	036	2010/07/08	130.000	2013/07
BERYLLIUM	01012	036	2010/07/08	.000	2013/07
CADMIUM	01027	036	2010/07/08	.000	2013/07
CHROMIUM (TOTAL)	01034	036	2010/07/08	.000	2013/07
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2010/07/08	.000	2013/07
LEAD	01051	WAIVED	2010/07/08	.000	
MERCURY	71900	036	2010/07/08	.000	2013/07
NICKEL	01067	036	2010/07/08	.000	2013/07
PERCHLORATE	A-031	036	2010/06/25	.000	2013/06
SELENIUM	01147	036	2010/07/08	.000	2013/07
THALLIUM	01059	036	2010/07/08	.000	2013/07

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800593***

System Name: ***R RANCH AT THE LAKE***

PS Code: ***2800593-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
NITRATE/NITRITE						
NITRATE (AS NO3)	**71850**	**012**	**2010/07/08**	**.000**	**2011/07**	**DUE**
NITRITE (AS N)	**00620**	**036**	**2007/06/18**	**< 400.000**	**2010/06**	**DUE**
RADIOLOGICAL						
GROSS ALPHA	**01501**	**108**	2011/04/07	**2.450**	2020/04	
GROSS BETA	**03501**	**WAIVED**				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	**A-080**	**WAIVED**	2008/05/29	**.000**		
RA-226 OR TOTAL RA BY 903.0 C.E.	**A-081**	**WAIVED**	2008/05/29	**.152**		
RADIUM 226	**09501**	**WAIVED**				
RADIUM 228	**11501**	**WAIVED**	2011/04/07	**1.430**		
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	**A-082**	**WAIVED**	2008/05/29	**.373**		
STRONTIUM-90	**13501**	**WAIVED**				
TRITIUM	**07000**	**WAIVED**				
URANIUM (PCI/L)	**28012**	**WAIVED**	2008/05/29	**.131**		
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	**34676**	**WAIVED**				
2,4,5-TP (SILVEX)	**39045**	**108**	2010/06/28	**< .000**	2019/06	
2,4-D	**39730**	**108**	2010/06/28	**< .000**	2019/06	
ALACHLOR	**77825**	**WAIVED**	2010/06/28	**< .000**		
ATRAZINE	**39033**	**036**	2010/06/28	**< .000**	2013/06	
BENTAZON	**38710**	**WAIVED**	2010/06/28	**< .000**		
BENZO (A) PYRENE	**34247**	**WAIVED**				
CARBOFURAN	**81405**	**036**	2010/06/28	**< .000**	2013/06	
CHLORDANE	**39350**	**WAIVED**				
DALAPON	**38432**	**036**	2010/06/28	**< .000**	2013/06	
DI(2-ETHYLHEXYL)ADIPATE	**A-026**	**WAIVED**				
DI(2-ETHYLHEXYL)PHTHALATE	**39100**	**WAIVED**				
DIBROMOCHLOROPROPANE (DBCP)	**38761**	**WAIVED**				
DINOSEB	**81287**	**036**	2010/06/28	**< .000**	2013/06	
DIQUAT	**78885**	**036**	2010/06/28	**< .000**	2013/06	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800593***

System Name: ***R RANCH AT THE LAKE***

PS Code: ***2800593-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
ENDOTHALL	38926	036	2010/06/28	< .000	2013/06	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	000				**DUE**
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**
METHOXYCHLOR	39480	000				**DUE**
MOLINATE	82199	WAIVED	2010/06/28	< .000		
OXAMYL	38865	036	2010/06/28	< .000	2013/06	
PENTACHLOROPHENOL	39032	036	2010/06/28	< .000	2013/06	
PICLORAM	39720	036	2010/06/28	< .000	2013/06	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2010/06/28	< .000	2013/06	
THIOBENCARB	A-001	WAIVED	2010/06/28	< .000		
TOXAPHENE	39400	000				**DUE**
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2007/06/18	.000	2013/06	
1,1,2,2-TETRACHLOROETHANE	34516	072	2007/06/18	.000	2013/06	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2007/06/18	.000	2013/06	
1,1,2-TRICHLOROETHANE	34511	072	2007/06/18	.000	2013/06	
1,1-DICHLOROETHANE	34496	072	2007/06/18	.000	2013/06	
1,1-DICHLOROETHYLENE	34501	072	2007/06/18	.000	2013/06	
1,2,4-TRICHLOROBENZENE	34551	072	2007/06/18	.000	2013/06	
1,2-DICHLOROBENZENE	34536	072	2007/06/18	.000	2013/06	
1,2-DICHLOROETHANE	34531	072	2007/06/18	.000	2013/06	
1,2-DICHLOROPROPANE	34541	072	2007/06/18	.000	2013/06	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800593***

System Name: ***R RANCH AT THE LAKE***

PS Code: ***2800593-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED VOC						
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2007/06/18	.000	2013/06	
1,4-DICHLOROBENZENE	34571	072	2007/06/18	.000	2013/06	
BENZENE	34030	072	2007/06/18	.000	2013/06	
CARBON TETRACHLORIDE	32102	072	2007/06/18	.000	2013/06	
CIS-1,2-DICHLOROETHYLENE	77093	072	2007/06/18	.000	2013/06	
DICHLOROMETHANE	34423	072	2007/06/18	.000	2013/06	
ETHYLBENZENE	34371	072	2007/06/18	.000	2013/06	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	036	**2007/06/18**	.000	**2010/06**	**DUE**
MONOCHLOROBENZENE	34301	072	2007/06/18	.000	2013/06	
STYRENE	77128	072	2007/06/18	.000	2013/06	
TETRACHLOROETHYLENE	34475	072	2007/06/18	.000	2013/06	
TOLUENE	34010	072	2007/06/18	.000	2013/06	
TRANS-1,2-DICHLOROETHYLENE	34546	072	2007/06/18	.000	2013/06	
TRICHLOROETHYLENE	39180	072	2007/06/18	.000	2013/06	
TRICHLOROFLUOROMETHANE	34488	072	2007/06/18	.000	2013/06	
VINYL CHLORIDE	39175	072	2007/06/18	.000	2013/06	
XYLENES (TOTAL)	81551	072	2007/06/18	.000	2013/06	
SECONDARY/GP						
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED	2010/07/08	12.300		
BICARBONATE ALKALINITY	00440	036	2010/07/08	452.000	2013/07	
CALCIUM	00916	036	2010/07/08	44.000	2013/07	
CARBONATE ALKALINITY	00445	036	2010/07/08	.000	2013/07	
CHLORIDE	00940	036	2010/07/08	11.000	2013/07	
COLOR	00081	036	2010/07/08	.000	2013/07	
COPPER	01042	036	2010/07/08	.000	2013/07	
FOAMING AGENTS (MBAS)	38260	036	2010/07/08	.000	2013/07	
HARDNESS (TOTAL) AS CACO3	00900	036	2010/07/08	360.000	2013/07	
HYDROXIDE ALKALINITY	71830	036	2010/07/08	.000	2013/07	
IRON	01045	036	2010/07/08	.000	2013/07	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800593***

System Name: ***R RANCH AT THE LAKE***

PS Code: ***2800593-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
MAGNESIUM	00927	036	2010/07/08	61.000	2013/07	
MANGANESE	01055	036	2010/07/08	.000	2013/07	
ODOR THRESHOLD @ 60 C	00086	036	2010/07/08	2.000	2013/07	
PH, LABORATORY	00403	036	2010/07/08	7.200	2013/07	
SILVER	01077	036	2010/07/08	.000	2013/07	
SODIUM	00929	036	2010/07/08	13.000	2013/07	
SPECIFIC CONDUCTANCE	00095	036	2010/07/08	700.000	2013/07	
SULFATE	00945	036	2010/07/08	15.000	2013/07	
TOTAL DISSOLVED SOLIDS	70300	036	2010/07/08	390.000	2013/07	
TURBIDITY, LABORATORY	82079	036	2010/07/08	.110	2013/07	
ZINC	01092	036	2010/07/08	.000	2013/07	

PS Code: ***2800593-003***

Source Name: ***WELL #3***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED				

INORGANIC

ALUMINUM	01105	036	2007/06/18	< 50.000	2010/06	DUE
ANTIMONY	01097	036	2007/06/18	.000	2010/06	DUE
ARSENIC	01002	036	2007/06/18	< 2.000	2010/06	DUE
ASBESTOS	81855	108	2005/06/09	< 2.200	2014/06	
BARIUM	01007	036	2007/06/18	120.000	2010/06	DUE
BERYLLIUM	01012	036	2007/06/18	< 1.000	2010/06	DUE
CADMIUM	01027	036	2007/06/18	.000	2010/06	DUE
CHROMIUM (TOTAL)	01034	036	2007/06/18	2.900	2010/06	DUE
CYANIDE	01291	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800593***

System Name: ***R RANCH AT THE LAKE***

PS Code: ***2800593-003***

Source Name: ***WELL #3***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
INORGANIC						
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2007/06/18	.180	2010/06	DUE
LEAD	01051	WAIVED	2007/06/18	< 5.000		
MERCURY	71900	036	2007/06/18	< 1.000	2010/06	DUE
NICKEL	01067	036	2007/06/18	< 10.000	2010/06	DUE
PERCHLORATE	A-031	036	2008/10/01	< 4.000	2011/10	DUE
SELENIUM	01147	036	2007/06/18	< 5.000	2010/06	DUE
THALLIUM	01059	036	2007/06/18	< 1.000	2010/06	DUE
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2008/11/14	6.500	2009/11	DUE
NITRITE (AS N)	00620	036	2007/06/18	< 400.000	2010/06	DUE
RADIOLOGICAL						
GROSS ALPHA	01501	108	2008/11/14	.097	2017/11	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED	2008/05/29	.063		
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED	2008/05/29	.175		
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED	2009/03/27	.131		
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED	2008/05/29	.373		
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED	2008/05/29	.279		
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	108	2007/06/18	.000	2016/06	
2,4-D	39730	108	2007/06/18	.000	2016/06	
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	036	2007/06/18	.000	2010/06	DUE
BENTAZON	38710	WAIVED	2007/06/18	.000		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800593***

System Name: ***R RANCH AT THE LAKE***

PS Code: ***2800593-003***

Source Name: ***WELL #3***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2007/06/18	.000	2010/06	DUE
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2007/06/18	.000	2010/06	DUE
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	036	2007/06/18	.000	2010/06	DUE
DIQUAT	78885	036	2007/06/18	.000	2010/06	DUE
ENDOTHALL	38926	036	2007/06/18	.000	2010/06	DUE
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	000				DUE
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				DUE
HEPTACHLOR EPOXIDE	39420	000				DUE
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				DUE
METHOXYCHLOR	39480	000				DUE
MOLINATE	82199	WAIVED				
OXAMYL	38865	036	2007/06/18	.000	2010/06	DUE
PENTACHLOROPHENOL	39032	036	2007/06/18	.000	2010/06	DUE
PICLORAM	39720	036	2007/06/18	.000	2010/06	DUE
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2007/06/18	.000	2010/06	DUE
THIOBENCARB	A-001	WAIVED				
TOXAPHENE	39400	000				DUE
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2007/06/18	.000	2013/06	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800593***

System Name: ***R RANCH AT THE LAKE***

PS Code: ***2800593-003***

Source Name: ***WELL #3***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED VOC						
1,1,2,2-TETRACHLOROETHANE	34516	072	2007/06/18	.000	2013/06	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2007/06/18	.000	2013/06	
1,1,2-TRICHLOROETHANE	34511	072	2007/06/18	.000	2013/06	
1,1-DICHLOROETHANE	34496	072	2007/06/18	.000	2013/06	
1,1-DICHLOROETHYLENE	34501	072	2007/06/18	.000	2013/06	
1,2,4-TRICHLOROBENZENE	34551	072	2007/06/18	.000	2013/06	
1,2-DICHLOROBENZENE	34536	072	2007/06/18	.000	2013/06	
1,2-DICHLOROETHANE	34531	072	2007/06/18	.000	2013/06	
1,2-DICHLOROPROPANE	34541	072	2007/06/18	.000	2013/06	
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2007/06/18	.000	2013/06	
1,4-DICHLOROBENZENE	34571	072	2007/06/18	.000	2013/06	
BENZENE	34030	072	2007/06/18	.000	2013/06	
CARBON TETRACHLORIDE	32102	072	2007/06/18	.000	2013/06	
CIS-1,2-DICHLOROETHYLENE	77093	072	2007/06/18	.000	2013/06	
DICHLOROMETHANE	34423	072	2007/06/18	.000	2013/06	
ETHYLBENZENE	34371	072	2007/06/18	.000	2013/06	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	036	**2007/06/18**	.000	**2010/06**	**DUE**
MONOCHLOROBENZENE	34301	072	2007/06/18	.000	2013/06	
STYRENE	77128	072	2007/06/18	.000	2013/06	
TETRACHLOROETHYLENE	34475	072	2007/06/18	.000	2013/06	
TOLUENE	34010	072	2007/06/18	.000	2013/06	
TRANS-1,2-DICHLOROETHYLENE	34546	072	2007/06/18	.000	2013/06	
TRICHLOROETHYLENE	39180	072	2007/06/18	.000	2013/06	
TRICHLOROFLUOROMETHANE	34488	072	2007/06/18	.000	2013/06	
VINYL CHLORIDE	39175	072	2007/06/18	.000	2013/06	
XYLENES (TOTAL)	81551	072	2007/06/18	.000	2013/06	
SECONDARY/GP						
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED	2007/06/18	12.000		
BICARBONATE ALKALINITY	00440	036	**2007/06/18**	390.000	**2010/06**	**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800593***

System Name: ***R RANCH AT THE LAKE***

PS Code: ***2800593-003***

Source Name: ***WELL #3***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
CALCIUM	00916	036	2007/06/18	44.000	2010/06	DUE
CARBONATE ALKALINITY	00445	036	2007/06/18	< 1.000	2010/06	DUE
CHLORIDE	00940	036	2007/06/18	12.000	2010/06	DUE
COLOR	00081	036	2007/06/18	5.000	2010/06	DUE
COPPER	01042	036	2007/06/18	< 50.000	2010/06	DUE
FOAMING AGENTS (MBAS)	38260	036	2007/06/18	< .050	2010/06	DUE
HARDNESS (TOTAL) AS CACO3	00900	036	2007/06/18	340.000	2010/06	DUE
HYDROXIDE ALKALINITY	71830	036	2007/06/18	< 1.000	2010/06	DUE
IRON	01045	036	2007/06/18	< 100.000	2010/06	DUE
MAGNESIUM	00927	036	2007/06/18	57.000	2010/06	DUE
MANGANESE	01055	036	2007/06/18	< 20.000	2010/06	DUE
ODOR THRESHOLD @ 60 C	00086	036	2007/06/18	< 1.000	2010/06	DUE
PH, LABORATORY	00403	036	2007/06/18	7.100	2010/06	DUE
SILVER	01077	036	2007/06/18	< 10.000	2010/06	DUE
SODIUM	00929	036	2007/06/18	11.000	2010/06	DUE
SPECIFIC CONDUCTANCE	00095	036	2007/06/18	670.000	2010/06	DUE
SULFATE	00945	036	2007/06/18	19.000	2010/06	DUE
TOTAL DISSOLVED SOLIDS	70300	036	2007/06/18	370.000	2010/06	DUE
TURBIDITY, LABORATORY	82079	036	2007/06/18	.410	2010/06	DUE
ZINC	01092	036	2007/06/18	< 50.000	2010/06	DUE

PS Code: ***2800593-004***

Source Name: ***WELL #4***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800593***

System Name: ***R RANCH AT THE LAKE***

PS Code: ***2800593-004***

Source Name: ***WELL #4***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
INORGANIC						
ALUMINUM	01105	036	2010/07/08	.000	2013/07	
ANTIMONY	01097	036	2010/07/08	.000	2013/07	
ARSENIC	01002	036	2010/07/08	.000	2013/07	
ASBESTOS	81855	000				**DUE**
BARIUM	01007	036	2010/07/08	130.000	2013/07	
BERYLLIUM	01012	036	2010/07/08	.000	2013/07	
CADMIUM	01027	036	2010/07/08	.000	2013/07	
CHROMIUM (TOTAL)	01034	036	2010/07/08	.000	2013/07	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2010/07/08	.000	2013/07	
LEAD	01051	WAIVED	2010/07/08	.000		
MERCURY	71900	036	2010/07/08	.000	2013/07	
NICKEL	01067	036	2010/07/08	.000	2013/07	
PERCHLORATE	A-031	036	2010/06/25	.000	2013/06	
SELENIUM	01147	036	2010/07/08	.000	2013/07	
THALLIUM	01059	036	2010/07/08	.000	2013/07	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	**2010/07/08**	.000	**2011/07**	**DUE**
NITRITE (AS N)	00620	000				**DUE**
RADIOLOGICAL						
GROSS ALPHA	01501	108	2011/04/07	1.170	2020/04	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED	2008/05/29	.000		
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED	2008/05/29	.151		
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED	2011/04/07	1.380		
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED	2008/05/29	.373		
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800593***

System Name: ***R RANCH AT THE LAKE***

PS Code: ***2800593-004***

Source Name: ***WELL #4***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
URANIUM (PCI/L)	28012	WAIVED	2008/05/29	.000		
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	108	2010/06/28	< .000	2019/06	
2,4-D	39730	108	2010/06/28	< .000	2019/06	
ALACHLOR	77825	WAIVED	2010/06/28	< .000		
ATRAZINE	39033	036	2010/06/28	< .000	2013/06	
BENTAZON	38710	WAIVED	2010/06/28	< .000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2010/06/28	< .000	2013/06	
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2010/06/28	< .000	2013/06	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	036	2010/06/28	< .000	2013/06	
DIQUAT	78885	036	2010/06/28	< .000	2013/06	
ENDOTHALL	38926	036	2010/06/28	< .000	2013/06	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	000				**DUE**
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**
METHOXYCHLOR	39480	000				**DUE**
MOLINATE	82199	WAIVED	2010/06/28	< .000		
OXAMYL	38865	036	2010/06/28	< .000	2013/06	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800593***

System Name: ***R RANCH AT THE LAKE***

PS Code: ***2800593-004***

Source Name: ***WELL #4***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
PENTACHLOROPHENOL	39032	036	2010/06/28	< .000	2013/06	
PICLORAM	39720	036	2010/06/28	< .000	2013/06	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2010/06/28	< .000	2013/06	
THIOBENCARB	A-001	WAIVED	2010/06/28	< .000		
TOXAPHENE	39400	000				**DUE**
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	000				**DUE**
1,1,2,2-TETRACHLOROETHANE	34516	000				**DUE**
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	000				**DUE**
1,1,2-TRICHLOROETHANE	34511	000				**DUE**
1,1-DICHLOROETHANE	34496	000				**DUE**
1,1-DICHLOROETHYLENE	34501	000				**DUE**
1,2,4-TRICHLOROBENZENE	34551	000				**DUE**
1,2-DICHLOROBENZENE	34536	000				**DUE**
1,2-DICHLOROETHANE	34531	000				**DUE**
1,2-DICHLOROPROPANE	34541	000				**DUE**
1,3-DICHLOROPROPENE (TOTAL)	34561	000				**DUE**
1,4-DICHLOROBENZENE	34571	000				**DUE**
BENZENE	34030	000				**DUE**
CARBON TETRACHLORIDE	32102	000				**DUE**
CIS-1,2-DICHLOROETHYLENE	77093	000				**DUE**
DICHLOROMETHANE	34423	000				**DUE**
ETHYLBENZENE	34371	000				**DUE**
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	000				**DUE**
MONOCHLOROBENZENE	34301	000				**DUE**
STYRENE	77128	000				**DUE**
TETRACHLOROETHYLENE	34475	000				**DUE**
TOLUENE	34010	000				**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800593***

System Name: ***R RANCH AT THE LAKE***

PS Code: ***2800593-004***

Source Name: ***WELL #4***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED VOC						
TRANS-1,2-DICHLOROETHYLENE	**34546**	**000**				**DUE**
TRICHLOROETHYLENE	**39180**	**000**				**DUE**
TRICHLOROFLUOROMETHANE	**34488**	**000**				**DUE**
VINYL CHLORIDE	**39175**	**000**				**DUE**
XYLENES (TOTAL)	**81551**	**000**				**DUE**
SECONDARY/GP						
AGGRSSIVE INDEX (CORROSIVITY)	**82383**	**WAIVED**	2010/07/08	**12.300**		
BICARBONATE ALKALINITY	**00440**	**036**	2010/07/08	**452.000**	2013/07	
CALCIUM	**00916**	**036**	2010/07/08	**44.000**	2013/07	
CARBONATE ALKALINITY	**00445**	**036**	2010/07/08	**.000**	2013/07	
CHLORIDE	**00940**	**036**	2010/07/08	**11.000**	2013/07	
COLOR	**00081**	**036**	2010/07/08	**.000**	2013/07	
COPPER	**01042**	**036**	2010/07/08	**.000**	2013/07	
FOAMING AGENTS (MBAS)	**38260**	**036**	2010/07/08	**.000**	2013/07	
HARDNESS (TOTAL) AS CACO3	**00900**	**036**	2010/07/08	**360.000**	2013/07	
HYDROXIDE ALKALINITY	**71830**	**036**	2010/07/08	**.000**	2013/07	
IRON	**01045**	**036**	2010/07/08	**.000**	2013/07	
MAGNESIUM	**00927**	**036**	2010/07/08	**61.000**	2013/07	
MANGANESE	**01055**	**036**	2010/07/08	**.000**	2013/07	
ODOR THRESHOLD @ 60 C	**00086**	**036**	2010/07/08	**2.000**	2013/07	
PH, LABORATORY	**00403**	**036**	2010/07/08	**7.200**	2013/07	
SILVER	**01077**	**036**	2010/07/08	**.000**	2013/07	
SODIUM	**00929**	**036**	2010/07/08	**13.000**	2013/07	
SPECIFIC CONDUCTANCE	**00095**	**036**	2010/07/08	**700.000**	2013/07	
SULFATE	**00945**	**036**	2010/07/08	**15.000**	2013/07	
TOTAL DISSOLVED SOLIDS	**70300**	**036**	2010/07/08	**390.000**	2013/07	
TURBIDITY, LABORATORY	**82079**	**036**	2010/07/08	**.110**	2013/07	
ZINC	**01092**	**036**	2010/07/08	**.000**	2013/07	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800593***

System Name: ***R RANCH AT THE LAKE***

PS Code: ***2800593-005***

Source Name: ***TREATMENT PLANT***

Source Number: ***005***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800593***

System Name: ***R RANCH AT THE LAKE***

PS Code: ***2800593-005***

Source Name: ***TREATMENT PLANT***

Source Number: ***005***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800593***

System Name: ***R RANCH AT THE LAKE***

PS Code: ***2800593-005***

Source Name: ***TREATMENT PLANT***

Source Number: ***005***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800593***

System Name: ***R RANCH AT THE LAKE***

PS Code: ***2800593-005***

Source Name: ***TREATMENT PLANT***

Source Number: ***005***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800593***

System Name: ***R RANCH AT THE LAKE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)

PS Code: ***2800593-005***

Source Name: ***TREATMENT PLANT***

Source Number: ***005***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800602***

System Name: ***GLASS MTN TRAILER PARK***

PS Code: ***2800602-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED	2003/06/05	900.000		
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2003/06/05	8.000	2004/06	**DUE**
NITRITE (AS N)	00620	036	2003/06/05	.000	2006/06	**DUE**
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800602***

System Name: ***GLASS MTN TRAILER PARK***

PS Code: ***2800602-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800602***

System Name: ***GLASS MTN TRAILER PARK***

PS Code: ***2800602-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800602***

System Name: ***GLASS MTN TRAILER PARK***

PS Code: ***2800602-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2003/06/05	50.000	
CALCIUM	00916	WAIVED	2003/06/05	7.700	
CARBONATE ALKALINITY	00445	WAIVED	2003/06/05	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2003/06/05	40.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2003/06/05	.000	
IRON	01045	000			**DUE**
MAGNESIUM	00927	WAIVED	2003/06/05	4.400	
MANGANESE	01055	000			**DUE**
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2003/06/05	6.200	
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED	2003/06/05	25.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800602***

System Name: ***GLASS MTN TRAILER PARK***

PS Code: ***2800602-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800602-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800602***

System Name: ***GLASS MTN TRAILER PARK***

PS Code: ***2800602-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800602***

System Name: ***GLASS MTN TRAILER PARK***

PS Code: ***2800602-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800602***

System Name: ***GLASS MTN TRAILER PARK***

PS Code: ***2800602-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800602***

System Name: ***GLASS MTN TRAILER PARK***

PS Code: ***2800602-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800609***

System Name: ***PHELPS VINEYARDS***

PS Code: ***2800609-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2006/10/19	.000		
INORGANIC						
ALUMINUM	01105	036	2006/10/19	.000	2009/10	DUE
ANTIMONY	01097	036	2006/10/19	.000	2009/10	DUE
ARSENIC	01002	036	2006/10/19	5.800	2009/10	DUE
ASBESTOS	81855	108	2011/12/13	.000	2020/12	
BARIUM	01007	036	2006/10/19	110.000	2009/10	DUE
BERYLLIUM	01012	036	2006/10/19	.000	2009/10	DUE
CADMIUM	01027	036	2006/10/19	.000	2009/10	DUE
CHROMIUM (TOTAL)	01034	036	2006/10/19	.000	2009/10	DUE
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2006/10/19	.000	2009/10	DUE
LEAD	01051	WAIVED	2006/10/19	.000		
MERCURY	71900	036	2006/10/19	.000	2009/10	DUE
NICKEL	01067	036	2006/10/19	.000	2009/10	DUE
PERCHLORATE	A-031	036	2008/09/05	.000	2011/09	DUE
SELENIUM	01147	036	2006/10/19	.000	2009/10	DUE
THALLIUM	01059	036	2006/10/19	.000	2009/10	DUE
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/12/13	< .000	2012/12	
NITRITE (AS N)	00620	036	2009/06/05	.000	2012/06	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2009/06/05	3.240	2018/06	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800609***

System Name: ***PHELPS VINEYARDS***

PS Code: ***2800609-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2009/10/06	.000		
2,4-D	39730	WAIVED	2009/10/06	.000		
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	036	2010/04/06	< .000	2013/04	
BENTAZON	38710	WAIVED	2009/10/06	.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2009/10/06	.000	2012/10	
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2009/10/06	.000	2012/10	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2008/10/09	.000		
DINOSEB	81287	036	2009/10/06	.000	2012/10	
DIQUAT	78885	036	2009/10/06	.000	2012/10	
ENDOTHALL	38926	036	2009/10/06	.000	2012/10	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2008/10/09	.000		
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800609***

System Name: ***PHELPS VINEYARDS***

PS Code: ***2800609-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	000				**DUE**
MOLINATE	82199	WAIVED	2006/10/19	.000		
OXAMYL	38865	036	2009/10/06	.000	2012/10	
PENTACHLOROPHENOL	39032	036	2009/10/06	.000	2012/10	
PICLORAM	39720	036	2009/10/06	.000	2012/10	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2010/04/06	< .000	2013/04	
THIOBENCARB	A-001	WAIVED	2006/10/19	.000		
TOXAPHENE	39400	000				**DUE**
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2008/10/09	.000	2014/10	
1,1,2,2-TETRACHLOROETHANE	34516	072	2008/10/09	.000	2014/10	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2008/10/09	.000	2014/10	
1,1,2-TRICHLOROETHANE	34511	072	2008/10/09	.000	2014/10	
1,1-DICHLOROETHANE	34496	072	2008/10/09	.000	2014/10	
1,1-DICHLOROETHYLENE	34501	072	2008/10/09	.000	2014/10	
1,2,4-TRICHLOROBENZENE	34551	072	2008/10/09	.000	2014/10	
1,2-DICHLOROBENZENE	34536	072	2008/10/09	.000	2014/10	
1,2-DICHLOROETHANE	34531	072	2008/10/09	.000	2014/10	
1,2-DICHLOROPROPANE	34541	072	2008/10/09	.000	2014/10	
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2008/10/09	.000	2014/10	
1,4-DICHLOROBENZENE	34571	072	2008/10/09	.000	2014/10	
BENZENE	34030	072	2008/10/09	.000	2014/10	
CARBON TETRACHLORIDE	32102	072	2008/10/09	.000	2014/10	
CIS-1,2-DICHLOROETHYLENE	77093	072	2008/10/09	.000	2014/10	
DICHLOROMETHANE	34423	072	2008/10/09	.000	2014/10	
ETHYLBENZENE	34371	072	2008/10/09	.000	2014/10	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2008/10/09	.000	2014/10	
MONOCHLOROBENZENE	34301	072	2008/10/09	.000	2014/10	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800609***

System Name: ***PHELPS VINEYARDS***

PS Code: ***2800609-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2008/10/09	.000	2014/10
TETRACHLOROETHYLENE	34475	072	2008/10/09	.000	2014/10
TOLUENE	34010	072	2008/10/09	.000	2014/10
TRANS-1,2-DICHLOROETHYLENE	34546	072	2008/10/09	.000	2014/10
TRICHLOROETHYLENE	39180	072	2008/10/09	.000	2014/10
TRICHLOROFLUOROMETHANE	34488	072	2008/10/09	.000	2014/10
VINYL CHLORIDE	39175	072	2008/10/09	.000	2014/10
XYLENES (TOTAL)	81551	072	2008/10/09	.000	2014/10
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2006/10/19	260.000	
CALCIUM	00916	WAIVED	2006/10/19	30.000	
CARBONATE ALKALINITY	00445	WAIVED	2006/10/19	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2006/10/19	200.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2006/10/19	.000	
IRON	01045	WAIVED	2006/10/19	790.000	
MAGNESIUM	00927	WAIVED	2006/10/19	31.000	
MANGANESE	01055	WAIVED	2006/10/19	160.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2006/10/19	7.400	
SILVER	01077	WAIVED	2006/10/19	.000	
SODIUM	00929	WAIVED	2006/10/19	30.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800609***

System Name: ***PHELPS VINEYARDS***

PS Code: ***2800609-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800609-002***

Source Name: ***WELL 2***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED	2006/10/23	.000	
INORGANIC					
ALUMINUM	01105	108	2006/10/23	.000	2015/10
ANTIMONY	01097	108	2006/10/23	.000	2015/10
ARSENIC	01002	108	2006/10/23	4.500	2015/10
ASBESTOS	81855	108	2011/12/13	2.000	2020/12
BARIUM	01007	108	2006/10/23	.000	2015/10
BERYLLIUM	01012	108	2006/10/23	.000	2015/10
CADMIUM	01027	108	2006/10/23	.000	2015/10
CHROMIUM (TOTAL)	01034	108	2006/10/23	.000	2015/10
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	108	2006/10/23	.000	2015/10
LEAD	01051	WAIVED	2006/10/23	.000	
MERCURY	71900	108	2006/10/23	.000	2015/10
NICKEL	01067	108	2006/10/23	.000	2015/10
PERCHLORATE	A-031	108	2008/09/05	.000	2017/09
SELENIUM	01147	108	2006/10/23	.000	2015/10
THALLIUM	01059	108	2006/10/23	.000	2015/10

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800609***

System Name: ***PHELPS VINEYARDS***

PS Code: ***2800609-002***

Source Name: ***WELL 2***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	108	2011/12/13	< .000	2020/12
NITRITE (AS N)	00620	108	2009/06/05	.000	2018/06
RADIOLOGICAL					
GROSS ALPHA	01501	108	2009/06/05	.680	2018/06
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2009/10/06	.000	
2,4-D	39730	WAIVED	2009/10/06	.000	
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED	2010/04/06	< .000	
BENTAZON	38710	WAIVED	2009/10/06	.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED	2009/10/06	.000	
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED	2009/10/06	.000	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2008/10/09	.000	
DINOSEB	81287	WAIVED	2009/10/06	.000	
DIQUAT	78885	WAIVED	2009/10/06	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800609***

System Name: ***PHELPS VINEYARDS***

PS Code: ***2800609-002***

Source Name: ***WELL 2***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED	2009/10/06	.000	
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2008/10/09	.000	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	000			DUE
HEPTACHLOR EPOXIDE	39420	000			DUE
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	000			DUE
METHOXYCHLOR	39480	000			DUE
MOLINATE	82199	WAIVED	2006/10/23	.000	
OXAMYL	38865	WAIVED	2009/10/06	.000	
PENTACHLOROPHENOL	39032	WAIVED	2009/10/06	.000	
PICLORAM	39720	WAIVED	2009/10/06	.000	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED	2010/04/06	< .000	
THIOBENCARB	A-001	WAIVED	2006/10/23	.000	
TOXAPHENE	39400	000			DUE
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED	2008/10/09	.000	
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED	2008/10/09	.000	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED	2008/10/09	.000	
1,1,2-TRICHLOROETHANE	34511	WAIVED	2008/10/09	.000	
1,1-DICHLOROETHANE	34496	WAIVED	2008/10/09	.000	
1,1-DICHLOROETHYLENE	34501	WAIVED	2008/10/09	.000	
1,2,4-TRICHLOROBENZENE	34551	WAIVED	2008/10/09	.000	
1,2-DICHLOROBENZENE	34536	WAIVED	2008/10/09	.000	
1,2-DICHLOROETHANE	34531	WAIVED	2008/10/09	.000	
1,2-DICHLOROPROPANE	34541	WAIVED	2008/10/09	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800609***

System Name: ***PHELPS VINEYARDS***

PS Code: ***2800609-002***

Source Name: ***WELL 2***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED VOC						
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED	2008/10/09	.000		
1,4-DICHLOROBENZENE	34571	WAIVED	2008/10/09	.000		
BENZENE	34030	WAIVED	2008/10/09	.000		
CARBON TETRACHLORIDE	32102	WAIVED	2008/10/09	.000		
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED	2008/10/09	.000		
DICHLOROMETHANE	34423	WAIVED	2008/10/09	.000		
ETHYLBENZENE	34371	WAIVED	2008/10/09	.000		
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	108	2008/10/09	.000	2017/10	
MONOCHLOROBENZENE	34301	WAIVED	2008/10/09	.000		
STYRENE	77128	WAIVED	2008/10/09	.000		
TETRACHLOROETHYLENE	34475	WAIVED	2008/10/09	.000		
TOLUENE	34010	WAIVED	2008/10/09	.000		
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED	2008/10/09	.000		
TRICHLOROETHYLENE	39180	WAIVED	2008/10/09	.000		
TRICHLOROFLUOROMETHANE	34488	WAIVED	2008/10/09	.000		
VINYL CHLORIDE	39175	WAIVED	2008/10/09	.000		
XYLENES (TOTAL)	81551	WAIVED	2008/10/09	.000		
SECONDARY/GP						
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED				
BICARBONATE ALKALINITY	00440	108	2006/10/23	390.000	2015/10	
CALCIUM	00916	108	2006/10/23	10.000	2015/10	
CARBONATE ALKALINITY	00445	108	2006/10/23	.000	2015/10	
CHLORIDE	00940	000				**DUE**
COLOR	00081	000				**DUE**
COPPER	01042	000				**DUE**
FOAMING AGENTS (MBAS)	38260	000				**DUE**
HARDNESS (TOTAL) AS CACO3	00900	108	2006/10/23	62.000	2015/10	
HYDROXIDE ALKALINITY	71830	108	2006/10/23	.000	2015/10	
IRON	01045	108	2006/10/23	.000	2015/10	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800609***

System Name: ***PHELPS VINEYARDS***

PS Code: ***2800609-002***

Source Name: ***WELL 2***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
SECONDARY/GP						
MAGNESIUM	00927	108	2006/10/23	9.600	2015/10	
MANGANESE	01055	108	2006/10/23	23.000	2015/10	
ODOR THRESHOLD @ 60 C	00086	000				DUE
PH, LABORATORY	00403	108	2006/10/23	8.100	2015/10	
SILVER	01077	108	2006/10/23	.000	2015/10	
SODIUM	00929	108	2006/10/23	120.000	2015/10	
SPECIFIC CONDUCTANCE	00095	000				DUE
SULFATE	00945	000				DUE
TOTAL DISSOLVED SOLIDS	70300	000				DUE
TURBIDITY, LABORATORY	82079	000				DUE
ZINC	01092	000				DUE

PS Code: ***2800609-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15				
DIAZINON	39570	WAIVED	2006/10/23	.000
INORGANIC				
ALUMINUM	01105	WAIVED	2006/10/23	.000
ANTIMONY	01097	WAIVED	2006/10/23	.000
ARSENIC	01002	WAIVED	2006/10/23	2.900
ASBESTOS	81855	WAIVED	2011/12/13	.000
BARIUM	01007	WAIVED	2006/10/23	.000
BERYLLIUM	01012	WAIVED	2006/10/23	.000
CADMIUM	01027	WAIVED	2006/10/23	.000
CHROMIUM (TOTAL)	01034	WAIVED	2006/10/23	.000
CYANIDE	01291	WAIVED		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800609***

System Name: ***PHELPS VINEYARDS***

PS Code: ***2800609-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2006/10/23	.000	
LEAD	01051	WAIVED	2006/10/23	10.000	
MERCURY	71900	WAIVED	2006/10/23	.000	
NICKEL	01067	WAIVED	2006/10/23	.000	
PERCHLORATE	A-031	WAIVED	2008/09/05	.000	
SELENIUM	01147	WAIVED	2006/10/23	.000	
THALLIUM	01059	WAIVED	2006/10/23	.000	
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED	2011/12/13	< .000	
NITRITE (AS N)	00620	WAIVED	2009/06/05	.000	
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED	2009/06/05	2.450	
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2009/10/06	.000	
2,4-D	39730	WAIVED	2009/10/06	.000	
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED	2010/04/06	< .000	
BENTAZON	38710	WAIVED	2009/10/06	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800609***

System Name: ***PHELPS VINEYARDS***

PS Code: ***2800609-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED	2009/10/06	.000	
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED	2009/10/06	.000	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2008/10/09	.000	
DINOSEB	81287	WAIVED	2009/10/06	.000	
DIQUAT	78885	WAIVED	2009/10/06	.000	
ENDOTHALL	38926	WAIVED	2009/10/06	.000	
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2008/10/09	.000	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED	2006/10/23	.000	
OXAMYL	38865	WAIVED	2009/10/06	.000	
PENTACHLOROPHENOL	39032	WAIVED	2009/10/06	.000	
PICLORAM	39720	WAIVED	2009/10/06	.000	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED	2010/04/06	< .000	
THIOBENCARB	A-001	WAIVED	2006/10/23	.000	
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED	2008/10/09	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800609***

System Name: ***PHELPS VINEYARDS***

PS Code: ***2800609-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED	2008/10/09	.000	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED	2008/10/09	.000	
1,1,2-TRICHLOROETHANE	34511	WAIVED	2008/10/09	.000	
1,1-DICHLOROETHANE	34496	WAIVED	2008/10/09	.000	
1,1-DICHLOROETHYLENE	34501	WAIVED	2008/10/09	.000	
1,2,4-TRICHLOROBENZENE	34551	WAIVED	2008/10/09	.000	
1,2-DICHLOROBENZENE	34536	WAIVED	2008/10/09	.000	
1,2-DICHLOROETHANE	34531	WAIVED	2008/10/09	.000	
1,2-DICHLOROPROPANE	34541	WAIVED	2008/10/09	.000	
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED	2008/10/09	.000	
1,4-DICHLOROBENZENE	34571	WAIVED	2008/10/09	.000	
BENZENE	34030	WAIVED	2008/10/09	.000	
CARBON TETRACHLORIDE	32102	WAIVED	2008/10/09	.000	
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED	2008/10/09	.000	
DICHLOROMETHANE	34423	WAIVED	2008/10/09	.000	
ETHYLBENZENE	34371	WAIVED	2008/10/09	.000	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED	2008/10/09	.000	
MONOCHLOROBENZENE	34301	WAIVED	2008/10/09	.000	
STYRENE	77128	WAIVED	2008/10/09	.000	
TETRACHLOROETHYLENE	34475	WAIVED	2008/10/09	.000	
TOLUENE	34010	WAIVED	2008/10/09	.000	
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED	2008/10/09	.000	
TRICHLOROETHYLENE	39180	WAIVED	2008/10/09	.000	
TRICHLOROFLUOROMETHANE	34488	WAIVED	2008/10/09	.000	
VINYL CHLORIDE	39175	WAIVED	2008/10/09	.000	
XYLENES (TOTAL)	81551	WAIVED	2008/10/09	.000	
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2006/10/23	160.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800609***

System Name: ***PHELPS VINEYARDS***

PS Code: ***2800609-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED	2006/10/23	17.000	
CARBONATE ALKALINITY	00445	WAIVED	2006/10/23	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2006/10/23	100.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2006/10/23	.000	
IRON	01045	WAIVED	2006/10/23	.000	
MAGNESIUM	00927	WAIVED	2006/10/23	13.000	
MANGANESE	01055	WAIVED	2006/10/23	70.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2006/10/23	6.800	
SILVER	01077	WAIVED	2006/10/23	.000	
SODIUM	00929	WAIVED	2006/10/23	30.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800613***

System Name: ***LOKOYA REDWOODS***

PS Code: ***2800613-001***

Source Name: ***SPRING 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2010/06/07	< .025		
INORGANIC						
ALUMINUM	01105	036	2010/06/07	< 50.000	2013/06	
ANTIMONY	01097	036	2010/06/07	< 6.000	2013/06	
ARSENIC	01002	036	2010/06/07	< 2.000	2013/06	
ASBESTOS	81855	000				**DUE**
BARIUM	01007	036	2010/06/07	< 100.000	2013/06	
BERYLLIUM	01012	036	2010/06/07	< 1.000	2013/06	
CADMIUM	01027	036	2010/06/07	< 1.000	2013/06	
CHROMIUM (TOTAL)	01034	036	2010/06/07	< 1.000	2013/06	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	**2007/06/14**	< .100	**2010/06**	**DUE**
LEAD	01051	WAIVED	2007/06/14	< 5.000		
MERCURY	71900	036	2010/06/07	< 1.000	2013/06	
NICKEL	01067	036	2010/06/07	< 10.000	2013/06	
PERCHLORATE	A-031	036	2010/07/21	< 4.000	2013/07	
SELENIUM	01147	036	2010/06/07	< 5.000	2013/06	
THALLIUM	01059	036	2010/06/07	< 1.000	2013/06	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	**2010/06/07**	4.200	**2011/06**	**DUE**
NITRITE (AS N)	00620	036	2010/06/07	< 400.000	2013/06	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2009/05/07	2.450	2018/05	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED	2009/05/07	1.450		
RADIUM 228	11501	WAIVED	2009/05/07	1.280		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800613***

System Name: ***LOKOYA REDWOODS***

PS Code: ***2800613-001***

Source Name: ***SPRING 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	108	2010/06/07	.000	2019/06	
2,4-D	39730	108	2010/06/07	.000	2019/06	
ALACHLOR	77825	WAIVED	2010/06/07	.000		
ATRAZINE	39033	036	2010/06/07	.000	2013/06	
BENTAZON	38710	WAIVED	2010/06/07	.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2010/06/07	.000	2013/06	
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2010/06/07	.000	2013/06	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	036	2010/06/07	.000	2013/06	
DIQUAT	78885	036	2010/06/07	.000	2013/06	
ENDOTHALL	38926	036	2010/06/07	.000	2013/06	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	000				**DUE**
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800613***

System Name: ***LOKOYA REDWOODS***

PS Code: ***2800613-001***

Source Name: ***SPRING 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	000				DUE
MOLINATE	82199	WAIVED	2010/06/07	.000		
OXAMYL	38865	036	2010/06/07	.000	2013/06	
PENTACHLOROPHENOL	39032	036	2010/06/07	.000	2013/06	
PICLORAM	39720	036	2010/06/07	.000	2013/06	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2010/06/07	.000	2013/06	
THIOBENCARB	A-001	WAIVED	2010/06/07	.000		
TOXAPHENE	39400	000				DUE
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2009/02/12	.000	2015/02	
1,1,2,2-TETRACHLOROETHANE	34516	072	2009/02/12	.000	2015/02	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2009/02/12	.000	2015/02	
1,1,2-TRICHLOROETHANE	34511	072	2009/02/12	.000	2015/02	
1,1-DICHLOROETHANE	34496	072	2009/02/12	.000	2015/02	
1,1-DICHLOROETHYLENE	34501	072	2009/02/12	.000	2015/02	
1,2,4-TRICHLOROBENZENE	34551	072	2009/02/12	.000	2015/02	
1,2-DICHLOROBENZENE	34536	072	2009/02/12	.000	2015/02	
1,2-DICHLOROETHANE	34531	072	2009/02/12	.000	2015/02	
1,2-DICHLOROPROPANE	34541	072	2009/02/12	.000	2015/02	
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2009/02/12	.000	2015/02	
1,4-DICHLOROBENZENE	34571	072	2009/02/12	.000	2015/02	
BENZENE	34030	072	2009/02/12	.000	2015/02	
CARBON TETRACHLORIDE	32102	072	2009/02/12	.000	2015/02	
CIS-1,2-DICHLOROETHYLENE	77093	072	2009/02/12	.000	2015/02	
DICHLOROMETHANE	34423	072	2009/02/12	.000	2015/02	
ETHYLBENZENE	34371	072	2009/02/12	.000	2015/02	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	036	**2009/02/12**	.000	**2012/02**	DUE
MONOCHLOROBENZENE	34301	072	2009/02/12	.000	2015/02	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800613***

System Name: ***LOKOYA REDWOODS***

PS Code: ***2800613-001***

Source Name: ***SPRING 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2009/02/12	.000	2015/02
TETRACHLOROETHYLENE	34475	072	2009/02/12	.000	2015/02
TOLUENE	34010	072	2009/02/12	.000	2015/02
TRANS-1,2-DICHLOROETHYLENE	34546	072	2009/02/12	.000	2015/02
TRICHLOROETHYLENE	39180	072	2009/02/12	.000	2015/02
TRICHLOROFLUOROMETHANE	34488	072	2009/02/12	.000	2015/02
VINYL CHLORIDE	39175	072	2009/02/12	.000	2015/02
XYLENES (TOTAL)	81551	072	2009/02/12	.000	2015/02
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED	2010/06/07	10.800	
BICARBONATE ALKALINITY	00440	036	2010/06/07	110.000	2013/06
CALCIUM	00916	036	2010/06/07	19.000	2013/06
CARBONATE ALKALINITY	00445	036	2010/06/07	< 1.000	2013/06
CHLORIDE	00940	036	2010/06/07	3.800	2013/06
COLOR	00081	036	2010/06/07	5.000	2013/06
COPPER	01042	036	2010/06/07	< 50.000	2013/06
FOAMING AGENTS (MBAS)	38260	036	2010/06/07	< .050	2013/06
HARDNESS (TOTAL) AS CACO3	00900	036	2010/06/07	93.000	2013/06
HYDROXIDE ALKALINITY	71830	036	2010/06/07	< 1.000	2013/06
IRON	01045	036	2010/06/07	< 100.000	2013/06
MAGNESIUM	00927	036	2010/06/07	11.000	2013/06
MANGANESE	01055	036	2010/06/07	< 20.000	2013/06
ODOR THRESHOLD @ 60 C	00086	036	2010/06/07	1.200	2013/06
PH, LABORATORY	00403	036	2010/06/07	7.200	2013/06
SILVER	01077	036	2010/06/07	< 10.000	2013/06
SODIUM	00929	036	2010/06/07	8.100	2013/06
SPECIFIC CONDUCTANCE	00095	036	2010/06/07	190.000	2013/06
SULFATE	00945	036	2010/06/07	7.000	2013/06
TOTAL DISSOLVED SOLIDS	70300	036	2010/06/07	140.000	2013/06

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800613***

System Name: ***LOKOYA REDWOODS***

PS Code: ***2800613-001***

Source Name: ***SPRING 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	036	2010/06/07	.350	2013/06
ZINC	01092	036	2010/06/07	< 50.000	2013/06

PS Code: ***2800613-002***

Source Name: ***WELL 001***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	000			DUE
ANTIMONY	01097	000			DUE
ARSENIC	01002	000			DUE
ASBESTOS	81855	000			DUE
BARIUM	01007	000			DUE
BERYLLIUM	01012	000			DUE
CADMIUM	01027	000			DUE
CHROMIUM (TOTAL)	01034	000			DUE
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	000			DUE
LEAD	01051	WAIVED			
MERCURY	71900	000			DUE
NICKEL	01067	000			DUE
PERCHLORATE	A-031	006			DUE
SELENIUM	01147	000			DUE
THALLIUM	01059	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800613***

System Name: ***LOKOYA REDWOODS***

PS Code: ***2800613-002***

Source Name: ***WELL 001***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	000			DUE
NITRITE (AS N)	00620	000			DUE
RADIOLOGICAL					
GROSS ALPHA	01501	000			DUE
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	000			DUE
2,4-D	39730	000			DUE
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	000			DUE
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	000			DUE
CHLORDANE	39350	WAIVED			
DALAPON	38432	000			DUE
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	000			DUE
DIQUAT	78885	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800613***

System Name: ***LOKOYA REDWOODS***

PS Code: ***2800613-002***

Source Name: ***WELL 001***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	000			DUE
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	000			DUE
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	000			DUE
HEPTACHLOR EPOXIDE	39420	000			DUE
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	000			DUE
METHOXYCHLOR	39480	000			DUE
MOLINATE	82199	WAIVED			
OXAMYL	38865	000			DUE
PENTACHLOROPHENOL	39032	000			DUE
PICLORAM	39720	000			DUE
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	000			DUE
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	000			DUE
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	000			DUE
1,1,2,2-TETRACHLOROETHANE	34516	000			DUE
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	000			DUE
1,1,2-TRICHLOROETHANE	34511	000			DUE
1,1-DICHLOROETHANE	34496	000			DUE
1,1-DICHLOROETHYLENE	34501	000			DUE
1,2,4-TRICHLOROBENZENE	34551	000			DUE
1,2-DICHLOROBENZENE	34536	000			DUE
1,2-DICHLOROETHANE	34531	000			DUE
1,2-DICHLOROPROPANE	34541	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800613***

System Name: ***LOKOYA REDWOODS***

PS Code: ***2800613-002***

Source Name: ***WELL 001***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	000			DUE
1,4-DICHLOROBENZENE	34571	000			DUE
BENZENE	34030	000			DUE
CARBON TETRACHLORIDE	32102	000			DUE
CIS-1,2-DICHLOROETHYLENE	77093	000			DUE
DICHLOROMETHANE	34423	000			DUE
ETHYLBENZENE	34371	000			DUE
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	000			DUE
MONOCHLOROBENZENE	34301	000			DUE
STYRENE	77128	000			DUE
TETRACHLOROETHYLENE	34475	000			DUE
TOLUENE	34010	000			DUE
TRANS-1,2-DICHLOROETHYLENE	34546	000			DUE
TRICHLOROETHYLENE	39180	000			DUE
TRICHLOROFLUOROMETHANE	34488	000			DUE
VINYL CHLORIDE	39175	000			DUE
XYLENES (TOTAL)	81551	000			DUE
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	000			DUE
COLOR	00081	000			DUE
COPPER	01042	000			DUE
FOAMING AGENTS (MBAS)	38260	000			DUE
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800613***

System Name: ***LOKOYA REDWOODS***

PS Code: ***2800613-002***

Source Name: ***WELL 001***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	000			DUE
PH, LABORATORY	00403	000			DUE
SILVER	01077	000			DUE
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	000			DUE
SULFATE	00945	000			DUE
TOTAL DISSOLVED SOLIDS	70300	000			DUE
TURBIDITY, LABORATORY	82079	000			DUE
ZINC	01092	000			DUE

PS Code: ***2800613-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED

INORGANIC

ALUMINUM	01105	WAIVED
ANTIMONY	01097	WAIVED
ARSENIC	01002	WAIVED
ASBESTOS	81855	WAIVED
BARIUM	01007	WAIVED
BERYLLIUM	01012	WAIVED
CADMIUM	01027	WAIVED
CHROMIUM (TOTAL)	01034	WAIVED
CYANIDE	01291	WAIVED

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800613***

System Name: ***LOKOYA REDWOODS***

PS Code: ***2800613-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800613***

System Name: ***LOKOYA REDWOODS***

PS Code: ***2800613-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800613***

System Name: ***LOKOYA REDWOODS***

PS Code: ***2800613-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800613***

System Name: ***LOKOYA REDWOODS***

PS Code: ***2800613-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800621***

System Name: ***MAYACAMAS VINEYARDS***

PS Code: ***2800621-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED	2007/06/07	.000		
ANTIMONY	01097	WAIVED	2007/06/07	.000		
ARSENIC	01002	WAIVED	2007/06/07	4.100		
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED	2007/06/07	.000		
BERYLLIUM	01012	WAIVED	2007/06/07	.000		
CADMIUM	01027	WAIVED	2007/06/07	.000		
CHROMIUM (TOTAL)	01034	WAIVED	2007/06/07	.000		
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED	2007/06/07	.000		
MERCURY	71900	WAIVED	2007/06/07	.000		
NICKEL	01067	WAIVED	2007/06/07	.000		
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED	2007/06/07	.000		
THALLIUM	01059	WAIVED	2007/06/07	.000		
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/04/28	< .000	2012/04	
NITRITE (AS N)	00620	036	2011/04/11	< .000	2014/04	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800621***

System Name: ***MAYACAMAS VINEYARDS***

PS Code: ***2800621-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800621***

System Name: ***MAYACAMAS VINEYARDS***

PS Code: ***2800621-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800621***

System Name: ***MAYACAMAS VINEYARDS***

PS Code: ***2800621-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED	2007/06/07	.000	
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800621***

System Name: ***MAYACAMAS VINEYARDS***

PS Code: ***2800621-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800632***

System Name: ***CANNON PARK WATER CO.***

PS Code: ***2800632-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2004/12/13	13.000	2005/12	**DUE**
NITRITE (AS N)	00620	000				**DUE**
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800632***

System Name: ***CANNON PARK WATER CO.***

PS Code: ***2800632-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800632***

System Name: ***CANNON PARK WATER CO.***

PS Code: ***2800632-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800632***

System Name: ***CANNON PARK WATER CO.***

PS Code: ***2800632-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800632***

System Name: ***CANNON PARK WATER CO.***

PS Code: ***2800632-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800632-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800632***

System Name: ***CANNON PARK WATER CO.***

PS Code: ***2800632-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED	2009/04/08	9.900	
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800632***

System Name: ***CANNON PARK WATER CO.***

PS Code: ***2800632-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800632***

System Name: ***CANNON PARK WATER CO.***

PS Code: ***2800632-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800632***

System Name: ***CANNON PARK WATER CO.***

PS Code: ***2800632-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	000			DUE
ANTIMONY	01097	000			DUE
ARSENIC	01002	000			DUE
ASBESTOS	81855	000			DUE
BARIUM	01007	000			DUE
BERYLLIUM	01012	000			DUE
CADMIUM	01027	000			DUE
CHROMIUM (TOTAL)	01034	000			DUE
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	000			DUE
LEAD	01051	WAIVED			
MERCURY	71900	000			DUE
NICKEL	01067	000			DUE
PERCHLORATE	A-031	006			DUE
SELENIUM	01147	000			DUE
THALLIUM	01059	000			DUE
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	000			DUE
NITRITE (AS N)	00620	000			DUE
RADIOLOGICAL					
GROSS ALPHA	01501	000			DUE
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	000			DUE
2,4-D	39730	000			DUE
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	000			DUE
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	000			DUE
CHLORDANE	39350	WAIVED			
DALAPON	38432	000			DUE
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	000			DUE
DIQUAT	78885	000			DUE
ENDOTHALL	38926	000			DUE
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	000			DUE
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	000			DUE
HEPTACHLOR EPOXIDE	39420	000			DUE
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	000			DUE
MOLINATE	82199	WAIVED			
OXAMYL	38865	000			DUE
PENTACHLOROPHENOL	39032	000			DUE
PICLORAM	39720	000			DUE
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	000			DUE
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	000			DUE
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	000			DUE
1,1,2,2-TETRACHLOROETHANE	34516	000			DUE
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	000			DUE
1,1,2-TRICHLOROETHANE	34511	000			DUE
1,1-DICHLOROETHANE	34496	000			DUE
1,1-DICHLOROETHYLENE	34501	000			DUE
1,2,4-TRICHLOROBENZENE	34551	000			DUE
1,2-DICHLOROBENZENE	34536	000			DUE
1,2-DICHLOROETHANE	34531	000			DUE
1,2-DICHLOROPROPANE	34541	000			DUE
1,3-DICHLOROPROPENE (TOTAL)	34561	000			DUE
1,4-DICHLOROBENZENE	34571	000			DUE
BENZENE	34030	000			DUE
CARBON TETRACHLORIDE	32102	000			DUE
CIS-1,2-DICHLOROETHYLENE	77093	000			DUE
DICHLOROMETHANE	34423	000			DUE
ETHYLBENZENE	34371	000			DUE
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	000			DUE
MONOCHLOROBENZENE	34301	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	000			DUE
TETRACHLOROETHYLENE	34475	000			DUE
TOLUENE	34010	000			DUE
TRANS-1,2-DICHLOROETHYLENE	34546	000			DUE
TRICHLOROETHYLENE	39180	000			DUE
TRICHLOROFLUOROMETHANE	34488	000			DUE
VINYL CHLORIDE	39175	000			DUE
XYLENES (TOTAL)	81551	000			DUE
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800635-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	036	2011/07/28	< 50.000	2014/07
ANTIMONY	01097	036	2011/07/28	< 6.000	2014/07
ARSENIC	01002	036	2011/07/28	< 2.000	2014/07
ASBESTOS	81855	108	2008/01/24	.000	2017/01
BARIUM	01007	036	2011/07/28	< 100.000	2014/07
BERYLLIUM	01012	036	2011/07/28	< 1.000	2014/07
CADMIUM	01027	036	2011/07/28	< 1.000	2014/07
CHROMIUM (TOTAL)	01034	036	2011/07/28	< 1.000	2014/07
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2011/07/28	.190	2014/07
LEAD	01051	WAIVED	2008/04/02	< 5.000	
MERCURY	71900	036	2011/07/28	< 1.000	2014/07
NICKEL	01067	036	2011/07/28	< 10.000	2014/07
PERCHLORATE	A-031	036	2011/07/28	< 4.000	2014/07
SELENIUM	01147	036	2011/07/28	< 5.000	2014/07
THALLIUM	01059	036	2011/07/28	< 1.000	2014/07

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2011/07/28	13.000	2012/07
NITRITE (AS N)	00620	036	2011/07/28	< 400.000	2014/07
RADIOLOGICAL					
GROSS ALPHA	01501	108	2008/10/15	.087	2017/10
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED	2008/10/15	.000	
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2011/07/28	.000	
2,4-D	39730	WAIVED	2011/07/28	.000	
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	036	2011/07/28	.000	2014/07
BENTAZON	38710	WAIVED	2011/07/28	.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	036	2011/07/28	.000	2014/07
CHLORDANE	39350	WAIVED			
DALAPON	38432	036	2011/07/28	.000	2014/07
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	036	2011/07/28	.000	2014/07
DIQUAT	78885	036	2011/07/28	.000	2014/07

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
ENDOTHALL	38926	036	2011/07/28	.000	2014/07	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2008/01/24	.000		
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**
METHOXYCHLOR	39480	000				**DUE**
MOLINATE	82199	WAIVED				
OXAMYL	38865	036	2011/07/28	.000	2014/07	
PENTACHLOROPHENOL	39032	036	2011/07/28	.000	2014/07	
PICLORAM	39720	036	2011/07/28	.000	2014/07	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2011/07/28	.000	2014/07	
THIOBENCARB	A-001	WAIVED				
TOXAPHENE	39400	000				**DUE**
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2008/01/24	.000	2014/01	
1,1,2,2-TETRACHLOROETHANE	34516	072	2008/01/24	.000	2014/01	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2008/01/24	.000	2014/01	
1,1,2-TRICHLOROETHANE	34511	072	2008/01/24	.000	2014/01	
1,1-DICHLOROETHANE	34496	072	2008/01/24	.000	2014/01	
1,1-DICHLOROETHYLENE	34501	072	2008/01/24	.000	2014/01	
1,2,4-TRICHLOROBENZENE	34551	072	2008/01/24	.000	2014/01	
1,2-DICHLOROBENZENE	34536	072	2008/01/24	.000	2014/01	
1,2-DICHLOROETHANE	34531	072	2008/01/24	.000	2014/01	
1,2-DICHLOROPROPANE	34541	072	2008/01/24	.000	2014/01	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2008/01/24	.000	2014/01
1,4-DICHLOROBENZENE	34571	072	2008/01/24	.000	2014/01
BENZENE	34030	072	2008/01/24	.000	2014/01
CARBON TETRACHLORIDE	32102	072	2008/01/24	.000	2014/01
CIS-1,2-DICHLOROETHYLENE	77093	072	2008/01/24	.000	2014/01
DICHLOROMETHANE	34423	072	2008/01/24	.000	2014/01
ETHYLBENZENE	34371	072	2008/01/24	.000	2014/01
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2008/01/24	.000	2014/01
MONOCHLOROBENZENE	34301	072	2008/01/24	.000	2014/01
STYRENE	77128	072	2008/01/24	.000	2014/01
TETRACHLOROETHYLENE	34475	072	2008/01/24	.000	2014/01
TOLUENE	34010	072	2008/01/24	.000	2014/01
TRANS-1,2-DICHLOROETHYLENE	34546	072	2008/01/24	.000	2014/01
TRICHLOROETHYLENE	39180	072	2008/01/24	.000	2014/01
TRICHLOROFLUOROMETHANE	34488	072	2008/01/24	.000	2014/01
VINYL CHLORIDE	39175	072	2008/01/24	.000	2014/01
XYLENES (TOTAL)	81551	072	2008/01/24	.000	2014/01
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2011/07/28	170.000	
CALCIUM	00916	WAIVED	2011/07/28	27.000	
CARBONATE ALKALINITY	00445	WAIVED	2011/07/28	< 1.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2011/07/28	130.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2011/07/28	< 1.000	
IRON	01045	WAIVED	2011/07/28	< 100.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED	2011/07/28	14.000	
MANGANESE	01055	WAIVED	2011/07/28	< 20.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2011/07/28	6.700	
SILVER	01077	WAIVED	2011/07/28	< 10.000	
SODIUM	00929	WAIVED	2011/07/28	23.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800635-003***

Source Name: ***WELL #3***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED			

INORGANIC

ALUMINUM	01105	000			DUE
ANTIMONY	01097	000			DUE
ARSENIC	01002	000			DUE
ASBESTOS	81855	000			DUE
BARIUM	01007	000			DUE
BERYLLIUM	01012	000			DUE
CADMIUM	01027	000			DUE
CHROMIUM (TOTAL)	01034	000			DUE
CYANIDE	01291	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-003***

Source Name: ***WELL #3***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	000			DUE
LEAD	01051	WAIVED			
MERCURY	71900	000			DUE
NICKEL	01067	000			DUE
PERCHLORATE	A-031	006			DUE
SELENIUM	01147	000			DUE
THALLIUM	01059	000			DUE
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	000			DUE
NITRITE (AS N)	00620	000			DUE
RADIOLOGICAL					
GROSS ALPHA	01501	000			DUE
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	000			DUE
2,4-D	39730	000			DUE
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	000			DUE
BENTAZON	38710	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-003***

Source Name: ***WELL #3***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	000			DUE
CHLORDANE	39350	WAIVED			
DALAPON	38432	000			DUE
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	000			DUE
DIQUAT	78885	000			DUE
ENDOTHALL	38926	000			DUE
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	000			DUE
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	000			DUE
HEPTACHLOR EPOXIDE	39420	000			DUE
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	000			DUE
METHOXYCHLOR	39480	000			DUE
MOLINATE	82199	WAIVED			
OXAMYL	38865	000			DUE
PENTACHLOROPHENOL	39032	000			DUE
PICLORAM	39720	000			DUE
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	000			DUE
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	000			DUE
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-003***

Source Name: ***WELL #3***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	000			DUE
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	000			DUE
1,1,2-TRICHLOROETHANE	34511	000			DUE
1,1-DICHLOROETHANE	34496	000			DUE
1,1-DICHLOROETHYLENE	34501	000			DUE
1,2,4-TRICHLOROBENZENE	34551	000			DUE
1,2-DICHLOROBENZENE	34536	000			DUE
1,2-DICHLOROETHANE	34531	000			DUE
1,2-DICHLOROPROPANE	34541	000			DUE
1,3-DICHLOROPROPENE (TOTAL)	34561	000			DUE
1,4-DICHLOROBENZENE	34571	000			DUE
BENZENE	34030	000			DUE
CARBON TETRACHLORIDE	32102	000			DUE
CIS-1,2-DICHLOROETHYLENE	77093	000			DUE
DICHLOROMETHANE	34423	000			DUE
ETHYLBENZENE	34371	000			DUE
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	000			DUE
MONOCHLOROBENZENE	34301	000			DUE
STYRENE	77128	000			DUE
TETRACHLOROETHYLENE	34475	000			DUE
TOLUENE	34010	000			DUE
TRANS-1,2-DICHLOROETHYLENE	34546	000			DUE
TRICHLOROETHYLENE	39180	000			DUE
TRICHLOROFLUOROMETHANE	34488	000			DUE
VINYL CHLORIDE	39175	000			DUE
XYLENES (TOTAL)	81551	000			DUE
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-003***

Source Name: ***WELL #3***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800635-005***

Source Name: ***WELL #5-BISTRO DON GIOVANNI***

Source Number: ***005***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED	2005/11/08	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800635
System Name: STRACK W.D. WATER

PS Code: 2800635-005
Source Name: WELL #5-BISTRO DON GIOVANNI
Source Number: 005
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
ALUMINUM	01105	WAIVED	2012/04/20	< 50.000	
ANTIMONY	01097	WAIVED	2012/04/20	< 6.000	
ARSENIC	01002	WAIVED	2012/04/20	< 2.000	
ASBESTOS	81855	WAIVED	2011/07/28	.000	
BARIUM	01007	WAIVED	2012/04/20	100.000	
BERYLLIUM	01012	WAIVED	2012/04/20	< 1.000	
CADMIUM	01027	WAIVED	2012/04/20	< 1.000	
CHROMIUM (TOTAL)	01034	WAIVED	2012/04/20	< 1.000	
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2012/04/20	.340	
LEAD	01051	WAIVED	2009/04/08	.000	
MERCURY	71900	WAIVED	2012/04/20	< 1.000	
NICKEL	01067	WAIVED	2012/04/20	< 10.000	
PERCHLORATE	A-031	WAIVED	2011/07/28	< 4.000	
SELENIUM	01147	WAIVED	2012/04/20	< 5.000	
THALLIUM	01059	WAIVED	2012/04/20	< 1.000	
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED	2012/04/20	< 2.000	
NITRITE (AS N)	00620	WAIVED	2012/04/20	< 400.000	
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED	2008/10/15	1.010	
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED	2008/10/15	.611	
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-005***

Source Name: ***WELL #5-BISTRO DON GIOVANNI***

Source Number: ***005***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2009/04/15	.000	
2,4-D	39730	WAIVED	2009/04/15	.000	
ALACHLOR	77825	WAIVED	2009/04/08	.000	
ATRAZINE	39033	WAIVED	2009/04/15	.000	
BENTAZON	38710	WAIVED	2009/04/15	.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED	2009/04/15	.000	
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED	2009/04/15	< 20.000	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED	2009/04/15	.000	
DIQUAT	78885	WAIVED	2009/04/15	.000	
ENDOTHALL	38926	WAIVED	2009/04/15	.000	
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED	2009/04/08	.000	
OXAMYL	38865	WAIVED	2009/04/15	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-005***

Source Name: ***WELL #5-BISTRO DON GIOVANNI***

Source Number: ***005***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
PENTACHLOROPHENOL	39032	WAIVED	2009/04/15	.000	
PICLORAM	39720	WAIVED	2009/04/15	.000	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED	2009/04/15	.000	
THIOBENCARB	A-001	WAIVED	2009/04/08	.000	
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED	2008/01/24	.000	
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED	2008/01/24	.000	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED	2008/01/24	.000	
1,1,2-TRICHLOROETHANE	34511	WAIVED	2008/01/24	.000	
1,1-DICHLOROETHANE	34496	WAIVED	2008/01/24	.000	
1,1-DICHLOROETHYLENE	34501	WAIVED	2008/01/24	.000	
1,2,4-TRICHLOROBENZENE	34551	WAIVED	2008/01/24	.000	
1,2-DICHLOROBENZENE	34536	WAIVED	2008/01/24	.000	
1,2-DICHLOROETHANE	34531	WAIVED	2008/01/24	.000	
1,2-DICHLOROPROPANE	34541	WAIVED	2008/01/24	.000	
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED	2008/01/24	.000	
1,4-DICHLOROBENZENE	34571	WAIVED	2008/01/24	.000	
BENZENE	34030	WAIVED	2008/01/24	.000	
CARBON TETRACHLORIDE	32102	WAIVED	2008/01/24	.000	
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED	2008/01/24	.000	
DICHLOROMETHANE	34423	WAIVED	2008/01/24	.000	
ETHYLBENZENE	34371	WAIVED	2008/01/24	.000	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED	2008/01/24	.000	
MONOCHLOROBENZENE	34301	WAIVED	2008/01/24	.000	
STYRENE	77128	WAIVED	2008/01/24	.000	
TETRACHLOROETHYLENE	34475	WAIVED	2008/01/24	.000	
TOLUENE	34010	WAIVED	2008/01/24	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-005***

Source Name: ***WELL #5-BISTRO DON GIOVANNI***

Source Number: ***005***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED	2008/01/24	.000	
TRICHLOROETHYLENE	39180	WAIVED	2008/01/24	.000	
TRICHLOROFLUOROMETHANE	34488	WAIVED	2008/01/24	.000	
VINYL CHLORIDE	39175	WAIVED	2008/01/24	.000	
XYLENES (TOTAL)	81551	WAIVED	2008/01/24	.000	
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2012/04/20	230.000	
CALCIUM	00916	WAIVED	2012/04/20	21.000	
CARBONATE ALKALINITY	00445	WAIVED	2012/04/20	< 1.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2012/04/20	93.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2012/04/20	< 1.000	
IRON	01045	WAIVED	2012/04/20	< 100.000	
MAGNESIUM	00927	WAIVED	2012/04/20	9.900	
MANGANESE	01055	WAIVED	2012/04/20	52.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2012/04/20	7.600	
SILVER	01077	WAIVED	2012/04/20	< 10.000	
SODIUM	00929	WAIVED	2012/04/20	50.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-006***

Source Name: ***TREATMENT PLANT***

Source Number: ***006***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-006***

Source Name: ***TREATMENT PLANT***

Source Number: ***006***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-006***

Source Name: ***TREATMENT PLANT***

Source Number: ***006***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-006***

Source Name: ***TREATMENT PLANT***

Source Number: ***006***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-006***

Source Name: ***TREATMENT PLANT***

Source Number: ***006***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800635-007***

Source Name: ***TREATMENT PLANT***

Source Number: ***007***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-007***

Source Name: ***TREATMENT PLANT***

Source Number: ***007***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-007***

Source Name: ***TREATMENT PLANT***

Source Number: ***007***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-007***

Source Name: ***TREATMENT PLANT***

Source Number: ***007***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-007***

Source Name: ***TREATMENT PLANT***

Source Number: ***007***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800635-008***

Source Name: ***TREATMENT PLANT***

Source Number: ***008***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-008***

Source Name: ***TREATMENT PLANT***

Source Number: ***008***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-008***

Source Name: ***TREATMENT PLANT***

Source Number: ***008***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-008***

Source Name: ***TREATMENT PLANT***

Source Number: ***008***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-008***

Source Name: ***TREATMENT PLANT***

Source Number: ***008***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800635-009***

Source Name: ***TREATMENT PLANT***

Source Number: ***009***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-009***

Source Name: ***TREATMENT PLANT***

Source Number: ***009***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-009***

Source Name: ***TREATMENT PLANT***

Source Number: ***009***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-009***

Source Name: ***TREATMENT PLANT***

Source Number: ***009***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-009***

Source Name: ***TREATMENT PLANT***

Source Number: ***009***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-010***

Source Name: ***TREATMENT PLANT***

Source Number: ***010***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-010***

Source Name: ***TREATMENT PLANT***

Source Number: ***010***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-010***

Source Name: ***TREATMENT PLANT***

Source Number: ***010***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-010***

Source Name: ***TREATMENT PLANT***

Source Number: ***010***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800635***

System Name: ***STRACK W.D. WATER***

PS Code: ***2800635-010***

Source Name: ***TREATMENT PLANT***

Source Number: ***010***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800648***

System Name: ***WINE COUNTRY INN***

PS Code: ***2800648-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED	2010/11/17	< .025	
INORGANIC					
ALUMINUM	01105	036	2011/06/15	< 50.000	2014/06
ANTIMONY	01097	036	2011/06/15	< 6.000	2014/06
ARSENIC	01002	036	2011/11/09	11.000	2014/11
ASBESTOS	81855	108	2010/11/17	.000	2019/11
BARIUM	01007	036	2010/11/17	< 100.000	2013/11
BERYLLIUM	01012	036	2011/06/15	< 1.000	2014/06
CADMIUM	01027	036	2010/11/17	< 1.000	2013/11
CHROMIUM (TOTAL)	01034	036	2010/11/17	< 1.000	2013/11
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2011/06/15	.290	2014/06
LEAD	01051	WAIVED			
MERCURY	71900	036	2010/11/17	< 1.000	2013/11
NICKEL	01067	036	2011/06/15	< 10.000	2014/06
PERCHLORATE	A-031	036	2011/06/15	< 4.000	2014/06
SELENIUM	01147	036	2009/06/03	.000	2012/06
THALLIUM	01059	036	2011/06/15	< 1.000	2014/06
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2011/06/15	7.500	2012/06
NITRITE (AS N)	00620	036	2011/06/15	< 400.000	2014/06
RADIOLOGICAL					
GROSS ALPHA	01501	108	2012/03/14	- .440	2021/03
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800648***

System Name: ***WINE COUNTRY INN***

PS Code: ***2800648-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2010/11/17	.000	
2,4-D	39730	WAIVED	2010/11/17	.000	
ALACHLOR	77825	WAIVED	2010/11/17	.000	
ATRAZINE	39033	036	2010/11/17	.000	2013/11
BENTAZON	38710	WAIVED	2010/11/17	.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	036	2010/11/17	.000	2013/11
CHLORDANE	39350	WAIVED	2010/11/17	.000	
DALAPON	38432	036	2010/11/17	.000	2013/11
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	036	2010/11/17	.000	2013/11
DIQUAT	78885	036	2010/11/17	.000	2013/11
ENDOTHALL	38926	036	2010/11/17	.000	2013/11
ENDRIN	39390	WAIVED	2010/11/17	.000	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2010/11/17	.000	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2010/11/17	.000	
HEPTACHLOR EPOXIDE	39420	WAIVED	2010/11/17	.000	
HEXACHLOROBENZENE	39700	WAIVED	2010/11/17	.000	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2010/11/17	.000	
LINDANE	39340	WAIVED	2010/11/17	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800648***

System Name: ***WINE COUNTRY INN***

PS Code: ***2800648-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED	2010/11/17	.000	
MOLINATE	82199	WAIVED	2010/11/17	.000	
OXAMYL	38865	036	2010/11/17	.000	2013/11
PENTACHLOROPHENOL	39032	036	2010/11/17	.000	2013/11
PICLORAM	39720	036	2010/11/17	.000	2013/11
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	036	2010/11/17	.000	2013/11
THIOBENCARB	A-001	WAIVED	2010/11/17	.000	
TOXAPHENE	39400	WAIVED	2010/11/17	.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	072	2010/11/17	.000	2016/11
1,1,2,2-TETRACHLOROETHANE	34516	072	2010/11/17	.000	2016/11
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2010/11/17	.000	2016/11
1,1,2-TRICHLOROETHANE	34511	072	2010/11/17	.000	2016/11
1,1-DICHLOROETHANE	34496	072	2010/11/17	.000	2016/11
1,1-DICHLOROETHYLENE	34501	072	2010/11/17	.000	2016/11
1,2,4-TRICHLOROBENZENE	34551	072	2010/11/17	.000	2016/11
1,2-DICHLOROBENZENE	34536	072	2010/11/17	.000	2016/11
1,2-DICHLOROETHANE	34531	072	2010/11/17	.000	2016/11
1,2-DICHLOROPROPANE	34541	072	2010/11/17	.000	2016/11
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2010/11/17	.000	2016/11
1,4-DICHLOROBENZENE	34571	072	2010/11/17	.000	2016/11
BENZENE	34030	072	2010/11/17	.000	2016/11
CARBON TETRACHLORIDE	32102	072	2010/11/17	.000	2016/11
CIS-1,2-DICHLOROETHYLENE	77093	072	2010/11/17	.000	2016/11
DICHLOROMETHANE	34423	072	2010/11/17	.000	2016/11
ETHYLBENZENE	34371	072	2010/11/17	.000	2016/11
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2010/11/17	.000	2016/11
MONOCHLOROBENZENE	34301	072	2010/11/17	.000	2016/11

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800648***

System Name: ***WINE COUNTRY INN***

PS Code: ***2800648-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2010/11/17	.000	2016/11
TETRACHLOROETHYLENE	34475	072	2010/11/17	.000	2016/11
TOLUENE	34010	072	2010/11/17	.000	2016/11
TRANS-1,2-DICHLOROETHYLENE	34546	072	2010/11/17	.000	2016/11
TRICHLOROETHYLENE	39180	072	2010/11/17	.000	2016/11
TRICHLOROFLUOROMETHANE	34488	072	2010/11/17	.000	2016/11
VINYL CHLORIDE	39175	072	2010/11/17	.000	2016/11
XYLENES (TOTAL)	81551	072	2010/11/17	.000	2016/11
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2011/06/15	170.000	
CALCIUM	00916	WAIVED	2009/06/03	18.000	
CARBONATE ALKALINITY	00445	WAIVED	2011/06/15	< 1.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2009/06/03	100.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2011/06/15	< 1.000	
IRON	01045	WAIVED	2011/06/15	< 100.000	
MAGNESIUM	00927	WAIVED	2009/06/03	12.000	
MANGANESE	01055	WAIVED	2009/06/03	330.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2011/06/15	6.900	
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED	2010/11/17	21.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800648***

System Name: ***WINE COUNTRY INN***

PS Code: ***2800648-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800648-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED	2012/04/11	< 2.000	
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800648***

System Name: ***WINE COUNTRY INN***

PS Code: ***2800648-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800648***

System Name: ***WINE COUNTRY INN***

PS Code: ***2800648-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800648***

System Name: ***WINE COUNTRY INN***

PS Code: ***2800648-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800648***

System Name: ***WINE COUNTRY INN***

PS Code: ***2800648-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800680
System Name: WILD HORSE VALLEY RANCH

PS Code: 2800680-001
Source Name: LPA REPORTED PRIMARY SOURCE
Source Number: 001
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED	2004/06/15	.000		
ANTIMONY	01097	WAIVED	2004/06/15	.000		
ARSENIC	01002	WAIVED	2004/06/15	.000		
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED	2004/06/15	.000		
BERYLLIUM	01012	WAIVED	2004/06/15	.000		
CADMIUM	01027	WAIVED	2004/06/15	.000		
CHROMIUM (TOTAL)	01034	WAIVED	2004/06/15	.000		
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2004/06/15	.200		
LEAD	01051	WAIVED	2004/06/15	.000		
MERCURY	71900	WAIVED	2004/06/15	.000		
NICKEL	01067	WAIVED	2004/06/15	.000		
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED	2004/06/15	.000		
THALLIUM	01059	WAIVED	2004/06/15	.000		
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2006/11/20	.000	2007/11	DUE
NITRITE (AS N)	00620	036	2004/06/15	.000	2007/06	DUE
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800680***

System Name: ***WILD HORSE VALLEY RANCH***

PS Code: ***2800680-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800680***

System Name: ***WILD HORSE VALLEY RANCH***

PS Code: ***2800680-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800680***

System Name: ***WILD HORSE VALLEY RANCH***

PS Code: ***2800680-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2004/06/15	90.000	
CALCIUM	00916	WAIVED	2004/06/15	8.900	
CARBONATE ALKALINITY	00445	WAIVED	2004/06/15	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2004/06/15	58.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2004/06/15	.000	
IRON	01045	WAIVED	2004/06/15	.000	
MAGNESIUM	00927	WAIVED	2004/06/15	6.100	
MANGANESE	01055	WAIVED	2004/06/15	.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2004/06/15	6.900	
SILVER	01077	WAIVED	2004/06/15	.000	
SODIUM	00929	WAIVED	2004/06/15	13.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800680***

System Name: ***WILD HORSE VALLEY RANCH***

PS Code: ***2800680-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800680-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
DIAZINON	39570	WAIVED			

INORGANIC

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
ALUMINUM	01105	WAIVED	2004/06/15	30.000	
ANTIMONY	01097	WAIVED	2004/06/15	.000	
ARSENIC	01002	WAIVED	2004/06/15	12.000	
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED	2004/06/15	.009	
BERYLLIUM	01012	WAIVED	2004/06/15	.000	
CADMIUM	01027	WAIVED	2004/06/15	.000	
CHROMIUM (TOTAL)	01034	WAIVED	2004/06/15	.007	
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2004/06/15	.300	
LEAD	01051	WAIVED	2004/06/15	.280	
MERCURY	71900	WAIVED	2004/06/15	.000	
NICKEL	01067	WAIVED	2004/06/15	.000	
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED	2004/06/15	.000	
THALLIUM	01059	WAIVED	2004/06/15	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800680
System Name: WILD HORSE VALLEY RANCH

PS Code: 2800680-002
Source Name: WELL #2
Source Number: 002
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2006/11/20	.000	2007/11	DUE
NITRITE (AS N)	00620	036	2004/06/15	.000	2007/06	DUE
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED				
2,4-D	39730	WAIVED				
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	WAIVED				
BENTAZON	38710	WAIVED				
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	WAIVED				
CHLORDANE	39350	WAIVED				
DALAPON	38432	WAIVED				
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	WAIVED				
DIQUAT	78885	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800680***

System Name: ***WILD HORSE VALLEY RANCH***

PS Code: ***2800680-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800680***

System Name: ***WILD HORSE VALLEY RANCH***

PS Code: ***2800680-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2004/06/15	70.000	
CALCIUM	00916	WAIVED	2004/06/15	4.200	
CARBONATE ALKALINITY	00445	WAIVED	2004/06/15	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2004/06/15	32.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2004/06/15	.000	
IRON	01045	WAIVED	2004/06/15	3.400	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800680***

System Name: ***WILD HORSE VALLEY RANCH***

PS Code: ***2800680-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
MAGNESIUM	00927	WAIVED	2004/06/15	1.900	
MANGANESE	01055	WAIVED	2004/06/15	.020	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2004/06/15	7.000	
SILVER	01077	WAIVED	2004/06/15	.000	
SODIUM	00929	WAIVED	2004/06/15	12.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800680-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800680***

System Name: ***WILD HORSE VALLEY RANCH***

PS Code: ***2800680-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800680***

System Name: ***WILD HORSE VALLEY RANCH***

PS Code: ***2800680-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800680***

System Name: ***WILD HORSE VALLEY RANCH***

PS Code: ***2800680-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800680***

System Name: ***WILD HORSE VALLEY RANCH***

PS Code: ***2800680-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800683***

System Name: ***COUNTRY INN, THE***

PS Code: ***2800683-001***

Source Name: ***WEST WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	000			DUE
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	000			DUE
NITRITE (AS N)	00620	000			DUE
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED	2011/02/09	.000	
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800683***

System Name: ***COUNTRY INN, THE***

PS Code: ***2800683-001***

Source Name: ***WEST WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800683***

System Name: ***COUNTRY INN, THE***

PS Code: ***2800683-001***

Source Name: ***WEST WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800683***

System Name: ***COUNTRY INN, THE***

PS Code: ***2800683-001***

Source Name: ***WEST WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800683***

System Name: ***COUNTRY INN, THE***

PS Code: ***2800683-001***

Source Name: ***WEST WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800717***

System Name: ***NAPA PIPE REDEVELOPMENT PARTNERS***

PS Code: ***2800717-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED	2007/04/27	.000	
INORGANIC					
ALUMINUM	01105	036	2010/04/19	.000	2013/04
ANTIMONY	01097	036	2010/04/19	.000	2013/04
ARSENIC	01002	036	2010/04/19	.000	2013/04
ASBESTOS	81855	108	2006/08/28	.000	2015/08
BARIUM	01007	036	2010/04/19	.000	2013/04
BERYLLIUM	01012	036	2010/04/19	.000	2013/04
CADMIUM	01027	036	2010/04/19	.000	2013/04
CHROMIUM (TOTAL)	01034	036	2010/04/19	.000	2013/04
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2010/04/19	.210	2013/04
LEAD	01051	WAIVED	2010/04/19	.000	
MERCURY	71900	036	2010/04/19	.000	2013/04
NICKEL	01067	036	2010/04/19	.000	2013/04
PERCHLORATE	A-031	036	2011/06/09	15.300	2014/06
SELENIUM	01147	036	2010/04/19	.000	2013/04
THALLIUM	01059	036	2010/04/19	.000	2013/04
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2012/04/17	< .000	2013/04
NITRITE (AS N)	00620	036	2010/04/19	.000	2013/04
RADIOLOGICAL					
GROSS ALPHA	01501	108	2010/10/21	2.490	2019/10
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800717***

System Name: ***NAPA PIPE REDEVELOPMENT PARTNERS***

PS Code: ***2800717-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2010/04/19	< .000		
2,4-D	39730	WAIVED	2010/04/19	< .000		
ALACHLOR	77825	WAIVED	2010/04/19	< .000		
ATRAZINE	39033	036	2010/04/19	< .000	2013/04	
BENTAZON	38710	WAIVED	2010/04/19	< .000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	WAIVED	2010/04/19	< .000		
CHLORDANE	39350	WAIVED	2002/06/12	.000		
DALAPON	38432	036	2010/04/19	< .000	2013/04	
DI(2-ETHYLHEXYL)ADIPATE	A-026	000				**DUE**
DI(2-ETHYLHEXYL)PHTHALATE	39100	000				**DUE**
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2009/05/20	.000		
DINOSEB	81287	WAIVED	2010/04/19	< .000		
DIQUAT	78885	WAIVED	2010/04/19	< .000		
ENDOTHALL	38926	WAIVED	2010/04/19	< .000		
ENDRIN	39390	WAIVED	2002/06/12	.000		
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2009/05/20	.000		
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	WAIVED	2002/06/12	.000		
HEPTACHLOR EPOXIDE	39420	WAIVED	2002/06/12	.000		
HEXACHLOROBENZENE	39700	WAIVED	2002/06/12	.000		
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2002/06/12	.000		
LINDANE	39340	WAIVED	2002/06/12	.000		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800717***

System Name: ***NAPA PIPE REDEVELOPMENT PARTNERS***

PS Code: ***2800717-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	WAIVED	2002/06/12	.000		
MOLINATE	82199	WAIVED	2010/04/19	< .000		
OXAMYL	38865	WAIVED	2010/04/19	< .000		
PENTACHLOROPHENOL	39032	WAIVED	2010/04/19	< .000		
PICLORAM	39720	036	2010/04/19	< .000	2013/04	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	036	**2002/06/12**	.000	**2005/06**	**DUE**
SIMAZINE	39055	036	2010/04/19	< .000	2013/04	
THIOBENCARB	A-001	WAIVED	2010/04/19	< .000		
TOXAPHENE	39400	WAIVED	2002/06/12	.000		
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2009/05/20	.000	2015/05	
1,1,2,2-TETRACHLOROETHANE	34516	072	2009/05/20	.000	2015/05	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2009/05/20	.000	2015/05	
1,1,2-TRICHLOROETHANE	34511	072	2009/05/20	.000	2015/05	
1,1-DICHLOROETHANE	34496	072	2009/05/20	.000	2015/05	
1,1-DICHLOROETHYLENE	34501	072	2009/05/20	.000	2015/05	
1,2,4-TRICHLOROBENZENE	34551	072	2009/05/20	.000	2015/05	
1,2-DICHLOROBENZENE	34536	072	2009/05/20	.000	2015/05	
1,2-DICHLOROETHANE	34531	072	2009/05/20	.000	2015/05	
1,2-DICHLOROPROPANE	34541	072	2009/05/20	.000	2015/05	
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2009/05/20	.000	2015/05	
1,4-DICHLOROBENZENE	34571	072	2009/05/20	.000	2015/05	
BENZENE	34030	072	2009/05/20	.000	2015/05	
CARBON TETRACHLORIDE	32102	072	2009/05/20	.000	2015/05	
CIS-1,2-DICHLOROETHYLENE	77093	072	2009/05/20	.000	2015/05	
DICHLOROMETHANE	34423	072	2009/05/20	.000	2015/05	
ETHYLBENZENE	34371	072	2009/05/20	.000	2015/05	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2009/05/20	.000	2015/05	
MONOCHLOROBENZENE	34301	072	2009/05/20	.000	2015/05	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800717***

System Name: ***NAPA PIPE REDEVELOPMENT PARTNERS***

PS Code: ***2800717-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2009/05/20	.000	2015/05
TETRACHLOROETHYLENE	34475	072	2009/05/20	.000	2015/05
TOLUENE	34010	072	2009/05/20	.000	2015/05
TRANS-1,2-DICHLOROETHYLENE	34546	072	2009/05/20	.000	2015/05
TRICHLOROETHYLENE	39180	072	2009/05/20	.000	2015/05
TRICHLOROFLUOROMETHANE	34488	072	2009/05/20	.000	2015/05
VINYL CHLORIDE	39175	072	2009/05/20	.000	2015/05
XYLENES (TOTAL)	81551	072	2009/05/20	.000	2015/05
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2010/04/19	190.000	
CALCIUM	00916	WAIVED	2010/04/19	34.000	
CARBONATE ALKALINITY	00445	WAIVED	2010/04/19	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2010/04/19	160.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2010/04/19	.000	
IRON	01045	WAIVED	2010/04/19	250.000	
MAGNESIUM	00927	WAIVED	2010/04/19	19.000	
MANGANESE	01055	WAIVED	2010/04/19	41.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2010/04/19	7.600	
SILVER	01077	WAIVED	2010/04/19	.000	
SODIUM	00929	WAIVED	2010/04/19	58.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800717***

System Name: ***NAPA PIPE REDEVELOPMENT PARTNERS***

PS Code: ***2800717-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800717-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	000			DUE
ANTIMONY	01097	000			DUE
ARSENIC	01002	000			DUE
ASBESTOS	81855	000			DUE
BARIUM	01007	000			DUE
BERYLLIUM	01012	000			DUE
CADMIUM	01027	000			DUE
CHROMIUM (TOTAL)	01034	000			DUE
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	000			DUE
LEAD	01051	WAIVED			
MERCURY	71900	000			DUE
NICKEL	01067	000			DUE
PERCHLORATE	A-031	006			DUE
SELENIUM	01147	000			DUE
THALLIUM	01059	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800717***

System Name: ***NAPA PIPE REDEVELOPMENT PARTNERS***

PS Code: ***2800717-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	000				DUE
NITRITE (AS N)	00620	000				DUE
RADIOLOGICAL						
GROSS ALPHA	01501	108	2007/12/31	.610	2016/12	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED				
2,4-D	39730	WAIVED				
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	000				DUE
BENTAZON	38710	WAIVED				
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	WAIVED				
CHLORDANE	39350	WAIVED				
DALAPON	38432	000				DUE
DI(2-ETHYLHEXYL)ADIPATE	A-026	000				DUE
DI(2-ETHYLHEXYL)PHTHALATE	39100	000				DUE
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	WAIVED				
DIQUAT	78885	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800717***

System Name: ***NAPA PIPE REDEVELOPMENT PARTNERS***

PS Code: ***2800717-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	000			DUE
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	000			DUE
SIMAZINE	39055	000			DUE
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	000			DUE
1,1,2,2-TETRACHLOROETHANE	34516	000			DUE
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	000			DUE
1,1,2-TRICHLOROETHANE	34511	000			DUE
1,1-DICHLOROETHANE	34496	000			DUE
1,1-DICHLOROETHYLENE	34501	000			DUE
1,2,4-TRICHLOROBENZENE	34551	000			DUE
1,2-DICHLOROBENZENE	34536	000			DUE
1,2-DICHLOROETHANE	34531	000			DUE
1,2-DICHLOROPROPANE	34541	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800717***

System Name: ***NAPA PIPE REDEVELOPMENT PARTNERS***

PS Code: ***2800717-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	000			DUE
1,4-DICHLOROBENZENE	34571	000			DUE
BENZENE	34030	000			DUE
CARBON TETRACHLORIDE	32102	000			DUE
CIS-1,2-DICHLOROETHYLENE	77093	000			DUE
DICHLOROMETHANE	34423	000			DUE
ETHYLBENZENE	34371	000			DUE
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	000			DUE
MONOCHLOROBENZENE	34301	000			DUE
STYRENE	77128	000			DUE
TETRACHLOROETHYLENE	34475	000			DUE
TOLUENE	34010	000			DUE
TRANS-1,2-DICHLOROETHYLENE	34546	000			DUE
TRICHLOROETHYLENE	39180	000			DUE
TRICHLOROFLUOROMETHANE	34488	000			DUE
VINYL CHLORIDE	39175	000			DUE
XYLENES (TOTAL)	81551	000			DUE
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800717***

System Name: ***NAPA PIPE REDEVELOPMENT PARTNERS***

PS Code: ***2800717-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800717-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800717***

System Name: ***NAPA PIPE REDEVELOPMENT PARTNERS***

PS Code: ***2800717-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800717***

System Name: ***NAPA PIPE REDEVELOPMENT PARTNERS***

PS Code: ***2800717-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800717***

System Name: ***NAPA PIPE REDEVELOPMENT PARTNERS***

PS Code: ***2800717-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800717***

System Name: ***NAPA PIPE REDEVELOPMENT PARTNERS***

PS Code: ***2800717-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800719***

System Name: ***MUND S MOBILE HOME PARK***

PS Code: ***2800719-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2010/07/14	4.800	2011/07	**DUE**
NITRITE (AS N)	00620	036	2010/07/14	< 400.000	2013/07	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800719***

System Name: ***MUND S MOBILE HOME PARK***

PS Code: ***2800719-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800719***

System Name: ***MUND S MOBILE HOME PARK***

PS Code: ***2800719-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800719***

System Name: ***MUND S MOBILE HOME PARK***

PS Code: ***2800719-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800719***

System Name: ***MUND S MOBILE HOME PARK***

PS Code: ***2800719-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800724***

System Name: ***MAPES HEIGHTS MUTUAL WATER CO***

PS Code: ***2800724-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	000			DUE
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	000			DUE
NITRITE (AS N)	00620	000			DUE
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800724***

System Name: ***MAPES HEIGHTS MUTUAL WATER CO***

PS Code: ***2800724-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800724***

System Name: ***MAPES HEIGHTS MUTUAL WATER CO***

PS Code: ***2800724-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800724***

System Name: ***MAPES HEIGHTS MUTUAL WATER CO***

PS Code: ***2800724-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800724***

System Name: ***MAPES HEIGHTS MUTUAL WATER CO***

PS Code: ***2800724-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800724-002***

Source Name: ***WELL 01***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	000			DUE
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800724***

System Name: ***MAPES HEIGHTS MUTUAL WATER CO***

PS Code: ***2800724-002***

Source Name: ***WELL 01***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	000			DUE
NITRITE (AS N)	00620	000			DUE
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800724***

System Name: ***MAPES HEIGHTS MUTUAL WATER CO***

PS Code: ***2800724-002***

Source Name: ***WELL 01***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800724***

System Name: ***MAPES HEIGHTS MUTUAL WATER CO***

PS Code: ***2800724-002***

Source Name: ***WELL 01***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800724***

System Name: ***MAPES HEIGHTS MUTUAL WATER CO***

PS Code: ***2800724-002***

Source Name: ***WELL 01***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
MAGNESIUM	**00927**	**000**				**DUE**
MANGANESE	**01055**	**000**				**DUE**
ODOR THRESHOLD @ 60 C	**00086**	**WAIVED**				
PH, LABORATORY	**00403**	**000**				**DUE**
SILVER	**01077**	**WAIVED**				
SODIUM	**00929**	**000**				**DUE**
SPECIFIC CONDUCTANCE	**00095**	**WAIVED**				
SULFATE	**00945**	**WAIVED**				
TOTAL DISSOLVED SOLIDS	**70300**	**WAIVED**				
TURBIDITY, LABORATORY	**82079**	**WAIVED**				
ZINC	**01092**	**WAIVED**				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800734***

System Name: ***WOODLOT ASSOC.,INC.***

PS Code: ***2800734-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	000			DUE
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	000			DUE
NITRITE (AS N)	00620	000			DUE
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800734***

System Name: ***WOODLOT ASSOC.,INC.***

PS Code: ***2800734-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800734***

System Name: ***WOODLOT ASSOC.,INC.***

PS Code: ***2800734-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800734***

System Name: ***WOODLOT ASSOC.,INC.***

PS Code: ***2800734-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800734***

System Name: ***WOODLOT ASSOC.,INC.***

PS Code: ***2800734-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800736***

System Name: ***DOMAINE CHANDON***

PS Code: ***2800736-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2008/04/22	< .250		
INORGANIC						
ALUMINUM	01105	036	2010/12/15	.000	2013/12	
ANTIMONY	01097	036	2010/12/15	.000	2013/12	
ARSENIC	01002	036	2010/12/15	2.800	2013/12	
ASBESTOS	81855	000				**DUE**
BARIUM	01007	036	2010/12/15	.000	2013/12	
BERYLLIUM	01012	036	2010/12/15	.000	2013/12	
CADMIUM	01027	036	2010/12/15	.000	2013/12	
CHROMIUM (TOTAL)	01034	036	2010/12/15	.000	2013/12	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2010/12/15	.000	2013/12	
LEAD	01051	WAIVED	2010/12/15	.000		
MERCURY	71900	036	2010/12/15	.000	2013/12	
NICKEL	01067	036	2010/12/15	.000	2013/12	
PERCHLORATE	A-031	036	2011/10/19	< .000	2014/10	
SELENIUM	01147	036	2010/12/15	.000	2013/12	
THALLIUM	01059	036	2010/12/15	.000	2013/12	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2012/01/31	< .000	2013/01	
NITRITE (AS N)	00620	036	2010/12/15	.000	2013/12	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2011/10/19	.380	2020/10	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800736***

System Name: ***DOMAINE CHANDON***

PS Code: ***2800736-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2010/04/26	< .000	
2,4-D	39730	WAIVED	2010/04/26	< .000	
ALACHLOR	77825	WAIVED	2012/01/31	< 1.000	
ATRAZINE	39033	036	2010/04/26	< .000	2013/04
BENTAZON	38710	WAIVED	2010/04/26	< .000	
BENZO (A) PYRENE	34247	WAIVED	2008/04/22	.000	
CARBOFURAN	81405	036	2010/04/26	< .000	2013/04
CHLORDANE	39350	WAIVED	2012/01/31	< .100	
DALAPON	38432	036	2010/04/26	< .000	2013/04
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED	2008/04/22	.000	
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED	2008/04/22	.000	
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2006/11/13	< .500	
DINOSEB	81287	036	2010/04/26	< .000	2013/04
DIQUAT	78885	036	2010/04/26	< .000	2013/04
ENDOTHALL	38926	036	2010/04/26	< .000	2013/04
ENDRIN	39390	WAIVED	2012/01/31	< .100	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2006/11/13	< .500	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2012/01/31	< .010	
HEPTACHLOR EPOXIDE	39420	WAIVED	2012/01/31	< .010	
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED	2012/01/31	< .200	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800736***

System Name: ***DOMAINE CHANDON***

PS Code: ***2800736-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED	2012/01/31	< 10.000	
MOLINATE	82199	WAIVED	2010/04/26	< .000	
OXAMYL	38865	036	2010/04/26	< .000	2013/04
PENTACHLOROPHENOL	39032	036	2010/04/26	< .000	2013/04
PICLORAM	39720	036	2010/04/26	< .000	2013/04
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2012/01/31	< .500	
SIMAZINE	39055	036	2010/04/26	< .000	2013/04
THIOBENCARB	A-001	WAIVED	2010/04/26	< .000	
TOXAPHENE	39400	WAIVED	2012/01/31	< 1.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	072	2006/11/13	.000	2012/11
1,1,2,2-TETRACHLOROETHANE	34516	072	2006/11/13	.000	2012/11
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2006/11/13	.000	2012/11
1,1,2-TRICHLOROETHANE	34511	072	2006/11/13	.000	2012/11
1,1-DICHLOROETHANE	34496	072	2006/11/13	.000	2012/11
1,1-DICHLOROETHYLENE	34501	072	2006/11/13	.000	2012/11
1,2,4-TRICHLOROBENZENE	34551	072	2006/11/13	.000	2012/11
1,2-DICHLOROBENZENE	34536	072	2006/11/13	.000	2012/11
1,2-DICHLOROETHANE	34531	072	2006/11/13	.000	2012/11
1,2-DICHLOROPROPANE	34541	072	2006/11/13	.000	2012/11
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2006/11/13	.000	2012/11
1,4-DICHLOROBENZENE	34571	072	2006/11/13	.000	2012/11
BENZENE	34030	072	2006/11/13	.000	2012/11
CARBON TETRACHLORIDE	32102	072	2006/11/13	.000	2012/11
CIS-1,2-DICHLOROETHYLENE	77093	072	2006/11/13	.000	2012/11
DICHLOROMETHANE	34423	072	2006/11/13	.000	2012/11
ETHYLBENZENE	34371	072	2006/11/13	.000	2012/11
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2010/04/26	.000	2016/04
MONOCHLOROBENZENE	34301	072	2006/11/13	.000	2012/11

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800736***

System Name: ***DOMAINE CHANDON***

PS Code: ***2800736-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2006/11/13	.000	2012/11
TETRACHLOROETHYLENE	34475	072	2006/11/13	.000	2012/11
TOLUENE	34010	072	2006/11/13	.000	2012/11
TRANS-1,2-DICHLOROETHYLENE	34546	072	2006/11/13	.000	2012/11
TRICHLOROETHYLENE	39180	072	2006/11/13	.000	2012/11
TRICHLOROFLUOROMETHANE	34488	072	2006/11/13	.000	2012/11
VINYL CHLORIDE	39175	072	2006/11/13	.000	2012/11
XYLENES (TOTAL)	81551	072	2006/11/13	.000	2012/11
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2010/04/26	170.000	
CALCIUM	00916	WAIVED	2010/04/26	26.000	
CARBONATE ALKALINITY	00445	WAIVED	2010/04/26	.000	
CHLORIDE	00940	WAIVED	2010/12/15	7.900	
COLOR	00081	WAIVED	2012/01/31	3.000	
COPPER	01042	WAIVED	2010/12/15	.000	
FOAMING AGENTS (MBAS)	38260	WAIVED	2010/12/15	.000	
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2010/04/26	120.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2010/04/26	.000	
IRON	01045	WAIVED	2010/04/26	1400.000	
MAGNESIUM	00927	WAIVED	2010/04/26	14.000	
MANGANESE	01055	WAIVED	2010/04/26	140.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED	2012/01/31	1.000	
PH, LABORATORY	00403	WAIVED	2010/12/15	8.000	
SILVER	01077	WAIVED	2010/12/15	.000	
SODIUM	00929	WAIVED	2010/04/26	20.000	
SPECIFIC CONDUCTANCE	00095	WAIVED	2012/01/31	340.000	
SULFATE	00945	WAIVED	2010/12/15	25.000	
TOTAL DISSOLVED SOLIDS	70300	WAIVED	2010/12/15	250.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800736***

System Name: ***DOMAINE CHANDON***

PS Code: ***2800736-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
SECONDARY/GP						
TURBIDITY, LABORATORY	82079	WAIVED	2012/01/31	.600		
ZINC	01092	WAIVED	2010/12/15	.000		

PS Code: ***2800736-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2006/11/13	< .250		
INORGANIC						
ALUMINUM	01105	036	2012/01/31	< .000	2015/01	
ANTIMONY	01097	036	2012/01/31	< .000	2015/01	
ARSENIC	01002	036	2012/01/31	< .000	2015/01	
ASBESTOS	81855	000				**DUE**
BARIUM	01007	036	2012/01/31	< .000	2015/01	
BERYLLIUM	01012	036	2012/01/31	< .000	2015/01	
CADMIUM	01027	036	2012/01/31	< .000	2015/01	
CHROMIUM (TOTAL)	01034	036	2012/01/31	< .000	2015/01	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	**2006/11/13**	.140	**2009/11**	**DUE**
LEAD	01051	WAIVED	2012/01/31	< .000		
MERCURY	71900	036	2012/01/31	< .000	2015/01	
NICKEL	01067	036	2012/01/31	< .000	2015/01	
PERCHLORATE	A-031	006				**DUE**
SELENIUM	01147	036	2012/01/31	< .000	2015/01	
THALLIUM	01059	036	2012/01/31	< .000	2015/01	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800736***

System Name: ***DOMAINE CHANDON***

PS Code: ***2800736-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2011/10/19	< .000	2012/10
NITRITE (AS N)	00620	036	2012/01/31	< .000	2015/01
RADIOLOGICAL					
GROSS ALPHA	01501	108	2012/01/31	.560	2021/01
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2012/01/31	< 1.000	
2,4-D	39730	WAIVED	2012/01/31	< 10.000	
ALACHLOR	77825	WAIVED	2006/11/13	.000	
ATRAZINE	39033	036	2012/01/31	< .500	2015/01
BENTAZON	38710	WAIVED	2012/01/31	< 2.000	
BENZO (A) PYRENE	34247	WAIVED	2006/11/13	.000	
CARBOFURAN	81405	036	2012/01/31	< 5.000	2015/01
CHLORDANE	39350	WAIVED	2006/11/13	.000	
DALAPON	38432	036	2012/01/31	< 10.000	2015/01
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED	2006/11/13	.000	
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED	2006/11/13	.000	
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2006/11/13	< .500	
DINOSEB	81287	036	2012/01/31	< 2.000	2015/01
DIQUAT	78885	036	2012/01/31	< 4.000	2015/01

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800736***

System Name: ***DOMAINE CHANDON***

PS Code: ***2800736-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	036	2012/01/31	< 45.000	2015/01
ENDRIN	39390	WAIVED	2006/11/13	.000	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2006/11/13	< .500	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2006/11/13	.000	
HEPTACHLOR EPOXIDE	39420	WAIVED	2006/11/13	.000	
HEXACHLOROBENZENE	39700	WAIVED	2006/11/13	.000	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2006/11/13	.000	
LINDANE	39340	WAIVED	2006/11/13	.000	
METHOXYCHLOR	39480	WAIVED	2006/11/13	.000	
MOLINATE	82199	WAIVED	2006/11/13	.000	
OXAMYL	38865	036	2012/01/31	< 20.000	2015/01
PENTACHLOROPHENOL	39032	036	2012/01/31	< .200	2015/01
PICLORAM	39720	036	2012/01/31	< 1.000	2015/01
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2006/11/13	.000	
SIMAZINE	39055	036	2012/01/31	< 1.000	2015/01
THIOBENCARB	A-001	WAIVED	2006/11/13	.000	
TOXAPHENE	39400	WAIVED	2006/11/13	.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	072	2006/11/13	.000	2012/11
1,1,2,2-TETRACHLOROETHANE	34516	072	2006/11/13	.000	2012/11
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2006/11/13	.000	2012/11
1,1,2-TRICHLOROETHANE	34511	072	2006/11/13	.000	2012/11
1,1-DICHLOROETHANE	34496	072	2006/11/13	.000	2012/11
1,1-DICHLOROETHYLENE	34501	072	2006/11/13	.000	2012/11
1,2,4-TRICHLOROBENZENE	34551	072	2006/11/13	.000	2012/11
1,2-DICHLOROBENZENE	34536	072	2006/11/13	.000	2012/11
1,2-DICHLOROETHANE	34531	072	2006/11/13	.000	2012/11
1,2-DICHLOROPROPANE	34541	072	2006/11/13	.000	2012/11

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800736***

System Name: ***DOMAINE CHANDON***

PS Code: ***2800736-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2006/11/13	.000	2012/11
1,4-DICHLOROBENZENE	34571	072	2006/11/13	.000	2012/11
BENZENE	34030	072	2006/11/13	.000	2012/11
CARBON TETRACHLORIDE	32102	072	2006/11/13	.000	2012/11
CIS-1,2-DICHLOROETHYLENE	77093	072	2006/11/13	.000	2012/11
DICHLOROMETHANE	34423	072	2006/11/13	.000	2012/11
ETHYLBENZENE	34371	072	2006/11/13	.000	2012/11
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2006/11/13	.000	2012/11
MONOCHLOROBENZENE	34301	072	2006/11/13	.000	2012/11
STYRENE	77128	072	2006/11/13	.000	2012/11
TETRACHLOROETHYLENE	34475	072	2006/11/13	.000	2012/11
TOLUENE	34010	072	2006/11/13	.000	2012/11
TRANS-1,2-DICHLOROETHYLENE	34546	072	2006/11/13	.000	2012/11
TRICHLOROETHYLENE	39180	072	2006/11/13	.000	2012/11
TRICHLOROFLUOROMETHANE	34488	072	2006/11/13	.000	2012/11
VINYL CHLORIDE	39175	072	2006/11/13	.000	2012/11
XYLENES (TOTAL)	81551	072	2006/11/13	.000	2012/11
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2006/11/13	120.000	
CALCIUM	00916	WAIVED	2006/11/13	20.000	
CARBONATE ALKALINITY	00445	WAIVED	2006/11/13	.000	
CHLORIDE	00940	WAIVED	2012/01/31	9.200	
COLOR	00081	WAIVED	2012/01/31	38.000	
COPPER	01042	WAIVED	2012/01/31	< .000	
FOAMING AGENTS (MBAS)	38260	WAIVED	2012/01/31	< .000	
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2006/11/13	110.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2006/11/13	.000	
IRON	01045	WAIVED	2006/11/13	4000.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800736***

System Name: ***DOMAINE CHANDON***

PS Code: ***2800736-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
MAGNESIUM	00927	WAIVED	2006/11/13	14.000	
MANGANESE	01055	WAIVED	2006/11/13	110.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED	2012/01/31	40.000	
PH, LABORATORY	00403	WAIVED	2006/11/13	7.050	
SILVER	01077	WAIVED	2012/01/31	< .000	
SODIUM	00929	WAIVED	2006/11/13	13.000	
SPECIFIC CONDUCTANCE	00095	WAIVED	2012/01/31	310.000	
SULFATE	00945	WAIVED	2012/01/31	22.000	
TOTAL DISSOLVED SOLIDS	70300	WAIVED	2012/01/31	220.000	
TURBIDITY, LABORATORY	82079	WAIVED	2012/01/31	3.100	
ZINC	01092	WAIVED	2012/01/31	< .000	

PS Code: ***2800736-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15		
DIAZINON	39570	WAIVED
INORGANIC		
ALUMINUM	01105	WAIVED
ANTIMONY	01097	WAIVED
ARSENIC	01002	WAIVED
ASBESTOS	81855	WAIVED
BARIUM	01007	WAIVED
BERYLLIUM	01012	WAIVED
CADMIUM	01027	WAIVED
CHROMIUM (TOTAL)	01034	WAIVED
CYANIDE	01291	WAIVED

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800736***

System Name: ***DOMAINE CHANDON***

PS Code: ***2800736-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800736***

System Name: ***DOMAINE CHANDON***

PS Code: ***2800736-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800736***

System Name: ***DOMAINE CHANDON***

PS Code: ***2800736-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800736***

System Name: ***DOMAINE CHANDON***

PS Code: ***2800736-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800740
System Name: MONT ST. JOHN CELLARS

PS Code: 2800740-001
Source Name: LPA REPORTED PRIMARY SOURCE
Source Number: 001
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED	2002/05/24	.000		
ANTIMONY	01097	WAIVED	2002/05/24	.000		
ARSENIC	01002	WAIVED	2002/05/24	2.000		
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED	2002/05/24	.000		
BERYLLIUM	01012	WAIVED	2002/05/24	.000		
CADMIUM	01027	WAIVED	2002/05/24	.000		
CHROMIUM (TOTAL)	01034	WAIVED	2002/05/24	.000		
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2002/05/24	.600		
LEAD	01051	WAIVED	2002/05/24	.000		
MERCURY	71900	WAIVED	2002/05/24	.000		
NICKEL	01067	WAIVED	2002/05/24	.000		
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED	2002/05/24	.000		
THALLIUM	01059	WAIVED	2002/05/24	.000		
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2002/05/24	7.000	2003/05	DUE
NITRITE (AS N)	00620	036	2002/05/24	.000	2005/05	DUE
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800740***

System Name: ***MONT ST. JOHN CELLARS***

PS Code: ***2800740-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800740***

System Name: ***MONT ST. JOHN CELLARS***

PS Code: ***2800740-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800740***

System Name: ***MONT ST. JOHN CELLARS***

PS Code: ***2800740-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED	2002/05/24	.000	
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800740***

System Name: ***MONT ST. JOHN CELLARS***

PS Code: ***2800740-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800741
System Name: ST. HELENA PREMIUM OUTLETS

PS Code: 2800741-001
Source Name: LPA REPORTED PRIMARY SOURCE
Source Number: 001
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2008/06/11	.000		
INORGANIC						
ALUMINUM	01105	036	2011/06/16	< .000	2014/06	
ANTIMONY	01097	036	2011/06/16	< .000	2014/06	
ARSENIC	01002	036	2011/06/16	6.700	2014/06	
ASBESTOS	81855	108	2007/05/30	.000	2016/05	
BARIUM	01007	036	2011/06/16	< .000	2014/06	
BERYLLIUM	01012	036	2011/06/16	< .000	2014/06	
CADMIUM	01027	036	2011/06/16	< .000	2014/06	
CHROMIUM (TOTAL)	01034	036	2011/06/16	< .000	2014/06	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2011/06/16	.100	2014/06	
LEAD	01051	WAIVED	2011/06/16	< .000		
MERCURY	71900	036	2011/06/16	< .000	2014/06	
NICKEL	01067	036	2011/06/16	< .000	2014/06	
PERCHLORATE	A-031	036	2011/06/16	< .000	2014/06	
SELENIUM	01147	036	2011/06/16	< .000	2014/06	
THALLIUM	01059	036	2011/06/16	< .000	2014/06	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2010/06/17	.000	2011/06	DUE
NITRITE (AS N)	00620	036	2009/10/07	.000	2012/10	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2008/06/12	.240	2017/06	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED	2006/08/31	.290		
RADIUM 228	11501	WAIVED	2006/08/31	.880		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800741
System Name: ST. HELENA PREMIUM OUTLETS

PS Code: 2800741-001
Source Name: LPA REPORTED PRIMARY SOURCE
Source Number: 001
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2011/06/16	< 1.000	
2,4-D	39730	WAIVED	2011/06/16	< 10.000	
ALACHLOR	77825	WAIVED	2008/06/11	.000	
ATRAZINE	39033	036	2011/06/16	< .500	2014/06
BENTAZON	38710	WAIVED	2011/06/16	< 2.000	
BENZO (A) PYRENE	34247	WAIVED	1996/12/19	.000	
CARBOFURAN	81405	036	2011/06/16	< 5.000	2014/06
CHLORDANE	39350	WAIVED	1996/12/19	.000	
DALAPON	38432	036	2011/06/16	< 10.000	2014/06
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED	1996/12/19	.000	
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED	1996/12/19	.000	
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2008/06/11	.000	
DINOSEB	81287	036	2011/06/16	< 2.000	2014/06
DIQUAT	78885	036	2011/06/16	< 4.000	2014/06
ENDOTHALL	38926	036	2011/06/16	< 45.000	2014/06
ENDRIN	39390	WAIVED	1996/12/19	.000	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2008/06/11	.000	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	1996/12/19	.000	
HEPTACHLOR EPOXIDE	39420	WAIVED	1996/12/19	.000	
HEXACHLOROBENZENE	39700	WAIVED	1996/12/19	.000	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED	1996/12/19	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800741***

System Name: ***ST. HELENA PREMIUM OUTLETS***

PS Code: ***2800741-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED	1996/12/19	.000	
MOLINATE	82199	WAIVED	2008/06/11	.000	
OXAMYL	38865	036	2011/06/16	< 20.000	2014/06
PENTACHLOROPHENOL	39032	036	2011/06/16	< .200	2014/06
PICLORAM	39720	036	2011/06/16	< 1.000	2014/06
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	1996/12/19	.000	
SIMAZINE	39055	036	2011/06/16	< 1.000	2014/06
THIOBENCARB	A-001	WAIVED	2008/06/11	.000	
TOXAPHENE	39400	WAIVED	1996/12/19	.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	072	2008/06/11	.000	2014/06
1,1,2,2-TETRACHLOROETHANE	34516	072	2008/06/11	.000	2014/06
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2008/06/11	.000	2014/06
1,1,2-TRICHLOROETHANE	34511	072	2008/06/11	.000	2014/06
1,1-DICHLOROETHANE	34496	072	2008/06/11	.000	2014/06
1,1-DICHLOROETHYLENE	34501	072	2008/06/11	.000	2014/06
1,2,4-TRICHLOROBENZENE	34551	072	2008/06/11	.000	2014/06
1,2-DICHLOROBENZENE	34536	072	2008/06/11	.000	2014/06
1,2-DICHLOROETHANE	34531	072	2008/06/11	.000	2014/06
1,2-DICHLOROPROPANE	34541	072	2008/06/11	.000	2014/06
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2008/06/11	.000	2014/06
1,4-DICHLOROBENZENE	34571	072	2008/06/11	.000	2014/06
BENZENE	34030	072	2008/06/11	.000	2014/06
CARBON TETRACHLORIDE	32102	072	2008/06/11	.000	2014/06
CIS-1,2-DICHLOROETHYLENE	77093	072	2008/06/11	.000	2014/06
DICHLOROMETHANE	34423	072	2008/06/11	.000	2014/06
ETHYLBENZENE	34371	072	2008/06/11	.000	2014/06
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2008/06/11	.000	2014/06
MONOCHLOROBENZENE	34301	072	2008/06/11	.000	2014/06

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800741
System Name: ST. HELENA PREMIUM OUTLETS

PS Code: 2800741-001
Source Name: LPA REPORTED PRIMARY SOURCE
Source Number: 001
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2008/06/11	.000	2014/06
TETRACHLOROETHYLENE	34475	072	2008/06/11	.000	2014/06
TOLUENE	34010	072	2008/06/11	.000	2014/06
TRANS-1,2-DICHLOROETHYLENE	34546	072	2008/06/11	.000	2014/06
TRICHLOROETHYLENE	39180	072	2008/06/11	.000	2014/06
TRICHLOROFLUOROMETHANE	34488	072	2008/06/11	.000	2014/06
VINYL CHLORIDE	39175	072	2008/06/11	.000	2014/06
XYLENES (TOTAL)	81551	072	2008/06/11	.000	2014/06
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2011/06/16	150.000	
CALCIUM	00916	WAIVED	2011/06/16	18.000	
CARBONATE ALKALINITY	00445	WAIVED	2011/06/16	< .000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED	2004/05/03	< 50.000	
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2004/05/03	110.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2011/06/16	< .000	
IRON	01045	WAIVED	2011/06/16	< .000	
MAGNESIUM	00927	WAIVED	2011/06/16	11.000	
MANGANESE	01055	WAIVED	2011/06/16	< .000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2008/06/11	7.400	
SILVER	01077	WAIVED	2011/06/16	< .000	
SODIUM	00929	WAIVED	2011/06/16	17.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800741***

System Name: ***ST. HELENA PREMIUM OUTLETS***

PS Code: ***2800741-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800742***

System Name: ***GOLDEN HAVEN MOTEL***

PS Code: ***2800742-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED	2004/04/13	3700.000		
ANTIMONY	01097	WAIVED	2004/04/13	.000		
ARSENIC	01002	WAIVED	2004/04/13	3.000		
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED	2004/04/13	.016		
BERYLLIUM	01012	WAIVED	2004/04/13	.000		
CADMIUM	01027	WAIVED	2004/04/13	.000		
CHROMIUM (TOTAL)	01034	WAIVED	2004/04/13	.000		
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED	2004/04/13	.000		
NICKEL	01067	WAIVED	2004/04/13	.000		
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED	2004/04/13	.000		
THALLIUM	01059	WAIVED	2004/04/13	.000		
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	**2010/10/04**	.000	**2011/10**	**DUE**
NITRITE (AS N)	00620	036	2011/02/11	.000	2014/02	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800742***

System Name: ***GOLDEN HAVEN MOTEL***

PS Code: ***2800742-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800742***

System Name: ***GOLDEN HAVEN MOTEL***

PS Code: ***2800742-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800742***

System Name: ***GOLDEN HAVEN MOTEL***

PS Code: ***2800742-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	WAIVED	2004/04/13	3.500	
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800742***

System Name: ***GOLDEN HAVEN MOTEL***

PS Code: ***2800742-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
TURBIDITY, LABORATORY	82079	WAIVED	2004/04/13	4.000	
ZINC	01092	WAIVED			

PS Code: ***2800742-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
DIAZINON	39570	WAIVED			

INORGANIC

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
ALUMINUM	01105	WAIVED	2003/06/19	.000	
ANTIMONY	01097	WAIVED	2007/08/02	.000	
ARSENIC	01002	WAIVED	2007/08/02	69.000	
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED	2003/06/19	.000	
BERYLLIUM	01012	WAIVED	2003/06/19	.000	
CADMIUM	01027	WAIVED	2003/06/19	.000	
CHROMIUM (TOTAL)	01034	WAIVED	2003/06/19	.000	
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2007/08/02	9.700	
LEAD	01051	WAIVED	2003/06/19	.000	
MERCURY	71900	WAIVED	2003/06/19	.000	
NICKEL	01067	WAIVED	2003/06/19	.000	
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED	2003/06/19	.000	
THALLIUM	01059	WAIVED	2003/06/19	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800742***

System Name: ***GOLDEN HAVEN MOTEL***

PS Code: ***2800742-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2008/11/10	.000	2009/11	DUE
NITRITE (AS N)	00620	036	2007/08/02	.000	2010/08	DUE
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED				
2,4-D	39730	WAIVED				
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	WAIVED				
BENTAZON	38710	WAIVED				
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	WAIVED				
CHLORDANE	39350	WAIVED				
DALAPON	38432	WAIVED				
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	WAIVED				
DIQUAT	78885	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800742***

System Name: ***GOLDEN HAVEN MOTEL***

PS Code: ***2800742-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800742***

System Name: ***GOLDEN HAVEN MOTEL***

PS Code: ***2800742-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	WAIVED	2003/06/19	200.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800742***

System Name: ***GOLDEN HAVEN MOTEL***

PS Code: ***2800742-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
SECONDARY/GP						
MAGNESIUM	00927	WAIVED	2003/06/19	.900		
MANGANESE	01055	WAIVED	2007/08/02	93.000		
ODOR THRESHOLD @ 60 C	00086	WAIVED				
PH, LABORATORY	00403	000				**DUE**
SILVER	01077	WAIVED	2003/06/19	.000		
SODIUM	00929	000				**DUE**
SPECIFIC CONDUCTANCE	00095	WAIVED				
SULFATE	00945	WAIVED				
TOTAL DISSOLVED SOLIDS	70300	WAIVED				
TURBIDITY, LABORATORY	82079	WAIVED				
ZINC	01092	WAIVED				

PS Code: ***2800742-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15		
DIAZINON	39570	WAIVED
INORGANIC		
ALUMINUM	01105	WAIVED
ANTIMONY	01097	WAIVED
ARSENIC	01002	WAIVED
ASBESTOS	81855	WAIVED
BARIUM	01007	WAIVED
BERYLLIUM	01012	WAIVED
CADMIUM	01027	WAIVED
CHROMIUM (TOTAL)	01034	WAIVED
CYANIDE	01291	WAIVED

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800742***

System Name: ***GOLDEN HAVEN MOTEL***

PS Code: ***2800742-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800742***

System Name: ***GOLDEN HAVEN MOTEL***

PS Code: ***2800742-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800742***

System Name: ***GOLDEN HAVEN MOTEL***

PS Code: ***2800742-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800742***

System Name: ***GOLDEN HAVEN MOTEL***

PS Code: ***2800742-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800749
System Name: KENT RASMUSSEN WINERY

PS Code: 2800749-001
Source Name: LPA REPORTED PRIMARY SOURCE
Source Number: 001
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED	2003/09/10	.000		
ANTIMONY	01097	WAIVED	2003/09/10	.000		
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED	2003/09/10	.000		
BERYLLIUM	01012	WAIVED	2003/09/10	.000		
CADMIUM	01027	WAIVED	2003/09/10	.000		
CHROMIUM (TOTAL)	01034	WAIVED	2003/09/10	.000		
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				DUE
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED	2003/09/10	.000		
NICKEL	01067	WAIVED	2003/09/10	.000		
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED	2003/09/10	.000		
THALLIUM	01059	WAIVED	2003/09/10	.000		
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2008/05/21	.000	2009/05	DUE
NITRITE (AS N)	00620	036	2008/05/21	.000	2011/05	DUE
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800749***

System Name: ***KENT RASMUSSEN WINERY***

PS Code: ***2800749-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800749***

System Name: ***KENT RASMUSSEN WINERY***

PS Code: ***2800749-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800749***

System Name: ***KENT RASMUSSEN WINERY***

PS Code: ***2800749-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800749***

System Name: ***KENT RASMUSSEN WINERY***

PS Code: ***2800749-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800811***

System Name: ***ACACIA WINERY***

PS Code: ***2800811-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED	2002/09/04	.000		
ANTIMONY	01097	WAIVED	2002/09/04	.000		
ARSENIC	01002	WAIVED	2002/09/04	5.000		
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED	2002/09/04	100.000		
BERYLLIUM	01012	WAIVED	2002/09/04	2.000		
CADMIUM	01027	WAIVED	2002/09/04	2.000		
CHROMIUM (TOTAL)	01034	WAIVED	2002/09/04	.000		
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2002/09/04	.300		
LEAD	01051	WAIVED	2002/09/04	6.000		
MERCURY	71900	WAIVED	2002/09/04	.000		
NICKEL	01067	WAIVED	2002/09/04	.000		
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED	2002/09/04	15.000		
THALLIUM	01059	WAIVED	2002/09/04	.000		
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/02/02	.000	2012/02	DUE
NITRITE (AS N)	00620	036	2011/02/02	.000	2014/02	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800811***

System Name: ***ACACIA WINERY***

PS Code: ***2800811-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800811***

System Name: ***ACACIA WINERY***

PS Code: ***2800811-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800811***

System Name: ***ACACIA WINERY***

PS Code: ***2800811-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED	2002/09/04	.000	
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800811***

System Name: ***ACACIA WINERY***

PS Code: ***2800811-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800811-003***

Source Name: ***WELL #3***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED	2002/09/04	.000	
ANTIMONY	01097	WAIVED	2002/09/04	.000	
ARSENIC	01002	WAIVED	2002/09/04	7.000	
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED	2002/09/04	.000	
BERYLLIUM	01012	WAIVED	2002/09/04	.000	
CADMIUM	01027	WAIVED	2002/09/04	.000	
CHROMIUM (TOTAL)	01034	WAIVED	2002/09/04	.000	
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2002/09/04	.700	
LEAD	01051	WAIVED	2002/09/04	9.000	
MERCURY	71900	WAIVED	2002/09/04	.000	
NICKEL	01067	WAIVED	2002/09/04	.000	
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED	2002/09/04	.000	
THALLIUM	01059	WAIVED	2002/09/04	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800811***

System Name: ***ACACIA WINERY***

PS Code: ***2800811-003***

Source Name: ***WELL #3***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
NITRATE/NITRITE						
NITRATE (AS NO3)	**71850**	**012**	**2011/02/02**	**.000**	**2012/02**	**DUE**
NITRITE (AS N)	**00620**	**036**	2011/02/02	**.000**	2014/02	
RADIOLOGICAL						
GROSS ALPHA	**01501**	**WAIVED**				
GROSS BETA	**03501**	**WAIVED**				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	**A-080**	**WAIVED**				
RA-226 OR TOTAL RA BY 903.0 C.E.	**A-081**	**WAIVED**				
RADIUM 226	**09501**	**WAIVED**				
RADIUM 228	**11501**	**WAIVED**				
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	**A-082**	**WAIVED**				
STRONTIUM-90	**13501**	**WAIVED**				
TRITIUM	**07000**	**WAIVED**				
URANIUM (PCI/L)	**28012**	**WAIVED**				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	**34676**	**WAIVED**				
2,4,5-TP (SILVEX)	**39045**	**WAIVED**				
2,4-D	**39730**	**WAIVED**				
ALACHLOR	**77825**	**WAIVED**				
ATRAZINE	**39033**	**WAIVED**				
BENTAZON	**38710**	**WAIVED**				
BENZO (A) PYRENE	**34247**	**WAIVED**				
CARBOFURAN	**81405**	**WAIVED**				
CHLORDANE	**39350**	**WAIVED**				
DALAPON	**38432**	**WAIVED**				
DI(2-ETHYLHEXYL)ADIPATE	**A-026**	**WAIVED**				
DI(2-ETHYLHEXYL)PHTHALATE	**39100**	**WAIVED**				
DIBROMOCHLOROPROPANE (DBCP)	**38761**	**WAIVED**				
DINOSEB	**81287**	**WAIVED**				
DIQUAT	**78885**	**WAIVED**				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800811***

System Name: ***ACACIA WINERY***

PS Code: ***2800811-003***

Source Name: ***WELL #3***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800811***

System Name: ***ACACIA WINERY***

PS Code: ***2800811-003***

Source Name: ***WELL #3***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800811***

System Name: ***ACACIA WINERY***

PS Code: ***2800811-003***

Source Name: ***WELL #3***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
SECONDARY/GP						
MAGNESIUM	00927	000				DUE
MANGANESE	01055	000				DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED				
PH, LABORATORY	00403	000				DUE
SILVER	01077	WAIVED	2002/09/04	.000		
SODIUM	00929	000				DUE
SPECIFIC CONDUCTANCE	00095	WAIVED				
SULFATE	00945	WAIVED				
TOTAL DISSOLVED SOLIDS	70300	WAIVED				
TURBIDITY, LABORATORY	82079	WAIVED				
ZINC	01092	WAIVED				

PS Code: ***2800811-004***

Source Name: ***WELL 004***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15		
DIAZINON	39570	WAIVED
INORGANIC		
ALUMINUM	01105	WAIVED
ANTIMONY	01097	WAIVED
ARSENIC	01002	WAIVED
ASBESTOS	81855	WAIVED
BARIUM	01007	WAIVED
BERYLLIUM	01012	WAIVED
CADMIUM	01027	WAIVED
CHROMIUM (TOTAL)	01034	WAIVED
CYANIDE	01291	WAIVED

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800811***

System Name: ***ACACIA WINERY***

PS Code: ***2800811-004***

Source Name: ***WELL 004***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
INORGANIC						
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				DUE
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/02/02	.000	2012/02	DUE
NITRITE (AS N)	00620	036	2011/02/02	.000	2014/02	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED				
2,4-D	39730	WAIVED				
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	WAIVED				
BENTAZON	38710	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800811***

System Name: ***ACACIA WINERY***

PS Code: ***2800811-004***

Source Name: ***WELL 004***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800811***

System Name: ***ACACIA WINERY***

PS Code: ***2800811-004***

Source Name: ***WELL 004***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800811***

System Name: ***ACACIA WINERY***

PS Code: ***2800811-004***

Source Name: ***WELL 004***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800811-005***

Source Name: ***TREATMENT PLANT***

Source Number: ***005***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800811***

System Name: ***ACACIA WINERY***

PS Code: ***2800811-005***

Source Name: ***TREATMENT PLANT***

Source Number: ***005***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800811***

System Name: ***ACACIA WINERY***

PS Code: ***2800811-005***

Source Name: ***TREATMENT PLANT***

Source Number: ***005***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800811***

System Name: ***ACACIA WINERY***

PS Code: ***2800811-005***

Source Name: ***TREATMENT PLANT***

Source Number: ***005***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800811***

System Name: ***ACACIA WINERY***

PS Code: ***2800811-005***

Source Name: ***TREATMENT PLANT***

Source Number: ***005***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800811***

System Name: ***ACACIA WINERY***

PS Code: ***2800811-006***

Source Name: ***WELL 006***

Source Number: ***006***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	000			DUE
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	000			DUE
NITRITE (AS N)	00620	000			DUE
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800811***

System Name: ***ACACIA WINERY***

PS Code: ***2800811-006***

Source Name: ***WELL 006***

Source Number: ***006***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800811***

System Name: ***ACACIA WINERY***

PS Code: ***2800811-006***

Source Name: ***WELL 006***

Source Number: ***006***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800811***

System Name: ***ACACIA WINERY***

PS Code: ***2800811-006***

Source Name: ***WELL 006***

Source Number: ***006***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800811***

System Name: ***ACACIA WINERY***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)

PS Code: ***2800811-006***

Source Name: ***WELL 006***

Source Number: ***006***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800811-008***

Source Name: ***WELL 008***

Source Number: ***008***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED			

INORGANIC

ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	000			**DUE**
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800811***

System Name: ***ACACIA WINERY***

PS Code: ***2800811-008***

Source Name: ***WELL 008***

Source Number: ***008***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2012/01/06	< .000	2013/01
NITRITE (AS N)	00620	036	2011/02/02	.000	2014/02
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800811***

System Name: ***ACACIA WINERY***

PS Code: ***2800811-008***

Source Name: ***WELL 008***

Source Number: ***008***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800811***

System Name: ***ACACIA WINERY***

PS Code: ***2800811-008***

Source Name: ***WELL 008***

Source Number: ***008***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800811***

System Name: ***ACACIA WINERY***

PS Code: ***2800811-008***

Source Name: ***WELL 008***

Source Number: ***008***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800811-009***

Source Name: ***WELL 009***

Source Number: ***009***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800811***

System Name: ***ACACIA WINERY***

PS Code: ***2800811-009***

Source Name: ***WELL 009***

Source Number: ***009***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	000			DUE
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	000			DUE
NITRITE (AS N)	00620	000			DUE
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800811***

System Name: ***ACACIA WINERY***

PS Code: ***2800811-009***

Source Name: ***WELL 009***

Source Number: ***009***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800811***

System Name: ***ACACIA WINERY***

PS Code: ***2800811-009***

Source Name: ***WELL 009***

Source Number: ***009***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800811***

System Name: ***ACACIA WINERY***

PS Code: ***2800811-009***

Source Name: ***WELL 009***

Source Number: ***009***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
CALCIUM	00916	000				DUE
CARBONATE ALKALINITY	00445	000				DUE
CHLORIDE	00940	WAIVED				
COLOR	00081	WAIVED				
COPPER	01042	WAIVED				
FOAMING AGENTS (MBAS)	38260	WAIVED				
HARDNESS (TOTAL) AS CACO3	00900	000				DUE
HYDROXIDE ALKALINITY	71830	000				DUE
IRON	01045	000				DUE
MAGNESIUM	00927	000				DUE
MANGANESE	01055	000				DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED				
PH, LABORATORY	00403	000				DUE
SILVER	01077	WAIVED				
SODIUM	00929	000				DUE
SPECIFIC CONDUCTANCE	00095	WAIVED				
SULFATE	00945	WAIVED				
TOTAL DISSOLVED SOLIDS	70300	WAIVED				
TURBIDITY, LABORATORY	82079	WAIVED				
ZINC	01092	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800840***

System Name: ***NAPA COUNTY SCHOOLS: POPE VALLEY***

PS Code: ***2800840-002***

Source Name: ***LAKE***

Source Number: ***002***

Source Status: ***ACTIVE RAW***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	012	2009/12/28	< 50.000	2010/12	DUE
ANTIMONY	01097	012	2009/12/28	< 6.000	2010/12	DUE
ARSENIC	01002	012	2009/12/28	< 2.000	2010/12	DUE
ASBESTOS	81855	108	2007/02/26	.000	2016/02	
BARIUM	01007	012	2009/12/28	< 100.000	2010/12	DUE
BERYLLIUM	01012	012	2009/12/28	< 1.000	2010/12	DUE
CADMIUM	01027	012	2009/12/28	< 1.000	2010/12	DUE
CHROMIUM (TOTAL)	01034	012	2009/12/28	< 1.000	2010/12	DUE
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	012	2009/12/28	.310	2010/12	DUE
LEAD	01051	WAIVED	2007/02/26	< 5.000		
MERCURY	71900	012	2009/12/28	< 1.000	2010/12	DUE
NICKEL	01067	012	2009/12/28	< 10.000	2010/12	DUE
PERCHLORATE	A-031	012	2010/06/28	< 4.000	2011/06	DUE
SELENIUM	01147	012	2009/12/28	< 5.000	2010/12	DUE
THALLIUM	01059	012	2009/12/28	< 1.000	2010/12	DUE
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	003	2009/12/28	9.000	2010/03	DUE
NITRITE (AS N)	00620	036	2009/12/28	< 400.000	2012/12	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2007/11/19	.000	2016/11	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800840***

System Name: ***NAPA COUNTY SCHOOLS: POPE VALLEY***

PS Code: ***2800840-002***

Source Name: ***LAKE***

Source Number: ***002***

Source Status: ***ACTIVE RAW***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2007/02/26	.000		
2,4-D	39730	WAIVED	2007/02/26	.000		
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	036	2007/02/26	.000	2010/02	DUE
BENTAZON	38710	WAIVED	2007/02/26	.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2007/02/26	.000	2010/02	DUE
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2007/02/26	.000	2010/02	DUE
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	036	2007/02/26	.000	2010/02	DUE
DIQUAT	78885	036	2007/02/26	.000	2010/02	DUE
ENDOTHALL	38926	036	2007/02/26	.000	2010/02	DUE
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	000				DUE
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				DUE
HEPTACHLOR EPOXIDE	39420	000				DUE
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800840***

System Name: ***NAPA COUNTY SCHOOLS: POPE VALLEY***

PS Code: ***2800840-002***

Source Name: ***LAKE***

Source Number: ***002***

Source Status: ***ACTIVE RAW***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	000				DUE
MOLINATE	82199	WAIVED				
OXAMYL	38865	036	2007/02/26	.000	2010/02	DUE
PENTACHLOROPHENOL	39032	036	2007/02/26	.000	2010/02	DUE
PICLORAM	39720	036	2007/02/26	.000	2010/02	DUE
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2007/02/26	.000	2010/02	DUE
THIOBENCARB	A-001	WAIVED				
TOXAPHENE	39400	000				DUE
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2009/12/28	.000	2015/12	
1,1,2,2-TETRACHLOROETHANE	34516	072	2009/12/28	.000	2015/12	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2009/12/28	.000	2015/12	
1,1,2-TRICHLOROETHANE	34511	072	2009/12/28	.000	2015/12	
1,1-DICHLOROETHANE	34496	072	2009/12/28	.000	2015/12	
1,1-DICHLOROETHYLENE	34501	072	2009/12/28	.000	2015/12	
1,2,4-TRICHLOROBENZENE	34551	072	2009/12/28	.000	2015/12	
1,2-DICHLOROBENZENE	34536	072	2009/12/28	.000	2015/12	
1,2-DICHLOROETHANE	34531	072	2009/12/28	.000	2015/12	
1,2-DICHLOROPROPANE	34541	072	2009/12/28	.000	2015/12	
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2009/12/28	.000	2015/12	
1,4-DICHLOROBENZENE	34571	072	2009/12/28	.000	2015/12	
BENZENE	34030	072	2009/12/28	.000	2015/12	
CARBON TETRACHLORIDE	32102	072	2009/12/28	.000	2015/12	
CIS-1,2-DICHLOROETHYLENE	77093	072	2009/12/28	.000	2015/12	
DICHLOROMETHANE	34423	072	2009/12/28	.000	2015/12	
ETHYLBENZENE	34371	072	2009/12/28	.000	2015/12	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2009/12/28	.000	2015/12	
MONOCHLOROBENZENE	34301	072	2009/12/28	.000	2015/12	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800840***

System Name: ***NAPA COUNTY SCHOOLS: POPE VALLEY***

PS Code: ***2800840-002***

Source Name: ***LAKE***

Source Number: ***002***

Source Status: ***ACTIVE RAW***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2009/12/28	.000	2015/12
TETRACHLOROETHYLENE	34475	072	2009/12/28	.000	2015/12
TOLUENE	34010	072	2009/12/28	.000	2015/12
TRANS-1,2-DICHLOROETHYLENE	34546	072	2009/12/28	.000	2015/12
TRICHLOROETHYLENE	39180	072	2009/12/28	.000	2015/12
TRICHLOROFLUOROMETHANE	34488	072	2009/12/28	.000	2015/12
VINYL CHLORIDE	39175	072	2009/12/28	.000	2015/12
XYLENES (TOTAL)	81551	072	2009/12/28	.000	2015/12
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED	2009/12/28	10.500	
BICARBONATE ALKALINITY	00440	WAIVED	2009/12/28	95.000	
CALCIUM	00916	WAIVED	2009/12/28	15.000	
CARBONATE ALKALINITY	00445	WAIVED	2009/12/28	< 1.000	
CHLORIDE	00940	WAIVED	2009/12/28	8.300	
COLOR	00081	WAIVED	2009/12/28	15.000	
COPPER	01042	WAIVED	2009/12/28	< 50.000	
FOAMING AGENTS (MBAS)	38260	WAIVED	2009/12/28	< .050	
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2009/12/28	69.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2009/12/28	< 1.000	
IRON	01045	WAIVED	2009/12/28	570.000	
MAGNESIUM	00927	WAIVED	2009/12/28	7.600	
MANGANESE	01055	WAIVED	2009/12/28	< 20.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED	2009/12/28	1.000	
PH, LABORATORY	00403	WAIVED	2009/12/28	7.000	
SILVER	01077	WAIVED	2009/12/28	< 10.000	
SODIUM	00929	WAIVED	2009/12/28	16.000	
SPECIFIC CONDUCTANCE	00095	WAIVED	2009/12/28	220.000	
SULFATE	00945	WAIVED	2009/12/28	20.000	
TOTAL DISSOLVED SOLIDS	70300	WAIVED	2009/12/28	150.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800840***

System Name: ***NAPA COUNTY SCHOOLS: POPE VALLEY***

PS Code: ***2800840-002***

Source Name: ***LAKE***

Source Number: ***002***

Source Status: ***ACTIVE RAW***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED	2009/12/28	.960	
ZINC	01092	WAIVED	2009/12/28	1400.000	

PS Code: ***2800840-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***SURFACE***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800840***

System Name: ***NAPA COUNTY SCHOOLS: POPE VALLEY***

PS Code: ***2800840-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800840***

System Name: ***NAPA COUNTY SCHOOLS: POPE VALLEY***

PS Code: ***2800840-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800840***

System Name: ***NAPA COUNTY SCHOOLS: POPE VALLEY***

PS Code: ***2800840-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800840***

System Name: ***NAPA COUNTY SCHOOLS: POPE VALLEY***

PS Code: ***2800840-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***SURFACE***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800844***

System Name: ***NVUSD: CAPELL VALLEY SCHOOL***

PS Code: ***2800844-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED	2004/05/19	.000	
INORGANIC					
ALUMINUM	01105	WAIVED	2004/05/19	.000	
ANTIMONY	01097	WAIVED	2004/05/19	.000	
ARSENIC	01002	WAIVED	2004/05/19	.000	
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED	2004/05/19	.140	
BERYLLIUM	01012	WAIVED	2004/05/19	.000	
CADMIUM	01027	WAIVED	2004/05/19	.000	
CHROMIUM (TOTAL)	01034	WAIVED	2004/05/19	.000	
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2004/05/19	.400	
LEAD	01051	WAIVED	2004/05/19	.000	
MERCURY	71900	WAIVED	2004/05/19	.000	
NICKEL	01067	WAIVED	2004/05/19	.000	
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED	2004/05/19	.000	
THALLIUM	01059	WAIVED	2004/05/19	.000	
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED	2004/05/19	.000	
NITRITE (AS N)	00620	WAIVED	2004/05/19	.000	
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800844***

System Name: ***NVUSD: CAPELL VALLEY SCHOOL***

PS Code: ***2800844-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED	2004/05/19	.000	
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2800844
System Name: NVUSD: CAPELL VALLEY SCHOOL

PS Code: 2800844-002
Source Name: TREATMENT PLANT
Source Number: 002
Source Status: ACTIVE TREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED	2004/05/19	.000	
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED	2004/05/19	.000	
THIOBENCARB	A-001	WAIVED	2004/05/19	.000	
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED	2004/05/19	.000	
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED	2004/05/19	.000	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED	2004/05/19	.000	
1,1,2-TRICHLOROETHANE	34511	WAIVED	2004/05/19	.000	
1,1-DICHLOROETHANE	34496	WAIVED	2004/05/19	.000	
1,1-DICHLOROETHYLENE	34501	WAIVED	2004/05/19	.000	
1,2,4-TRICHLOROBENZENE	34551	WAIVED	2004/05/19	.000	
1,2-DICHLOROBENZENE	34536	WAIVED	2004/05/19	.000	
1,2-DICHLOROETHANE	34531	WAIVED	2004/05/19	.000	
1,2-DICHLOROPROPANE	34541	WAIVED	2004/05/19	.000	
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED	2004/05/19	.000	
1,4-DICHLOROBENZENE	34571	WAIVED	2004/05/19	.000	
BENZENE	34030	WAIVED	2004/05/19	.000	
CARBON TETRACHLORIDE	32102	WAIVED	2004/05/19	.000	
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED	2004/05/19	.000	
DICHLOROMETHANE	34423	WAIVED	2004/05/19	.000	
ETHYLBENZENE	34371	WAIVED	2004/05/19	.000	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED	2004/05/19	.000	
MONOCHLOROBENZENE	34301	WAIVED	2004/05/19	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800844***

System Name: ***NVUSD: CAPELL VALLEY SCHOOL***

PS Code: ***2800844-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED	2004/05/19	.000	
TETRACHLOROETHYLENE	34475	WAIVED	2004/05/19	.000	
TOLUENE	34010	WAIVED	2004/05/19	.000	
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED	2004/05/19	.000	
TRICHLOROETHYLENE	39180	WAIVED	2004/05/19	.000	
TRICHLOROFLUOROMETHANE	34488	WAIVED	2004/05/19	.000	
VINYL CHLORIDE	39175	WAIVED	2004/05/19	.000	
XYLENES (TOTAL)	81551	WAIVED	2004/05/19	.000	
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2004/05/19	207.000	
CALCIUM	00916	WAIVED	2004/05/19	11.000	
CARBONATE ALKALINITY	00445	WAIVED	2004/05/19	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2004/05/19	32.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2004/05/19	.000	
IRON	01045	WAIVED	2004/05/19	.190	
MAGNESIUM	00927	WAIVED	2004/05/19	1.200	
MANGANESE	01055	WAIVED	2004/05/19	.009	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2004/05/19	8.200	
SILVER	01077	WAIVED	2004/05/19	.000	
SODIUM	00929	WAIVED	2004/05/19	78.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800844***

System Name: ***NVUSD: CAPELL VALLEY SCHOOL***

PS Code: ***2800844-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
SECONDARY/GP						
TURBIDITY, LABORATORY	82079	WAIVED				
ZINC	01092	WAIVED				

PS Code: ***2800844-003***

Source Name: ***WELL 002***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	036	2010/01/28	.000	2013/01	
ANTIMONY	01097	036	2010/01/28	.000	2013/01	
ARSENIC	01002	036	2010/01/28	.000	2013/01	
ASBESTOS	81855	000				**DUE**
BARIUM	01007	036	2010/01/28	250.000	2013/01	
BERYLLIUM	01012	036	2010/01/28	.000	2013/01	
CADMIUM	01027	036	2010/01/28	.000	2013/01	
CHROMIUM (TOTAL)	01034	036	2010/01/28	.000	2013/01	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2010/01/28	.330	2013/01	
LEAD	01051	WAIVED	2010/01/28	.000		
MERCURY	71900	036	2010/01/28	.000	2013/01	
NICKEL	01067	036	2010/01/28	.000	2013/01	
PERCHLORATE	A-031	006				**DUE**
SELENIUM	01147	036	2010/01/28	.000	2013/01	
THALLIUM	01059	036	2010/01/28	.000	2013/01	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800844***

System Name: ***NVUSD: CAPELL VALLEY SCHOOL***

PS Code: ***2800844-003***

Source Name: ***WELL 002***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2010/01/28	.000	2011/01	DUE
NITRITE (AS N)	00620	036	2010/01/28	.000	2013/01	
RADIOLOGICAL						
GROSS ALPHA	01501	000				DUE
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2010/02/02	.000		
2,4-D	39730	WAIVED	2010/02/02	.000		
ALACHLOR	77825	WAIVED	2010/02/02	.000		
ATRAZINE	39033	036	2010/02/02	.000	2013/02	
BENTAZON	38710	WAIVED	2010/02/02	.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2010/02/02	.000	2013/02	
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2010/02/02	.000	2013/02	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	036	2010/02/02	.000	2013/02	
DIQUAT	78885	036	2010/02/02	.000	2013/02	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800844***

System Name: ***NVUSD: CAPELL VALLEY SCHOOL***

PS Code: ***2800844-003***

Source Name: ***WELL 002***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
ENDOTHALL	38926	036	2010/02/02	.000	2013/02	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	000				DUE
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				DUE
HEPTACHLOR EPOXIDE	39420	000				DUE
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				DUE
METHOXYCHLOR	39480	000				DUE
MOLINATE	82199	WAIVED				
OXAMYL	38865	036	2010/02/02	.000	2013/02	
PENTACHLOROPHENOL	39032	036	2010/02/02	.000	2013/02	
PICLORAM	39720	036	2010/02/02	.000	2013/02	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2010/02/02	.000	2013/02	
THIOBENCARB	A-001	WAIVED				
TOXAPHENE	39400	000				DUE
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	000				DUE
1,1,2,2-TETRACHLOROETHANE	34516	000				DUE
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	000				DUE
1,1,2-TRICHLOROETHANE	34511	000				DUE
1,1-DICHLOROETHANE	34496	000				DUE
1,1-DICHLOROETHYLENE	34501	000				DUE
1,2,4-TRICHLOROBENZENE	34551	000				DUE
1,2-DICHLOROBENZENE	34536	000				DUE
1,2-DICHLOROETHANE	34531	000				DUE
1,2-DICHLOROPROPANE	34541	000				DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800844***

System Name: ***NVUSD: CAPELL VALLEY SCHOOL***

PS Code: ***2800844-003***

Source Name: ***WELL 002***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	000			DUE
1,4-DICHLOROBENZENE	34571	000			DUE
BENZENE	34030	000			DUE
CARBON TETRACHLORIDE	32102	000			DUE
CIS-1,2-DICHLOROETHYLENE	77093	000			DUE
DICHLOROMETHANE	34423	000			DUE
ETHYLBENZENE	34371	000			DUE
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	000			DUE
MONOCHLOROBENZENE	34301	000			DUE
STYRENE	77128	000			DUE
TETRACHLOROETHYLENE	34475	000			DUE
TOLUENE	34010	000			DUE
TRANS-1,2-DICHLOROETHYLENE	34546	000			DUE
TRICHLOROETHYLENE	39180	000			DUE
TRICHLOROFLUOROMETHANE	34488	000			DUE
VINYL CHLORIDE	39175	000			DUE
XYLENES (TOTAL)	81551	000			DUE
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2010/01/28	260.000	
CALCIUM	00916	WAIVED	2010/01/28	12.000	
CARBONATE ALKALINITY	00445	WAIVED	2010/01/28	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2010/01/28	34.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2010/01/28	.000	
IRON	01045	WAIVED	2010/01/28	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800844***

System Name: ***NVUSD: CAPELL VALLEY SCHOOL***

PS Code: ***2800844-003***

Source Name: ***WELL 002***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED	2010/01/28	.600	
MANGANESE	01055	WAIVED	2010/01/28	.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2010/01/28	8.100	
SILVER	01077	WAIVED	2010/01/28	.000	
SODIUM	00929	WAIVED	2010/01/28	84.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800845***

System Name: ***NVUSD: WOODEN VALLEY SCHOOL***

PS Code: ***2800845-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2008/02/27	.000		
INORGANIC						
ALUMINUM	01105	036	2008/02/27	.000	2011/02	DUE
ANTIMONY	01097	036	2008/02/27	.000	2011/02	DUE
ARSENIC	01002	036	2008/02/27	.000	2011/02	DUE
ASBESTOS	81855	000				DUE
BARIUM	01007	036	2008/02/27	150.000	2011/02	DUE
BERYLLIUM	01012	036	2008/02/27	.000	2011/02	DUE
CADMIUM	01027	036	2008/02/27	.000	2011/02	DUE
CHROMIUM (TOTAL)	01034	036	2008/02/27	.000	2011/02	DUE
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2008/02/27	.210	2011/02	DUE
LEAD	01051	WAIVED	2008/02/27	16.000		
MERCURY	71900	036	2008/02/27	.000	2011/02	DUE
NICKEL	01067	036	2008/02/27	.000	2011/02	DUE
PERCHLORATE	A-031	006	2008/09/23	.000	2009/03	DUE
SELENIUM	01147	036	2008/02/27	.000	2011/02	DUE
THALLIUM	01059	036	2008/02/27	.000	2011/02	DUE
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2010/01/28	.000	2011/01	DUE
NITRITE (AS N)	00620	036	2008/02/27	.000	2011/02	DUE
RADIOLOGICAL						
GROSS ALPHA	01501	108	2008/07/02	2.280	2017/07	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800845***

System Name: ***NVUSD: WOODEN VALLEY SCHOOL***

PS Code: ***2800845-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2008/02/27	< 1.000		
2,4-D	39730	WAIVED	2008/02/27	< 10.000		
ALACHLOR	77825	WAIVED	2008/02/27	.000		
ATRAZINE	39033	036	2008/02/27	.000	2011/02	DUE
BENTAZON	38710	WAIVED	2008/02/27	< 2.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2008/02/27	< 5.000	2011/02	DUE
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2008/02/27	< 10.000	2011/02	DUE
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2010/01/28	.000		
DINOSEB	81287	036	2008/02/27	< 2.000	2011/02	DUE
DIQUAT	78885	036	2008/02/27	< 4.000	2011/02	DUE
ENDOTHALL	38926	036	2008/02/27	< 45.000	2011/02	DUE
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2010/01/28	.000		
GLYPHOSATE	79743	WAIVED	1988/06/29	< 5.000		
HEPTACHLOR	39410	000				DUE
HEPTACHLOR EPOXIDE	39420	000				DUE
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800845***

System Name: ***NVUSD: WOODEN VALLEY SCHOOL***

PS Code: ***2800845-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	000				DUE
MOLINATE	82199	WAIVED	2008/02/27	.000		
OXAMYL	38865	036	2008/02/27	< 20.000	2011/02	DUE
PENTACHLOROPHENOL	39032	036	2008/02/27	< .200	2011/02	DUE
PICLORAM	39720	036	2008/02/27	< 1.000	2011/02	DUE
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2008/02/27	.000	2011/02	DUE
THIOBENCARB	A-001	WAIVED	2008/02/27	.000		
TOXAPHENE	39400	000				DUE
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2010/01/28	.000	2016/01	
1,1,2,2-TETRACHLOROETHANE	34516	072	2010/01/28	.000	2016/01	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2010/01/28	.000	2016/01	
1,1,2-TRICHLOROETHANE	34511	072	2010/01/28	.000	2016/01	
1,1-DICHLOROETHANE	34496	072	2010/01/28	.000	2016/01	
1,1-DICHLOROETHYLENE	34501	072	2010/01/28	.000	2016/01	
1,2,4-TRICHLOROBENZENE	34551	072	2010/01/28	.000	2016/01	
1,2-DICHLOROBENZENE	34536	072	2010/01/28	.000	2016/01	
1,2-DICHLOROETHANE	34531	072	2010/01/28	.000	2016/01	
1,2-DICHLOROPROPANE	34541	072	2010/01/28	.000	2016/01	
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2010/01/28	.000	2016/01	
1,4-DICHLOROBENZENE	34571	072	2010/01/28	.000	2016/01	
BENZENE	34030	072	2010/01/28	.000	2016/01	
CARBON TETRACHLORIDE	32102	072	2010/01/28	.000	2016/01	
CIS-1,2-DICHLOROETHYLENE	77093	072	2010/01/28	.000	2016/01	
DICHLOROMETHANE	34423	072	2010/01/28	.000	2016/01	
ETHYLBENZENE	34371	072	2010/01/28	.000	2016/01	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2010/01/28	.000	2016/01	
MONOCHLOROBENZENE	34301	072	2010/01/28	.000	2016/01	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800845***

System Name: ***NVUSD: WOODEN VALLEY SCHOOL***

PS Code: ***2800845-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2010/01/28	.000	2016/01
TETRACHLOROETHYLENE	34475	072	2010/01/28	.000	2016/01
TOLUENE	34010	072	2010/01/28	.000	2016/01
TRANS-1,2-DICHLOROETHYLENE	34546	072	2010/01/28	.000	2016/01
TRICHLOROETHYLENE	39180	072	2010/01/28	.000	2016/01
TRICHLOROFLUOROMETHANE	34488	072	2010/01/28	.000	2016/01
VINYL CHLORIDE	39175	072	2010/01/28	.000	2016/01
XYLENES (TOTAL)	81551	072	2010/01/28	.000	2016/01
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2008/02/27	260.000	
CALCIUM	00916	WAIVED	2008/02/27	44.000	
CARBONATE ALKALINITY	00445	WAIVED	2008/02/27	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2008/02/27	200.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2008/02/27	.000	
IRON	01045	WAIVED	2008/02/27	1100.000	
MAGNESIUM	00927	WAIVED	2008/02/27	18.000	
MANGANESE	01055	WAIVED	2008/02/27	76.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2008/02/27	7.200	
SILVER	01077	WAIVED	2008/02/27	.000	
SODIUM	00929	WAIVED	2008/02/27	45.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800845***

System Name: ***NVUSD: WOODEN VALLEY SCHOOL***

PS Code: ***2800845-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800845-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800845***

System Name: ***NVUSD: WOODEN VALLEY SCHOOL***

PS Code: ***2800845-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800845***

System Name: ***NVUSD: WOODEN VALLEY SCHOOL***

PS Code: ***2800845-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800845***

System Name: ***NVUSD: WOODEN VALLEY SCHOOL***

PS Code: ***2800845-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800845***

System Name: ***NVUSD: WOODEN VALLEY SCHOOL***

PS Code: ***2800845-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800847***

System Name: ***NVUSD: CARNEROS SCHOOL***

PS Code: ***2800847-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2008/02/27	.000		
INORGANIC						
ALUMINUM	01105	036	2008/02/27	.000	2011/02	DUE
ANTIMONY	01097	036	2008/02/27	.000	2011/02	DUE
ARSENIC	01002	036	2008/02/27	4.800	2011/02	DUE
ASBESTOS	81855	108	2004/05/18	.000	2013/05	
BARIUM	01007	036	2008/02/27	180.000	2011/02	DUE
BERYLLIUM	01012	036	2008/02/27	.000	2011/02	DUE
CADMIUM	01027	036	2008/02/27	.000	2011/02	DUE
CHROMIUM (TOTAL)	01034	036	2008/02/27	.000	2011/02	DUE
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2008/02/27	.000	2011/02	DUE
LEAD	01051	WAIVED	2008/02/27	.000		
MERCURY	71900	036	2008/02/27	.000	2011/02	DUE
NICKEL	01067	036	2008/02/27	.000	2011/02	DUE
PERCHLORATE	A-031	006	2008/09/23	.000	2009/03	DUE
SELENIUM	01147	036	2008/02/27	.000	2011/02	DUE
THALLIUM	01059	036	2008/02/27	.000	2011/02	DUE
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2010/02/03	.000	2011/02	DUE
NITRITE (AS N)	00620	036	2008/02/27	.000	2011/02	DUE
RADIOLOGICAL						
GROSS ALPHA	01501	108	2008/12/15	.870	2017/12	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800847***

System Name: ***NVUSD: CARNEROS SCHOOL***

PS Code: ***2800847-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2008/02/27	< 1.000		
2,4-D	39730	WAIVED	2008/02/27	< 10.000		
ALACHLOR	77825	WAIVED	2008/02/27	.000		
ATRAZINE	39033	036	**2008/02/27**	.000	**2011/02**	**DUE**
BENTAZON	38710	WAIVED	2008/02/27	< 2.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	**2008/02/27**	< 5.000	**2011/02**	**DUE**
CHLORDANE	39350	WAIVED	2004/05/18	.000		
DALAPON	38432	036	**2008/02/27**	< 10.000	**2011/02**	**DUE**
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2010/02/03	.000		
DINOSEB	81287	036	**2008/02/27**	< 2.000	**2011/02**	**DUE**
DIQUAT	78885	036	**2008/02/27**	< 4.000	**2011/02**	**DUE**
ENDOTHALL	38926	036	**2008/02/27**	< 45.000	**2011/02**	**DUE**
ENDRIN	39390	WAIVED	2004/05/18	.000		
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2010/02/03	.000		
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	WAIVED	2004/05/18	.000		
HEPTACHLOR EPOXIDE	39420	WAIVED	2004/05/18	.000		
HEXACHLOROBENZENE	39700	WAIVED	2004/05/18	.000		
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2004/05/18	.000		
LINDANE	39340	WAIVED	2004/05/18	.000		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800847***

System Name: ***NVUSD: CARNEROS SCHOOL***

PS Code: ***2800847-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	WAIVED	2004/05/18	.000		
MOLINATE	82199	WAIVED	2008/02/27	.000		
OXAMYL	38865	036	2008/02/27	< 20.000	2011/02	DUE
PENTACHLOROPHENOL	39032	036	2008/02/27	< .200	2011/02	DUE
PICLORAM	39720	036	2008/02/27	< 1.000	2011/02	DUE
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2004/05/18	.000		
SIMAZINE	39055	036	2008/02/27	.000	2011/02	DUE
THIOBENCARB	A-001	WAIVED	2008/02/27	.000		
TOXAPHENE	39400	WAIVED	2004/05/18	.000		
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2010/02/03	.000	2016/02	
1,1,2,2-TETRACHLOROETHANE	34516	072	2010/02/03	.000	2016/02	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2010/02/03	.000	2016/02	
1,1,2-TRICHLOROETHANE	34511	072	2010/02/03	.000	2016/02	
1,1-DICHLOROETHANE	34496	072	2010/02/03	.000	2016/02	
1,1-DICHLOROETHYLENE	34501	072	2010/02/03	.000	2016/02	
1,2,4-TRICHLOROBENZENE	34551	072	2010/02/03	.000	2016/02	
1,2-DICHLOROBENZENE	34536	072	2010/02/03	.000	2016/02	
1,2-DICHLOROETHANE	34531	072	2010/02/03	.000	2016/02	
1,2-DICHLOROPROPANE	34541	072	2010/02/03	.000	2016/02	
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2010/02/03	.000	2016/02	
1,4-DICHLOROBENZENE	34571	072	2010/02/03	.000	2016/02	
BENZENE	34030	072	2010/02/03	.000	2016/02	
CARBON TETRACHLORIDE	32102	072	2010/02/03	.500	2016/02	
CIS-1,2-DICHLOROETHYLENE	77093	072	2010/02/03	.000	2016/02	
DICHLOROMETHANE	34423	072	2010/02/03	.000	2016/02	
ETHYLBENZENE	34371	072	2010/02/03	.000	2016/02	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2010/02/03	.000	2016/02	
MONOCHLOROBENZENE	34301	072	2010/02/03	.000	2016/02	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800847***

System Name: ***NVUSD: CARNEROS SCHOOL***

PS Code: ***2800847-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2010/02/03	.000	2016/02
TETRACHLOROETHYLENE	34475	072	2010/02/03	.000	2016/02
TOLUENE	34010	072	2010/02/03	.000	2016/02
TRANS-1,2-DICHLOROETHYLENE	34546	072	2010/02/03	.000	2016/02
TRICHLOROETHYLENE	39180	072	2010/02/03	.000	2016/02
TRICHLOROFLUOROMETHANE	34488	072	2010/02/03	.000	2016/02
VINYL CHLORIDE	39175	072	2010/02/03	.000	2016/02
XYLENES (TOTAL)	81551	072	2010/02/03	.000	2016/02
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2008/02/27	330.000	
CALCIUM	00916	WAIVED	2008/02/27	17.000	
CARBONATE ALKALINITY	00445	WAIVED	2008/02/27	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2008/02/27	110.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2008/02/27	.000	
IRON	01045	WAIVED	2008/02/27	610.000	
MAGNESIUM	00927	WAIVED	2008/02/27	15.000	
MANGANESE	01055	WAIVED	2008/02/27	170.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2008/02/27	7.900	
SILVER	01077	WAIVED	2008/02/27	.000	
SODIUM	00929	WAIVED	2008/02/27	110.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800847***

System Name: ***NVUSD: CARNEROS SCHOOL***

PS Code: ***2800847-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800847-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800847***

System Name: ***NVUSD: CARNEROS SCHOOL***

PS Code: ***2800847-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800847***

System Name: ***NVUSD: CARNEROS SCHOOL***

PS Code: ***2800847-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800847***

System Name: ***NVUSD: CARNEROS SCHOOL***

PS Code: ***2800847-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800847***

System Name: ***NVUSD: CARNEROS SCHOOL***

PS Code: ***2800847-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800848***

System Name: ***NVUSD: MT. GEORGE SCHOOL***

PS Code: ***2800848-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800848***

System Name: ***NVUSD: MT. GEORGE SCHOOL***

PS Code: ***2800848-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800848***

System Name: ***NVUSD: MT. GEORGE SCHOOL***

PS Code: ***2800848-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800848***

System Name: ***NVUSD: MT. GEORGE SCHOOL***

PS Code: ***2800848-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800848***

System Name: ***NVUSD: MT. GEORGE SCHOOL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)

PS Code: ***2800848-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2800848-003***

Source Name: ***WELL 002***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED			

INORGANIC

ALUMINUM	01105	000			**DUE**
ANTIMONY	01097	000			**DUE**
ARSENIC	01002	000			**DUE**
ASBESTOS	81855	000			**DUE**
BARIUM	01007	000			**DUE**
BERYLLIUM	01012	000			**DUE**
CADMIUM	01027	000			**DUE**
CHROMIUM (TOTAL)	01034	000			**DUE**
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	000			**DUE**
LEAD	01051	WAIVED			
MERCURY	71900	000			**DUE**
NICKEL	01067	000			**DUE**
PERCHLORATE	A-031	006			**DUE**
SELENIUM	01147	000			**DUE**
THALLIUM	01059	000			**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800848***

System Name: ***NVUSD: MT. GEORGE SCHOOL***

PS Code: ***2800848-003***

Source Name: ***WELL 002***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	000				DUE
NITRITE (AS N)	00620	000				DUE
RADIOLOGICAL						
GROSS ALPHA	01501	000				DUE
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2010/02/02	.000		
2,4-D	39730	WAIVED	2010/02/02	.000		
ALACHLOR	77825	WAIVED	2010/02/02	.000		
ATRAZINE	39033	036	2010/02/02	.000	2013/02	
BENTAZON	38710	WAIVED	2010/02/02	.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2010/02/02	.000	2013/02	
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2010/02/02	.000	2013/02	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	036	2010/02/02	.000	2013/02	
DIQUAT	78885	036	2010/02/02	.000	2013/02	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800848***

System Name: ***NVUSD: MT. GEORGE SCHOOL***

PS Code: ***2800848-003***

Source Name: ***WELL 002***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
ENDOTHALL	38926	036	2010/02/02	.000	2013/02	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	000				DUE
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				DUE
HEPTACHLOR EPOXIDE	39420	000				DUE
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				DUE
METHOXYCHLOR	39480	000				DUE
MOLINATE	82199	WAIVED	2010/02/02	.000		
OXAMYL	38865	036	2010/02/02	.000	2013/02	
PENTACHLOROPHENOL	39032	036	2010/02/02	.000	2013/02	
PICLORAM	39720	036	2010/02/02	.000	2013/02	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2010/02/02	.000	2013/02	
THIOBENCARB	A-001	WAIVED	2010/02/02	.000		
TOXAPHENE	39400	000				DUE
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	000				DUE
1,1,2,2-TETRACHLOROETHANE	34516	000				DUE
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	000				DUE
1,1,2-TRICHLOROETHANE	34511	000				DUE
1,1-DICHLOROETHANE	34496	000				DUE
1,1-DICHLOROETHYLENE	34501	000				DUE
1,2,4-TRICHLOROBENZENE	34551	000				DUE
1,2-DICHLOROBENZENE	34536	000				DUE
1,2-DICHLOROETHANE	34531	000				DUE
1,2-DICHLOROPROPANE	34541	000				DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800848***

System Name: ***NVUSD: MT. GEORGE SCHOOL***

PS Code: ***2800848-003***

Source Name: ***WELL 002***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	000			DUE
1,4-DICHLOROBENZENE	34571	000			DUE
BENZENE	34030	000			DUE
CARBON TETRACHLORIDE	32102	000			DUE
CIS-1,2-DICHLOROETHYLENE	77093	000			DUE
DICHLOROMETHANE	34423	000			DUE
ETHYLBENZENE	34371	000			DUE
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	000			DUE
MONOCHLOROBENZENE	34301	000			DUE
STYRENE	77128	000			DUE
TETRACHLOROETHYLENE	34475	000			DUE
TOLUENE	34010	000			DUE
TRANS-1,2-DICHLOROETHYLENE	34546	000			DUE
TRICHLOROETHYLENE	39180	000			DUE
TRICHLOROFLUOROMETHANE	34488	000			DUE
VINYL CHLORIDE	39175	000			DUE
XYLENES (TOTAL)	81551	000			DUE
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800848***

System Name: ***NVUSD: MT. GEORGE SCHOOL***

PS Code: ***2800848-003***

Source Name: ***WELL 002***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
MAGNESIUM	**00927**	**000**				**DUE**
MANGANESE	**01055**	**000**				**DUE**
ODOR THRESHOLD @ 60 C	**00086**	**WAIVED**				
PH, LABORATORY	**00403**	**000**				**DUE**
SILVER	**01077**	**WAIVED**				
SODIUM	**00929**	**000**				**DUE**
SPECIFIC CONDUCTANCE	**00095**	**WAIVED**				
SULFATE	**00945**	**WAIVED**				
TOTAL DISSOLVED SOLIDS	**70300**	**WAIVED**				
TURBIDITY, LABORATORY	**82079**	**WAIVED**				
ZINC	**01092**	**WAIVED**				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800970***

System Name: ***HOWELL MTN SCHOOL***

PS Code: ***2800970-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	036	2010/03/30	< 50.000	2013/03	
ANTIMONY	01097	036	2010/03/30	< 6.000	2013/03	
ARSENIC	01002	036	2010/03/30	< 2.000	2013/03	
ASBESTOS	81855	000				**DUE**
BARIUM	01007	036	2010/03/30	< 100.000	2013/03	
BERYLLIUM	01012	036	2010/03/30	< 1.000	2013/03	
CADMIUM	01027	036	2010/03/30	< 1.000	2013/03	
CHROMIUM (TOTAL)	01034	036	2010/03/30	< 1.000	2013/03	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2010/03/30	.280	2013/03	
LEAD	01051	WAIVED				
MERCURY	71900	036	2010/03/30	< 1.000	2013/03	
NICKEL	01067	036	2010/03/30	< 10.000	2013/03	
PERCHLORATE	A-031	006	**2011/08/23**	< 4.000	**2012/02**	**DUE**
SELENIUM	01147	036	2010/03/30	< 5.000	2013/03	
THALLIUM	01059	036	2010/03/30	< 1.000	2013/03	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	**2010/03/30**	8.600	**2011/03**	**DUE**
NITRITE (AS N)	00620	000				**DUE**
RADIOLOGICAL						
GROSS ALPHA	01501	108	2006/12/27	.953	2015/12	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800970***

System Name: ***HOWELL MTN SCHOOL***

PS Code: ***2800970-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	000			DUE
2,4-D	39730	000			DUE
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	000			DUE
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	000			DUE
CHLORDANE	39350	WAIVED			
DALAPON	38432	000			DUE
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	000			DUE
DIQUAT	78885	000			DUE
ENDOTHALL	38926	000			DUE
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	000			DUE
GLYPHOSATE	79743	WAIVED	1988/06/29	< 5.000	
HEPTACHLOR	39410	000			DUE
HEPTACHLOR EPOXIDE	39420	000			DUE
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800970***

System Name: ***HOWELL MTN SCHOOL***

PS Code: ***2800970-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	000				DUE
MOLINATE	82199	WAIVED				
OXAMYL	38865	000				DUE
PENTACHLOROPHENOL	39032	000				DUE
PICLORAM	39720	000				DUE
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	1988/06/08	< .500	1991/06	DUE
THIOBENCARB	A-001	WAIVED				
TOXAPHENE	39400	000				DUE
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	1988/06/29	.000	1994/06	DUE
1,1,2,2-TETRACHLOROETHANE	34516	072	1988/06/29	.000	1994/06	DUE
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	1988/06/29	.000	1994/06	DUE
1,1,2-TRICHLOROETHANE	34511	072	1988/06/29	.000	1994/06	DUE
1,1-DICHLOROETHANE	34496	072	1988/06/29	.000	1994/06	DUE
1,1-DICHLOROETHYLENE	34501	072	1988/06/29	.000	1994/06	DUE
1,2,4-TRICHLOROBENZENE	34551	000				DUE
1,2-DICHLOROBENZENE	34536	072	1988/06/29	.000	1994/06	DUE
1,2-DICHLOROETHANE	34531	072	1988/06/29	.000	1994/06	DUE
1,2-DICHLOROPROPANE	34541	000				DUE
1,3-DICHLOROPROPENE (TOTAL)	34561	000				DUE
1,4-DICHLOROBENZENE	34571	072	1988/06/29	.000	1994/06	DUE
BENZENE	34030	072	1988/06/29	.000	1994/06	DUE
CARBON TETRACHLORIDE	32102	072	1988/06/29	.000	1994/06	DUE
CIS-1,2-DICHLOROETHYLENE	77093	072	1988/06/29	.000	1994/06	DUE
DICHLOROMETHANE	34423	072	1988/06/29	.000	1994/06	DUE
ETHYLBENZENE	34371	072	1988/06/29	.000	1994/06	DUE
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	000				DUE
MONOCHLOROBENZENE	34301	072	1988/06/29	.000	1994/06	DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800970***

System Name: ***HOWELL MTN SCHOOL***

PS Code: ***2800970-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED VOC						
STYRENE	77128	000				DUE
TETRACHLOROETHYLENE	34475	072	1988/06/29	.000	1994/06	DUE
TOLUENE	34010	072	1988/06/29	.000	1994/06	DUE
TRANS-1,2-DICHLOROETHYLENE	34546	072	1988/06/29	.000	1994/06	DUE
TRICHLOROETHYLENE	39180	072	1988/06/29	.000	1994/06	DUE
TRICHLOROFLUOROMETHANE	34488	072	1988/06/29	.000	1994/06	DUE
VINYL CHLORIDE	39175	072	1988/06/29	.000	1994/06	DUE
XYLENES (TOTAL)	81551	072	1988/06/29	.000	1994/06	DUE
SECONDARY/GP						
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED				
BICARBONATE ALKALINITY	00440	000				DUE
CALCIUM	00916	WAIVED	2010/03/30	10.000		
CARBONATE ALKALINITY	00445	000				DUE
CHLORIDE	00940	WAIVED				
COLOR	00081	WAIVED				
COPPER	01042	WAIVED	2010/03/30	< 50.000		
FOAMING AGENTS (MBAS)	38260	WAIVED				
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2010/03/30	39.000		
HYDROXIDE ALKALINITY	71830	000				DUE
IRON	01045	WAIVED	2010/03/30	< 100.000		
MAGNESIUM	00927	WAIVED	2010/03/30	3.400		
MANGANESE	01055	WAIVED	2010/03/30	< 20.000		
ODOR THRESHOLD @ 60 C	00086	WAIVED				
PH, LABORATORY	00403	WAIVED	2010/03/30	6.900		
SILVER	01077	WAIVED	2010/03/30	< 10.000		
SODIUM	00929	WAIVED	2010/03/30	9.500		
SPECIFIC CONDUCTANCE	00095	WAIVED				
SULFATE	00945	WAIVED				
TOTAL DISSOLVED SOLIDS	70300	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800970***

System Name: ***HOWELL MTN SCHOOL***

PS Code: ***2800970-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED	2010/03/30	< 50.000	

PS Code: ***2800970-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800970***

System Name: ***HOWELL MTN SCHOOL***

PS Code: ***2800970-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800970***

System Name: ***HOWELL MTN SCHOOL***

PS Code: ***2800970-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800970***

System Name: ***HOWELL MTN SCHOOL***

PS Code: ***2800970-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2800970***

System Name: ***HOWELL MTN SCHOOL***

PS Code: ***2800970-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801002***

System Name: ***ETUDE WINES***

PS Code: ***2801002-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2012/03/22	< .000	2013/03	
NITRITE (AS N)	00620	036	2012/01/26	< .000	2015/01	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801002***

System Name: ***ETUDE WINES***

PS Code: ***2801002-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801002***

System Name: ***ETUDE WINES***

PS Code: ***2801002-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801002***

System Name: ***ETUDE WINES***

PS Code: ***2801002-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2012/01/26	340.000	
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	WAIVED	2012/01/26	< .000	
CHLORIDE	00940	WAIVED	2012/01/26	65.000	
COLOR	00081	WAIVED	2012/01/26	20.000	
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2012/01/26	220.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2012/01/26	< .000	
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2012/01/26	7.800	
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED	2012/01/26	860.000	
SULFATE	00945	WAIVED	2012/01/26	79.000	
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801002***

System Name: ***ETUDE WINES***

PS Code: ***2801002-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED	2012/01/26	4.700	
ZINC	01092	WAIVED			

PS Code: ***2801002-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801002***

System Name: ***ETUDE WINES***

PS Code: ***2801002-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801002***

System Name: ***ETUDE WINES***

PS Code: ***2801002-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801002***

System Name: ***ETUDE WINES***

PS Code: ***2801002-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801002***

System Name: ***ETUDE WINES***

PS Code: ***2801002-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801003***

System Name: ***CHATEAU BOSWELL***

PS Code: ***2801003-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED	2003/02/13	.000		
ANTIMONY	01097	WAIVED	2003/02/13	.000		
ARSENIC	01002	WAIVED	2003/02/13	.000		
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED	2003/02/13	.000		
BERYLLIUM	01012	WAIVED	2003/02/13	.000		
CADMIUM	01027	WAIVED	2003/02/13	.000		
CHROMIUM (TOTAL)	01034	WAIVED	2003/02/13	.000		
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED	2003/02/13	.000		
NICKEL	01067	WAIVED	2003/02/13	.000		
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED	2003/02/13	.000		
THALLIUM	01059	WAIVED	2003/02/13	.000		
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	**2006/03/22**	.000	**2007/03**	**DUE**
NITRITE (AS N)	00620	036	**2003/02/13**	.000	**2006/02**	**DUE**
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801003***

System Name: ***CHATEAU BOSWELL***

PS Code: ***2801003-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801003***

System Name: ***CHATEAU BOSWELL***

PS Code: ***2801003-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801003***

System Name: ***CHATEAU BOSWELL***

PS Code: ***2801003-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801003***

System Name: ***CHATEAU BOSWELL***

PS Code: ***2801003-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801004***

System Name: ***CHATEAU MONTELENA WINERY***

PS Code: ***2801004-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED	2010/08/09	< .025	
INORGANIC					
ALUMINUM	01105	WAIVED	2010/08/09	< 50.000	
ANTIMONY	01097	WAIVED	2010/08/09	< 6.000	
ARSENIC	01002	WAIVED	2010/08/09	< 2.000	
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED	2010/08/09	< 100.000	
BERYLLIUM	01012	WAIVED	2010/08/09	< 1.000	
CADMIUM	01027	WAIVED	2010/08/09	< 1.000	
CHROMIUM (TOTAL)	01034	WAIVED	2010/08/09	< 1.000	
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2010/08/09	.230	
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED	2010/08/09	< 1.000	
NICKEL	01067	WAIVED	2010/08/09	< 10.000	
PERCHLORATE	A-031	WAIVED	2011/12/13	< 4.000	
SELENIUM	01147	WAIVED	2010/08/09	< 5.000	
THALLIUM	01059	WAIVED	2010/08/09	< 1.000	
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2011/08/23	< 2.000	2012/08
NITRITE (AS N)	00620	036	2010/08/09	< 400.000	2013/08
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED	2011/12/13	.475	
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801004***

System Name: ***CHATEAU MONTELENA WINERY***

PS Code: ***2801004-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2010/08/09	.000	
2,4-D	39730	WAIVED	2010/08/09	.000	
ALACHLOR	77825	WAIVED	2010/08/09	.000	
ATRAZINE	39033	WAIVED	2010/08/09	.000	
BENTAZON	38710	WAIVED	2010/08/09	.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED	2010/08/09	.000	
CHLORDANE	39350	WAIVED	2010/08/09	.000	
DALAPON	38432	WAIVED	2010/08/09	.000	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED	2010/08/09	.000	
DIQUAT	78885	WAIVED	2010/08/09	.000	
ENDOTHALL	38926	WAIVED	2010/08/09	.000	
ENDRIN	39390	WAIVED	2010/08/09	.000	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2010/08/09	.000	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2010/08/09	.000	
HEPTACHLOR EPOXIDE	39420	WAIVED	2010/08/09	.000	
HEXACHLOROBENZENE	39700	WAIVED	2010/08/09	.000	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2010/08/09	.000	
LINDANE	39340	WAIVED	2010/08/09	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801004***

System Name: ***CHATEAU MONTELENA WINERY***

PS Code: ***2801004-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED	2010/08/09	.000	
MOLINATE	82199	WAIVED	2010/08/09	.000	
OXAMYL	38865	WAIVED	2010/08/09	.000	
PENTACHLOROPHENOL	39032	WAIVED	2010/08/09	.000	
PICLORAM	39720	WAIVED	2010/08/09	.000	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED	2010/08/09	.000	
THIOBENCARB	A-001	WAIVED	2010/08/09	.000	
TOXAPHENE	39400	WAIVED	2010/08/09	.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED	2010/08/09	.000	
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED	2010/08/09	.000	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED	2010/08/09	.000	
1,1,2-TRICHLOROETHANE	34511	WAIVED	2010/08/09	.000	
1,1-DICHLOROETHANE	34496	WAIVED	2010/08/09	.000	
1,1-DICHLOROETHYLENE	34501	WAIVED	2010/08/09	.000	
1,2,4-TRICHLOROBENZENE	34551	WAIVED	2010/08/09	.000	
1,2-DICHLOROBENZENE	34536	WAIVED	2010/08/09	.000	
1,2-DICHLOROETHANE	34531	WAIVED	2010/08/09	.000	
1,2-DICHLOROPROPANE	34541	WAIVED	2010/08/09	.000	
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED	2010/08/09	.000	
1,4-DICHLOROBENZENE	34571	WAIVED	2010/08/09	.000	
BENZENE	34030	WAIVED	2010/08/09	.000	
CARBON TETRACHLORIDE	32102	WAIVED	2010/08/09	.000	
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED	2010/08/09	.000	
DICHLOROMETHANE	34423	WAIVED	2010/08/09	.000	
ETHYLBENZENE	34371	WAIVED	2010/08/09	.000	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED	2010/08/09	.000	
MONOCHLOROBENZENE	34301	WAIVED	2010/08/09	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801004***

System Name: ***CHATEAU MONTELENA WINERY***

PS Code: ***2801004-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED	2010/08/09	.000	
TETRACHLOROETHYLENE	34475	WAIVED	2010/08/09	.000	
TOLUENE	34010	WAIVED	2010/08/09	.000	
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED	2010/08/09	.000	
TRICHLOROETHYLENE	39180	WAIVED	2010/08/09	.000	
TRICHLOROFLUOROMETHANE	34488	WAIVED	2010/08/09	.000	
VINYL CHLORIDE	39175	WAIVED	2010/08/09	.000	
XYLENES (TOTAL)	81551	WAIVED	2010/08/09	.000	
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2010/08/09	180.000	
CALCIUM	00916	WAIVED	2010/08/09	37.000	
CARBONATE ALKALINITY	00445	WAIVED	2010/08/09	< 1.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED	2010/08/09	< 50.000	
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2010/08/09	160.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2010/08/09	< 1.000	
IRON	01045	WAIVED	2010/08/09	910.000	
MAGNESIUM	00927	WAIVED	2010/08/09	16.000	
MANGANESE	01055	WAIVED	2010/08/09	130.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2010/08/09	7.000	
SILVER	01077	WAIVED	2010/08/09	< 10.000	
SODIUM	00929	WAIVED	2010/08/09	20.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801004***

System Name: ***CHATEAU MONTELENA WINERY***

PS Code: ***2801004-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED	2010/08/09	< 50.000	

PS Code: ***2801004-002***

Source Name: ***CALIST CITY WATER***

Source Number: ***002***

Source Status: ***PURCHASED TREATED***

Water type: ***SURFACE***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801004***

System Name: ***CHATEAU MONTELENA WINERY***

PS Code: ***2801004-002***

Source Name: ***CALIST CITY WATER***

Source Number: ***002***

Source Status: ***PURCHASED TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801004***

System Name: ***CHATEAU MONTELENA WINERY***

PS Code: ***2801004-002***

Source Name: ***CALIST CITY WATER***

Source Number: ***002***

Source Status: ***PURCHASED TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801004***

System Name: ***CHATEAU MONTELENA WINERY***

PS Code: ***2801004-002***

Source Name: ***CALIST CITY WATER***

Source Number: ***002***

Source Status: ***PURCHASED TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801004***

System Name: ***CHATEAU MONTELENA WINERY***

PS Code: ***2801004-002***

Source Name: ***CALIST CITY WATER***

Source Number: ***002***

Source Status: ***PURCHASED TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801004-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801004***

System Name: ***CHATEAU MONTELENA WINERY***

PS Code: ***2801004-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801004***

System Name: ***CHATEAU MONTELENA WINERY***

PS Code: ***2801004-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801004***

System Name: ***CHATEAU MONTELENA WINERY***

PS Code: ***2801004-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801004***

System Name: ***CHATEAU MONTELENA WINERY***

PS Code: ***2801004-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED	2010/10/12	< 100.000	
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED	2010/10/12	< 20.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801004-004***

Source Name: ***WELL 002***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED	2010/08/09	< .025	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801004***

System Name: ***CHATEAU MONTELENA WINERY***

PS Code: ***2801004-004***

Source Name: ***WELL 002***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED	2011/12/13	< 4.000		
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/08/23	< 2.000	2012/08	
NITRITE (AS N)	00620	000				**DUE**
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED	2011/12/13	.709		
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801004***

System Name: ***CHATEAU MONTELENA WINERY***

PS Code: ***2801004-004***

Source Name: ***WELL 002***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2010/08/09	.000	
2,4-D	39730	WAIVED	2010/08/09	.000	
ALACHLOR	77825	WAIVED	2010/08/09	.000	
ATRAZINE	39033	WAIVED	2010/08/09	.000	
BENTAZON	38710	WAIVED	2010/08/09	.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED	2010/08/09	.000	
CHLORDANE	39350	WAIVED	2010/08/09	.000	
DALAPON	38432	WAIVED	2010/08/09	.000	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED	2010/08/09	.000	
DIQUAT	78885	WAIVED	2010/08/09	.000	
ENDOTHALL	38926	WAIVED	2010/08/09	.000	
ENDRIN	39390	WAIVED	2010/08/09	.000	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2010/08/09	.000	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2010/08/09	.000	
HEPTACHLOR EPOXIDE	39420	WAIVED	2010/08/09	.000	
HEXACHLOROBENZENE	39700	WAIVED	2010/08/09	.000	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2010/08/09	.000	
LINDANE	39340	WAIVED	2010/08/09	.000	
METHOXYCHLOR	39480	WAIVED	2010/08/09	.000	
MOLINATE	82199	WAIVED	2010/08/09	.000	
OXAMYL	38865	WAIVED	2010/08/09	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801004***

System Name: ***CHATEAU MONTELENA WINERY***

PS Code: ***2801004-004***

Source Name: ***WELL 002***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
PENTACHLOROPHENOL	39032	WAIVED	2010/08/09	.000	
PICLORAM	39720	WAIVED	2010/08/09	.000	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED	2010/08/09	.000	
THIOBENCARB	A-001	WAIVED	2010/08/09	.000	
TOXAPHENE	39400	WAIVED	2010/08/09	.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED	2010/08/09	.000	
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED	2010/08/09	.000	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED	2010/08/09	.000	
1,1,2-TRICHLOROETHANE	34511	WAIVED	2010/08/09	.000	
1,1-DICHLOROETHANE	34496	WAIVED	2010/08/09	.000	
1,1-DICHLOROETHYLENE	34501	WAIVED	2010/08/09	.000	
1,2,4-TRICHLOROBENZENE	34551	WAIVED	2010/08/09	.000	
1,2-DICHLOROBENZENE	34536	WAIVED	2010/08/09	.000	
1,2-DICHLOROETHANE	34531	WAIVED	2010/08/09	.000	
1,2-DICHLOROPROPANE	34541	WAIVED	2010/08/09	.000	
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED	2010/08/09	.000	
1,4-DICHLOROBENZENE	34571	WAIVED	2010/08/09	.000	
BENZENE	34030	WAIVED	2010/08/09	.000	
CARBON TETRACHLORIDE	32102	WAIVED	2010/08/09	.000	
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED	2010/08/09	.000	
DICHLOROMETHANE	34423	WAIVED	2010/08/09	.000	
ETHYLBENZENE	34371	WAIVED	2010/08/09	.000	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED	2010/08/09	.000	
MONOCHLOROBENZENE	34301	WAIVED	2010/08/09	.000	
STYRENE	77128	WAIVED	2010/08/09	.000	
TETRACHLOROETHYLENE	34475	WAIVED	2010/08/09	.000	
TOLUENE	34010	WAIVED	2010/08/09	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801004***

System Name: ***CHATEAU MONTELENA WINERY***

PS Code: ***2801004-004***

Source Name: ***WELL 002***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED	2010/08/09	.000	
TRICHLOROETHYLENE	39180	WAIVED	2010/08/09	.000	
TRICHLOROFLUOROMETHANE	34488	WAIVED	2010/08/09	.000	
VINYL CHLORIDE	39175	WAIVED	2010/08/09	.000	
XYLENES (TOTAL)	81551	WAIVED	2010/08/09	.000	
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801006***

System Name: ***CLOS DU VAL WINE CO.***

PS Code: ***2801006-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2007/08/21	.000		
INORGANIC						
ALUMINUM	01105	036	2011/02/23	.000	2014/02	
ANTIMONY	01097	036	2011/02/23	.000	2014/02	
ARSENIC	01002	036	2011/02/23	.000	2014/02	
ASBESTOS	81855	108	2008/05/13	.000	2017/05	
BARIUM	01007	036	2011/02/23	.000	2014/02	
BERYLLIUM	01012	036	2011/02/23	.000	2014/02	
CADMIUM	01027	036	2011/02/23	.000	2014/02	
CHROMIUM (TOTAL)	01034	036	2011/02/23	.000	2014/02	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2011/02/23	.240	2014/02	
LEAD	01051	WAIVED	2011/02/23	.000		
MERCURY	71900	036	2011/02/23	4.000	2014/02	
NICKEL	01067	036	2011/02/23	.000	2014/02	
PERCHLORATE	A-031	006	**2009/08/06**	.000	**2010/02**	**DUE**
SELENIUM	01147	036	2011/02/23	.000	2014/02	
THALLIUM	01059	036	2011/02/23	.000	2014/02	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2012/02/08	< .000	2013/02	
NITRITE (AS N)	00620	036	2010/02/09	.000	2013/02	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2011/11/15	1.890	2020/11	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801006***

System Name: ***CLOS DU VAL WINE CO.***

PS Code: ***2801006-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2011/02/23	< 1.000	
2,4-D	39730	WAIVED	2011/02/23	< 10.000	
ALACHLOR	77825	WAIVED	2007/08/21	.000	
ATRAZINE	39033	036	2011/02/23	< .500	2014/02
BENTAZON	38710	WAIVED	2011/02/23	< 2.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	036	2011/02/23	< 5.000	2014/02
CHLORDANE	39350	WAIVED	2003/09/17	.000	
DALAPON	38432	036	2011/02/23	< 10.000	2014/02
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2007/08/21	.000	
DINOSEB	81287	036	2011/02/23	< 2.000	2014/02
DIQUAT	78885	036	2011/02/23	< 4.000	2014/02
ENDOTHALL	38926	036	2011/02/23	< 45.000	2014/02
ENDRIN	39390	WAIVED	2003/09/17	.000	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2007/08/21	.000	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2003/09/17	.000	
HEPTACHLOR EPOXIDE	39420	WAIVED	2003/09/17	.000	
HEXACHLOROBENZENE	39700	WAIVED	2003/09/17	.000	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2003/09/17	.000	
LINDANE	39340	WAIVED	2003/09/17	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801006***

System Name: ***CLOS DU VAL WINE CO.***

PS Code: ***2801006-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED	2003/09/17	.000	
MOLINATE	82199	WAIVED	2007/08/21	.000	
OXAMYL	38865	036	2011/02/23	< 20.000	2014/02
PENTACHLOROPHENOL	39032	036	2011/02/23	< .200	2014/02
PICLORAM	39720	036	2011/02/23	< 1.000	2014/02
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2003/09/17	.000	
SIMAZINE	39055	036	2011/02/23	< 1.000	2014/02
THIOBENCARB	A-001	WAIVED	2007/08/21	.000	
TOXAPHENE	39400	WAIVED	2003/09/17	.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	072	2007/08/21	.000	2013/08
1,1,2,2-TETRACHLOROETHANE	34516	072	2007/08/21	.000	2013/08
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2007/08/21	.000	2013/08
1,1,2-TRICHLOROETHANE	34511	072	2007/08/21	.000	2013/08
1,1-DICHLOROETHANE	34496	072	2007/08/21	.000	2013/08
1,1-DICHLOROETHYLENE	34501	072	2007/08/21	.000	2013/08
1,2,4-TRICHLOROBENZENE	34551	072	2007/08/21	.000	2013/08
1,2-DICHLOROBENZENE	34536	072	2007/08/21	.000	2013/08
1,2-DICHLOROETHANE	34531	072	2007/08/21	.000	2013/08
1,2-DICHLOROPROPANE	34541	072	2007/08/21	.000	2013/08
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2007/08/21	.000	2013/08
1,4-DICHLOROBENZENE	34571	072	2007/08/21	.000	2013/08
BENZENE	34030	072	2007/08/21	.000	2013/08
CARBON TETRACHLORIDE	32102	072	2007/08/21	.000	2013/08
CIS-1,2-DICHLOROETHYLENE	77093	072	2007/08/21	.000	2013/08
DICHLOROMETHANE	34423	072	2007/08/21	.000	2013/08
ETHYLBENZENE	34371	072	2007/08/21	.000	2013/08
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2007/08/21	.000	2013/08
MONOCHLOROBENZENE	34301	072	2007/08/21	.000	2013/08

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801006***

System Name: ***CLOS DU VAL WINE CO.***

PS Code: ***2801006-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2007/08/21	.000	2013/08
TETRACHLOROETHYLENE	34475	072	2007/08/21	.000	2013/08
TOLUENE	34010	072	2007/08/21	.000	2013/08
TRANS-1,2-DICHLOROETHYLENE	34546	072	2007/08/21	.000	2013/08
TRICHLOROETHYLENE	39180	072	2007/08/21	.000	2013/08
TRICHLOROFLUOROMETHANE	34488	072	2007/08/21	.000	2013/08
VINYL CHLORIDE	39175	072	2007/08/21	.000	2013/08
XYLENES (TOTAL)	81551	072	2007/08/21	.000	2013/08
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2011/02/23	51.000	
CALCIUM	00916	WAIVED	2011/02/23	9.100	
CARBONATE ALKALINITY	00445	WAIVED	2011/02/23	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2011/02/23	36.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2011/02/23	.000	
IRON	01045	WAIVED	2011/02/23	3980.000	
MAGNESIUM	00927	WAIVED	2011/02/23	3.100	
MANGANESE	01055	WAIVED	2011/02/23	241.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2011/02/23	6.800	
SILVER	01077	WAIVED	2011/02/23	.000	
SODIUM	00929	WAIVED	2011/02/23	20.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801006***

System Name: ***CLOS DU VAL WINE CO.***

PS Code: ***2801006-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801006-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801006***

System Name: ***CLOS DU VAL WINE CO.***

PS Code: ***2801006-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801006***

System Name: ***CLOS DU VAL WINE CO.***

PS Code: ***2801006-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801006***

System Name: ***CLOS DU VAL WINE CO.***

PS Code: ***2801006-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801006***

System Name: ***CLOS DU VAL WINE CO.***

PS Code: ***2801006-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801007***

System Name: ***CLOS PEGASE WINERY***

PS Code: ***2801007-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED	2009/03/16	< 50.000	
ANTIMONY	01097	WAIVED	2009/03/16	< 6.000	
ARSENIC	01002	WAIVED	2009/03/16	4.100	
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED	2009/03/16	< 100.000	
BERYLLIUM	01012	WAIVED	2009/03/16	< 1.000	
CADMIUM	01027	WAIVED	2009/03/16	< 1.000	
CHROMIUM (TOTAL)	01034	WAIVED	2009/03/16	< 1.000	
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2009/03/16	.330	
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED	2009/03/16	< 1.000	
NICKEL	01067	WAIVED	2009/03/16	< 10.000	
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED	2009/03/16	< 5.000	
THALLIUM	01059	WAIVED	2009/03/16	< 1.000	
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2012/02/03	< 2.000	2013/02
NITRITE (AS N)	00620	036	2012/02/03	< 400.000	2015/02
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801007***

System Name: ***CLOS PEGASE WINERY***

PS Code: ***2801007-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801007***

System Name: ***CLOS PEGASE WINERY***

PS Code: ***2801007-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801007***

System Name: ***CLOS PEGASE WINERY***

PS Code: ***2801007-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2009/03/16	49.000	
CALCIUM	00916	WAIVED	2009/03/16	16.000	
CARBONATE ALKALINITY	00445	WAIVED	2009/03/16	< 1.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2009/03/16	58.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2009/03/16	< 1.000	
IRON	01045	WAIVED	2009/03/16	18000.000	
MAGNESIUM	00927	WAIVED	2009/03/16	4.400	
MANGANESE	01055	WAIVED	2009/03/16	1100.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2009/03/16	5.900	
SILVER	01077	WAIVED	2009/03/16	< 10.000	
SODIUM	00929	WAIVED	2009/03/16	18.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801007***

System Name: ***CLOS PEGASE WINERY***

PS Code: ***2801007-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801008***

System Name: ***ARTESA VINEYARDS & WINERY***

PS Code: ***2801008-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2007/08/28	.000		
INORGANIC						
ALUMINUM	01105	036	2010/11/01	.000	2013/11	
ANTIMONY	01097	036	2010/11/01	.000	2013/11	
ARSENIC	01002	036	2012/04/23	4.700	2015/04	
ASBESTOS	81855	108	2007/08/28	.000	2016/08	
BARIUM	01007	036	2010/11/01	.000	2013/11	
BERYLLIUM	01012	036	2010/11/01	.000	2013/11	
CADMIUM	01027	036	2010/11/01	.000	2013/11	
CHROMIUM (TOTAL)	01034	036	2012/04/23	< .000	2015/04	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2012/03/21	.160	2015/03	
LEAD	01051	WAIVED	2010/11/01	.000		
MERCURY	71900	036	2010/11/01	.000	2013/11	
NICKEL	01067	036	2010/11/01	.000	2013/11	
PERCHLORATE	A-031	036	**2008/10/27**	.000	**2011/10**	**DUE**
SELENIUM	01147	036	2010/11/01	.000	2013/11	
THALLIUM	01059	036	2010/11/01	.000	2013/11	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2012/04/23	< .000	2013/04	
NITRITE (AS N)	00620	036	2012/04/23	< .000	2015/04	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2009/01/20	1.560	2018/01	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801008***

System Name: ***ARTESA VINEYARDS & WINERY***

PS Code: ***2801008-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2010/11/01	< 1.000	
2,4-D	39730	WAIVED	2010/11/01	< 10.000	
ALACHLOR	77825	WAIVED	2007/08/28	< 1.000	
ATRAZINE	39033	036	2010/11/01	< .500	2013/11
BENTAZON	38710	WAIVED	2010/11/01	< 2.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	036	2010/11/01	< 5.000	2013/11
CHLORDANE	39350	WAIVED	2007/08/28	< .100	
DALAPON	38432	036	2010/11/01	< 10.000	2013/11
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2007/08/28	< .010	
DINOSEB	81287	036	2010/11/01	< 2.000	2013/11
DIQUAT	78885	036	2010/11/01	< 4.000	2013/11
ENDOTHALL	38926	036	2010/11/01	< 45.000	2013/11
ENDRIN	39390	WAIVED	2007/08/28	< .100	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2007/08/28	< .020	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2007/08/28	< .010	
HEPTACHLOR EPOXIDE	39420	WAIVED	2007/08/28	< .010	
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED	2007/08/28	< .200	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801008***

System Name: ***ARTESA VINEYARDS & WINERY***

PS Code: ***2801008-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED	2007/08/28	< 10.000	
MOLINATE	82199	WAIVED	2007/08/28	.000	
OXAMYL	38865	036	2010/11/01	< 20.000	2013/11
PENTACHLOROPHENOL	39032	036	2010/11/01	< .200	2013/11
PICLORAM	39720	036	2010/11/01	< 1.000	2013/11
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2007/08/28	< .500	
SIMAZINE	39055	036	2010/11/01	< 1.000	2013/11
THIOBENCARB	A-001	WAIVED	2007/08/28	.000	
TOXAPHENE	39400	WAIVED	2007/08/28	< 1.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	072	2007/08/28	.000	2013/08
1,1,2,2-TETRACHLOROETHANE	34516	072	2007/08/28	.000	2013/08
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2007/08/28	.000	2013/08
1,1,2-TRICHLOROETHANE	34511	072	2007/08/28	.000	2013/08
1,1-DICHLOROETHANE	34496	072	2007/08/28	.000	2013/08
1,1-DICHLOROETHYLENE	34501	072	2007/08/28	.000	2013/08
1,2,4-TRICHLOROBENZENE	34551	072	2007/08/28	.000	2013/08
1,2-DICHLOROBENZENE	34536	072	2007/08/28	.000	2013/08
1,2-DICHLOROETHANE	34531	072	2007/08/28	.000	2013/08
1,2-DICHLOROPROPANE	34541	072	2007/08/28	.000	2013/08
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2007/08/28	.000	2013/08
1,4-DICHLOROBENZENE	34571	072	2007/08/28	.000	2013/08
BENZENE	34030	072	2007/08/28	.000	2013/08
CARBON TETRACHLORIDE	32102	072	2007/08/28	.000	2013/08
CIS-1,2-DICHLOROETHYLENE	77093	072	2007/08/28	.000	2013/08
DICHLOROMETHANE	34423	072	2007/08/28	.000	2013/08
ETHYLBENZENE	34371	072	2007/08/28	.000	2013/08
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2007/08/28	.000	2013/08
MONOCHLOROBENZENE	34301	072	2007/08/28	.000	2013/08

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2801008
System Name: ARTESA VINEYARDS & WINERY

PS Code: 2801008-001
Source Name: LPA REPORTED PRIMARY SOURCE
Source Number: 001
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2007/08/28	.000	2013/08
TETRACHLOROETHYLENE	34475	072	2007/08/28	.000	2013/08
TOLUENE	34010	072	2007/08/28	.000	2013/08
TRANS-1,2-DICHLOROETHYLENE	34546	072	2007/08/28	.000	2013/08
TRICHLOROETHYLENE	39180	072	2007/08/28	.000	2013/08
TRICHLOROFLUOROMETHANE	34488	072	2007/08/28	.000	2013/08
VINYL CHLORIDE	39175	072	2007/08/28	.000	2013/08
XYLENES (TOTAL)	81551	072	2007/08/28	.000	2013/08
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2010/11/01	90.000	
CALCIUM	00916	WAIVED	2010/11/01	12.000	
CARBONATE ALKALINITY	00445	WAIVED	2010/11/01	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2010/11/01	64.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2010/11/01	.000	
IRON	01045	WAIVED	2012/04/23	< .000	
MAGNESIUM	00927	WAIVED	2010/11/01	7.200	
MANGANESE	01055	WAIVED	2012/04/23	< .000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2010/11/01	7.300	
SILVER	01077	WAIVED	2010/11/01	.000	
SODIUM	00929	WAIVED	2010/11/01	10.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801008***

System Name: ***ARTESA VINEYARDS & WINERY***

PS Code: ***2801008-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
TURBIDITY, LABORATORY	82079	WAIVED	2007/08/28	.140		
ZINC	01092	WAIVED				

PS Code: ***2801008-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED	2007/08/28	.000		

INORGANIC

ALUMINUM	01105	036	2012/03/21	< .000	2015/03	
ANTIMONY	01097	036	2012/03/21	< .000	2015/03	
ARSENIC	01002	036	2012/04/23	6.200	2015/04	
ASBESTOS	81855	108	2007/08/28	.000	2016/08	
BARIUM	01007	036	2012/03/21	< .000	2015/03	
BERYLLIUM	01012	036	2012/03/21	< .000	2015/03	
CADMIUM	01027	036	2012/03/21	< .000	2015/03	
CHROMIUM (TOTAL)	01034	036	2012/04/23	< .000	2015/04	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	**2005/05/25**	.240	**2008/05**	**DUE**
LEAD	01051	WAIVED	2012/03/21	< .000		
MERCURY	71900	036	2012/03/21	< .000	2015/03	
NICKEL	01067	036	2012/03/21	< .000	2015/03	
PERCHLORATE	A-031	036	**2008/10/27**	.000	**2011/10**	**DUE**
SELENIUM	01147	036	2012/03/21	< .000	2015/03	
THALLIUM	01059	036	2012/03/21	< .000	2015/03	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801008***

System Name: ***ARTESA VINEYARDS & WINERY***

PS Code: ***2801008-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2012/04/23	< .000	2013/04
NITRITE (AS N)	00620	036	2012/04/23	< .000	2015/04
RADIOLOGICAL					
GROSS ALPHA	01501	108	2009/01/20	.910	2018/01
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2010/11/01	< 1.000	
2,4-D	39730	WAIVED	2010/11/01	< 10.000	
ALACHLOR	77825	WAIVED	2007/08/28	< 1.000	
ATRAZINE	39033	036	2010/11/01	< .500	2013/11
BENTAZON	38710	WAIVED	2010/11/01	< 2.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	036	2010/11/01	< 5.000	2013/11
CHLORDANE	39350	WAIVED	2007/08/28	< .100	
DALAPON	38432	036	2010/11/01	< 10.000	2013/11
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2007/08/28	< .010	
DINOSEB	81287	036	2010/11/01	< 2.000	2013/11
DIQUAT	78885	036	2010/11/01	< 4.000	2013/11

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801008***

System Name: ***ARTESA VINEYARDS & WINERY***

PS Code: ***2801008-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	036	2010/11/01	< 45.000	2013/11
ENDRIN	39390	WAIVED	2007/08/28	< .100	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2007/08/28	< .020	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2007/08/28	< .010	
HEPTACHLOR EPOXIDE	39420	WAIVED	2007/08/28	< .010	
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED	2007/08/28	< .200	
METHOXYCHLOR	39480	WAIVED	2007/08/28	< 10.000	
MOLINATE	82199	WAIVED	2007/08/28	.000	
OXAMYL	38865	036	2010/11/01	< 20.000	2013/11
PENTACHLOROPHENOL	39032	036	2010/11/01	< .200	2013/11
PICLORAM	39720	036	2010/11/01	< 1.000	2013/11
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2007/08/28	< .500	
SIMAZINE	39055	036	2010/11/01	< 1.000	2013/11
THIOBENCARB	A-001	WAIVED	2007/08/28	.000	
TOXAPHENE	39400	WAIVED	2007/08/28	< 1.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	072	2007/08/28	.000	2013/08
1,1,2,2-TETRACHLOROETHANE	34516	072	2007/08/28	.000	2013/08
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2007/08/28	.000	2013/08
1,1,2-TRICHLOROETHANE	34511	072	2007/08/28	.000	2013/08
1,1-DICHLOROETHANE	34496	072	2007/08/28	.000	2013/08
1,1-DICHLOROETHYLENE	34501	072	2007/08/28	.000	2013/08
1,2,4-TRICHLOROBENZENE	34551	072	2007/08/28	.000	2013/08
1,2-DICHLOROBENZENE	34536	072	2007/08/28	.000	2013/08
1,2-DICHLOROETHANE	34531	072	2007/08/28	.000	2013/08
1,2-DICHLOROPROPANE	34541	072	2007/08/28	.000	2013/08

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801008***

System Name: ***ARTESA VINEYARDS & WINERY***

PS Code: ***2801008-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2007/08/28	.000	2013/08
1,4-DICHLOROBENZENE	34571	072	2007/08/28	.000	2013/08
BENZENE	34030	072	2007/08/28	.000	2013/08
CARBON TETRACHLORIDE	32102	072	2007/08/28	.000	2013/08
CIS-1,2-DICHLOROETHYLENE	77093	072	2007/08/28	.000	2013/08
DICHLOROMETHANE	34423	072	2007/08/28	.000	2013/08
ETHYLBENZENE	34371	072	2007/08/28	.000	2013/08
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2007/08/28	.000	2013/08
MONOCHLOROBENZENE	34301	072	2007/08/28	.000	2013/08
STYRENE	77128	072	2007/08/28	.000	2013/08
TETRACHLOROETHYLENE	34475	072	2007/08/28	.000	2013/08
TOLUENE	34010	072	2007/08/28	.000	2013/08
TRANS-1,2-DICHLOROETHYLENE	34546	072	2007/08/28	.000	2013/08
TRICHLOROETHYLENE	39180	072	2007/08/28	.000	2013/08
TRICHLOROFLUOROMETHANE	34488	072	2007/08/28	.000	2013/08
VINYL CHLORIDE	39175	072	2007/08/28	.000	2013/08
XYLENES (TOTAL)	81551	072	2007/08/28	.000	2013/08
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2010/11/01	92.000	
CALCIUM	00916	WAIVED	2010/11/01	14.000	
CARBONATE ALKALINITY	00445	WAIVED	2010/11/01	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2010/11/01	75.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2010/11/01	.000	
IRON	01045	WAIVED	2012/04/23	263.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801008***

System Name: ***ARTESA VINEYARDS & WINERY***

PS Code: ***2801008-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED	2010/11/01	8.300	
MANGANESE	01055	WAIVED	2012/04/23	101.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2010/11/01	7.400	
SILVER	01077	WAIVED	2012/03/21	< .000	
SODIUM	00929	WAIVED	2010/11/01	10.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED	2007/08/28	.200	
ZINC	01092	WAIVED			

PS Code: ***2801008-003***

Source Name: ***WELL 003***

Source Number: ***003***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED	2006/10/11	.000	

INORGANIC

ALUMINUM	01105	108	2006/10/11	.000	2015/10
ANTIMONY	01097	108	2006/10/11	.000	2015/10
ARSENIC	01002	108	2012/04/23	6.400	2021/04
ASBESTOS	81855	108	2007/08/28	.000	2016/08
BARIUM	01007	108	2006/10/11	.000	2015/10
BERYLLIUM	01012	108	2006/10/11	.000	2015/10
CADMIUM	01027	108	2006/10/11	.000	2015/10
CHROMIUM (TOTAL)	01034	108	2012/04/23	< .000	2021/04
CYANIDE	01291	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801008***

System Name: ***ARTESA VINEYARDS & WINERY***

PS Code: ***2801008-003***

Source Name: ***WELL 003***

Source Number: ***003***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	108	2006/10/11	.200	2015/10
LEAD	01051	WAIVED	2006/10/11	< 29.000	
MERCURY	71900	108	2006/10/11	.000	2015/10
NICKEL	01067	108	2006/10/11	.000	2015/10
PERCHLORATE	A-031	108	2008/10/27	.000	2017/10
SELENIUM	01147	108	2006/10/11	.000	2015/10
THALLIUM	01059	108	2006/10/11	.000	2015/10
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	108	2012/04/23	< .000	2021/04
NITRITE (AS N)	00620	108	2012/04/23	< .000	2021/04
RADIOLOGICAL					
GROSS ALPHA	01501	108	2009/01/20	1.360	2018/01
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2006/10/11	< 1.000	
2,4-D	39730	WAIVED	2006/10/11	< 10.000	
ALACHLOR	77825	WAIVED	2006/10/11	< 1.000	
ATRAZINE	39033	WAIVED	2006/10/11	.000	
BENTAZON	38710	WAIVED	2006/10/11	< 2.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801008***

System Name: ***ARTESA VINEYARDS & WINERY***

PS Code: ***2801008-003***

Source Name: ***WELL 003***

Source Number: ***003***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED	2006/10/11	< 5.000	
CHLORDANE	39350	WAIVED	2006/10/11	< .100	
DALAPON	38432	WAIVED	2006/10/11	< 10.000	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2006/10/11	< .010	
DINOSEB	81287	WAIVED	2006/10/11	< 2.000	
DIQUAT	78885	WAIVED	2006/10/11	< 4.000	
ENDOTHALL	38926	WAIVED	2006/10/11	< 45.000	
ENDRIN	39390	WAIVED	2006/10/11	< .100	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2006/10/11	< .020	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2006/10/11	< .010	
HEPTACHLOR EPOXIDE	39420	WAIVED	2006/10/11	< .010	
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED	2006/10/11	< .200	
METHOXYCHLOR	39480	WAIVED	2006/10/11	< 10.000	
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED	2006/10/11	< 20.000	
PENTACHLOROPHENOL	39032	WAIVED	2006/10/11	< .200	
PICLORAM	39720	WAIVED	2006/10/11	< 1.000	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2006/10/11	< .500	
SIMAZINE	39055	WAIVED	2006/10/11	.000	
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED	2006/10/11	< 1.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED	2006/10/11	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801008***

System Name: ***ARTESA VINEYARDS & WINERY***

PS Code: ***2801008-003***

Source Name: ***WELL 003***

Source Number: ***003***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED	2006/10/11	.000	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED	2006/10/11	.000	
1,1,2-TRICHLOROETHANE	34511	WAIVED	2006/10/11	.000	
1,1-DICHLOROETHANE	34496	WAIVED	2006/10/11	.000	
1,1-DICHLOROETHYLENE	34501	WAIVED	2006/10/11	.000	
1,2,4-TRICHLOROBENZENE	34551	WAIVED	2006/10/11	.000	
1,2-DICHLOROBENZENE	34536	WAIVED	2006/10/11	.000	
1,2-DICHLOROETHANE	34531	WAIVED	2006/10/11	.000	
1,2-DICHLOROPROPANE	34541	WAIVED	2006/10/11	.000	
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED	2006/10/11	.000	
1,4-DICHLOROBENZENE	34571	WAIVED	2006/10/11	.000	
BENZENE	34030	WAIVED	2006/10/11	.000	
CARBON TETRACHLORIDE	32102	WAIVED	2006/10/11	.000	
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED	2006/10/11	.000	
DICHLOROMETHANE	34423	WAIVED	2006/10/11	.000	
ETHYLBENZENE	34371	WAIVED	2006/10/11	.000	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	108	2006/10/11	.000	2015/10
MONOCHLOROBENZENE	34301	WAIVED	2006/10/11	.000	
STYRENE	77128	WAIVED	2006/10/11	.000	
TETRACHLOROETHYLENE	34475	WAIVED	2006/10/11	.000	
TOLUENE	34010	WAIVED	2006/10/11	.000	
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED	2006/10/11	.000	
TRICHLOROETHYLENE	39180	WAIVED	2006/10/11	.000	
TRICHLOROFLUOROMETHANE	34488	WAIVED	2006/10/11	.000	
VINYL CHLORIDE	39175	WAIVED	2006/10/11	.000	
XYLENES (TOTAL)	81551	WAIVED	2006/10/11	.000	
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	108	2006/10/11	130.000	2015/10

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801008***

System Name: ***ARTESA VINEYARDS & WINERY***

PS Code: ***2801008-003***

Source Name: ***WELL 003***

Source Number: ***003***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
CALCIUM	00916	108	2006/10/11	18.000	2015/10	
CARBONATE ALKALINITY	00445	108	2006/10/11	.000	2015/10	
CHLORIDE	00940	108	2012/03/21	6.000	2021/03	
COLOR	00081	108	2012/03/21	4.000	2021/03	
COPPER	01042	108	2012/03/21	< .000	2021/03	
FOAMING AGENTS (MBAS)	38260	000				**DUE**
HARDNESS (TOTAL) AS CACO3	00900	108	2006/10/11	92.000	2015/10	
HYDROXIDE ALKALINITY	71830	108	2006/10/11	.000	2015/10	
IRON	01045	108	2012/04/23	242.000	2021/04	
MAGNESIUM	00927	108	2006/10/11	10.000	2015/10	
MANGANESE	01055	108	2012/04/23	205.000	2021/04	
ODOR THRESHOLD @ 60 C	00086	108	2012/03/21	8.000	2021/03	
PH, LABORATORY	00403	108	2007/08/28	7.200	2016/08	
SILVER	01077	108	2006/10/11	.000	2015/10	
SODIUM	00929	108	2006/10/11	15.000	2015/10	
SPECIFIC CONDUCTANCE	00095	108	2012/03/21	210.000	2021/03	
SULFATE	00945	108	2012/03/21	8.400	2021/03	
TOTAL DISSOLVED SOLIDS	70300	108	2012/03/21	200.000	2021/03	
TURBIDITY, LABORATORY	82079	108	2007/08/28	1.700	2016/08	
ZINC	01092	108	2012/03/21	< .000	2021/03	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801009***

System Name: ***CONN CREEK WINERY***

PS Code: ***2801009-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/08/03	5.200	2012/08	
NITRITE (AS N)	00620	036	2011/08/03	< 400.000	2014/08	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801009***

System Name: ***CONN CREEK WINERY***

PS Code: ***2801009-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801009***

System Name: ***CONN CREEK WINERY***

PS Code: ***2801009-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801009***

System Name: ***CONN CREEK WINERY***

PS Code: ***2801009-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801009***

System Name: ***CONN CREEK WINERY***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)

PS Code: ***2801009-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801009-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED			

INORGANIC

ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801009***

System Name: ***CONN CREEK WINERY***

PS Code: ***2801009-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED	2005/07/13	5.300	
NITRITE (AS N)	00620	WAIVED	2005/07/13	< 400.000	
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801009***

System Name: ***CONN CREEK WINERY***

PS Code: ***2801009-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801009***

System Name: ***CONN CREEK WINERY***

PS Code: ***2801009-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801009***

System Name: ***CONN CREEK WINERY***

PS Code: ***2801009-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801010***

System Name: ***COSENTINO WINERY***

PS Code: ***2801010-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED	2003/03/17	.000		
ANTIMONY	01097	WAIVED	2003/03/17	.000		
ARSENIC	01002	WAIVED	2003/03/17	2.000		
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED	2003/03/17	.000		
BERYLLIUM	01012	WAIVED	2003/03/17	.000		
CADMIUM	01027	WAIVED	2003/03/17	.000		
CHROMIUM (TOTAL)	01034	WAIVED	2003/03/17	.000		
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2003/03/17	.400		
LEAD	01051	WAIVED	2003/03/17	.000		
MERCURY	71900	WAIVED	2003/03/17	.000		
NICKEL	01067	WAIVED	2003/03/17	.000		
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED	2003/03/17	.000		
THALLIUM	01059	WAIVED	2003/03/17	.000		
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2010/05/20	.000	2011/05	DUE
NITRITE (AS N)	00620	036	2009/05/15	.000	2012/05	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801010***

System Name: ***COSENTINO WINERY***

PS Code: ***2801010-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801010***

System Name: ***COSENTINO WINERY***

PS Code: ***2801010-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801010***

System Name: ***COSENTINO WINERY***

PS Code: ***2801010-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	WAIVED	2003/03/17	.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED	2003/03/17	.000	
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801010***

System Name: ***COSENTINO WINERY***

PS Code: ***2801010-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801010-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801010***

System Name: ***COSENTINO WINERY***

PS Code: ***2801010-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801010***

System Name: ***COSENTINO WINERY***

PS Code: ***2801010-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801010***

System Name: ***COSENTINO WINERY***

PS Code: ***2801010-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801010***

System Name: ***COSENTINO WINERY***

PS Code: ***2801010-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801011***

System Name: ***DOMAINE CARNEROS***

PS Code: ***2801011-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2002/06/17	.000		
INORGANIC						
ALUMINUM	01105	036	2002/06/17	.000	2005/06	DUE
ANTIMONY	01097	036	2002/06/17	.000	2005/06	DUE
ARSENIC	01002	036	2002/06/17	28.000	2005/06	DUE
ASBESTOS	81855	108	2002/06/17	.000	2011/06	DUE
BARIUM	01007	036	2002/06/17	.000	2005/06	DUE
BERYLLIUM	01012	036	2002/06/17	.000	2005/06	DUE
CADMIUM	01027	036	2002/06/17	.000	2005/06	DUE
CHROMIUM (TOTAL)	01034	036	2002/06/17	7.000	2005/06	DUE
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2002/06/17	.600	2005/06	DUE
LEAD	01051	WAIVED	2002/06/17	55.000		
MERCURY	71900	036	2002/06/17	.000	2005/06	DUE
NICKEL	01067	036	2002/06/17	160.000	2005/06	DUE
PERCHLORATE	A-031	006				DUE
SELENIUM	01147	036	2002/06/17	.000	2005/06	DUE
THALLIUM	01059	036	2002/06/17	.000	2005/06	DUE
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2002/06/17	31.000	2003/06	DUE
NITRITE (AS N)	00620	036	2002/06/17	.000	2005/06	DUE
RADIOLOGICAL						
GROSS ALPHA	01501	108	2008/03/17	1.570	2017/03	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801011***

System Name: ***DOMAINE CARNEROS***

PS Code: ***2801011-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2002/06/17	.000		
2,4-D	39730	WAIVED	2002/06/17	.000		
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	036	**2002/06/17**	.000	**2005/06**	**DUE**
BENTAZON	38710	WAIVED	2002/06/17	.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	**2002/06/17**	.000	**2005/06**	**DUE**
CHLORDANE	39350	WAIVED	2002/06/17	.000		
DALAPON	38432	036	**2002/06/17**	.000	**2005/06**	**DUE**
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2002/06/17	.000		
DINOSEB	81287	036	**2002/06/17**	.000	**2005/06**	**DUE**
DIQUAT	78885	036	**2002/06/17**	.000	**2005/06**	**DUE**
ENDOTHALL	38926	036	**2002/06/17**	.000	**2005/06**	**DUE**
ENDRIN	39390	WAIVED	2002/06/17	.000		
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2002/06/17	.000		
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	WAIVED	2002/06/17	.000		
HEPTACHLOR EPOXIDE	39420	WAIVED	2002/06/17	.000		
HEXACHLOROBENZENE	39700	WAIVED	2002/06/17	.000		
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2002/06/17	.000		
LINDANE	39340	WAIVED	2002/06/17	.000		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801011***

System Name: ***DOMAINE CARNEROS***

PS Code: ***2801011-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	WAIVED	2002/06/17	.000		
MOLINATE	82199	WAIVED	2002/06/17	.000		
OXAMYL	38865	036	2002/06/17	.000	2005/06	DUE
PENTACHLOROPHENOL	39032	036	2002/06/17	.000	2005/06	DUE
PICLORAM	39720	036	2002/06/17	.000	2005/06	DUE
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2002/06/17	.000		
SIMAZINE	39055	036	2002/06/17	.000	2005/06	DUE
THIOBENCARB	A-001	WAIVED	2002/06/17	.000		
TOXAPHENE	39400	WAIVED	2002/06/17	.000		
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2002/06/17	.000	2008/06	DUE
1,1,2,2-TETRACHLOROETHANE	34516	072	2002/06/17	.000	2008/06	DUE
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2002/06/17	.000	2008/06	DUE
1,1,2-TRICHLOROETHANE	34511	072	2002/06/17	.000	2008/06	DUE
1,1-DICHLOROETHANE	34496	072	2002/06/17	.000	2008/06	DUE
1,1-DICHLOROETHYLENE	34501	072	2002/06/17	.000	2008/06	DUE
1,2,4-TRICHLOROBENZENE	34551	072	2002/06/17	.000	2008/06	DUE
1,2-DICHLOROBENZENE	34536	072	2002/06/17	.000	2008/06	DUE
1,2-DICHLOROETHANE	34531	072	2002/06/17	.000	2008/06	DUE
1,2-DICHLOROPROPANE	34541	072	2002/06/17	.000	2008/06	DUE
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2002/06/17	.000	2008/06	DUE
1,4-DICHLOROBENZENE	34571	072	2002/06/17	.000	2008/06	DUE
BENZENE	34030	072	2002/06/17	.000	2008/06	DUE
CARBON TETRACHLORIDE	32102	072	2002/06/17	.000	2008/06	DUE
CIS-1,2-DICHLOROETHYLENE	77093	072	2002/06/17	.000	2008/06	DUE
DICHLOROMETHANE	34423	072	2002/06/17	.000	2008/06	DUE
ETHYLBENZENE	34371	072	2002/06/17	.000	2008/06	DUE
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2002/06/17	.000	2008/06	DUE
MONOCHLOROBENZENE	34301	072	2002/06/17	.000	2008/06	DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801011***

System Name: ***DOMAINE CARNEROS***

PS Code: ***2801011-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED VOC						
STYRENE	77128	072	2002/06/17	.000	2008/06	DUE
TETRACHLOROETHYLENE	34475	072	2002/06/17	.000	2008/06	DUE
TOLUENE	34010	072	2002/06/17	.000	2008/06	DUE
TRANS-1,2-DICHLOROETHYLENE	34546	072	2002/06/17	.000	2008/06	DUE
TRICHLOROETHYLENE	39180	072	2002/06/17	.000	2008/06	DUE
TRICHLOROFLUOROMETHANE	34488	072	2002/06/17	.000	2008/06	DUE
VINYL CHLORIDE	39175	072	2002/06/17	.000	2008/06	DUE
XYLENES (TOTAL)	81551	072	2002/06/17	.000	2008/06	DUE
SECONDARY/GP						
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED				
BICARBONATE ALKALINITY	00440	WAIVED	2002/06/17	510.000		
CALCIUM	00916	000				DUE
CARBONATE ALKALINITY	00445	WAIVED	2002/06/17	.000		
CHLORIDE	00940	WAIVED				
COLOR	00081	WAIVED				
COPPER	01042	WAIVED				
FOAMING AGENTS (MBAS)	38260	WAIVED				
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2002/06/17	40.000		
HYDROXIDE ALKALINITY	71830	WAIVED	2002/06/17	.000		
IRON	01045	WAIVED	2002/06/17	600.000		
MAGNESIUM	00927	WAIVED	2002/06/17	2.800		
MANGANESE	01055	WAIVED	2002/06/17	180.000		
ODOR THRESHOLD @ 60 C	00086	WAIVED				
PH, LABORATORY	00403	WAIVED	2002/06/17	7.500		
SILVER	01077	WAIVED	2002/06/17	.000		
SODIUM	00929	WAIVED	2002/06/17	190.000		
SPECIFIC CONDUCTANCE	00095	WAIVED				
SULFATE	00945	WAIVED				
TOTAL DISSOLVED SOLIDS	70300	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801011***

System Name: ***DOMAINE CARNEROS***

PS Code: ***2801011-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
SECONDARY/GP						
TURBIDITY, LABORATORY	82079	WAIVED				
ZINC	01092	WAIVED				

PS Code: ***2801011-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2007/06/13	.000		
INORGANIC						
ALUMINUM	01105	036	2010/06/22	.000	2013/06	
ANTIMONY	01097	036	2010/06/22	.000	2013/06	
ARSENIC	01002	036	2012/03/12	9.200	2015/03	
ASBESTOS	81855	108	2010/06/22	.000	2019/06	
BARIUM	01007	036	2010/06/22	.000	2013/06	
BERYLLIUM	01012	036	2010/06/22	.000	2013/06	
CADMIUM	01027	036	2010/06/22	.000	2013/06	
CHROMIUM (TOTAL)	01034	036	2010/06/22	.000	2013/06	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2010/06/22	.260	2013/06	
LEAD	01051	WAIVED	2010/06/22	.000		
MERCURY	71900	036	2010/06/22	.000	2013/06	
NICKEL	01067	036	2010/06/22	.000	2013/06	
PERCHLORATE	A-031	036	**2009/03/20**	< .000	**2012/03**	**DUE**
SELENIUM	01147	036	2010/06/22	.000	2013/06	
THALLIUM	01059	036	2010/06/22	.000	2013/06	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801011***

System Name: ***DOMAINE CARNEROS***

PS Code: ***2801011-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2012/02/06	< .000	2013/02
NITRITE (AS N)	00620	036	2012/02/06	< .000	2015/02
RADIOLOGICAL					
GROSS ALPHA	01501	108	2009/06/10	1.460	2018/06
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2010/06/22	< .000	
2,4-D	39730	WAIVED	2010/06/22	< .000	
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	036	2010/06/22	< .000	2013/06
BENTAZON	38710	WAIVED	2010/06/22	< .000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	036	2010/06/22	< .000	2013/06
CHLORDANE	39350	WAIVED	2002/06/17	.000	
DALAPON	38432	036	2010/06/22	< .000	2013/06
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2007/06/13	.000	
DINOSEB	81287	036	2010/06/22	< .000	2013/06
DIQUAT	78885	036	2010/06/22	< .000	2013/06

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801011***

System Name: ***DOMAINE CARNEROS***

PS Code: ***2801011-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	036	2010/06/22	< .000	2013/06
ENDRIN	39390	WAIVED	2002/06/17	.000	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2007/06/13	.000	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2002/06/17	.000	
HEPTACHLOR EPOXIDE	39420	WAIVED	2002/06/17	.000	
HEXACHLOROBENZENE	39700	WAIVED	2002/06/17	.000	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2002/06/17	.000	
LINDANE	39340	WAIVED	2002/06/17	.000	
METHOXYCHLOR	39480	WAIVED	2002/06/17	.000	
MOLINATE	82199	WAIVED	2007/06/13	.000	
OXAMYL	38865	036	2010/06/22	< .000	2013/06
PENTACHLOROPHENOL	39032	036	2010/06/22	< .000	2013/06
PICLORAM	39720	036	2010/06/22	< .000	2013/06
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2002/06/17	.000	
SIMAZINE	39055	036	2010/06/22	< .000	2013/06
THIOBENCARB	A-001	WAIVED	2007/06/13	.000	
TOXAPHENE	39400	WAIVED	2002/06/17	.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	072	2010/06/22	.000	2016/06
1,1,2,2-TETRACHLOROETHANE	34516	072	2010/06/22	.000	2016/06
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2010/06/22	.000	2016/06
1,1,2-TRICHLOROETHANE	34511	072	2010/06/22	.000	2016/06
1,1-DICHLOROETHANE	34496	072	2010/06/22	.000	2016/06
1,1-DICHLOROETHYLENE	34501	072	2010/06/22	.000	2016/06
1,2,4-TRICHLOROBENZENE	34551	072	2010/06/22	.000	2016/06
1,2-DICHLOROBENZENE	34536	072	2010/06/22	.000	2016/06
1,2-DICHLOROETHANE	34531	072	2010/06/22	.000	2016/06
1,2-DICHLOROPROPANE	34541	072	2010/06/22	.000	2016/06

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801011***

System Name: ***DOMAINE CARNEROS***

PS Code: ***2801011-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2010/06/22	.000	2016/06
1,4-DICHLOROBENZENE	34571	072	2010/06/22	.000	2016/06
BENZENE	34030	072	2010/06/22	.000	2016/06
CARBON TETRACHLORIDE	32102	072	2010/06/22	.000	2016/06
CIS-1,2-DICHLOROETHYLENE	77093	072	2010/06/22	.000	2016/06
DICHLOROMETHANE	34423	072	2010/06/22	.000	2016/06
ETHYLBENZENE	34371	072	2010/06/22	.000	2016/06
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2010/06/22	.000	2016/06
MONOCHLOROBENZENE	34301	072	2010/06/22	.000	2016/06
STYRENE	77128	072	2010/06/22	.000	2016/06
TETRACHLOROETHYLENE	34475	072	2010/06/22	.000	2016/06
TOLUENE	34010	072	2010/06/22	.000	2016/06
TRANS-1,2-DICHLOROETHYLENE	34546	072	2010/06/22	.000	2016/06
TRICHLOROETHYLENE	39180	072	2010/06/22	.000	2016/06
TRICHLOROFLUOROMETHANE	34488	072	2010/06/22	.000	2016/06
VINYL CHLORIDE	39175	072	2010/06/22	.000	2016/06
XYLENES (TOTAL)	81551	072	2010/06/22	.000	2016/06
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2010/06/22	392.000	
CALCIUM	00916	WAIVED	2010/06/22	5.500	
CARBONATE ALKALINITY	00445	WAIVED	2010/06/22	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2010/06/22	22.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2010/06/22	.000	
IRON	01045	WAIVED	2010/06/22	390.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801011***

System Name: ***DOMAINE CARNEROS***

PS Code: ***2801011-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
MAGNESIUM	00927	WAIVED	2010/06/22	1.700	
MANGANESE	01055	WAIVED	2010/06/22	190.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2010/06/22	7.600	
SILVER	01077	WAIVED	2010/06/22	.000	
SODIUM	00929	WAIVED	2010/06/22	138.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801011-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801011***

System Name: ***DOMAINE CARNEROS***

PS Code: ***2801011-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED	2010/12/15	1.300	
GROSS BETA	03501	WAIVED	2010/12/15	3.200	
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801011***

System Name: ***DOMAINE CARNEROS***

PS Code: ***2801011-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801011***

System Name: ***DOMAINE CARNEROS***

PS Code: ***2801011-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801011***

System Name: ***DOMAINE CARNEROS***

PS Code: ***2801011-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801012***

System Name: ***ALPHA AND OMEGA WINERY***

PS Code: ***2801012-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	036	2012/04/20	< 50.000	2015/04	
ANTIMONY	01097	036	2012/04/20	< 6.000	2015/04	
ARSENIC	01002	036	2012/04/20	< 2.000	2015/04	
ASBESTOS	81855	108	2009/02/15	.000	2018/02	
BARIUM	01007	036	2012/04/20	290.000	2015/04	
BERYLLIUM	01012	036	2012/04/20	< 1.000	2015/04	
CADMIUM	01027	036	2012/04/20	< 1.000	2015/04	
CHROMIUM (TOTAL)	01034	036	2012/04/20	< 1.000	2015/04	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2012/04/20	.260	2015/04	
LEAD	01051	WAIVED	2005/10/04	.000		
MERCURY	71900	036	2012/04/20	< 1.000	2015/04	
NICKEL	01067	036	2012/04/20	22.000	2015/04	
PERCHLORATE	A-031	006				**DUE**
SELENIUM	01147	036	2012/04/20	< 5.000	2015/04	
THALLIUM	01059	036	2012/04/20	< 1.000	2015/04	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2012/04/20	< 2.000	2013/04	
NITRITE (AS N)	00620	036	2012/04/20	< 400.000	2015/04	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2012/01/04	1.480	2021/01	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801012***

System Name: ***ALPHA AND OMEGA WINERY***

PS Code: ***2801012-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2009/02/15	.000		
2,4-D	39730	WAIVED	2009/02/15	.000		
ALACHLOR	77825	WAIVED	2009/02/15	.000		
ATRAZINE	39033	036	**2009/02/15**	.000	**2012/02**	**DUE**
BENTAZON	38710	WAIVED	2009/02/15	.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	**2009/02/15**	.000	**2012/02**	**DUE**
CHLORDANE	39350	WAIVED	2009/02/15	.000		
DALAPON	38432	036	**2009/02/15**	.000	**2012/02**	**DUE**
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	036	**2009/02/15**	.000	**2012/02**	**DUE**
DIQUAT	78885	036	**2009/02/15**	.000	**2012/02**	**DUE**
ENDOTHALL	38926	036	**2009/02/15**	.000	**2012/02**	**DUE**
ENDRIN	39390	WAIVED	2009/02/15	.000		
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2009/02/15	.000		
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	WAIVED	2009/02/15	.000		
HEPTACHLOR EPOXIDE	39420	WAIVED	2009/02/15	.000		
HEXACHLOROBENZENE	39700	WAIVED	2009/02/15	.000		
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2009/02/15	.000		
LINDANE	39340	WAIVED	2009/02/15	.000		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801012***

System Name: ***ALPHA AND OMEGA WINERY***

PS Code: ***2801012-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	WAIVED	2009/02/15	.000		
MOLINATE	82199	WAIVED				
OXAMYL	38865	036	2009/02/15	.000	2012/02	DUE
PENTACHLOROPHENOL	39032	036	2009/02/15	.000	2012/02	DUE
PICLORAM	39720	036	2009/02/15	.000	2012/02	DUE
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2009/02/15	.000	2012/02	DUE
THIOBENCARB	A-001	WAIVED				
TOXAPHENE	39400	WAIVED	2009/02/15	.000		
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2009/02/15	.000	2015/02	
1,1,2,2-TETRACHLOROETHANE	34516	072	2009/02/15	.000	2015/02	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2009/02/15	.000	2015/02	
1,1,2-TRICHLOROETHANE	34511	072	2009/02/15	.000	2015/02	
1,1-DICHLOROETHANE	34496	072	2009/02/15	.000	2015/02	
1,1-DICHLOROETHYLENE	34501	072	2009/02/15	.000	2015/02	
1,2,4-TRICHLOROBENZENE	34551	072	2009/02/15	.000	2015/02	
1,2-DICHLOROBENZENE	34536	072	2009/02/15	.000	2015/02	
1,2-DICHLOROETHANE	34531	072	2009/02/15	.000	2015/02	
1,2-DICHLOROPROPANE	34541	072	2009/02/15	.000	2015/02	
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2009/02/15	.000	2015/02	
1,4-DICHLOROBENZENE	34571	072	2009/02/15	.000	2015/02	
BENZENE	34030	072	2009/02/15	.000	2015/02	
CARBON TETRACHLORIDE	32102	072	2009/02/15	.000	2015/02	
CIS-1,2-DICHLOROETHYLENE	77093	072	2009/02/15	.000	2015/02	
DICHLOROMETHANE	34423	072	2009/02/15	.000	2015/02	
ETHYLBENZENE	34371	072	2009/02/15	.000	2015/02	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2009/02/15	.000	2015/02	
MONOCHLOROBENZENE	34301	072	2009/02/15	.000	2015/02	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801012***

System Name: ***ALPHA AND OMEGA WINERY***

PS Code: ***2801012-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2009/02/15	.000	2015/02
TETRACHLOROETHYLENE	34475	072	2009/02/15	.000	2015/02
TOLUENE	34010	072	2009/02/15	.000	2015/02
TRANS-1,2-DICHLOROETHYLENE	34546	072	2009/02/15	.000	2015/02
TRICHLOROETHYLENE	39180	072	2009/02/15	.000	2015/02
TRICHLOROFLUOROMETHANE	34488	072	2009/02/15	.000	2015/02
VINYL CHLORIDE	39175	072	2009/02/15	.000	2015/02
XYLENES (TOTAL)	81551	072	2009/02/15	.000	2015/02
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2012/04/20	360.000	
CALCIUM	00916	WAIVED	2012/04/20	28.000	
CARBONATE ALKALINITY	00445	WAIVED	2012/04/20	< 1.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2012/04/20	300.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2012/04/20	< 1.000	
IRON	01045	WAIVED	2012/04/20	< 100.000	
MAGNESIUM	00927	WAIVED	2012/04/20	55.000	
MANGANESE	01055	WAIVED	2012/04/20	840.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2012/04/20	7.200	
SILVER	01077	WAIVED	2012/04/20	< 10.000	
SODIUM	00929	WAIVED	2012/04/20	39.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801012***

System Name: ***ALPHA AND OMEGA WINERY***

PS Code: ***2801012-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2801014
System Name: RUDD WINES, INC., DBA RUDD

PS Code: 2801014-001
Source Name: LPA REPORTED PRIMARY SOURCE
Source Number: 001
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED	2002/06/17	.000		
ANTIMONY	01097	WAIVED	2002/06/17	.000		
ARSENIC	01002	WAIVED	2012/02/16	< 2.000		
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED	2002/06/17	.000		
BERYLLIUM	01012	WAIVED	2002/06/17	.000		
CADMIUM	01027	WAIVED	2002/06/17	.000		
CHROMIUM (TOTAL)	01034	WAIVED	2002/06/17	.000		
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				DUE
LEAD	01051	WAIVED	2002/06/17	.000		
MERCURY	71900	WAIVED	2002/06/17	.000		
NICKEL	01067	WAIVED	2002/06/17	.000		
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED	2002/06/17	.000		
THALLIUM	01059	WAIVED	2002/06/17	.000		
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2012/02/16	< 2.000	2013/02	
NITRITE (AS N)	00620	036	2011/08/23	< .000	2014/08	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801014***

System Name: ***RUDD WINES, INC., DBA RUDD***

PS Code: ***2801014-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801014***

System Name: ***RUDD WINES, INC., DBA RUDD***

PS Code: ***2801014-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801014***

System Name: ***RUDD WINES, INC., DBA RUDD***

PS Code: ***2801014-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED	2002/06/17	.000	
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801014***

System Name: ***RUDD WINES, INC., DBA RUDD***

PS Code: ***2801014-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801014-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801014***

System Name: ***RUDD WINES, INC., DBA RUDD***

PS Code: ***2801014-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801014***

System Name: ***RUDD WINES, INC., DBA RUDD***

PS Code: ***2801014-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801014***

System Name: ***RUDD WINES, INC., DBA RUDD***

PS Code: ***2801014-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801014***

System Name: ***RUDD WINES, INC., DBA RUDD***

PS Code: ***2801014-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801015***

System Name: ***FRANK FAMILY VINEYARDS***

PS Code: ***2801015-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE K-1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED	2011/07/27	< 50.000	
ANTIMONY	01097	WAIVED	2011/07/27	< 6.000	
ARSENIC	01002	WAIVED	2011/07/27	37.000	
ASBESTOS	81855	WAIVED	2008/04/09	.000	
BARIUM	01007	WAIVED	2011/07/27	< 100.000	
BERYLLIUM	01012	WAIVED	2011/07/27	< 1.000	
CADMIUM	01027	WAIVED	2011/07/27	< 1.000	
CHROMIUM (TOTAL)	01034	WAIVED	2011/07/27	< 1.000	
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2011/07/27	.330	
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED	2011/07/27	< 1.000	
NICKEL	01067	WAIVED	2011/07/27	< 10.000	
PERCHLORATE	A-031	WAIVED	2011/02/02	< 4.000	
SELENIUM	01147	WAIVED	2011/07/27	< 5.000	
THALLIUM	01059	WAIVED	2011/07/27	< 1.000	
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2011/07/27	< 2.000	2012/07
NITRITE (AS N)	00620	036	2010/06/16	< 400.000	2013/06
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED	2012/01/11	.000	
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801015***

System Name: ***FRANK FAMILY VINEYARDS***

PS Code: ***2801015-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE K-1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2011/07/27	.000	
2,4-D	39730	WAIVED	2011/07/27	.000	
ALACHLOR	77825	WAIVED	2008/04/09	.000	
ATRAZINE	39033	WAIVED	2011/07/27	.000	
BENTAZON	38710	WAIVED	2011/07/27	.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED	2011/07/27	.000	
CHLORDANE	39350	WAIVED	2008/04/09	.000	
DALAPON	38432	WAIVED	2011/07/27	.000	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED	2011/07/27	.000	
DIQUAT	78885	WAIVED	2011/07/27	.000	
ENDOTHALL	38926	WAIVED	2011/07/27	.000	
ENDRIN	39390	WAIVED	2008/04/09	.000	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2008/04/09	.000	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2008/04/09	.000	
HEPTACHLOR EPOXIDE	39420	WAIVED	2008/04/09	.000	
HEXACHLOROBENZENE	39700	WAIVED	2008/04/09	.000	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2008/04/09	.000	
LINDANE	39340	WAIVED	2008/04/09	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801015***

System Name: ***FRANK FAMILY VINEYARDS***

PS Code: ***2801015-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE K-1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED	2008/04/09	.000	
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED	2011/07/27	.000	
PENTACHLOROPHENOL	39032	WAIVED	2011/07/27	.000	
PICLORAM	39720	WAIVED	2011/07/27	.000	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED	2011/07/27	.000	
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED	2008/04/09	.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED	2008/04/09	.000	
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED	2008/04/09	.000	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED	2008/04/09	.000	
1,1,2-TRICHLOROETHANE	34511	WAIVED	2008/04/09	.000	
1,1-DICHLOROETHANE	34496	WAIVED	2008/04/09	.000	
1,1-DICHLOROETHYLENE	34501	WAIVED	2008/04/09	.000	
1,2,4-TRICHLOROBENZENE	34551	WAIVED	2008/04/09	.000	
1,2-DICHLOROBENZENE	34536	WAIVED	2008/04/09	.000	
1,2-DICHLOROETHANE	34531	WAIVED	2008/04/09	.000	
1,2-DICHLOROPROPANE	34541	WAIVED	2008/04/09	.000	
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED	2008/04/09	.000	
1,4-DICHLOROBENZENE	34571	WAIVED	2008/04/09	.000	
BENZENE	34030	WAIVED	2008/04/09	.000	
CARBON TETRACHLORIDE	32102	WAIVED	2008/04/09	.000	
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED	2008/04/09	.000	
DICHLOROMETHANE	34423	WAIVED	2008/04/09	.000	
ETHYLBENZENE	34371	WAIVED	2008/04/09	.000	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED	2008/04/09	.000	
MONOCHLOROBENZENE	34301	WAIVED	2008/04/09	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2801015
System Name: FRANK FAMILY VINEYARDS

PS Code: 2801015-001
Source Name: LPA REPORTED PRIMARY SOURCE K-1
Source Number: 001
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED	2008/04/09	.000	
TETRACHLOROETHYLENE	34475	WAIVED	2008/04/09	.000	
TOLUENE	34010	WAIVED	2008/04/09	5.900	
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED	2008/04/09	.000	
TRICHLOROETHYLENE	39180	WAIVED	2008/04/09	.000	
TRICHLOROFLUOROMETHANE	34488	WAIVED	2008/04/09	.000	
VINYL CHLORIDE	39175	WAIVED	2008/04/09	.000	
XYLENES (TOTAL)	81551	WAIVED	2008/04/09	.000	
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2011/07/27	190.000	
CALCIUM	00916	WAIVED	2011/07/27	14.000	
CARBONATE ALKALINITY	00445	WAIVED	2011/07/27	< 1.000	
CHLORIDE	00940	WAIVED	2008/04/09	6.300	
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED	2008/04/09	< .050	
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2011/07/27	76.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2011/07/27	< 1.000	
IRON	01045	WAIVED	2011/07/27	1700.000	
MAGNESIUM	00927	WAIVED	2011/07/27	10.000	
MANGANESE	01055	WAIVED	2011/07/27	1000.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2011/07/27	7.300	
SILVER	01077	WAIVED	2011/07/27	< 10.000	
SODIUM	00929	WAIVED	2011/07/27	34.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED	2008/04/09	11.000	
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801015***

System Name: ***FRANK FAMILY VINEYARDS***

PS Code: ***2801015-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE K-1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801015-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801015***

System Name: ***FRANK FAMILY VINEYARDS***

PS Code: ***2801015-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED	2011/02/02	.247	
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801015***

System Name: ***FRANK FAMILY VINEYARDS***

PS Code: ***2801015-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801015***

System Name: ***FRANK FAMILY VINEYARDS***

PS Code: ***2801015-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801015***

System Name: ***FRANK FAMILY VINEYARDS***

PS Code: ***2801015-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801016***

System Name: ***HESS WINERY***

PS Code: ***2801016-001***

Source Name: ***PATRICK SPRING***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED	2006/05/17	.000	
INORGANIC					
ALUMINUM	01105	036	2009/05/15	670.000	2012/05
ANTIMONY	01097	036	2009/05/15	.000	2012/05
ARSENIC	01002	036	2009/05/15	.000	2012/05
ASBESTOS	81855	108	2011/02/09	.000	2020/02
BARIUM	01007	036	2009/05/15	.000	2012/05
BERYLLIUM	01012	036	2009/05/15	.000	2012/05
CADMIUM	01027	036	2009/05/15	.000	2012/05
CHROMIUM (TOTAL)	01034	036	2009/05/15	.000	2012/05
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2009/05/15	.000	2012/05
LEAD	01051	WAIVED	2009/05/15	.000	
MERCURY	71900	036	2009/05/15	.000	2012/05
NICKEL	01067	036	2009/05/15	.000	2012/05
PERCHLORATE	A-031	036	2012/02/09	< .000	2015/02
SELENIUM	01147	036	2009/05/15	.000	2012/05
THALLIUM	01059	036	2009/05/15	.000	2012/05
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2012/02/09	3.600	2013/02
NITRITE (AS N)	00620	036	2009/05/15	.000	2012/05
RADIOLOGICAL					
GROSS ALPHA	01501	108	2009/01/22	.820	2018/01
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED	2009/01/22	.900	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801016***

System Name: ***HESS WINERY***

PS Code: ***2801016-001***

Source Name: ***PATRICK SPRING***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	108	2009/05/15	.000	2018/05	
2,4-D	39730	108	2009/05/15	.000	2018/05	
ALACHLOR	77825	WAIVED	2009/05/15	.000		
ATRAZINE	39033	036	2009/05/15	.000	2012/05	
BENTAZON	38710	WAIVED	2009/05/15	.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2009/05/15	.000	2012/05	
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2009/05/15	.000	2012/05	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2009/05/15	.000		
DINOSEB	81287	036	2009/05/15	.000	2012/05	
DIQUAT	78885	036	2009/05/15	.000	2012/05	
ENDOTHALL	38926	036	2009/05/15	.000	2012/05	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	108	2009/05/15	.000	2018/05	
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801016***

System Name: ***HESS WINERY***

PS Code: ***2801016-001***

Source Name: ***PATRICK SPRING***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	000				**DUE**
MOLINATE	82199	WAIVED	2009/05/15	.000		
OXAMYL	38865	036	2009/05/15	.000	2012/05	
PENTACHLOROPHENOL	39032	036	2009/05/15	.000	2012/05	
PICLORAM	39720	036	2009/05/15	.000	2012/05	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2009/05/15	.000	2012/05	
THIOBENCARB	A-001	WAIVED	2009/05/15	.000		
TOXAPHENE	39400	000				**DUE**
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2009/05/15	.000	2015/05	
1,1,2,2-TETRACHLOROETHANE	34516	072	2009/05/15	.000	2015/05	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2009/05/15	.000	2015/05	
1,1,2-TRICHLOROETHANE	34511	072	2009/05/15	.000	2015/05	
1,1-DICHLOROETHANE	34496	072	2009/05/15	.000	2015/05	
1,1-DICHLOROETHYLENE	34501	072	2009/05/15	.000	2015/05	
1,2,4-TRICHLOROBENZENE	34551	072	2009/05/15	.000	2015/05	
1,2-DICHLOROBENZENE	34536	072	2009/05/15	.000	2015/05	
1,2-DICHLOROETHANE	34531	072	2009/05/15	.000	2015/05	
1,2-DICHLOROPROPANE	34541	072	2009/05/15	.000	2015/05	
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2009/05/15	.000	2015/05	
1,4-DICHLOROBENZENE	34571	072	2009/05/15	.000	2015/05	
BENZENE	34030	072	2009/05/15	.000	2015/05	
CARBON TETRACHLORIDE	32102	072	2009/05/15	.000	2015/05	
CIS-1,2-DICHLOROETHYLENE	77093	072	2009/05/15	.000	2015/05	
DICHLOROMETHANE	34423	072	2009/05/15	.000	2015/05	
ETHYLBENZENE	34371	072	2009/05/15	.000	2015/05	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	036	2009/05/15	.000	2012/05	
MONOCHLOROBENZENE	34301	072	2009/05/15	.000	2015/05	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801016***

System Name: ***HESS WINERY***

PS Code: ***2801016-001***

Source Name: ***PATRICK SPRING***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2009/05/15	.000	2015/05
TETRACHLOROETHYLENE	34475	072	2009/05/15	.000	2015/05
TOLUENE	34010	072	2009/05/15	.000	2015/05
TRANS-1,2-DICHLOROETHYLENE	34546	072	2009/05/15	.000	2015/05
TRICHLOROETHYLENE	39180	072	2009/05/15	.000	2015/05
TRICHLOROFLUOROMETHANE	34488	072	2009/05/15	.000	2015/05
VINYL CHLORIDE	39175	072	2009/05/15	.000	2015/05
XYLENES (TOTAL)	81551	072	2009/05/15	.000	2015/05
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED	2009/05/15	9.400	
BICARBONATE ALKALINITY	00440	036	2009/05/15	39.000	2012/05
CALCIUM	00916	036	2009/05/15	5.700	2012/05
CARBONATE ALKALINITY	00445	036	2009/05/15	.000	2012/05
CHLORIDE	00940	036	2009/05/15	6.800	2012/05
COLOR	00081	036	2009/05/15	9.000	2012/05
COPPER	01042	036	2009/05/15	.000	2012/05
FOAMING AGENTS (MBAS)	38260	036	2009/05/15	.000	2012/05
HARDNESS (TOTAL) AS CACO3	00900	036	2009/05/15	23.000	2012/05
HYDROXIDE ALKALINITY	71830	036	2009/05/15	.000	2012/05
IRON	01045	036	2009/05/15	.000	2012/05
MAGNESIUM	00927	036	2009/05/15	2.100	2012/05
MANGANESE	01055	036	2009/05/15	.000	2012/05
ODOR THRESHOLD @ 60 C	00086	036	2009/05/15	.000	2012/05
PH, LABORATORY	00403	036	2009/05/15	6.700	2012/05
SILVER	01077	036	2009/05/15	.000	2012/05
SODIUM	00929	036	2009/05/15	11.000	2012/05
SPECIFIC CONDUCTANCE	00095	036	2009/05/15	100.000	2012/05
SULFATE	00945	036	2009/05/15	6.900	2012/05
TOTAL DISSOLVED SOLIDS	70300	036	2009/05/15	120.000	2012/05

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801016***

System Name: ***HESS WINERY***

PS Code: ***2801016-001***

Source Name: ***PATRICK SPRING***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	036	2010/03/23	6.000	2013/03
ZINC	01092	036	2009/05/15	.000	2012/05

PS Code: ***2801016-002***

Source Name: ***SPRING #2-MAIN***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED	2006/05/17	.000	
INORGANIC					
ALUMINUM	01105	036	2009/05/15	.000	2012/05
ANTIMONY	01097	036	2009/05/15	.000	2012/05
ARSENIC	01002	036	2009/05/15	2.200	2012/05
ASBESTOS	81855	108	2011/02/09	.000	2020/02
BARIUM	01007	036	2009/05/15	.000	2012/05
BERYLLIUM	01012	036	2009/05/15	.000	2012/05
CADMIUM	01027	036	2009/05/15	.000	2012/05
CHROMIUM (TOTAL)	01034	036	2009/05/15	.000	2012/05
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2009/05/15	.000	2012/05
LEAD	01051	WAIVED	2009/05/15	.000	
MERCURY	71900	036	2009/05/15	.000	2012/05
NICKEL	01067	036	2009/05/15	.000	2012/05
PERCHLORATE	A-031	036	2012/02/09	< .000	2015/02
SELENIUM	01147	036	2009/05/15	.000	2012/05
THALLIUM	01059	036	2009/05/15	.000	2012/05

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801016***

System Name: ***HESS WINERY***

PS Code: ***2801016-002***

Source Name: ***SPRING #2-MAIN***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2012/02/09	< .000	2013/02
NITRITE (AS N)	00620	036	2009/05/15	.000	2012/05
RADIOLOGICAL					
GROSS ALPHA	01501	108	2009/01/22	1.380	2018/01
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED	2009/01/22	.740	
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	108	2009/05/15	.000	2018/05
2,4-D	39730	108	2009/05/15	.000	2018/05
ALACHLOR	77825	WAIVED	2009/05/15	.000	
ATRAZINE	39033	036	2009/05/15	.000	2012/05
BENTAZON	38710	WAIVED	2009/05/15	.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	036	2009/05/15	.000	2012/05
CHLORDANE	39350	WAIVED			
DALAPON	38432	036	2009/05/15	.000	2012/05
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2009/05/15	.000	
DINOSEB	81287	036	2009/05/15	.000	2012/05
DIQUAT	78885	036	2009/05/15	.000	2012/05

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801016***

System Name: ***HESS WINERY***

PS Code: ***2801016-002***

Source Name: ***SPRING #2-MAIN***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
ENDOTHALL	38926	036	2009/05/15	.000	2012/05	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	108	2009/05/15	.000	2018/05	
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**
METHOXYCHLOR	39480	000				**DUE**
MOLINATE	82199	WAIVED	2009/05/15	.000		
OXAMYL	38865	036	2009/05/15	.000	2012/05	
PENTACHLOROPHENOL	39032	036	2009/05/15	.000	2012/05	
PICLORAM	39720	036	2009/05/15	.000	2012/05	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2009/05/15	.000	2012/05	
THIOBENCARB	A-001	WAIVED	2009/05/15	.000		
TOXAPHENE	39400	000				**DUE**
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2009/05/15	.000	2015/05	
1,1,2,2-TETRACHLOROETHANE	34516	072	2009/05/15	.000	2015/05	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2009/05/15	.000	2015/05	
1,1,2-TRICHLOROETHANE	34511	072	2009/05/15	.000	2015/05	
1,1-DICHLOROETHANE	34496	072	2009/05/15	.000	2015/05	
1,1-DICHLOROETHYLENE	34501	072	2009/05/15	.000	2015/05	
1,2,4-TRICHLOROBENZENE	34551	072	2009/05/15	.000	2015/05	
1,2-DICHLOROBENZENE	34536	072	2009/05/15	.000	2015/05	
1,2-DICHLOROETHANE	34531	072	2009/05/15	.000	2015/05	
1,2-DICHLOROPROPANE	34541	072	2009/05/15	.000	2015/05	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801016***

System Name: ***HESS WINERY***

PS Code: ***2801016-002***

Source Name: ***SPRING #2-MAIN***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2009/05/15	.000	2015/05
1,4-DICHLOROBENZENE	34571	072	2009/05/15	.000	2015/05
BENZENE	34030	072	2009/05/15	.000	2015/05
CARBON TETRACHLORIDE	32102	072	2009/05/15	.000	2015/05
CIS-1,2-DICHLOROETHYLENE	77093	072	2009/05/15	.000	2015/05
DICHLOROMETHANE	34423	072	2009/05/15	.000	2015/05
ETHYLBENZENE	34371	072	2009/05/15	.000	2015/05
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	036	2009/05/15	.000	2012/05
MONOCHLOROBENZENE	34301	072	2009/05/15	.000	2015/05
STYRENE	77128	072	2009/05/15	.000	2015/05
TETRACHLOROETHYLENE	34475	072	2009/05/15	.000	2015/05
TOLUENE	34010	072	2009/05/15	.000	2015/05
TRANS-1,2-DICHLOROETHYLENE	34546	072	2009/05/15	.000	2015/05
TRICHLOROETHYLENE	39180	072	2009/05/15	.000	2015/05
TRICHLOROFLUOROMETHANE	34488	072	2009/05/15	.000	2015/05
VINYL CHLORIDE	39175	072	2009/05/15	.000	2015/05
XYLENES (TOTAL)	81551	072	2009/05/15	.000	2015/05
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED	2009/05/15	9.000	
BICARBONATE ALKALINITY	00440	036	2009/05/15	27.000	2012/05
CALCIUM	00916	036	2009/05/15	3.500	2012/05
CARBONATE ALKALINITY	00445	036	2009/05/15	.000	2012/05
CHLORIDE	00940	036	2009/05/15	5.700	2012/05
COLOR	00081	036	2009/05/15	.000	2012/05
COPPER	01042	036	2009/05/15	.000	2012/05
FOAMING AGENTS (MBAS)	38260	036	2009/05/15	.000	2012/05
HARDNESS (TOTAL) AS CACO3	00900	036	2009/05/15	12.000	2012/05
HYDROXIDE ALKALINITY	71830	036	2009/05/15	.000	2012/05
IRON	01045	036	2009/05/15	.000	2012/05

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801016***

System Name: ***HESS WINERY***

PS Code: ***2801016-002***

Source Name: ***SPRING #2-MAIN***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
MAGNESIUM	00927	036	2009/05/15	.790	2012/05
MANGANESE	01055	036	2009/05/15	.000	2012/05
ODOR THRESHOLD @ 60 C	00086	036	2009/05/15	.000	2012/05
PH, LABORATORY	00403	036	2009/05/15	6.700	2012/05
SILVER	01077	036	2009/05/15	.000	2012/05
SODIUM	00929	036	2009/05/15	12.000	2012/05
SPECIFIC CONDUCTANCE	00095	036	2009/05/15	86.000	2012/05
SULFATE	00945	036	2009/05/15	8.400	2012/05
TOTAL DISSOLVED SOLIDS	70300	036	2009/05/15	72.000	2012/05
TURBIDITY, LABORATORY	82079	036	2010/03/23	.290	2013/03
ZINC	01092	036	2009/05/15	.000	2012/05

PS Code: ***2801016-003***

Source Name: ***SPRING #3-MIDDLE***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED	2006/05/17	.000	
INORGANIC					
ALUMINUM	01105	036	2009/05/15	.000	2012/05
ANTIMONY	01097	036	2009/05/15	.000	2012/05
ARSENIC	01002	036	2009/05/15	2.400	2012/05
ASBESTOS	81855	108	2011/02/09	.000	2020/02
BARIUM	01007	036	2009/05/15	120.000	2012/05
BERYLLIUM	01012	036	2009/05/15	.000	2012/05
CADMIUM	01027	036	2009/05/15	.000	2012/05
CHROMIUM (TOTAL)	01034	036	2009/05/15	.000	2012/05
CYANIDE	01291	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801016***

System Name: ***HESS WINERY***

PS Code: ***2801016-003***

Source Name: ***SPRING #3-MIDDLE***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2009/05/15	.000	2012/05
LEAD	01051	WAIVED	2009/05/15	.000	
MERCURY	71900	036	2009/05/15	.000	2012/05
NICKEL	01067	036	2009/05/15	.000	2012/05
PERCHLORATE	A-031	036	2012/02/09	< .000	2015/02
SELENIUM	01147	036	2009/05/15	.000	2012/05
THALLIUM	01059	036	2009/05/15	.000	2012/05
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2012/02/09	3.700	2013/02
NITRITE (AS N)	00620	036	2009/05/15	.000	2012/05
RADIOLOGICAL					
GROSS ALPHA	01501	108	2009/01/22	2.110	2018/01
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED	2009/01/22	1.010	
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	108	2009/05/15	.000	2018/05
2,4-D	39730	108	2009/05/15	.000	2018/05
ALACHLOR	77825	WAIVED	2009/05/15	.000	
ATRAZINE	39033	036	2009/05/15	.000	2012/05
BENTAZON	38710	WAIVED	2009/05/15	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801016***

System Name: ***HESS WINERY***

PS Code: ***2801016-003***

Source Name: ***SPRING #3-MIDDLE***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2009/05/15	.000	2012/05	
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2009/05/15	.000	2012/05	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2009/05/15	.000		
DINOSEB	81287	036	2009/05/15	.000	2012/05	
DIQUAT	78885	036	2009/05/15	.000	2012/05	
ENDOTHALL	38926	036	2009/05/15	.000	2012/05	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	108	2009/05/15	.000	2018/05	
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**
METHOXYCHLOR	39480	000				**DUE**
MOLINATE	82199	WAIVED	2009/05/15	.000		
OXAMYL	38865	036	2009/05/15	.000	2012/05	
PENTACHLOROPHENOL	39032	036	2009/05/15	.000	2012/05	
PICLORAM	39720	036	2009/05/15	.000	2012/05	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2009/05/15	.000	2012/05	
THIOBENCARB	A-001	WAIVED	2009/05/15	.000		
TOXAPHENE	39400	000				**DUE**
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2009/05/15	.000	2015/05	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801016***

System Name: ***HESS WINERY***

PS Code: ***2801016-003***

Source Name: ***SPRING #3-MIDDLE***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	072	2009/05/15	.000	2015/05
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2009/05/15	.000	2015/05
1,1,2-TRICHLOROETHANE	34511	072	2009/05/15	.000	2015/05
1,1-DICHLOROETHANE	34496	072	2009/05/15	.000	2015/05
1,1-DICHLOROETHYLENE	34501	072	2009/05/15	.000	2015/05
1,2,4-TRICHLOROBENZENE	34551	072	2009/05/15	.000	2015/05
1,2-DICHLOROBENZENE	34536	072	2009/05/15	.000	2015/05
1,2-DICHLOROETHANE	34531	072	2009/05/15	.000	2015/05
1,2-DICHLOROPROPANE	34541	072	2009/05/15	.000	2015/05
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2009/05/15	.000	2015/05
1,4-DICHLOROBENZENE	34571	072	2009/05/15	.000	2015/05
BENZENE	34030	072	2009/05/15	.000	2015/05
CARBON TETRACHLORIDE	32102	072	2009/05/15	.000	2015/05
CIS-1,2-DICHLOROETHYLENE	77093	072	2009/05/15	.000	2015/05
DICHLOROMETHANE	34423	072	2009/05/15	.000	2015/05
ETHYLBENZENE	34371	072	2009/05/15	.000	2015/05
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	036	2009/05/15	.000	2012/05
MONOCHLOROBENZENE	34301	072	2009/05/15	.000	2015/05
STYRENE	77128	072	2009/05/15	.000	2015/05
TETRACHLOROETHYLENE	34475	072	2009/05/15	.000	2015/05
TOLUENE	34010	072	2009/05/15	.000	2015/05
TRANS-1,2-DICHLOROETHYLENE	34546	072	2009/05/15	.000	2015/05
TRICHLOROETHYLENE	39180	072	2009/05/15	.000	2015/05
TRICHLOROFLUOROMETHANE	34488	072	2009/05/15	.000	2015/05
VINYL CHLORIDE	39175	072	2009/05/15	.000	2015/05
XYLENES (TOTAL)	81551	072	2009/05/15	.000	2015/05
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED	2009/05/15	9.000	
BICARBONATE ALKALINITY	00440	036	2009/05/15	34.000	2012/05

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801016***

System Name: ***HESS WINERY***

PS Code: ***2801016-003***

Source Name: ***SPRING #3-MIDDLE***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	036	2009/05/15	4.700	2012/05
CARBONATE ALKALINITY	00445	036	2009/05/15	.000	2012/05
CHLORIDE	00940	036	2009/05/15	6.900	2012/05
COLOR	00081	036	2009/05/15	.000	2012/05
COPPER	01042	036	2009/05/15	.000	2012/05
FOAMING AGENTS (MBAS)	38260	036	2009/05/15	.000	2012/05
HARDNESS (TOTAL) AS CACO3	00900	036	2009/05/15	17.000	2012/05
HYDROXIDE ALKALINITY	71830	036	2009/05/15	.000	2012/05
IRON	01045	036	2009/05/15	.000	2012/05
MAGNESIUM	00927	036	2009/05/15	1.200	2012/05
MANGANESE	01055	036	2009/05/15	.000	2012/05
ODOR THRESHOLD @ 60 C	00086	036	2009/05/15	.000	2012/05
PH, LABORATORY	00403	036	2009/05/15	6.400	2012/05
SILVER	01077	036	2009/05/15	.000	2012/05
SODIUM	00929	036	2009/05/15	13.000	2012/05
SPECIFIC CONDUCTANCE	00095	036	2009/05/15	98.000	2012/05
SULFATE	00945	036	2009/05/15	8.000	2012/05
TOTAL DISSOLVED SOLIDS	70300	036	2009/05/15	95.000	2012/05
TURBIDITY, LABORATORY	82079	036	2010/03/23	23.000	2013/03
ZINC	01092	036	2009/05/15	.000	2012/05

PS Code: ***2801016-004***

Source Name: ***SPRING 4-HIGH SPRING***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED	2006/05/17	.000

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2801016
System Name: HESS WINERY

PS Code: 2801016-004
Source Name: SPRING 4-HIGH SPRING
Source Number: 004
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
ALUMINUM	01105	WAIVED	2006/05/17	.000	
ANTIMONY	01097	WAIVED	2006/05/17	.000	
ARSENIC	01002	WAIVED	2006/05/17	< 54.000	
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED	2006/05/17	220.000	
BERYLLIUM	01012	WAIVED	2006/05/17	.000	
CADMIUM	01027	WAIVED	2006/05/17	.000	
CHROMIUM (TOTAL)	01034	WAIVED	2006/05/17	.000	
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2006/05/17	.000	
LEAD	01051	WAIVED	2006/05/17	< 10.000	
MERCURY	71900	WAIVED	2006/05/17	.001	
NICKEL	01067	WAIVED	2006/05/17	5.300	
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED	2006/05/17	6.000	
THALLIUM	01059	WAIVED	2006/05/17	.000	
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED	2006/05/17	.000	
NITRITE (AS N)	00620	WAIVED	2006/05/17	.000	
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED	2007/04/24	4.640	
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED	2007/04/24	1.610	
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801016***

System Name: ***HESS WINERY***

PS Code: ***2801016-004***

Source Name: ***SPRING 4-HIGH SPRING***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2006/05/17	< 1.000	
2,4-D	39730	WAIVED	2006/05/17	< 10.000	
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED	2006/05/17	.000	
BENTAZON	38710	WAIVED	2006/05/17	< 2.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED	2006/05/17	< 5.000	
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED	2006/05/17	< 10.000	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2006/05/17	.000	
DINOSEB	81287	WAIVED	2006/05/17	< 2.000	
DIQUAT	78885	WAIVED	2006/05/17	< 4.000	
ENDOTHALL	38926	WAIVED	2006/05/17	< 45.000	
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2006/05/17	.000	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED	2006/05/17	.000	
OXAMYL	38865	WAIVED	2006/05/17	< 20.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801016***

System Name: ***HESS WINERY***

PS Code: ***2801016-004***

Source Name: ***SPRING 4-HIGH SPRING***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
PENTACHLOROPHENOL	39032	WAIVED	2006/05/17	< .200	
PICLORAM	39720	WAIVED	2006/05/17	< 1.000	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED	2006/05/17	.000	
THIOBENCARB	A-001	WAIVED	2006/05/17	.000	
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED	2006/05/17	.000	
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED	2006/05/17	.000	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED	2006/05/17	.000	
1,1,2-TRICHLOROETHANE	34511	WAIVED	2006/05/17	.000	
1,1-DICHLOROETHANE	34496	WAIVED	2006/05/17	.000	
1,1-DICHLOROETHYLENE	34501	WAIVED	2006/05/17	.000	
1,2,4-TRICHLOROBENZENE	34551	WAIVED	2006/05/17	.000	
1,2-DICHLOROBENZENE	34536	WAIVED	2006/05/17	.000	
1,2-DICHLOROETHANE	34531	WAIVED	2006/05/17	.000	
1,2-DICHLOROPROPANE	34541	WAIVED	2006/05/17	.000	
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED	2006/05/17	.000	
1,4-DICHLOROBENZENE	34571	WAIVED	2006/05/17	.000	
BENZENE	34030	WAIVED	2006/05/17	.000	
CARBON TETRACHLORIDE	32102	WAIVED	2006/05/17	.000	
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED	2006/05/17	.000	
DICHLOROMETHANE	34423	WAIVED	2006/05/17	.000	
ETHYLBENZENE	34371	WAIVED	2006/05/17	.000	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED	2006/05/17	.000	
MONOCHLOROBENZENE	34301	WAIVED	2006/05/17	.000	
STYRENE	77128	WAIVED	2006/05/17	.000	
TETRACHLOROETHYLENE	34475	WAIVED	2006/05/17	.000	
TOLUENE	34010	WAIVED	2006/05/17	.900	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801016***

System Name: ***HESS WINERY***

PS Code: ***2801016-004***

Source Name: ***SPRING 4-HIGH SPRING***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED	2006/05/17	.000	
TRICHLOROETHYLENE	39180	WAIVED	2006/05/17	.000	
TRICHLOROFLUOROMETHANE	34488	WAIVED	2006/05/17	.000	
VINYL CHLORIDE	39175	WAIVED	2006/05/17	.000	
XYLENES (TOTAL)	81551	WAIVED	2006/05/17	.000	
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED	2006/05/17	8.700	
BICARBONATE ALKALINITY	00440	WAIVED	2006/05/17	44.000	
CALCIUM	00916	WAIVED	2006/05/17	6.000	
CARBONATE ALKALINITY	00445	WAIVED	2006/05/17	.000	
CHLORIDE	00940	WAIVED	2006/05/17	5.400	
COLOR	00081	WAIVED	2006/05/17	85.000	
COPPER	01042	WAIVED	2006/05/17	.000	
FOAMING AGENTS (MBAS)	38260	WAIVED	2006/05/17	.000	
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2006/05/17	23.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2006/05/17	.000	
IRON	01045	WAIVED	2006/05/17	7600.000	
MAGNESIUM	00927	WAIVED	2006/05/17	< 2.000	
MANGANESE	01055	WAIVED	2006/05/17	1100.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED	2006/05/17	20.000	
PH, LABORATORY	00403	WAIVED	2006/05/17	5.900	
SILVER	01077	WAIVED	2006/05/17	.000	
SODIUM	00929	WAIVED	2006/05/17	< 8.400	
SPECIFIC CONDUCTANCE	00095	WAIVED	2006/05/17	110.000	
SULFATE	00945	WAIVED	2006/05/17	5.700	
TOTAL DISSOLVED SOLIDS	70300	WAIVED	2006/05/17	100.000	
TURBIDITY, LABORATORY	82079	WAIVED	2006/05/17	54.000	
ZINC	01092	WAIVED	2006/05/17	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801016***

System Name: ***HESS WINERY***

PS Code: ***2801016-005***

Source Name: ***TREATMENT PLANT***

Source Number: ***005***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801016***

System Name: ***HESS WINERY***

PS Code: ***2801016-005***

Source Name: ***TREATMENT PLANT***

Source Number: ***005***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801016***

System Name: ***HESS WINERY***

PS Code: ***2801016-005***

Source Name: ***TREATMENT PLANT***

Source Number: ***005***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801016***

System Name: ***HESS WINERY***

PS Code: ***2801016-005***

Source Name: ***TREATMENT PLANT***

Source Number: ***005***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801016***

System Name: ***HESS WINERY***

PS Code: ***2801016-005***

Source Name: ***TREATMENT PLANT***

Source Number: ***005***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801020***

System Name: ***ESPINOZA WATER SYSTEM***

PS Code: ***2801020-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2005/08/09	.000		
INORGANIC						
ALUMINUM	01105	036	2009/10/21	.000	2012/10	
ANTIMONY	01097	036	2009/10/21	.000	2012/10	
ARSENIC	01002	036	2009/10/21	8.600	2012/10	
ASBESTOS	81855	000				**DUE**
BARIUM	01007	036	2009/10/21	120.000	2012/10	
BERYLLIUM	01012	036	2009/10/21	.000	2012/10	
CADMIUM	01027	036	2009/10/21	.000	2012/10	
CHROMIUM (TOTAL)	01034	036	2009/10/21	.000	2012/10	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2009/10/21	.210	2012/10	
LEAD	01051	WAIVED	2004/05/12	.000		
MERCURY	71900	036	2009/10/21	.000	2012/10	
NICKEL	01067	036	2009/10/21	.000	2012/10	
PERCHLORATE	A-031	036	2011/07/20	< .000	2014/07	
SELENIUM	01147	036	2009/10/21	.000	2012/10	
THALLIUM	01059	036	2009/10/21	.000	2012/10	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/05/05	< .000	2012/05	
NITRITE (AS N)	00620	036	2009/09/30	.000	2012/09	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2011/10/13	.000	2020/10	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED	2011/07/20	1.960		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801020***

System Name: ***ESPINOZA WATER SYSTEM***

PS Code: ***2801020-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	108	2009/10/14	.000	2018/10
2,4-D	39730	WAIVED	2009/10/14	.000	
ALACHLOR	77825	WAIVED	2009/10/14	.000	
ATRAZINE	39033	036	2009/10/14	.000	2012/10
BENTAZON	38710	WAIVED	2009/10/14	.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED	2009/10/14	.000	
CHLORDANE	39350	WAIVED	2005/08/30	.000	
DALAPON	38432	036	2009/10/14	.000	2012/10
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2005/08/30	.000	
DINOSEB	81287	WAIVED	2009/10/14	.000	
DIQUAT	78885	036	2009/10/14	.000	2012/10
ENDOTHALL	38926	036	2009/10/14	.000	2012/10
ENDRIN	39390	WAIVED	2005/08/30	.000	
ETHYLENE DIBROMIDE (EDB)	77651	108	2005/08/30	.000	2014/08
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	108	2005/08/30	.000	2014/08
HEPTACHLOR EPOXIDE	39420	108	2005/08/30	.000	2014/08
HEXACHLOROBENZENE	39700	WAIVED	2005/08/30	.000	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2005/08/30	.000	
LINDANE	39340	108	2005/08/30	.000	2014/08

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801020***

System Name: ***ESPINOZA WATER SYSTEM***

PS Code: ***2801020-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	108	2005/08/30	.000	2014/08
MOLINATE	82199	WAIVED	2005/08/09	.000	
OXAMYL	38865	036	2009/10/14	.000	2012/10
PENTACHLOROPHENOL	39032	036	2009/10/14	.000	2012/10
PICLORAM	39720	036	2009/10/14	.000	2012/10
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2005/08/30	.000	
SIMAZINE	39055	036	2009/10/14	.000	2012/10
THIOBENCARB	A-001	WAIVED	2005/08/09	.000	
TOXAPHENE	39400	WAIVED	2005/08/30	.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	072	2010/12/22	.000	2016/12
1,1,2,2-TETRACHLOROETHANE	34516	072	2010/12/22	.000	2016/12
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2010/12/22	.000	2016/12
1,1,2-TRICHLOROETHANE	34511	072	2010/12/22	.000	2016/12
1,1-DICHLOROETHANE	34496	072	2010/12/22	.000	2016/12
1,1-DICHLOROETHYLENE	34501	072	2010/12/22	.000	2016/12
1,2,4-TRICHLOROBENZENE	34551	072	2010/12/22	.000	2016/12
1,2-DICHLOROBENZENE	34536	072	2010/12/22	.000	2016/12
1,2-DICHLOROETHANE	34531	072	2010/12/22	.000	2016/12
1,2-DICHLOROPROPANE	34541	072	2010/12/22	.000	2016/12
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2010/12/22	.000	2016/12
1,4-DICHLOROBENZENE	34571	072	2010/12/22	.000	2016/12
BENZENE	34030	072	2010/12/22	.000	2016/12
CARBON TETRACHLORIDE	32102	072	2010/12/22	.000	2016/12
CIS-1,2-DICHLOROETHYLENE	77093	072	2010/12/22	.000	2016/12
DICHLOROMETHANE	34423	072	2010/12/22	.000	2016/12
ETHYLBENZENE	34371	072	2010/12/22	.000	2016/12
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	036	2010/12/22	.000	2013/12
MONOCHLOROBENZENE	34301	072	2010/12/22	.000	2016/12

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2801020
System Name: ESPINOZA WATER SYSTEM

PS Code: 2801020-001
Source Name: LPA REPORTED PRIMARY SOURCE
Source Number: 001
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2010/12/22	.000	2016/12
TETRACHLOROETHYLENE	34475	072	2010/12/22	.000	2016/12
TOLUENE	34010	072	2010/12/22	.000	2016/12
TRANS-1,2-DICHLOROETHYLENE	34546	072	2010/12/22	.000	2016/12
TRICHLOROETHYLENE	39180	072	2010/12/22	.000	2016/12
TRICHLOROFLUOROMETHANE	34488	072	2010/12/22	.000	2016/12
VINYL CHLORIDE	39175	072	2010/12/22	.000	2016/12
XYLENES (TOTAL)	81551	072	2010/12/22	.000	2016/12
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED	2009/10/21	11.500	
BICARBONATE ALKALINITY	00440	036	2009/10/21	160.000	2012/10
CALCIUM	00916	036	2009/10/21	19.000	2012/10
CARBONATE ALKALINITY	00445	036	2009/10/21	.000	2012/10
CHLORIDE	00940	036	2009/10/21	11.000	2012/10
COLOR	00081	036	2009/10/21	3.000	2012/10
COPPER	01042	036	2009/10/21	.000	2012/10
FOAMING AGENTS (MBAS)	38260	036	2009/10/21	.000	2012/10
HARDNESS (TOTAL) AS CACO3	00900	036	2009/10/21	84.000	2012/10
HYDROXIDE ALKALINITY	71830	036	2009/10/21	.000	2012/10
IRON	01045	036	2009/10/21	.000	2012/10
MAGNESIUM	00927	036	2012/01/17	8.500	2015/01
MANGANESE	01055	036	2012/04/25	431.000	2015/04
ODOR THRESHOLD @ 60 C	00086	036	2009/10/21	4.000	2012/10
PH, LABORATORY	00403	036	2009/10/21	7.700	2012/10
SILVER	01077	036	2011/07/20	< .000	2014/07
SODIUM	00929	036	2009/10/21	44.000	2012/10
SPECIFIC CONDUCTANCE	00095	036	2009/10/21	350.000	2012/10
SULFATE	00945	036	2009/10/21	25.000	2012/10
TOTAL DISSOLVED SOLIDS	70300	036	2009/10/21	220.000	2012/10

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801020***

System Name: ***ESPINOZA WATER SYSTEM***

PS Code: ***2801020-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
TURBIDITY, LABORATORY	82079	036	2009/10/21	.000	2012/10
ZINC	01092	036	2009/10/21	.000	2012/10

PS Code: ***2801020-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED

INORGANIC

ALUMINUM	01105	WAIVED
ANTIMONY	01097	WAIVED
ARSENIC	01002	WAIVED
ASBESTOS	81855	WAIVED
BARIUM	01007	WAIVED
BERYLLIUM	01012	WAIVED
CADMIUM	01027	WAIVED
CHROMIUM (TOTAL)	01034	WAIVED
CYANIDE	01291	WAIVED
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED
LEAD	01051	WAIVED
MERCURY	71900	WAIVED
NICKEL	01067	WAIVED
PERCHLORATE	A-031	WAIVED
SELENIUM	01147	WAIVED
THALLIUM	01059	WAIVED

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801020***

System Name: ***ESPINOZA WATER SYSTEM***

PS Code: ***2801020-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801020***

System Name: ***ESPINOZA WATER SYSTEM***

PS Code: ***2801020-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801020***

System Name: ***ESPINOZA WATER SYSTEM***

PS Code: ***2801020-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801020***

System Name: ***ESPINOZA WATER SYSTEM***

PS Code: ***2801020-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801022***

System Name: ***MILAT WINERY***

PS Code: ***2801022-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED	2002/03/27	100.000		
ANTIMONY	01097	WAIVED	2002/03/27	.000		
ARSENIC	01002	WAIVED	2002/03/27	.000		
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED	2002/03/27	.000		
BERYLLIUM	01012	WAIVED	2002/03/27	.000		
CADMIUM	01027	WAIVED	2002/03/27	.000		
CHROMIUM (TOTAL)	01034	WAIVED	2002/03/27	.000		
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED	2002/03/27	.000		
MERCURY	71900	WAIVED	2002/03/27	.000		
NICKEL	01067	WAIVED	2002/03/27	.000		
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED	2002/03/27	.000		
THALLIUM	01059	WAIVED	2002/03/27	.000		
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/07/18	< .000	2012/07	
NITRITE (AS N)	00620	036	2011/07/18	< .000	2014/07	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801022***

System Name: ***MILAT WINERY***

PS Code: ***2801022-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801022***

System Name: ***MILAT WINERY***

PS Code: ***2801022-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801022***

System Name: ***MILAT WINERY***

PS Code: ***2801022-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	WAIVED	2002/03/27	2100.000	
MAGNESIUM	00927	000			DUE
MANGANESE	01055	WAIVED	2002/03/27	170.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED	2002/03/27	.000	
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801022***

System Name: ***MILAT WINERY***

PS Code: ***2801022-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801024***

System Name: ***MUMM OF NAPA VALLEY***

PS Code: ***2801024-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	036	2011/11/09	< 50.000	2014/11
ANTIMONY	01097	036	2011/11/09	< 6.000	2014/11
ARSENIC	01002	036	2011/11/09	4.900	2014/11
ASBESTOS	81855	108	2009/01/14	.000	2018/01
BARIUM	01007	036	2011/11/09	< 100.000	2014/11
BERYLLIUM	01012	036	2011/11/09	< 1.000	2014/11
CADMIUM	01027	036	2011/11/09	< 1.000	2014/11
CHROMIUM (TOTAL)	01034	036	2011/11/09	2.500	2014/11
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2011/11/09	.270	2014/11
LEAD	01051	WAIVED	2005/02/23	< 5.000	
MERCURY	71900	036	2011/11/09	< 1.000	2014/11
NICKEL	01067	036	2011/11/09	< 10.000	2014/11
PERCHLORATE	A-031	036	2011/11/09	< 4.000	2014/11
SELENIUM	01147	036	2011/11/09	< 5.000	2014/11
THALLIUM	01059	036	2011/11/09	< 1.000	2014/11
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2011/11/09	5.200	2012/11
NITRITE (AS N)	00620	036	2011/11/09	< 400.000	2014/11
RADIOLOGICAL					
GROSS ALPHA	01501	108	2010/01/13	1.140	2019/01
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801024***

System Name: ***MUMM OF NAPA VALLEY***

PS Code: ***2801024-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2011/11/09	.000		
2,4-D	39730	WAIVED	2011/11/09	.000		
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	036	2011/11/09	.000	2014/11	
BENTAZON	38710	WAIVED	2011/11/09	.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2011/11/09	.000	2014/11	
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2011/11/09	.000	2014/11	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	036	2011/11/09	.000	2014/11	
DIQUAT	78885	036	2011/11/09	.000	2014/11	
ENDOTHALL	38926	036	2011/11/09	.000	2014/11	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	000				**DUE**
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801024***

System Name: ***MUMM OF NAPA VALLEY***

PS Code: ***2801024-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	000				**DUE**
MOLINATE	82199	WAIVED				
OXAMYL	38865	036	2011/11/09	.000	2014/11	
PENTACHLOROPHENOL	39032	036	2011/11/09	.000	2014/11	
PICLORAM	39720	036	2011/11/09	.000	2014/11	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2011/11/09	.000	2014/11	
THIOBENCARB	A-001	WAIVED				
TOXAPHENE	39400	000				**DUE**
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2009/01/14	.000	2015/01	
1,1,2,2-TETRACHLOROETHANE	34516	072	2009/01/14	.000	2015/01	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2009/01/14	.000	2015/01	
1,1,2-TRICHLOROETHANE	34511	072	2009/01/14	.000	2015/01	
1,1-DICHLOROETHANE	34496	072	2009/01/14	.000	2015/01	
1,1-DICHLOROETHYLENE	34501	072	2009/01/14	.000	2015/01	
1,2,4-TRICHLOROBENZENE	34551	072	2009/01/14	.000	2015/01	
1,2-DICHLOROBENZENE	34536	072	2009/01/14	.000	2015/01	
1,2-DICHLOROETHANE	34531	072	2009/01/14	.000	2015/01	
1,2-DICHLOROPROPANE	34541	072	2009/01/14	.000	2015/01	
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2009/01/14	.000	2015/01	
1,4-DICHLOROBENZENE	34571	072	2009/01/14	.000	2015/01	
BENZENE	34030	072	2009/01/14	.000	2015/01	
CARBON TETRACHLORIDE	32102	072	2009/01/14	.000	2015/01	
CIS-1,2-DICHLOROETHYLENE	77093	072	2009/01/14	.000	2015/01	
DICHLOROMETHANE	34423	072	2009/01/14	.000	2015/01	
ETHYLBENZENE	34371	072	2009/01/14	.000	2015/01	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2011/11/09	.000	2017/11	
MONOCHLOROBENZENE	34301	072	2009/01/14	.000	2015/01	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801024***

System Name: ***MUMM OF NAPA VALLEY***

PS Code: ***2801024-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2009/01/14	.000	2015/01
TETRACHLOROETHYLENE	34475	072	2009/01/14	.000	2015/01
TOLUENE	34010	072	2009/01/14	.000	2015/01
TRANS-1,2-DICHLOROETHYLENE	34546	072	2009/01/14	.000	2015/01
TRICHLOROETHYLENE	39180	072	2009/01/14	.000	2015/01
TRICHLOROFLUOROMETHANE	34488	072	2009/01/14	.000	2015/01
VINYL CHLORIDE	39175	072	2009/01/14	.000	2015/01
XYLENES (TOTAL)	81551	072	2009/01/14	.000	2015/01
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED	2011/11/09	11.100	
BICARBONATE ALKALINITY	00440	WAIVED	2011/11/09	210.000	
CALCIUM	00916	WAIVED	2011/11/09	18.000	
CARBONATE ALKALINITY	00445	WAIVED	2011/11/09	< 1.000	
CHLORIDE	00940	WAIVED	2011/11/09	8.500	
COLOR	00081	WAIVED	2011/11/09	5.000	
COPPER	01042	WAIVED	2011/11/09	< 50.000	
FOAMING AGENTS (MBAS)	38260	WAIVED	2011/11/09	< .050	
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2011/11/09	150.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2011/11/09	< 1.000	
IRON	01045	WAIVED	2011/11/09	< 100.000	
MAGNESIUM	00927	WAIVED	2011/11/09	26.000	
MANGANESE	01055	WAIVED	2011/11/09	< 20.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED	2011/11/09	< 1.000	
PH, LABORATORY	00403	WAIVED	2011/11/09	7.200	
SILVER	01077	WAIVED	2011/11/09	< 10.000	
SODIUM	00929	WAIVED	2011/11/09	18.000	
SPECIFIC CONDUCTANCE	00095	WAIVED	2011/11/09	370.000	
SULFATE	00945	WAIVED	2011/11/09	9.400	
TOTAL DISSOLVED SOLIDS	70300	WAIVED	2011/11/09	270.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801024***

System Name: ***MUMM OF NAPA VALLEY***

PS Code: ***2801024-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED	2011/11/09	2.800	
ZINC	01092	WAIVED	2011/11/09	95.000	

PS Code: ***2801024-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801024***

System Name: ***MUMM OF NAPA VALLEY***

PS Code: ***2801024-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801024***

System Name: ***MUMM OF NAPA VALLEY***

PS Code: ***2801024-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801024***

System Name: ***MUMM OF NAPA VALLEY***

PS Code: ***2801024-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801024***

System Name: ***MUMM OF NAPA VALLEY***

PS Code: ***2801024-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801024-005***

Source Name:

Source Number: ***005***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801024***

System Name: ***MUMM OF NAPA VALLEY***

PS Code: ***2801024-005***

Source Name:

Source Number: ***005***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801024***

System Name: ***MUMM OF NAPA VALLEY***

PS Code: ***2801024-005***

Source Name:

Source Number: ***005***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801024***

System Name: ***MUMM OF NAPA VALLEY***

PS Code: ***2801024-005***

Source Name:

Source Number: ***005***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801024***

System Name: ***MUMM OF NAPA VALLEY***

PS Code: ***2801024-005***

Source Name:

Source Number: ***005***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801025***

System Name: ***NEWTON VINEYARD***

PS Code: ***2801025-001***

Source Name: ***GREENHOUSE WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2006/11/14	< .250		
INORGANIC						
ALUMINUM	01105	WAIVED	2006/11/14	360.000		
ANTIMONY	01097	WAIVED	2006/11/14	< 6.000		
ARSENIC	01002	WAIVED	2006/11/14	.000		
ASBESTOS	81855	WAIVED	2006/11/14	.000		
BARIUM	01007	WAIVED	2006/11/14	120.000		
BERYLLIUM	01012	WAIVED	2006/11/14	.000		
CADMIUM	01027	WAIVED	2006/11/14	< 1.000		
CHROMIUM (TOTAL)	01034	WAIVED	2006/11/14	< 10.000		
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2006/11/14	.170		
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED	2006/11/14	< 1.000		
NICKEL	01067	WAIVED	2006/11/14	< 10.000		
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED	2006/11/14	.000		
THALLIUM	01059	WAIVED	2006/11/14	< 2.000		
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2006/11/14	.420	2007/11	DUE
NITRITE (AS N)	00620	036	2006/11/14	.000	2009/11	DUE
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801025***

System Name: ***NEWTON VINEYARD***

PS Code: ***2801025-001***

Source Name: ***GREENHOUSE WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2006/11/14	.000	
2,4-D	39730	WAIVED	2006/11/14	.000	
ALACHLOR	77825	WAIVED	2006/11/14	.000	
ATRAZINE	39033	WAIVED	2006/11/14	.000	
BENTAZON	38710	WAIVED	2006/11/14	.000	
BENZO (A) PYRENE	34247	WAIVED	2006/11/14	.000	
CARBOFURAN	81405	WAIVED	2006/11/14	.000	
CHLORDANE	39350	WAIVED	2006/11/14	.000	
DALAPON	38432	WAIVED	2006/11/14	.000	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED	2006/11/14	.000	
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED	2006/11/14	.000	
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2006/11/14	< .500	
DINOSEB	81287	WAIVED	2006/11/14	.000	
DIQUAT	78885	WAIVED	2006/11/14	.000	
ENDOTHALL	38926	WAIVED	2006/11/14	.000	
ENDRIN	39390	WAIVED	2006/11/14	.000	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2006/11/14	< .500	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2006/11/14	.000	
HEPTACHLOR EPOXIDE	39420	WAIVED	2006/11/14	.000	
HEXACHLOROBENZENE	39700	WAIVED	2006/11/14	.000	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2006/11/14	.000	
LINDANE	39340	WAIVED	2006/11/14	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801025***

System Name: ***NEWTON VINEYARD***

PS Code: ***2801025-001***

Source Name: ***GREENHOUSE WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED	2006/11/14	.000	
MOLINATE	82199	WAIVED	2006/11/14	.000	
OXAMYL	38865	WAIVED	2006/11/14	.000	
PENTACHLOROPHENOL	39032	WAIVED	2006/11/14	.000	
PICLORAM	39720	WAIVED	2006/11/14	.000	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2006/11/14	.000	
SIMAZINE	39055	WAIVED	2006/11/14	.000	
THIOBENCARB	A-001	WAIVED	2006/11/14	.000	
TOXAPHENE	39400	WAIVED	2006/11/14	.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED	2006/11/14	.000	
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED	2006/11/14	.000	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED	2006/11/14	< 10.000	
1,1,2-TRICHLOROETHANE	34511	WAIVED	2006/11/14	.000	
1,1-DICHLOROETHANE	34496	WAIVED	2006/11/14	.000	
1,1-DICHLOROETHYLENE	34501	WAIVED	2006/11/14	.000	
1,2,4-TRICHLOROBENZENE	34551	WAIVED	2006/11/14	.000	
1,2-DICHLOROBENZENE	34536	WAIVED	2006/11/14	.000	
1,2-DICHLOROETHANE	34531	WAIVED	2006/11/14	.000	
1,2-DICHLOROPROPANE	34541	WAIVED	2006/11/14	.000	
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED	2006/11/14	.000	
1,4-DICHLOROBENZENE	34571	WAIVED	2006/11/14	.000	
BENZENE	34030	WAIVED	2006/11/14	.000	
CARBON TETRACHLORIDE	32102	WAIVED	2006/11/14	.000	
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED	2006/11/14	.000	
DICHLOROMETHANE	34423	WAIVED	2006/11/14	.000	
ETHYLBENZENE	34371	WAIVED	2006/11/14	.000	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED	2006/11/14	< 3.000	
MONOCHLOROBENZENE	34301	WAIVED	2006/11/14	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801025***

System Name: ***NEWTON VINEYARD***

PS Code: ***2801025-001***

Source Name: ***GREENHOUSE WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED	2006/11/14	.000	
TETRACHLOROETHYLENE	34475	WAIVED	2006/11/14	.000	
TOLUENE	34010	WAIVED	2006/11/14	.000	
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED	2006/11/14	.000	
TRICHLOROETHYLENE	39180	WAIVED	2006/11/14	.000	
TRICHLOROFLUOROMETHANE	34488	WAIVED	2006/11/14	< 5.000	
VINYL CHLORIDE	39175	WAIVED	2006/11/14	.000	
XYLENES (TOTAL)	81551	WAIVED	2006/11/14	.000	
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2006/11/14	270.000	
CALCIUM	00916	WAIVED	2006/11/14	60.000	
CARBONATE ALKALINITY	00445	WAIVED	2006/11/14	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2006/11/14	310.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2006/11/14	.000	
IRON	01045	WAIVED	2006/11/14	.000	
MAGNESIUM	00927	WAIVED	2006/11/14	38.000	
MANGANESE	01055	WAIVED	2006/11/14	38.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2006/11/14	7.390	
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED	2006/11/14	24.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801025***

System Name: ***NEWTON VINEYARD***

PS Code: ***2801025-001***

Source Name: ***GREENHOUSE WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801025-004***

Source Name: ***TREATMENT PLANT***

Source Number: ***004***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801025***

System Name: ***NEWTON VINEYARD***

PS Code: ***2801025-004***

Source Name: ***TREATMENT PLANT***

Source Number: ***004***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801025***

System Name: ***NEWTON VINEYARD***

PS Code: ***2801025-004***

Source Name: ***TREATMENT PLANT***

Source Number: ***004***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801025***

System Name: ***NEWTON VINEYARD***

PS Code: ***2801025-004***

Source Name: ***TREATMENT PLANT***

Source Number: ***004***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801025***

System Name: ***NEWTON VINEYARD***

PS Code: ***2801025-004***

Source Name: ***TREATMENT PLANT***

Source Number: ***004***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801025-005***

Source Name: ***EFRA WELL***

Source Number: ***005***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801025***

System Name: ***NEWTON VINEYARD***

PS Code: ***2801025-005***

Source Name: ***EFRA WELL***

Source Number: ***005***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
INORGANIC						
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				DUE
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	000				DUE
NITRITE (AS N)	00620	000				DUE
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED				
2,4-D	39730	WAIVED				
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	WAIVED				
BENTAZON	38710	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801025***

System Name: ***NEWTON VINEYARD***

PS Code: ***2801025-005***

Source Name: ***EFRA WELL***

Source Number: ***005***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801025***

System Name: ***NEWTON VINEYARD***

PS Code: ***2801025-005***

Source Name: ***EFRA WELL***

Source Number: ***005***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801025***

System Name: ***NEWTON VINEYARD***

PS Code: ***2801025-005***

Source Name: ***EFRA WELL***

Source Number: ***005***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801026***

System Name: ***OPUS ONE WINERY***

PS Code: ***2801026-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2003/06/17	.000		
INORGANIC						
ALUMINUM	01105	036	2011/04/13	88.000	2014/04	
ANTIMONY	01097	036	2011/04/13	< 2.000	2014/04	
ARSENIC	01002	036	2011/04/13	< 2.000	2014/04	
ASBESTOS	81855	108	2003/06/17	.000	2012/06	
BARIUM	01007	036	2011/04/13	156.000	2014/04	
BERYLLIUM	01012	036	2011/04/13	< 1.000	2014/04	
CADMIUM	01027	036	2011/04/13	< 1.000	2014/04	
CHROMIUM (TOTAL)	01034	036	2011/04/13	< 10.000	2014/04	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2011/04/13	.200	2014/04	
LEAD	01051	WAIVED	2011/04/13	4.000		
MERCURY	71900	036	2011/04/13	< .200	2014/04	
NICKEL	01067	036	2011/04/13	< 10.000	2014/04	
PERCHLORATE	A-031	036	2010/08/31	< 4.000	2013/08	
SELENIUM	01147	036	2011/04/13	< 2.000	2014/04	
THALLIUM	01059	036	2011/04/13	< 1.000	2014/04	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/04/13	4.030	2012/04	
NITRITE (AS N)	00620	036	**2003/06/17**	.000	**2006/06**	**DUE**
RADIOLOGICAL						
GROSS ALPHA	01501	108	2012/02/13	- .060	2021/02	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801026***

System Name: ***OPUS ONE WINERY***

PS Code: ***2801026-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2003/06/17	.000	
2,4-D	39730	WAIVED	2003/06/17	.000	
ALACHLOR	77825	WAIVED	2000/08/02	.000	
ATRAZINE	39033	036	2011/04/13	< .300	2014/04
BENTAZON	38710	WAIVED	2003/06/17	.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	036	2011/04/13	.000	2014/04
CHLORDANE	39350	WAIVED	2000/08/02	.000	
DALAPON	38432	036	2011/04/13	< 5.000	2014/04
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED	2000/08/02	.000	
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED	2000/08/02	.000	
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	036	2011/04/13	< .200	2014/04
DIQUAT	78885	036	2011/04/13	.000	2014/04
ENDOTHALL	38926	036	2011/04/13	< 20.000	2014/04
ENDRIN	39390	WAIVED	2000/08/02	.000	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2000/08/02	.000	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2000/08/02	.000	
HEPTACHLOR EPOXIDE	39420	WAIVED	2000/08/02	.000	
HEXACHLOROBENZENE	39700	WAIVED	2000/08/02	.000	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2000/08/02	.000	
LINDANE	39340	WAIVED	2000/08/02	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801026***

System Name: ***OPUS ONE WINERY***

PS Code: ***2801026-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED	2000/08/02	.000	
MOLINATE	82199	WAIVED	2003/06/17	.000	
OXAMYL	38865	036	2011/04/13	.000	2014/04
PENTACHLOROPHENOL	39032	036	2011/04/13	< .050	2014/04
PICLORAM	39720	036	2011/04/13	< .050	2014/04
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	036	2011/04/13	< .300	2014/04
THIOBENCARB	A-001	WAIVED	2003/06/17	.000	
TOXAPHENE	39400	WAIVED	2000/08/02	.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	072	2009/02/19	< .500	2015/02
1,1,2,2-TETRACHLOROETHANE	34516	072	2009/02/19	< .500	2015/02
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2009/02/19	< 10.000	2015/02
1,1,2-TRICHLOROETHANE	34511	072	2009/02/19	< .500	2015/02
1,1-DICHLOROETHANE	34496	072	2009/02/19	< .500	2015/02
1,1-DICHLOROETHYLENE	34501	072	2009/02/19	< .500	2015/02
1,2,4-TRICHLOROBENZENE	34551	072	2009/02/19	< .500	2015/02
1,2-DICHLOROBENZENE	34536	072	2009/02/19	< .500	2015/02
1,2-DICHLOROETHANE	34531	072	2009/02/19	< .500	2015/02
1,2-DICHLOROPROPANE	34541	072	2009/02/19	< .500	2015/02
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2009/02/19	< .500	2015/02
1,4-DICHLOROBENZENE	34571	072	2009/02/19	< .500	2015/02
BENZENE	34030	072	2009/02/19	< .500	2015/02
CARBON TETRACHLORIDE	32102	072	2009/02/19	< .500	2015/02
CIS-1,2-DICHLOROETHYLENE	77093	072	2009/02/19	< .500	2015/02
DICHLOROMETHANE	34423	072	2009/02/19	< .500	2015/02
ETHYLBENZENE	34371	072	2009/02/19	< .500	2015/02
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2009/02/19	< 3.000	2015/02
MONOCHLOROBENZENE	34301	072	2009/02/19	< .500	2015/02

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801026***

System Name: ***OPUS ONE WINERY***

PS Code: ***2801026-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2009/02/19	< .500	2015/02
TETRACHLOROETHYLENE	34475	072	2009/02/19	< .500	2015/02
TOLUENE	34010	072	2009/02/19	< .500	2015/02
TRANS-1,2-DICHLOROETHYLENE	34546	072	2009/02/19	< .500	2015/02
TRICHLOROETHYLENE	39180	072	2009/02/19	< .500	2015/02
TRICHLOROFLUOROMETHANE	34488	072	2009/02/19	< 5.000	2015/02
VINYL CHLORIDE	39175	072	2009/02/19	< .500	2015/02
XYLENES (TOTAL)	81551	072	2009/02/19	< .500	2015/02
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2011/04/13	157.000	
CALCIUM	00916	WAIVED	2011/04/13	31.500	
CARBONATE ALKALINITY	00445	WAIVED	2011/04/13	< 1.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2011/04/13	222.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2011/04/13	< 1.000	
IRON	01045	WAIVED	2011/04/13	< 10.000	
MAGNESIUM	00927	WAIVED	2011/04/13	27.600	
MANGANESE	01055	WAIVED	2011/04/13	< 10.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2011/04/13	7.000	
SILVER	01077	WAIVED	2003/06/17	.000	
SODIUM	00929	WAIVED	2011/04/13	26.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801026***

System Name: ***OPUS ONE WINERY***

PS Code: ***2801026-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801026-002***

Source Name: ***WELL 2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED	2003/06/17	.000	
INORGANIC					
ALUMINUM	01105	036	2011/04/13	75.000	2014/04
ANTIMONY	01097	036	2011/04/13	< 2.000	2014/04
ARSENIC	01002	036	2011/04/13	< 2.000	2014/04
ASBESTOS	81855	108	2003/06/17	.000	2012/06
BARIUM	01007	036	2011/04/13	180.000	2014/04
BERYLLIUM	01012	036	2011/04/13	< 1.000	2014/04
CADMIUM	01027	036	2011/04/13	< 1.000	2014/04
CHROMIUM (TOTAL)	01034	036	2011/04/13	< 10.000	2014/04
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2011/04/13	.400	2014/04
LEAD	01051	WAIVED	2011/04/13	1.500	
MERCURY	71900	036	2011/04/13	< .200	2014/04
NICKEL	01067	036	2011/04/13	< 10.000	2014/04
PERCHLORATE	A-031	036	2011/09/13	< 4.000	2014/09
SELENIUM	01147	036	2011/04/13	< 2.000	2014/04
THALLIUM	01059	036	2011/04/13	< 1.000	2014/04

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801026***

System Name: ***OPUS ONE WINERY***

PS Code: ***2801026-002***

Source Name: ***WELL 2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/04/13	.460	2012/04	
NITRITE (AS N)	00620	036	**2003/06/17**	.000	**2006/06**	**DUE**
RADIOLOGICAL						
GROSS ALPHA	01501	108	2012/02/13	- .380	2021/02	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2003/06/17	.000		
2,4-D	39730	WAIVED	2003/06/17	.000		
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	036	2011/04/13	< .300	2014/04	
BENTAZON	38710	WAIVED	2003/06/17	.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2011/04/13	.000	2014/04	
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2011/04/13	< 5.000	2014/04	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	036	2011/04/13	< .200	2014/04	
DIQUAT	78885	036	2011/04/13	.000	2014/04	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801026***

System Name: ***OPUS ONE WINERY***

PS Code: ***2801026-002***

Source Name: ***WELL 2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
ENDOTHALL	38926	036	2011/04/13	< 20.000	2014/04	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	000				**DUE**
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**
METHOXYCHLOR	39480	000				**DUE**
MOLINATE	82199	WAIVED	2003/06/17	.000		
OXAMYL	38865	036	2011/04/13	.000	2014/04	
PENTACHLOROPHENOL	39032	036	2011/04/13	< .050	2014/04	
PICLORAM	39720	036	2011/04/13	< .050	2014/04	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2011/04/13	< .300	2014/04	
THIOBENCARB	A-001	WAIVED	2003/06/17	.000		
TOXAPHENE	39400	000				**DUE**
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2003/07/23	.000	2009/07	**DUE**
1,1,2,2-TETRACHLOROETHANE	34516	072	2003/07/23	.000	2009/07	**DUE**
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2003/07/23	.000	2009/07	**DUE**
1,1,2-TRICHLOROETHANE	34511	072	2003/07/23	.000	2009/07	**DUE**
1,1-DICHLOROETHANE	34496	072	2003/07/23	.000	2009/07	**DUE**
1,1-DICHLOROETHYLENE	34501	072	2003/07/23	.000	2009/07	**DUE**
1,2,4-TRICHLOROBENZENE	34551	072	2003/07/23	.000	2009/07	**DUE**
1,2-DICHLOROBENZENE	34536	072	2003/07/23	.000	2009/07	**DUE**
1,2-DICHLOROETHANE	34531	072	2003/07/23	.000	2009/07	**DUE**
1,2-DICHLOROPROPANE	34541	072	2003/07/23	.000	2009/07	**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801026***
System Name: ***OPUS ONE WINERY***

PS Code: ***2801026-002***
Source Name: ***WELL 2***
Source Number: ***002***
Source Status: ***ACTIVE UNTREATED***
Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED VOC						
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2003/07/23	.000	2009/07	DUE
1,4-DICHLOROBENZENE	34571	072	2003/07/23	.000	2009/07	DUE
BENZENE	34030	072	2003/07/23	.000	2009/07	DUE
CARBON TETRACHLORIDE	32102	072	2003/07/23	.000	2009/07	DUE
CIS-1,2-DICHLOROETHYLENE	77093	072	2003/07/23	.000	2009/07	DUE
DICHLOROMETHANE	34423	072	2003/07/23	.000	2009/07	DUE
ETHYLBENZENE	34371	072	2003/07/23	.000	2009/07	DUE
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2011/07/19	< .500	2017/07	
MONOCHLOROBENZENE	34301	072	2003/07/23	.000	2009/07	DUE
STYRENE	77128	072	2003/07/23	.000	2009/07	DUE
TETRACHLOROETHYLENE	34475	072	2003/07/23	.000	2009/07	DUE
TOLUENE	34010	072	2003/07/23	.000	2009/07	DUE
TRANS-1,2-DICHLOROETHYLENE	34546	072	2003/07/23	.000	2009/07	DUE
TRICHLOROETHYLENE	39180	072	2003/07/23	.000	2009/07	DUE
TRICHLOROFLUOROMETHANE	34488	072	2003/07/23	.000	2009/07	DUE
VINYL CHLORIDE	39175	072	2003/07/23	.000	2009/07	DUE
XYLENES (TOTAL)	81551	072	2003/07/23	.000	2009/07	DUE
SECONDARY/GP						
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED				
BICARBONATE ALKALINITY	00440	WAIVED	2011/04/13	233.000		
CALCIUM	00916	WAIVED	2011/04/13	29.400		
CARBONATE ALKALINITY	00445	WAIVED	2011/04/13	< 1.000		
CHLORIDE	00940	WAIVED				
COLOR	00081	WAIVED				
COPPER	01042	WAIVED				
FOAMING AGENTS (MBAS)	38260	WAIVED				
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2011/04/13	171.000		
HYDROXIDE ALKALINITY	71830	WAIVED	2011/04/13	< 1.000		
IRON	01045	WAIVED	2011/04/13	29.000		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801026***

System Name: ***OPUS ONE WINERY***

PS Code: ***2801026-002***

Source Name: ***WELL 2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED	2011/04/13	18.600	
MANGANESE	01055	WAIVED	2011/04/13	< 10.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2011/04/13	7.700	
SILVER	01077	WAIVED	2003/06/17	.000	
SODIUM	00929	WAIVED	2011/04/13	57.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801026-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED

INORGANIC

ALUMINUM	01105	WAIVED
ANTIMONY	01097	WAIVED
ARSENIC	01002	WAIVED
ASBESTOS	81855	WAIVED
BARIUM	01007	WAIVED
BERYLLIUM	01012	WAIVED
CADMIUM	01027	WAIVED
CHROMIUM (TOTAL)	01034	WAIVED
CYANIDE	01291	WAIVED

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801026***

System Name: ***OPUS ONE WINERY***

PS Code: ***2801026-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801026***

System Name: ***OPUS ONE WINERY***

PS Code: ***2801026-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801026***

System Name: ***OPUS ONE WINERY***

PS Code: ***2801026-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801026***

System Name: ***OPUS ONE WINERY***

PS Code: ***2801026-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801026-004***

Source Name: ***WELL 003***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801026***

System Name: ***OPUS ONE WINERY***

PS Code: ***2801026-004***

Source Name: ***WELL 003***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
INORGANIC						
ALUMINUM	01105	000				DUE
ANTIMONY	01097	000				DUE
ARSENIC	01002	000				DUE
ASBESTOS	81855	000				DUE
BARIUM	01007	000				DUE
BERYLLIUM	01012	000				DUE
CADMIUM	01027	000				DUE
CHROMIUM (TOTAL)	01034	000				DUE
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				DUE
LEAD	01051	WAIVED				
MERCURY	71900	000				DUE
NICKEL	01067	000				DUE
PERCHLORATE	A-031	006				DUE
SELENIUM	01147	000				DUE
THALLIUM	01059	000				DUE
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	000				DUE
NITRITE (AS N)	00620	000				DUE
RADIOLOGICAL						
GROSS ALPHA	01501	108	2011/10/17	- .570	2020/10	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801026***

System Name: ***OPUS ONE WINERY***

PS Code: ***2801026-004***

Source Name: ***WELL 003***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	000			DUE
2,4-D	39730	000			DUE
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	000			DUE
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	000			DUE
CHLORDANE	39350	WAIVED			
DALAPON	38432	000			DUE
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	000			DUE
DIQUAT	78885	000			DUE
ENDOTHALL	38926	000			DUE
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	000			DUE
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	000			DUE
HEPTACHLOR EPOXIDE	39420	000			DUE
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	000			DUE
METHOXYCHLOR	39480	000			DUE
MOLINATE	82199	WAIVED			
OXAMYL	38865	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801026***

System Name: ***OPUS ONE WINERY***

PS Code: ***2801026-004***

Source Name: ***WELL 003***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
PENTACHLOROPHENOL	39032	000			DUE
PICLORAM	39720	000			DUE
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	000			DUE
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	000			DUE
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	000			DUE
1,1,2,2-TETRACHLOROETHANE	34516	000			DUE
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	000			DUE
1,1,2-TRICHLOROETHANE	34511	000			DUE
1,1-DICHLOROETHANE	34496	000			DUE
1,1-DICHLOROETHYLENE	34501	000			DUE
1,2,4-TRICHLOROBENZENE	34551	000			DUE
1,2-DICHLOROBENZENE	34536	000			DUE
1,2-DICHLOROETHANE	34531	000			DUE
1,2-DICHLOROPROPANE	34541	000			DUE
1,3-DICHLOROPROPENE (TOTAL)	34561	000			DUE
1,4-DICHLOROBENZENE	34571	000			DUE
BENZENE	34030	000			DUE
CARBON TETRACHLORIDE	32102	000			DUE
CIS-1,2-DICHLOROETHYLENE	77093	000			DUE
DICHLOROMETHANE	34423	000			DUE
ETHYLBENZENE	34371	000			DUE
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	000			DUE
MONOCHLOROBENZENE	34301	000			DUE
STYRENE	77128	000			DUE
TETRACHLOROETHYLENE	34475	000			DUE
TOLUENE	34010	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801026***

System Name: ***OPUS ONE WINERY***

PS Code: ***2801026-004***

Source Name: ***WELL 003***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
TRANS-1,2-DICHLOROETHYLENE	34546	000			DUE
TRICHLOROETHYLENE	39180	000			DUE
TRICHLOROFLUOROMETHANE	34488	000			DUE
VINYL CHLORIDE	39175	000			DUE
XYLENES (TOTAL)	81551	000			DUE
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801027***

System Name: ***PEJU PROVINCE***

PS Code: ***2801027-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED	2009/04/28	< .200	
INORGANIC					
ALUMINUM	01105	036	2009/04/28	440.000	2012/04
ANTIMONY	01097	036	2009/04/28	< 2.000	2012/04
ARSENIC	01002	036	2009/04/28	< 2.000	2012/04
ASBESTOS	81855	108	2009/04/28	.000	2018/04
BARIUM	01007	036	2009/04/28	140.000	2012/04
BERYLLIUM	01012	036	2009/04/28	2.000	2012/04
CADMIUM	01027	036	2009/04/28	2.000	2012/04
CHROMIUM (TOTAL)	01034	036	2009/04/28	11.000	2012/04
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2009/04/28	< .100	2012/04
LEAD	01051	WAIVED	2009/04/28	1.600	
MERCURY	71900	036	2009/04/28	< .200	2012/04
NICKEL	01067	036	2009/04/28	30.000	2012/04
PERCHLORATE	A-031	036	2010/08/31	< 4.000	2013/08
SELENIUM	01147	036	2009/04/28	< 2.000	2012/04
THALLIUM	01059	036	2009/04/28	< 1.000	2012/04
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2012/04/24	< 2.000	2013/04
NITRITE (AS N)	00620	036	2012/04/24	< 400.000	2015/04
RADIOLOGICAL					
GROSS ALPHA	01501	108	2010/10/06	- .080	2019/10
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801027***

System Name: ***PEJU PROVINCE***

PS Code: ***2801027-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2009/11/03	< .070	
2,4-D	39730	WAIVED	2009/11/03	< .400	
ALACHLOR	77825	WAIVED	2009/04/28	< .200	
ATRAZINE	39033	036	2009/04/28	< .300	2012/04
BENTAZON	38710	WAIVED	2009/11/03	< .800	
BENZO (A) PYRENE	34247	WAIVED	2009/04/28	< .100	
CARBOFURAN	81405	036	2009/04/28	< 5.000	2012/04
CHLORDANE	39350	WAIVED	2009/04/28	< .500	
DALAPON	38432	036	2009/11/03	< 5.000	2012/11
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED	2009/04/28	< 1.000	
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED	2009/04/28	< 3.000	
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2009/09/03	< .010	
DINOSEB	81287	036	2009/11/03	< .200	2012/11
DIQUAT	78885	036	2009/04/28	< 4.000	2012/04
ENDOTHALL	38926	036	2009/04/28	< .000	2012/04
ENDRIN	39390	WAIVED	2009/04/28	< .005	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2009/09/03	< .020	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2009/04/28	< .005	
HEPTACHLOR EPOXIDE	39420	WAIVED	2009/04/28	< .005	
HEXACHLOROBENZENE	39700	WAIVED	2009/04/28	< .100	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2009/04/28	< 1.000	
LINDANE	39340	WAIVED	2009/04/28	< .005	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801027***

System Name: ***PEJU PROVINCE***

PS Code: ***2801027-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED	2009/04/28	< .005	
MOLINATE	82199	WAIVED	2009/04/28	< .500	
OXAMYL	38865	036	2009/04/28	< 20.000	2012/04
PENTACHLOROPHENOL	39032	036	2009/11/03	< .050	2012/11
PICLORAM	39720	036	2009/11/03	< .050	2012/11
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2009/04/28	< .200	
SIMAZINE	39055	036	2009/04/28	< .300	2012/04
THIOBENCARB	A-001	WAIVED	2009/04/28	< .500	
TOXAPHENE	39400	WAIVED	2009/04/28	< 2.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	072	2009/04/28	< .500	2015/04
1,1,2,2-TETRACHLOROETHANE	34516	072	2009/04/28	< .500	2015/04
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2009/04/28	< .500	2015/04
1,1,2-TRICHLOROETHANE	34511	072	2009/04/28	< .500	2015/04
1,1-DICHLOROETHANE	34496	072	2009/04/28	< .500	2015/04
1,1-DICHLOROETHYLENE	34501	072	2009/04/28	< .500	2015/04
1,2,4-TRICHLOROBENZENE	34551	072	2009/04/28	< .500	2015/04
1,2-DICHLOROBENZENE	34536	072	2009/04/28	< .500	2015/04
1,2-DICHLOROETHANE	34531	072	2009/04/28	< .500	2015/04
1,2-DICHLOROPROPANE	34541	072	2009/04/28	< .500	2015/04
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2009/04/28	< .500	2015/04
1,4-DICHLOROBENZENE	34571	072	2009/04/28	< .500	2015/04
BENZENE	34030	072	2009/04/28	< .500	2015/04
CARBON TETRACHLORIDE	32102	072	2009/04/28	< .500	2015/04
CIS-1,2-DICHLOROETHYLENE	77093	072	2009/04/28	< .500	2015/04
DICHLOROMETHANE	34423	072	2009/04/28	< .500	2015/04
ETHYLBENZENE	34371	072	2009/04/28	< .500	2015/04
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2009/04/28	< .500	2015/04
MONOCHLOROBENZENE	34301	072	2009/04/28	< .500	2015/04

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801027***

System Name: ***PEJU PROVINCE***

PS Code: ***2801027-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2009/04/28	< .500	2015/04
TETRACHLOROETHYLENE	34475	072	2009/04/28	< .500	2015/04
TOLUENE	34010	072	2009/04/28	< .500	2015/04
TRANS-1,2-DICHLOROETHYLENE	34546	072	2009/04/28	< .500	2015/04
TRICHLOROETHYLENE	39180	072	2009/04/28	< .500	2015/04
TRICHLOROFLUOROMETHANE	34488	072	2009/04/28	< .500	2015/04
VINYL CHLORIDE	39175	072	2009/04/28	< .500	2015/04
XYLENES (TOTAL)	81551	072	2009/04/28	< 1.000	2015/04
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2009/04/28	121.000	
CALCIUM	00916	WAIVED	2009/04/28	72.300	
CARBONATE ALKALINITY	00445	WAIVED	2009/04/28	< 1.000	
CHLORIDE	00940	WAIVED	2009/04/28	30.400	
COLOR	00081	WAIVED			
COPPER	01042	WAIVED	2009/04/28	< 50.000	
FOAMING AGENTS (MBAS)	38260	WAIVED	2009/04/28	< .100	
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2009/04/28	308.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2009/04/28	< 1.000	
IRON	01045	WAIVED	2009/04/28	1130.000	
MAGNESIUM	00927	WAIVED	2009/04/28	31.000	
MANGANESE	01055	WAIVED	2009/04/28	102.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2009/04/28	6.200	
SILVER	01077	WAIVED	2009/04/28	< 10.000	
SODIUM	00929	WAIVED	2009/04/28	18.000	
SPECIFIC CONDUCTANCE	00095	WAIVED	2009/04/28	498.000	
SULFATE	00945	WAIVED	2009/04/28	85.600	
TOTAL DISSOLVED SOLIDS	70300	WAIVED	2009/04/28	327.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801027***

System Name: ***PEJU PROVINCE***

PS Code: ***2801027-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED	2009/04/28	710.000	

PS Code: ***2801027-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED	2009/07/07	< .200	
INORGANIC					
ALUMINUM	01105	WAIVED	2009/04/28	70.000	
ANTIMONY	01097	WAIVED	2009/04/28	< 2.000	
ARSENIC	01002	WAIVED	2009/04/28	< 2.000	
ASBESTOS	81855	WAIVED	2009/04/28	.000	
BARIUM	01007	WAIVED	2009/04/28	100.000	
BERYLLIUM	01012	WAIVED	2009/04/28	2.000	
CADMIUM	01027	WAIVED	2009/04/28	2.000	
CHROMIUM (TOTAL)	01034	WAIVED	2009/04/28	< 10.000	
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2009/04/28	.300	
LEAD	01051	WAIVED	2009/04/28	1.600	
MERCURY	71900	WAIVED	2009/04/28	< .200	
NICKEL	01067	WAIVED	2009/04/28	22.000	
PERCHLORATE	A-031	WAIVED	2009/10/20	< 4.000	
SELENIUM	01147	WAIVED	2009/04/28	< 2.000	
THALLIUM	01059	WAIVED	2009/04/28	< 1.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801027***

System Name: ***PEJU PROVINCE***

PS Code: ***2801027-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED	2009/04/28	< 2.000	
NITRITE (AS N)	00620	WAIVED	2009/04/28	< 400.000	
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED	2009/07/07	- .020	
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2009/07/07	< .070	
2,4-D	39730	WAIVED	2009/07/07	< .400	
ALACHLOR	77825	WAIVED	2009/07/07	< .200	
ATRAZINE	39033	WAIVED	2009/07/07	< .300	
BENTAZON	38710	WAIVED	2009/07/07	< .800	
BENZO (A) PYRENE	34247	WAIVED	2009/07/07	< .100	
CARBOFURAN	81405	WAIVED	2009/07/07	< 5.000	
CHLORDANE	39350	WAIVED	2009/07/07	< .500	
DALAPON	38432	WAIVED	2009/07/07	< 5.000	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED	2009/07/07	< 1.000	
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED	2009/07/07	< 3.000	
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2009/07/07	< 1.000	
DINOSEB	81287	WAIVED	2009/07/07	< .200	
DIQUAT	78885	WAIVED	2009/07/07	< 4.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801027***

System Name: ***PEJU PROVINCE***

PS Code: ***2801027-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED	2009/07/07	< 45.000	
ENDRIN	39390	WAIVED	2009/07/07	< .005	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2009/07/07	< .020	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2009/07/07	< .005	
HEPTACHLOR EPOXIDE	39420	WAIVED	2009/07/07	< .005	
HEXACHLOROBENZENE	39700	WAIVED	2009/07/07	< .100	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2009/07/07	< 1.000	
LINDANE	39340	WAIVED	2009/07/07	< .005	
METHOXYCHLOR	39480	WAIVED	2009/07/07	< .005	
MOLINATE	82199	WAIVED	2009/07/07	< .500	
OXAMYL	38865	WAIVED	2009/07/07	< 20.000	
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2009/07/07	< .200	
SIMAZINE	39055	WAIVED	2009/07/07	< .300	
THIOBENCARB	A-001	WAIVED	2009/07/07	< .500	
TOXAPHENE	39400	WAIVED	2009/07/07	< 2.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED	2009/07/07	< .500	
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED	2009/07/07	< .500	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED	2009/07/07	< .500	
1,1,2-TRICHLOROETHANE	34511	WAIVED	2009/07/07	< .500	
1,1-DICHLOROETHANE	34496	WAIVED	2009/07/07	< .500	
1,1-DICHLOROETHYLENE	34501	WAIVED	2009/07/07	< .500	
1,2,4-TRICHLOROBENZENE	34551	WAIVED	2009/07/07	< .500	
1,2-DICHLOROBENZENE	34536	WAIVED	2009/07/07	< .500	
1,2-DICHLOROETHANE	34531	WAIVED	2009/07/07	< .500	
1,2-DICHLOROPROPANE	34541	WAIVED	2009/07/07	< .500	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801027***

System Name: ***PEJU PROVINCE***

PS Code: ***2801027-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED	2009/07/07	< .500	
1,4-DICHLOROBENZENE	34571	WAIVED	2009/07/07	< .500	
BENZENE	34030	WAIVED	2009/07/07	< .500	
CARBON TETRACHLORIDE	32102	WAIVED	2009/07/07	< .500	
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED	2009/07/07	< .500	
DICHLOROMETHANE	34423	WAIVED	2009/07/07	< .500	
ETHYLBENZENE	34371	WAIVED	2009/07/07	< .500	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED	2009/07/07	< .500	
MONOCHLOROBENZENE	34301	WAIVED	2009/07/07	< .500	
STYRENE	77128	WAIVED	2009/07/07	< .500	
TETRACHLOROETHYLENE	34475	WAIVED	2009/07/07	< .500	
TOLUENE	34010	WAIVED	2009/07/07	< .500	
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED	2009/07/07	< .500	
TRICHLOROETHYLENE	39180	WAIVED	2009/07/07	< .500	
TRICHLOROFLUOROMETHANE	34488	WAIVED	2009/07/07	< .500	
VINYL CHLORIDE	39175	WAIVED	2009/07/07	< .500	
XYLENES (TOTAL)	81551	WAIVED	2009/07/07	< 1.000	
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2009/04/28	220.000	
CALCIUM	00916	WAIVED	2009/04/28	34.700	
CARBONATE ALKALINITY	00445	WAIVED	2009/04/28	< 1.000	
CHLORIDE	00940	WAIVED	2009/04/28	5.000	
COLOR	00081	WAIVED			
COPPER	01042	WAIVED	2009/04/28	52.000	
FOAMING AGENTS (MBAS)	38260	WAIVED	2009/04/28	< .100	
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2009/04/28	155.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2009/04/28	< 1.000	
IRON	01045	WAIVED	2009/04/28	1470.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801027***

System Name: ***PEJU PROVINCE***

PS Code: ***2801027-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED	2009/04/28	16.500	
MANGANESE	01055	WAIVED	2009/04/28	622.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2009/04/28	6.900	
SILVER	01077	WAIVED	2009/04/28	< 10.000	
SODIUM	00929	WAIVED	2009/04/28	41.000	
SPECIFIC CONDUCTANCE	00095	WAIVED	2009/04/28	429.000	
SULFATE	00945	WAIVED	2009/04/28	17.300	
TOTAL DISSOLVED SOLIDS	70300	WAIVED	2009/04/28	290.000	
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED	2009/04/28	442.000	

PS Code: ***2801027-003***

Source Name: ***WELL 2***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***SURFACE***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED			

INORGANIC

ALUMINUM	01105	000			**DUE**
ANTIMONY	01097	000			**DUE**
ARSENIC	01002	000			**DUE**
ASBESTOS	81855	000			**DUE**
BARIUM	01007	000			**DUE**
BERYLLIUM	01012	000			**DUE**
CADMIUM	01027	000			**DUE**
CHROMIUM (TOTAL)	01034	000			**DUE**
CYANIDE	01291	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801027***

System Name: ***PEJU PROVINCE***

PS Code: ***2801027-003***

Source Name: ***WELL 2***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
INORGANIC						
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				DUE
LEAD	01051	WAIVED				
MERCURY	71900	000				DUE
NICKEL	01067	000				DUE
PERCHLORATE	A-031	036	2010/08/31	< 4.000	2013/08	
SELENIUM	01147	000				DUE
THALLIUM	01059	000				DUE
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2012/04/24	< 2.000	2013/04	
NITRITE (AS N)	00620	036	2012/04/24	< 400.000	2015/04	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2010/10/06	.150	2019/10	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2010/02/10	< .070		
2,4-D	39730	WAIVED	2010/02/10	< .400		
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	000				DUE
BENTAZON	38710	WAIVED	2010/02/10	< .800		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801027***

System Name: ***PEJU PROVINCE***

PS Code: ***2801027-003***

Source Name: ***WELL 2***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	000				**DUE**
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2010/02/10	< 5.000	2013/02	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	036	2010/02/10	< .200	2013/02	
DIQUAT	78885	000				**DUE**
ENDOTHALL	38926	000				**DUE**
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	000				**DUE**
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**
METHOXYCHLOR	39480	000				**DUE**
MOLINATE	82199	WAIVED				
OXAMYL	38865	000				**DUE**
PENTACHLOROPHENOL	39032	036	2010/02/10	< .050	2013/02	
PICLORAM	39720	036	2010/02/10	< .050	2013/02	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	000				**DUE**
THIOBENCARB	A-001	WAIVED				
TOXAPHENE	39400	000				**DUE**
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	000				**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801027***

System Name: ***PEJU PROVINCE***

PS Code: ***2801027-003***

Source Name: ***WELL 2***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	000			DUE
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	000			DUE
1,1,2-TRICHLOROETHANE	34511	000			DUE
1,1-DICHLOROETHANE	34496	000			DUE
1,1-DICHLOROETHYLENE	34501	000			DUE
1,2,4-TRICHLOROBENZENE	34551	000			DUE
1,2-DICHLOROBENZENE	34536	000			DUE
1,2-DICHLOROETHANE	34531	000			DUE
1,2-DICHLOROPROPANE	34541	000			DUE
1,3-DICHLOROPROPENE (TOTAL)	34561	000			DUE
1,4-DICHLOROBENZENE	34571	000			DUE
BENZENE	34030	000			DUE
CARBON TETRACHLORIDE	32102	000			DUE
CIS-1,2-DICHLOROETHYLENE	77093	000			DUE
DICHLOROMETHANE	34423	000			DUE
ETHYLBENZENE	34371	000			DUE
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	000			DUE
MONOCHLOROBENZENE	34301	000			DUE
STYRENE	77128	000			DUE
TETRACHLOROETHYLENE	34475	000			DUE
TOLUENE	34010	000			DUE
TRANS-1,2-DICHLOROETHYLENE	34546	000			DUE
TRICHLOROETHYLENE	39180	000			DUE
TRICHLOROFLUOROMETHANE	34488	000			DUE
VINYL CHLORIDE	39175	000			DUE
XYLENES (TOTAL)	81551	000			DUE
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801027***

System Name: ***PEJU PROVINCE***

PS Code: ***2801027-003***

Source Name: ***WELL 2***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***SURFACE***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801027-004***

Source Name: ***WELL 3***

Source Number: ***004***

Source Status: ***STANDBY UNTREATED***

Water type: ***SURFACE***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801027***

System Name: ***PEJU PROVINCE***

PS Code: ***2801027-004***

Source Name: ***WELL 3***

Source Number: ***004***

Source Status: ***STANDBY UNTREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
INORGANIC						
ALUMINUM	01105	000				DUE
ANTIMONY	01097	000				DUE
ARSENIC	01002	000				DUE
ASBESTOS	81855	000				DUE
BARIUM	01007	000				DUE
BERYLLIUM	01012	000				DUE
CADMIUM	01027	000				DUE
CHROMIUM (TOTAL)	01034	000				DUE
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				DUE
LEAD	01051	WAIVED				
MERCURY	71900	000				DUE
NICKEL	01067	000				DUE
PERCHLORATE	A-031	108	2010/08/31	< 4.000	2019/08	
SELENIUM	01147	000				DUE
THALLIUM	01059	000				DUE
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	000				DUE
NITRITE (AS N)	00620	000				DUE
RADIOLOGICAL						
GROSS ALPHA	01501	108	2010/10/06	.320	2019/10	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801027***

System Name: ***PEJU PROVINCE***

PS Code: ***2801027-004***

Source Name: ***WELL 3***

Source Number: ***004***

Source Status: ***STANDBY UNTREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2010/06/16	< .070		
2,4-D	39730	WAIVED	2010/06/16	< .400		
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	000				**DUE**
BENTAZON	38710	WAIVED	2010/06/16	< .800		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	000				**DUE**
CHLORDANE	39350	WAIVED				
DALAPON	38432	WAIVED	2010/06/16	< 5.000		
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	WAIVED	2010/06/16	< .200		
DIQUAT	78885	000				**DUE**
ENDOTHALL	38926	000				**DUE**
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	000				**DUE**
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**
METHOXYCHLOR	39480	000				**DUE**
MOLINATE	82199	WAIVED				
OXAMYL	38865	000				**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801027***

System Name: ***PEJU PROVINCE***

PS Code: ***2801027-004***

Source Name: ***WELL 3***

Source Number: ***004***

Source Status: ***STANDBY UNTREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
PENTACHLOROPHENOL	39032	000			DUE
PICLORAM	39720	WAIVED	2010/06/16	< .050	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	000			DUE
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	000			DUE
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	000			DUE
1,1,2,2-TETRACHLOROETHANE	34516	000			DUE
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	000			DUE
1,1,2-TRICHLOROETHANE	34511	000			DUE
1,1-DICHLOROETHANE	34496	000			DUE
1,1-DICHLOROETHYLENE	34501	000			DUE
1,2,4-TRICHLOROBENZENE	34551	000			DUE
1,2-DICHLOROBENZENE	34536	000			DUE
1,2-DICHLOROETHANE	34531	000			DUE
1,2-DICHLOROPROPANE	34541	000			DUE
1,3-DICHLOROPROPENE (TOTAL)	34561	000			DUE
1,4-DICHLOROBENZENE	34571	000			DUE
BENZENE	34030	000			DUE
CARBON TETRACHLORIDE	32102	000			DUE
CIS-1,2-DICHLOROETHYLENE	77093	000			DUE
DICHLOROMETHANE	34423	000			DUE
ETHYLBENZENE	34371	000			DUE
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	000			DUE
MONOCHLOROBENZENE	34301	000			DUE
STYRENE	77128	000			DUE
TETRACHLOROETHYLENE	34475	000			DUE
TOLUENE	34010	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801027***

System Name: ***PEJU PROVINCE***

PS Code: ***2801027-004***

Source Name: ***WELL 3***

Source Number: ***004***

Source Status: ***STANDBY UNTREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
TRANS-1,2-DICHLOROETHYLENE	34546	000			DUE
TRICHLOROETHYLENE	39180	000			DUE
TRICHLOROFLUOROMETHANE	34488	000			DUE
VINYL CHLORIDE	39175	000			DUE
XYLENES (TOTAL)	81551	000			DUE
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	000			DUE
COLOR	00081	000			DUE
COPPER	01042	000			DUE
FOAMING AGENTS (MBAS)	38260	000			DUE
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	000			DUE
PH, LABORATORY	00403	000			DUE
SILVER	01077	000			DUE
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	000			DUE
SULFATE	00945	000			DUE
TOTAL DISSOLVED SOLIDS	70300	000			DUE
TURBIDITY, LABORATORY	82079	000			DUE
ZINC	01092	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801028***

System Name: ***CARDINALE ESTATE***

PS Code: ***2801028-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2006/02/10	.000		
INORGANIC						
ALUMINUM	01105	036	2009/10/27	.000	2012/10	
ANTIMONY	01097	036	2009/10/27	.000	2012/10	
ARSENIC	01002	036	2009/10/27	7.600	2012/10	
ASBESTOS	81855	108	2009/10/27	.000	2018/10	
BARIUM	01007	036	2009/10/27	.000	2012/10	
BERYLLIUM	01012	036	2009/10/27	.000	2012/10	
CADMIUM	01027	036	2009/10/27	.000	2012/10	
CHROMIUM (TOTAL)	01034	036	2009/10/27	.000	2012/10	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2009/10/27	.110	2012/10	
LEAD	01051	WAIVED	2009/10/27	.000		
MERCURY	71900	036	2009/10/27	.000	2012/10	
NICKEL	01067	036	2009/10/27	.000	2012/10	
PERCHLORATE	A-031	006	**2010/06/25**	.000	**2010/12**	**DUE**
SELENIUM	01147	036	2009/10/27	.000	2012/10	
THALLIUM	01059	036	2009/10/27	.000	2012/10	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	**2009/10/27**	.000	**2010/10**	**DUE**
NITRITE (AS N)	00620	036	2009/10/27	.000	2012/10	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2011/01/05	.890	2020/01	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801028***

System Name: ***CARDINALE ESTATE***

PS Code: ***2801028-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2009/10/27	.000		
2,4-D	39730	WAIVED	2009/10/27	.000		
ALACHLOR	77825	WAIVED	2009/10/27	.000		
ATRAZINE	39033	036	2009/10/27	.000	2012/10	
BENTAZON	38710	WAIVED	2009/10/27	.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2009/10/27	.000	2012/10	
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2009/10/27	.000	2012/10	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2009/10/27	.000		
DINOSEB	81287	036	2009/10/27	.000	2012/10	
DIQUAT	78885	036	2009/10/27	.000	2012/10	
ENDOTHALL	38926	036	2009/10/27	.000	2012/10	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2009/10/27	.000		
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801028***

System Name: ***CARDINALE ESTATE***

PS Code: ***2801028-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	000				**DUE**
MOLINATE	82199	WAIVED	2006/02/10	.000		
OXAMYL	38865	036	2009/10/27	.000	2012/10	
PENTACHLOROPHENOL	39032	036	2009/10/27	.000	2012/10	
PICLORAM	39720	036	2009/10/27	.000	2012/10	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2009/10/27	.000	2012/10	
THIOBENCARB	A-001	WAIVED	2006/02/10	.000		
TOXAPHENE	39400	000				**DUE**
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2009/10/27	.000	2015/10	
1,1,2,2-TETRACHLOROETHANE	34516	072	2009/10/27	.000	2015/10	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2009/10/27	.000	2015/10	
1,1,2-TRICHLOROETHANE	34511	072	2009/10/27	.000	2015/10	
1,1-DICHLOROETHANE	34496	072	2009/10/27	.000	2015/10	
1,1-DICHLOROETHYLENE	34501	072	2009/10/27	.000	2015/10	
1,2,4-TRICHLOROBENZENE	34551	072	2009/10/27	.000	2015/10	
1,2-DICHLOROBENZENE	34536	072	2009/10/27	.000	2015/10	
1,2-DICHLOROETHANE	34531	072	2009/10/27	.000	2015/10	
1,2-DICHLOROPROPANE	34541	072	2009/10/27	.000	2015/10	
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2009/10/27	.000	2015/10	
1,4-DICHLOROBENZENE	34571	072	2009/10/27	.000	2015/10	
BENZENE	34030	072	2009/10/27	.000	2015/10	
CARBON TETRACHLORIDE	32102	072	2009/10/27	.000	2015/10	
CIS-1,2-DICHLOROETHYLENE	77093	072	2009/10/27	.000	2015/10	
DICHLOROMETHANE	34423	072	2009/10/27	.000	2015/10	
ETHYLBENZENE	34371	072	2009/10/27	.000	2015/10	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2009/10/27	.000	2015/10	
MONOCHLOROBENZENE	34301	072	2009/10/27	.000	2015/10	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801028***

System Name: ***CARDINALE ESTATE***

PS Code: ***2801028-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2009/10/27	.000	2015/10
TETRACHLOROETHYLENE	34475	072	2009/10/27	.000	2015/10
TOLUENE	34010	072	2009/10/27	.000	2015/10
TRANS-1,2-DICHLOROETHYLENE	34546	072	2009/10/27	.000	2015/10
TRICHLOROETHYLENE	39180	072	2009/10/27	.000	2015/10
TRICHLOROFLUOROMETHANE	34488	072	2009/10/27	.000	2015/10
VINYL CHLORIDE	39175	072	2009/10/27	.000	2015/10
XYLENES (TOTAL)	81551	072	2009/10/27	.000	2015/10
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2009/10/27	230.000	
CALCIUM	00916	WAIVED	2009/10/27	33.000	
CARBONATE ALKALINITY	00445	WAIVED	2009/10/27	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2009/10/27	160.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2009/10/27	.000	
IRON	01045	WAIVED	2009/10/27	.000	
MAGNESIUM	00927	WAIVED	2009/10/27	17.000	
MANGANESE	01055	WAIVED	2009/10/27	88.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2009/10/27	7.600	
SILVER	01077	WAIVED	2009/10/27	.000	
SODIUM	00929	WAIVED	2009/10/27	40.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801028***

System Name: ***CARDINALE ESTATE***

PS Code: ***2801028-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801028-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED	2006/06/19	.000	
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801028***

System Name: ***CARDINALE ESTATE***

PS Code: ***2801028-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801028***

System Name: ***CARDINALE ESTATE***

PS Code: ***2801028-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801028***

System Name: ***CARDINALE ESTATE***

PS Code: ***2801028-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801028***

System Name: ***CARDINALE ESTATE***

PS Code: ***2801028-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2801029
System Name: PINE RIDGE WINERY

PS Code: 2801029-002
Source Name: WELL #2 SOUTH
Source Number: 002
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2005/01/04	.000		
INORGANIC						
ALUMINUM	01105	036	2008/02/13	.000	2011/02	DUE
ANTIMONY	01097	036	2008/02/13	.000	2011/02	DUE
ARSENIC	01002	036	2008/02/13	220.000	2011/02	DUE
ASBESTOS	81855	108	2007/09/17	.400	2016/09	
BARIUM	01007	036	2008/02/13	.000	2011/02	DUE
BERYLLIUM	01012	036	2008/02/13	.000	2011/02	DUE
CADMIUM	01027	036	2008/02/13	.000	2011/02	DUE
CHROMIUM (TOTAL)	01034	036	2008/02/13	.000	2011/02	DUE
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2008/02/13	.400	2011/02	DUE
LEAD	01051	WAIVED	2008/02/13	.000		
MERCURY	71900	036	2008/02/13	.000	2011/02	DUE
NICKEL	01067	036	2008/02/13	12.000	2011/02	DUE
PERCHLORATE	A-031	036	2011/02/09	< .200	2014/02	
SELENIUM	01147	036	2008/02/13	.000	2011/02	DUE
THALLIUM	01059	036	2008/02/13	.000	2011/02	DUE
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2010/08/09	.000	2011/08	DUE
NITRITE (AS N)	00620	036	2008/02/14	.000	2011/02	DUE
RADIOLOGICAL						
GROSS ALPHA	01501	108	2008/11/04	< 3.000	2017/11	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED	2008/11/04	< 1.000		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801029***

System Name: ***PINE RIDGE WINERY***

PS Code: ***2801029-002***

Source Name: ***WELL #2 SOUTH***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED	2011/02/09	.000	
2,4,5-TP (SILVEX)	39045	WAIVED	2011/02/09	.000	
2,4-D	39730	WAIVED	2011/02/09	.000	
ALACHLOR	77825	WAIVED	2005/01/04	.000	
ATRAZINE	39033	036	2011/02/09	.000	2014/02
BENTAZON	38710	WAIVED	2008/02/13	< .500	
BENZO (A) PYRENE	34247	WAIVED	2005/01/04	.000	
CARBOFURAN	81405	036	2011/02/09	.000	2014/02
CHLORDANE	39350	WAIVED	2005/01/04	.000	
DALAPON	38432	036	2011/02/09	.000	2014/02
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED	2005/01/04	.000	
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED	2005/01/04	.000	
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2011/02/09	.000	
DINOSEB	81287	036	2011/02/09	.000	2014/02
DIQUAT	78885	036	2011/02/09	.000	2014/02
ENDOTHALL	38926	036	2011/02/09	.000	2014/02
ENDRIN	39390	WAIVED	2005/01/04	.000	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2011/02/09	.000	
GLYPHOSATE	79743	WAIVED	2005/01/04	.000	
HEPTACHLOR	39410	WAIVED	2011/02/09	.000	
HEPTACHLOR EPOXIDE	39420	WAIVED	2011/02/09	.000	
HEXACHLOROBENZENE	39700	WAIVED	2005/01/04	.000	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2005/01/04	.000	
LINDANE	39340	WAIVED	2011/02/09	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801029***

System Name: ***PINE RIDGE WINERY***

PS Code: ***2801029-002***

Source Name: ***WELL #2 SOUTH***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED	2011/02/09	.000	
MOLINATE	82199	WAIVED	2005/01/04	.000	
OXAMYL	38865	036	2011/02/09	.000	2014/02
PENTACHLOROPHENOL	39032	036	2011/02/09	.000	2014/02
PICLORAM	39720	036	2011/02/09	.000	2014/02
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2005/01/04	.000	
SIMAZINE	39055	036	2011/02/09	.000	2014/02
THIOBENCARB	A-001	WAIVED	2005/01/04	.000	
TOXAPHENE	39400	WAIVED	2011/02/09	.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	072	2010/02/09	.000	2016/02
1,1,2,2-TETRACHLOROETHANE	34516	072	2010/02/09	.000	2016/02
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2010/02/09	.000	2016/02
1,1,2-TRICHLOROETHANE	34511	072	2010/02/09	.000	2016/02
1,1-DICHLOROETHANE	34496	072	2010/02/09	.000	2016/02
1,1-DICHLOROETHYLENE	34501	072	2010/02/09	.000	2016/02
1,2,4-TRICHLOROBENZENE	34551	072	2010/02/09	.000	2016/02
1,2-DICHLOROBENZENE	34536	072	2010/02/09	.000	2016/02
1,2-DICHLOROETHANE	34531	072	2010/02/09	.000	2016/02
1,2-DICHLOROPROPANE	34541	072	2010/02/09	.000	2016/02
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2010/02/09	.000	2016/02
1,4-DICHLOROBENZENE	34571	072	2010/02/09	.000	2016/02
BENZENE	34030	072	2010/02/09	.000	2016/02
CARBON TETRACHLORIDE	32102	072	2010/02/09	.000	2016/02
CIS-1,2-DICHLOROETHYLENE	77093	072	2010/02/09	.000	2016/02
DICHLOROMETHANE	34423	072	2010/02/09	.000	2016/02
ETHYLBENZENE	34371	072	2010/02/09	.000	2016/02
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2011/02/09	.000	2017/02
MONOCHLOROBENZENE	34301	072	2010/02/09	.000	2016/02

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801029***

System Name: ***PINE RIDGE WINERY***

PS Code: ***2801029-002***

Source Name: ***WELL #2 SOUTH***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2010/02/09	.000	2016/02
TETRACHLOROETHYLENE	34475	072	2010/02/09	.000	2016/02
TOLUENE	34010	072	2010/02/09	.000	2016/02
TRANS-1,2-DICHLOROETHYLENE	34546	072	2010/02/09	.000	2016/02
TRICHLOROETHYLENE	39180	072	2010/02/09	.000	2016/02
TRICHLOROFLUOROMETHANE	34488	072	2010/02/09	.000	2016/02
VINYL CHLORIDE	39175	072	2010/02/09	.000	2016/02
XYLENES (TOTAL)	81551	072	2010/02/09	.000	2016/02
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2005/01/04	100.000	
CALCIUM	00916	WAIVED	2011/02/09	49.000	
CARBONATE ALKALINITY	00445	WAIVED	2005/01/04	.000	
CHLORIDE	00940	WAIVED	2008/02/13	7.200	
COLOR	00081	WAIVED	2008/02/13	3.000	
COPPER	01042	WAIVED	2008/02/13	.000	
FOAMING AGENTS (MBAS)	38260	WAIVED	2008/02/13	.000	
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2011/02/09	170.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2005/01/04	.000	
IRON	01045	WAIVED	2008/02/13	2200.000	
MAGNESIUM	00927	WAIVED	2011/02/09	20.000	
MANGANESE	01055	WAIVED	2008/02/13	180.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED	2008/02/13	.000	
PH, LABORATORY	00403	WAIVED	2008/02/13	6.200	
SILVER	01077	WAIVED	2008/02/13	.000	
SODIUM	00929	WAIVED	2011/02/09	23.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED	2008/02/13	130.000	
TOTAL DISSOLVED SOLIDS	70300	WAIVED	2008/02/13	300.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801029***

System Name: ***PINE RIDGE WINERY***

PS Code: ***2801029-002***

Source Name: ***WELL #2 SOUTH***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED	2008/02/13	1.000	
ZINC	01092	WAIVED	2008/02/13	.000	

PS Code: ***2801029-003***

Source Name: ***WELL 003***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED	2005/01/04	.000	
INORGANIC					
ALUMINUM	01105	036	2011/02/09	.000	2014/02
ANTIMONY	01097	036	2011/02/09	.000	2014/02
ARSENIC	01002	036	2011/02/09	50.000	2014/02
ASBESTOS	81855	108	2007/09/17	.990	2016/09
BARIUM	01007	036	2011/02/09	.000	2014/02
BERYLLIUM	01012	036	2011/02/09	.000	2014/02
CADMIUM	01027	036	2011/02/09	.000	2014/02
CHROMIUM (TOTAL)	01034	036	2011/02/09	.000	2014/02
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2011/02/09	.510	2014/02
LEAD	01051	WAIVED	2011/02/09	.000	
MERCURY	71900	036	2011/02/09	.000	2014/02
NICKEL	01067	036	2011/02/09	.000	2014/02
PERCHLORATE	A-031	036	2011/02/09	< .200	2014/02
SELENIUM	01147	036	2011/02/09	.000	2014/02
THALLIUM	01059	036	2011/02/09	.000	2014/02

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801029***

System Name: ***PINE RIDGE WINERY***

PS Code: ***2801029-003***

Source Name: ***WELL 003***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
NITRATE/NITRITE						
NITRATE (AS NO3)	**71850**	**012**	**2011/02/09**	**.000**	**2012/02**	**DUE**
NITRITE (AS N)	**00620**	**036**	2011/02/09	**.000**	2014/02	
RADIOLOGICAL						
GROSS ALPHA	**01501**	**108**	2008/11/04	**< 3.000**	2017/11	
GROSS BETA	**03501**	**WAIVED**				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	**A-080**	**WAIVED**				
RA-226 OR TOTAL RA BY 903.0 C.E.	**A-081**	**WAIVED**				
RADIUM 226	**09501**	**WAIVED**				
RADIUM 228	**11501**	**WAIVED**	2008/11/04	**< 1.000**		
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	**A-082**	**WAIVED**				
STRONTIUM-90	**13501**	**WAIVED**				
TRITIUM	**07000**	**WAIVED**				
URANIUM (PCI/L)	**28012**	**WAIVED**				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	**34676**	**WAIVED**	2011/02/09	**.000**		
2,4,5-TP (SILVEX)	**39045**	**WAIVED**	2011/02/09	**.000**		
2,4-D	**39730**	**WAIVED**	2011/02/09	**.000**		
ALACHLOR	**77825**	**WAIVED**	2011/02/09	**.000**		
ATRAZINE	**39033**	**036**	2011/02/09	**.000**	2014/02	
BENTAZON	**38710**	**WAIVED**	2011/02/09	**.000**		
BENZO (A) PYRENE	**34247**	**WAIVED**	2011/02/09	**.000**		
CARBOFURAN	**81405**	**036**	2011/02/09	**.000**	2014/02	
CHLORDANE	**39350**	**WAIVED**	2011/02/09	**.000**		
DALAPON	**38432**	**036**	2011/02/09	**.000**	2014/02	
DI(2-ETHYLHEXYL)ADIPATE	**A-026**	**WAIVED**	2011/02/09	**.000**		
DI(2-ETHYLHEXYL)PHTHALATE	**39100**	**WAIVED**	2011/02/09	**.000**		
DIBROMOCHLOROPROPANE (DBCP)	**38761**	**WAIVED**	2011/02/09	**.000**		
DINOSEB	**81287**	**036**	2011/02/09	**.000**	2014/02	
DIQUAT	**78885**	**036**	2011/02/09	**.000**	2014/02	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801029***

System Name: ***PINE RIDGE WINERY***

PS Code: ***2801029-003***

Source Name: ***WELL 003***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	036	2011/02/09	.000	2014/02
ENDRIN	39390	WAIVED	2011/02/09	.000	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2011/02/09	.000	
GLYPHOSATE	79743	WAIVED	2011/02/09	.000	
HEPTACHLOR	39410	WAIVED	2011/02/09	.000	
HEPTACHLOR EPOXIDE	39420	WAIVED	2011/02/09	.000	
HEXACHLOROBENZENE	39700	WAIVED	2011/02/09	.000	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2011/02/09	.000	
LINDANE	39340	WAIVED	2011/02/09	.000	
METHOXYCHLOR	39480	WAIVED	2011/02/09	.000	
MOLINATE	82199	WAIVED	2011/02/09	.000	
OXAMYL	38865	036	2011/02/09	.000	2014/02
PENTACHLOROPHENOL	39032	036	2011/02/09	.000	2014/02
PICLORAM	39720	036	2011/02/09	.000	2014/02
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2005/01/04	.000	
SIMAZINE	39055	036	2011/02/09	.000	2014/02
THIOBENCARB	A-001	WAIVED	2011/02/09	.000	
TOXAPHENE	39400	WAIVED	2011/02/09	.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	072	2010/02/09	.000	2016/02
1,1,2,2-TETRACHLOROETHANE	34516	072	2010/02/09	.000	2016/02
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2010/02/09	.000	2016/02
1,1,2-TRICHLOROETHANE	34511	072	2010/02/09	.000	2016/02
1,1-DICHLOROETHANE	34496	072	2010/02/09	.000	2016/02
1,1-DICHLOROETHYLENE	34501	072	2010/02/09	.000	2016/02
1,2,4-TRICHLOROBENZENE	34551	072	2010/02/09	.000	2016/02
1,2-DICHLOROBENZENE	34536	072	2010/02/09	.000	2016/02
1,2-DICHLOROETHANE	34531	072	2010/02/09	.000	2016/02
1,2-DICHLOROPROPANE	34541	072	2010/02/09	.000	2016/02

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801029***

System Name: ***PINE RIDGE WINERY***

PS Code: ***2801029-003***

Source Name: ***WELL 003***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2010/02/09	.000	2016/02
1,4-DICHLOROBENZENE	34571	072	2010/02/09	.000	2016/02
BENZENE	34030	072	2010/02/09	.000	2016/02
CARBON TETRACHLORIDE	32102	072	2010/02/09	.000	2016/02
CIS-1,2-DICHLOROETHYLENE	77093	072	2010/02/09	.000	2016/02
DICHLOROMETHANE	34423	072	2010/02/09	.000	2016/02
ETHYLBENZENE	34371	072	2010/02/09	.000	2016/02
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2011/02/09	.000	2017/02
MONOCHLOROBENZENE	34301	072	2010/02/09	.000	2016/02
STYRENE	77128	072	2010/02/09	.000	2016/02
TETRACHLOROETHYLENE	34475	072	2010/02/09	.000	2016/02
TOLUENE	34010	072	2010/02/09	2.400	2016/02
TRANS-1,2-DICHLOROETHYLENE	34546	072	2010/02/09	.000	2016/02
TRICHLOROETHYLENE	39180	072	2010/02/09	.000	2016/02
TRICHLOROFLUOROMETHANE	34488	072	2010/02/09	.000	2016/02
VINYL CHLORIDE	39175	072	2010/02/09	.000	2016/02
XYLENES (TOTAL)	81551	072	2010/02/09	.000	2016/02
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2011/02/09	140.000	
CALCIUM	00916	WAIVED	2011/02/09	55.000	
CARBONATE ALKALINITY	00445	WAIVED	2011/02/09	.000	
CHLORIDE	00940	WAIVED	2011/02/09	24.000	
COLOR	00081	WAIVED	2011/02/09	.000	
COPPER	01042	WAIVED	2011/02/09	.000	
FOAMING AGENTS (MBAS)	38260	WAIVED	2011/02/09	.000	
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2011/02/09	210.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2011/02/09	.000	
IRON	01045	WAIVED	2011/02/09	77.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801029***

System Name: ***PINE RIDGE WINERY***

PS Code: ***2801029-003***

Source Name: ***WELL 003***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
MAGNESIUM	00927	WAIVED	2011/02/09	18.000	
MANGANESE	01055	WAIVED	2011/02/09	100.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED	2011/02/09	.000	
PH, LABORATORY	00403	WAIVED	2011/02/09	6.400	
SILVER	01077	WAIVED	2011/02/09	.000	
SODIUM	00929	WAIVED	2011/02/09	24.000	
SPECIFIC CONDUCTANCE	00095	WAIVED	2011/02/09	520.000	
SULFATE	00945	WAIVED	2011/02/09	86.000	
TOTAL DISSOLVED SOLIDS	70300	WAIVED	2011/02/09	320.000	
TURBIDITY, LABORATORY	82079	WAIVED	2011/02/09	.200	
ZINC	01092	WAIVED	2011/02/09	24.000	

PS Code: ***2801029-004***

Source Name: ***WELL 004***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED	2005/01/04	.000	
INORGANIC					
ALUMINUM	01105	036	2011/02/09	.000	2014/02
ANTIMONY	01097	036	2011/02/09	.000	2014/02
ARSENIC	01002	036	2011/02/09	8.000	2014/02
ASBESTOS	81855	108	2007/09/17	.400	2016/09
BARIUM	01007	036	2011/02/09	.000	2014/02
BERYLLIUM	01012	036	2011/02/09	.000	2014/02
CADMIUM	01027	036	2011/02/09	.000	2014/02
CHROMIUM (TOTAL)	01034	036	2011/02/09	.000	2014/02
CYANIDE	01291	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801029***

System Name: ***PINE RIDGE WINERY***

PS Code: ***2801029-004***

Source Name: ***WELL 004***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
INORGANIC						
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2011/02/09	.500	2014/02	
LEAD	01051	WAIVED	2011/02/09	1.000		
MERCURY	71900	036	2011/02/09	.000	2014/02	
NICKEL	01067	036	2011/02/09	.000	2014/02	
PERCHLORATE	A-031	036	2011/02/09	< .200	2014/02	
SELENIUM	01147	036	2011/02/09	.000	2014/02	
THALLIUM	01059	036	2011/02/09	.000	2014/02	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	**2011/02/09**	.000	**2012/02**	**DUE**
NITRITE (AS N)	00620	036	2011/02/09	.000	2014/02	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2008/11/04	< 3.000	2017/11	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED	2008/11/04	< 1.000		
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED	2011/02/09	.000		
2,4,5-TP (SILVEX)	39045	WAIVED	2011/02/09	.000		
2,4-D	39730	WAIVED	2011/02/09	.000		
ALACHLOR	77825	WAIVED	2011/02/09	.000		
ATRAZINE	39033	036	2011/02/09	.000	2014/02	
BENTAZON	38710	WAIVED	2011/02/09	.000		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801029***

System Name: ***PINE RIDGE WINERY***

PS Code: ***2801029-004***

Source Name: ***WELL 004***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED	2011/02/09	.000	
CARBOFURAN	81405	036	2011/02/09	.000	2014/02
CHLORDANE	39350	WAIVED	2011/02/09	.000	
DALAPON	38432	036	2011/02/09	.000	2014/02
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED	2011/02/09	.000	
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED	2011/02/09	.000	
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2011/02/09	.000	
DINOSEB	81287	036	2011/02/09	.000	2014/02
DIQUAT	78885	036	2011/02/09	.000	2014/02
ENDOTHALL	38926	036	2011/02/09	.000	2014/02
ENDRIN	39390	WAIVED	2011/02/09	.000	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2011/02/09	.000	
GLYPHOSATE	79743	WAIVED	2011/02/09	.000	
HEPTACHLOR	39410	WAIVED	2011/02/09	.000	
HEPTACHLOR EPOXIDE	39420	WAIVED	2011/02/09	.000	
HEXACHLOROBENZENE	39700	WAIVED	2011/02/09	.000	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2011/02/09	.000	
LINDANE	39340	WAIVED	2011/02/09	.000	
METHOXYCHLOR	39480	WAIVED	2011/02/09	.000	
MOLINATE	82199	WAIVED	2011/02/09	.000	
OXAMYL	38865	036	2011/02/09	.000	2014/02
PENTACHLOROPHENOL	39032	036	2011/02/09	.000	2014/02
PICLORAM	39720	036	2011/02/09	.000	2014/02
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2005/01/04	.000	
SIMAZINE	39055	036	2011/02/09	.000	2014/02
THIOBENCARB	A-001	WAIVED	2011/02/09	.000	
TOXAPHENE	39400	WAIVED	2011/02/09	.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	072	2008/03/31	.000	2014/03

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801029***

System Name: ***PINE RIDGE WINERY***

PS Code: ***2801029-004***

Source Name: ***WELL 004***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED VOC						
1,1,2,2-TETRACHLOROETHANE	34516	072	2008/03/31	.000	2014/03	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2008/03/31	.000	2014/03	
1,1,2-TRICHLOROETHANE	34511	072	2008/03/31	.000	2014/03	
1,1-DICHLOROETHANE	34496	072	2008/03/31	.000	2014/03	
1,1-DICHLOROETHYLENE	34501	072	2008/03/31	.000	2014/03	
1,2,4-TRICHLOROBENZENE	34551	072	2008/03/31	.000	2014/03	
1,2-DICHLOROBENZENE	34536	072	2008/03/31	.000	2014/03	
1,2-DICHLOROETHANE	34531	072	2008/03/31	.000	2014/03	
1,2-DICHLOROPROPANE	34541	072	2008/03/31	.000	2014/03	
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2008/03/31	.000	2014/03	
1,4-DICHLOROBENZENE	34571	072	2008/03/31	.000	2014/03	
BENZENE	34030	072	**2005/01/04**	.000	**2011/01**	**DUE**
CARBON TETRACHLORIDE	32102	072	2008/03/31	.000	2014/03	
CIS-1,2-DICHLOROETHYLENE	77093	072	2008/03/31	.000	2014/03	
DICHLOROMETHANE	34423	072	2008/03/31	.000	2014/03	
ETHYLBENZENE	34371	072	2008/03/31	.000	2014/03	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2011/02/09	.000	2017/02	
MONOCHLOROBENZENE	34301	072	2008/03/31	.000	2014/03	
STYRENE	77128	072	2008/03/31	.000	2014/03	
TETRACHLOROETHYLENE	34475	072	2008/03/31	.000	2014/03	
TOLUENE	34010	072	2008/03/31	.000	2014/03	
TRANS-1,2-DICHLOROETHYLENE	34546	072	2008/03/31	.000	2014/03	
TRICHLOROETHYLENE	39180	072	2008/03/31	.000	2014/03	
TRICHLOROFLUOROMETHANE	34488	072	2008/03/31	.000	2014/03	
VINYL CHLORIDE	39175	072	2008/03/31	.000	2014/03	
XYLENES (TOTAL)	81551	072	2008/03/31	.000	2014/03	
SECONDARY/GP						
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED				
BICARBONATE ALKALINITY	00440	WAIVED	2011/02/09	150.000		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801029***

System Name: ***PINE RIDGE WINERY***

PS Code: ***2801029-004***

Source Name: ***WELL 004***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED	2011/02/09	58.000	
CARBONATE ALKALINITY	00445	WAIVED	2011/02/09	.000	
CHLORIDE	00940	WAIVED	2011/02/09	27.000	
COLOR	00081	WAIVED	2011/02/09	.000	
COPPER	01042	WAIVED	2011/02/09	.000	
FOAMING AGENTS (MBAS)	38260	WAIVED	2011/02/09	.000	
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2011/02/09	220.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2011/02/09	.000	
IRON	01045	WAIVED	2011/02/09	600.000	
MAGNESIUM	00927	WAIVED	2011/02/09	18.000	
MANGANESE	01055	WAIVED	2011/02/09	100.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED	2011/02/09	.000	
PH, LABORATORY	00403	WAIVED	2011/02/09	6.600	
SILVER	01077	WAIVED	2011/02/09	.000	
SODIUM	00929	WAIVED	2011/02/09	24.000	
SPECIFIC CONDUCTANCE	00095	WAIVED	2011/02/09	540.000	
SULFATE	00945	WAIVED	2011/02/09	78.000	
TOTAL DISSOLVED SOLIDS	70300	WAIVED	2011/02/09	340.000	
TURBIDITY, LABORATORY	82079	WAIVED	2011/02/09	1.100	
ZINC	01092	WAIVED	2011/02/09	150.000	

PS Code: ***2801029-005***

Source Name: ***TREATMENT PLANT***

Source Number: ***005***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801029***

System Name: ***PINE RIDGE WINERY***

PS Code: ***2801029-005***

Source Name: ***TREATMENT PLANT***

Source Number: ***005***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED	2012/05/01	.000	
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED	2009/08/17	.000	
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED	2007/12/04	.000	
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801029***

System Name: ***PINE RIDGE WINERY***

PS Code: ***2801029-005***

Source Name: ***TREATMENT PLANT***

Source Number: ***005***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801029***

System Name: ***PINE RIDGE WINERY***

PS Code: ***2801029-005***

Source Name: ***TREATMENT PLANT***

Source Number: ***005***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801029***

System Name: ***PINE RIDGE WINERY***

PS Code: ***2801029-005***

Source Name: ***TREATMENT PLANT***

Source Number: ***005***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED	2009/08/17	160.000	
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801030***

System Name: ***RANCHO LA JOTA***

PS Code: ***2801030-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	000			DUE
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	000			DUE
NITRITE (AS N)	00620	000			DUE
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801030***

System Name: ***RANCHO LA JOTA***

PS Code: ***2801030-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801030***

System Name: ***RANCHO LA JOTA***

PS Code: ***2801030-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801030***

System Name: ***RANCHO LA JOTA***

PS Code: ***2801030-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801030***

System Name: ***RANCHO LA JOTA***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)

PS Code: ***2801030-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801030-002***

Source Name: ***WELL 001***

Source Number: ***002***

Source Status: ***STANDBY RAW***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED			

INORGANIC

ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801030***

System Name: ***RANCHO LA JOTA***

PS Code: ***2801030-002***

Source Name: ***WELL 001***

Source Number: ***002***

Source Status: ***STANDBY RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	108	2009/02/12	8.900	2018/02
NITRITE (AS N)	00620	108	2009/02/12	< 400.000	2018/02
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801030***

System Name: ***RANCHO LA JOTA***

PS Code: ***2801030-002***

Source Name: ***WELL 001***

Source Number: ***002***

Source Status: ***STANDBY RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801030***

System Name: ***RANCHO LA JOTA***

PS Code: ***2801030-002***

Source Name: ***WELL 001***

Source Number: ***002***

Source Status: ***STANDBY RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801030***

System Name: ***RANCHO LA JOTA***

PS Code: ***2801030-002***

Source Name: ***WELL 001***

Source Number: ***002***

Source Status: ***STANDBY RAW***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2801031
System Name: RAYMOND VINEYARD & CELLAR

PS Code: 2801031-001
Source Name: LPA REPORTED PRIMARY SOURCE
Source Number: 001
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED	2011/10/17	< .000	
ANTIMONY	01097	WAIVED	2011/10/17	< .000	
ARSENIC	01002	WAIVED	2011/10/17	< .000	
ASBESTOS	81855	WAIVED	2011/10/17	< .200	
BARIUM	01007	WAIVED	2011/10/17	< .000	
BERYLLIUM	01012	WAIVED	2011/10/17	< .000	
CADMIUM	01027	WAIVED	2011/10/17	< .000	
CHROMIUM (TOTAL)	01034	WAIVED	2011/10/17	< .000	
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2011/10/17	.240	
LEAD	01051	WAIVED	2011/10/17	< .000	
MERCURY	71900	WAIVED	2011/10/17	< .000	
NICKEL	01067	WAIVED	2011/10/17	< .000	
PERCHLORATE	A-031	WAIVED	2011/10/17	< .000	
SELENIUM	01147	WAIVED	2011/10/17	< .000	
THALLIUM	01059	WAIVED	2011/10/17	< .000	
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2011/10/17	2.600	2012/10
NITRITE (AS N)	00620	036	2011/10/17	< .000	2014/10
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2801031
System Name: RAYMOND VINEYARD & CELLAR

PS Code: 2801031-001
Source Name: LPA REPORTED PRIMARY SOURCE
Source Number: 001
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2011/10/17	< 1.000	
2,4-D	39730	WAIVED	2011/10/17	< 10.000	
ALACHLOR	77825	WAIVED	2011/10/17	< 1.000	
ATRAZINE	39033	WAIVED	2011/10/17	< .500	
BENTAZON	38710	WAIVED	2011/10/17	< 2.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED	2011/10/17	< 5.000	
CHLORDANE	39350	WAIVED	2011/10/17	< .100	
DALAPON	38432	WAIVED	2011/10/17	< 10.000	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2011/10/17	< .010	
DINOSEB	81287	WAIVED	2011/10/17	< 2.000	
DIQUAT	78885	WAIVED	2011/10/17	< 4.000	
ENDOTHALL	38926	WAIVED	2011/10/17	< 45.000	
ENDRIN	39390	WAIVED	2011/10/17	< .100	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2011/10/17	< .020	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2011/10/17	< .010	
HEPTACHLOR EPOXIDE	39420	WAIVED	2011/10/17	< .010	
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED	2011/10/17	< .200	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801031***

System Name: ***RAYMOND VINEYARD & CELLAR***

PS Code: ***2801031-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED	2011/10/17	< 10.000	
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED	2011/10/17	< 20.000	
PENTACHLOROPHENOL	39032	WAIVED	2011/10/17	< .200	
PICLORAM	39720	WAIVED	2011/10/17	< 1.000	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2011/10/17	< .500	
SIMAZINE	39055	WAIVED	2011/10/17	< 1.000	
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED	2011/10/17	< 1.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED	2011/10/17	< .000	
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED	2011/10/17	< .000	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED	2011/10/17	< .000	
1,1,2-TRICHLOROETHANE	34511	WAIVED	2011/10/17	< .000	
1,1-DICHLOROETHANE	34496	WAIVED	2011/10/17	< .000	
1,1-DICHLOROETHYLENE	34501	WAIVED	2011/10/17	< .000	
1,2,4-TRICHLOROBENZENE	34551	WAIVED	2011/10/17	< .000	
1,2-DICHLOROBENZENE	34536	WAIVED	2011/10/17	< .000	
1,2-DICHLOROETHANE	34531	WAIVED	2011/10/17	< .000	
1,2-DICHLOROPROPANE	34541	WAIVED	2011/10/17	< .000	
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED	2011/10/17	< .000	
1,4-DICHLOROBENZENE	34571	WAIVED	2011/10/17	< .000	
BENZENE	34030	WAIVED	2011/10/17	< .000	
CARBON TETRACHLORIDE	32102	WAIVED	2011/10/17	< .000	
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED	2011/10/17	< .000	
DICHLOROMETHANE	34423	WAIVED	2011/10/17	< .000	
ETHYLBENZENE	34371	WAIVED	2011/10/17	< .000	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED	2011/10/17	< .000	
MONOCHLOROBENZENE	34301	WAIVED	2011/10/17	< .000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2801031
System Name: RAYMOND VINEYARD & CELLAR

PS Code: 2801031-001
Source Name: LPA REPORTED PRIMARY SOURCE
Source Number: 001
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED	2011/10/17	< .000	
TETRACHLOROETHYLENE	34475	WAIVED	2011/10/17	< .000	
TOLUENE	34010	WAIVED	2011/10/17	< .000	
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED	2011/10/17	< .000	
TRICHLOROETHYLENE	39180	WAIVED	2011/10/17	< .000	
TRICHLOROFLUOROMETHANE	34488	WAIVED	2011/10/17	< .000	
VINYL CHLORIDE	39175	WAIVED	2011/10/17	< .000	
XYLENES (TOTAL)	81551	WAIVED	2011/10/17	< .000	
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2011/10/17	217.000	
CALCIUM	00916	WAIVED	2011/10/17	28.000	
CARBONATE ALKALINITY	00445	WAIVED	2011/10/17	< .000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2011/10/17	140.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2011/10/17	< .000	
IRON	01045	WAIVED	2011/10/17	< .000	
MAGNESIUM	00927	WAIVED	2011/10/17	17.000	
MANGANESE	01055	WAIVED	2011/10/17	195.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2011/10/17	7.200	
SILVER	01077	WAIVED	2011/10/17	< .000	
SODIUM	00929	WAIVED	2011/10/17	30.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2801031
System Name: RAYMOND VINEYARD & CELLAR

PS Code: 2801031-001
Source Name: LPA REPORTED PRIMARY SOURCE
Source Number: 001
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: 2801031-002
Source Name: TREATMENT PLANT
Source Number: 002
Source Status: ACTIVE TREATED
Water type: GROUNDWATER OR WELL

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801031***

System Name: ***RAYMOND VINEYARD & CELLAR***

PS Code: ***2801031-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801031***

System Name: ***RAYMOND VINEYARD & CELLAR***

PS Code: ***2801031-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801031***

System Name: ***RAYMOND VINEYARD & CELLAR***

PS Code: ***2801031-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801031***

System Name: ***RAYMOND VINEYARD & CELLAR***

PS Code: ***2801031-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801033***

System Name: ***ROMBAUER VINEYARDS***

PS Code: ***2801033-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED	2003/03/04	.000		
ANTIMONY	01097	WAIVED	2003/03/04	.000		
ARSENIC	01002	WAIVED	2003/03/04	3.000		
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED	2003/03/04	.000		
BERYLLIUM	01012	WAIVED	2003/03/04	.000		
CADMIUM	01027	WAIVED	2003/03/04	.000		
CHROMIUM (TOTAL)	01034	WAIVED	2003/03/04	.000		
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2003/03/04	.300		
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED	2003/03/04	.000		
NICKEL	01067	WAIVED	2003/03/04	.000		
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED	2003/03/04	.000		
THALLIUM	01059	WAIVED	2003/03/04	.000		
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2010/10/22	.000	2011/10	DUE
NITRITE (AS N)	00620	036	2008/12/01	.000	2011/12	DUE
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801033***

System Name: ***ROMBAUER VINEYARDS***

PS Code: ***2801033-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801033***

System Name: ***ROMBAUER VINEYARDS***

PS Code: ***2801033-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801033***

System Name: ***ROMBAUER VINEYARDS***

PS Code: ***2801033-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2003/03/04	60.000	
CALCIUM	00916	WAIVED	2003/03/04	4.000	
CARBONATE ALKALINITY	00445	WAIVED	2003/03/04	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2003/03/04	26.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2003/03/04	.000	
IRON	01045	WAIVED	2003/03/04	100.000	
MAGNESIUM	00927	WAIVED	2003/03/04	2.100	
MANGANESE	01055	WAIVED	2003/03/04	.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2003/03/04	7.000	
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED	2003/03/04	9.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801033***

System Name: ***ROMBAUER VINEYARDS***

PS Code: ***2801033-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801033-002***

Source Name: ***VINEYARD WELL***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801033***

System Name: ***ROMBAUER VINEYARDS***

PS Code: ***2801033-002***

Source Name: ***VINEYARD WELL***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED	2010/10/22	.000	
NITRITE (AS N)	00620	WAIVED	2008/12/01	.000	
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801033***

System Name: ***ROMBAUER VINEYARDS***

PS Code: ***2801033-002***

Source Name: ***VINEYARD WELL***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801033***

System Name: ***ROMBAUER VINEYARDS***

PS Code: ***2801033-002***

Source Name: ***VINEYARD WELL***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801033***

System Name: ***ROMBAUER VINEYARDS***

PS Code: ***2801033-002***

Source Name: ***VINEYARD WELL***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801035***

System Name: ***ROUND HILL WINERY***

PS Code: ***2801035-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2009/05/14	.000		
INORGANIC						
ALUMINUM	01105	036	2008/06/04	.000	2011/06	DUE
ANTIMONY	01097	036	2008/06/04	.000	2011/06	DUE
ARSENIC	01002	036	2008/06/04	.000	2011/06	DUE
ASBESTOS	81855	108	2004/02/19	.000	2013/02	
BARIUM	01007	036	2008/06/04	.000	2011/06	DUE
BERYLLIUM	01012	036	2008/06/04	.000	2011/06	DUE
CADMIUM	01027	036	2008/06/04	.000	2011/06	DUE
CHROMIUM (TOTAL)	01034	036	2008/06/04	.000	2011/06	DUE
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2008/06/04	.000	2011/06	DUE
LEAD	01051	WAIVED	2004/02/19	.000		
MERCURY	71900	036	2008/06/04	.000	2011/06	DUE
NICKEL	01067	036	2008/06/04	.000	2011/06	DUE
PERCHLORATE	A-031	036	2010/01/20	.000	2013/01	
SELENIUM	01147	036	2008/06/04	.000	2011/06	DUE
THALLIUM	01059	036	2008/06/04	.000	2011/06	DUE
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2009/08/13	.000	2010/08	DUE
NITRITE (AS N)	00620	036	2008/05/23	.000	2011/05	DUE
RADIOLOGICAL						
GROSS ALPHA	01501	108	2007/06/14	.133	2016/06	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801035***

System Name: ***ROUND HILL WINERY***

PS Code: ***2801035-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2009/05/14	.000	
2,4-D	39730	WAIVED	2009/05/14	.000	
ALACHLOR	77825	WAIVED	2009/05/14	.000	
ATRAZINE	39033	036	2009/05/14	.000	2012/05
BENTAZON	38710	WAIVED	2009/05/14	.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	036	2009/05/14	.000	2012/05
CHLORDANE	39350	WAIVED	2004/02/19	.000	
DALAPON	38432	036	2009/05/14	.000	2012/05
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2009/05/19	.000	
DINOSEB	81287	036	2009/05/14	.000	2012/05
DIQUAT	78885	036	2009/05/14	.000	2012/05
ENDOTHALL	38926	036	2009/05/14	.000	2012/05
ENDRIN	39390	WAIVED	2004/02/19	.000	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2009/05/19	.000	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2004/02/19	.000	
HEPTACHLOR EPOXIDE	39420	WAIVED	2004/02/19	.000	
HEXACHLOROBENZENE	39700	WAIVED	2004/02/19	.000	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2004/02/19	.000	
LINDANE	39340	WAIVED	2004/02/19	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801035***

System Name: ***ROUND HILL WINERY***

PS Code: ***2801035-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED	2004/02/19	.000	
MOLINATE	82199	WAIVED	2009/05/14	.000	
OXAMYL	38865	036	2009/05/14	.000	2012/05
PENTACHLOROPHENOL	39032	036	2009/05/14	.000	2012/05
PICLORAM	39720	036	2009/05/14	.000	2012/05
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2004/02/19	.000	
SIMAZINE	39055	036	2009/05/14	.000	2012/05
THIOBENCARB	A-001	WAIVED	2009/05/14	.000	
TOXAPHENE	39400	WAIVED	2004/02/19	.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	072	2009/05/19	.000	2015/05
1,1,2,2-TETRACHLOROETHANE	34516	072	2009/05/19	.000	2015/05
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2009/05/19	.000	2015/05
1,1,2-TRICHLOROETHANE	34511	072	2009/05/19	.000	2015/05
1,1-DICHLOROETHANE	34496	072	2009/05/19	.000	2015/05
1,1-DICHLOROETHYLENE	34501	072	2009/05/19	.000	2015/05
1,2,4-TRICHLOROBENZENE	34551	072	2009/05/19	.000	2015/05
1,2-DICHLOROBENZENE	34536	072	2009/05/19	.000	2015/05
1,2-DICHLOROETHANE	34531	072	2009/05/19	.000	2015/05
1,2-DICHLOROPROPANE	34541	072	2009/05/19	.000	2015/05
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2009/05/19	.000	2015/05
1,4-DICHLOROBENZENE	34571	072	2009/05/19	.000	2015/05
BENZENE	34030	072	2009/05/19	.000	2015/05
CARBON TETRACHLORIDE	32102	072	2009/05/19	.000	2015/05
CIS-1,2-DICHLOROETHYLENE	77093	072	2009/05/19	.000	2015/05
DICHLOROMETHANE	34423	072	2009/05/19	.000	2015/05
ETHYLBENZENE	34371	072	2009/05/19	.000	2015/05
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2009/05/19	.000	2015/05
MONOCHLOROBENZENE	34301	072	2009/05/19	.000	2015/05

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801035***

System Name: ***ROUND HILL WINERY***

PS Code: ***2801035-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2009/05/19	.000	2015/05
TETRACHLOROETHYLENE	34475	072	2009/05/19	.000	2015/05
TOLUENE	34010	072	2009/05/19	.000	2015/05
TRANS-1,2-DICHLOROETHYLENE	34546	072	2009/05/19	.000	2015/05
TRICHLOROETHYLENE	39180	072	2009/05/19	.000	2015/05
TRICHLOROFLUOROMETHANE	34488	072	2009/05/19	.000	2015/05
VINYL CHLORIDE	39175	072	2009/05/19	.000	2015/05
XYLENES (TOTAL)	81551	072	2009/05/19	.000	2015/05
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2004/02/19	270.000	
CALCIUM	00916	WAIVED	2004/02/19	19.000	
CARBONATE ALKALINITY	00445	WAIVED	2004/02/19	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2009/05/14	120.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2004/02/19	.000	
IRON	01045	WAIVED	2008/06/04	.000	
MAGNESIUM	00927	WAIVED	2008/06/04	16.000	
MANGANESE	01055	WAIVED	2004/02/19	120.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2004/02/19	8.100	
SILVER	01077	WAIVED	2004/02/19	.000	
SODIUM	00929	WAIVED	2004/02/19	50.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801035***

System Name: ***ROUND HILL WINERY***

PS Code: ***2801035-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
SECONDARY/GP						
TURBIDITY, LABORATORY	82079	WAIVED				
ZINC	01092	WAIVED				

PS Code: ***2801035-002***

Source Name: ***WELL 002-Y2K***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2007/02/05	.000		
INORGANIC						
ALUMINUM	01105	036	2011/08/10	< .000	2014/08	
ANTIMONY	01097	036	2011/08/10	< .000	2014/08	
ARSENIC	01002	036	2011/08/10	< .000	2014/08	
ASBESTOS	81855	000				**DUE**
BARIUM	01007	036	2011/08/10	< .000	2014/08	
BERYLLIUM	01012	036	2011/08/10	< .000	2014/08	
CADMIUM	01027	036	2011/08/10	< .000	2014/08	
CHROMIUM (TOTAL)	01034	036	2011/08/10	< .000	2014/08	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2011/08/10	< .000	2014/08	
LEAD	01051	WAIVED	2011/08/10	< .000		
MERCURY	71900	036	2011/08/10	< .000	2014/08	
NICKEL	01067	036	2011/08/10	< .000	2014/08	
PERCHLORATE	A-031	006				**DUE**
SELENIUM	01147	036	2011/08/10	< .000	2014/08	
THALLIUM	01059	036	2011/08/10	< .000	2014/08	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801035***

System Name: ***ROUND HILL WINERY***

PS Code: ***2801035-002***

Source Name: ***WELL 002-Y2K***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/05/18	< .000	2012/05	
NITRITE (AS N)	00620	036	2011/08/10	< .000	2014/08	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2006/12/14	.753	2015/12	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2007/02/05	< 1.000		
2,4-D	39730	WAIVED	2007/02/05	< 10.000		
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	036	2007/02/05	.000	2010/02	DUE
BENTAZON	38710	WAIVED	2007/02/05	< 2.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2007/02/05	< 5.000	2010/02	DUE
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2007/02/05	< 10.000	2010/02	DUE
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	036	2007/02/05	< 2.000	2010/02	DUE
DIQUAT	78885	036	2007/02/05	< 4.000	2010/02	DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801035***

System Name: ***ROUND HILL WINERY***

PS Code: ***2801035-002***

Source Name: ***WELL 002-Y2K***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
ENDOTHALL	38926	036	2007/02/05	< 45.000	2010/02	DUE
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	000				DUE
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				DUE
HEPTACHLOR EPOXIDE	39420	000				DUE
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				DUE
METHOXYCHLOR	39480	000				DUE
MOLINATE	82199	WAIVED	2007/02/05	.000		
OXAMYL	38865	036	2007/02/05	< 20.000	2010/02	DUE
PENTACHLOROPHENOL	39032	036	2007/02/05	< .200	2010/02	DUE
PICLORAM	39720	036	2007/02/05	< 1.000	2010/02	DUE
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2007/02/05	.000	2010/02	DUE
THIOBENCARB	A-001	WAIVED	2007/02/05	.000		
TOXAPHENE	39400	000				DUE
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	000				DUE
1,1,2,2-TETRACHLOROETHANE	34516	000				DUE
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	000				DUE
1,1,2-TRICHLOROETHANE	34511	000				DUE
1,1-DICHLOROETHANE	34496	000				DUE
1,1-DICHLOROETHYLENE	34501	000				DUE
1,2,4-TRICHLOROBENZENE	34551	000				DUE
1,2-DICHLOROBENZENE	34536	000				DUE
1,2-DICHLOROETHANE	34531	000				DUE
1,2-DICHLOROPROPANE	34541	000				DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801035***

System Name: ***ROUND HILL WINERY***

PS Code: ***2801035-002***

Source Name: ***WELL 002-Y2K***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	000			DUE
1,4-DICHLOROBENZENE	34571	000			DUE
BENZENE	34030	000			DUE
CARBON TETRACHLORIDE	32102	000			DUE
CIS-1,2-DICHLOROETHYLENE	77093	000			DUE
DICHLOROMETHANE	34423	000			DUE
ETHYLBENZENE	34371	000			DUE
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	000			DUE
MONOCHLOROBENZENE	34301	000			DUE
STYRENE	77128	000			DUE
TETRACHLOROETHYLENE	34475	000			DUE
TOLUENE	34010	000			DUE
TRANS-1,2-DICHLOROETHYLENE	34546	000			DUE
TRICHLOROETHYLENE	39180	000			DUE
TRICHLOROFLUOROMETHANE	34488	000			DUE
VINYL CHLORIDE	39175	000			DUE
XYLENES (TOTAL)	81551	000			DUE
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2011/08/10	273.000	
CALCIUM	00916	WAIVED	2011/08/10	20.000	
CARBONATE ALKALINITY	00445	WAIVED	2011/08/10	< .000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2007/02/05	120.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2011/08/10	< .000	
IRON	01045	WAIVED	2011/08/10	< .000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801035***

System Name: ***ROUND HILL WINERY***

PS Code: ***2801035-002***

Source Name: ***WELL 002-Y2K***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED	2011/08/10	15.000	
MANGANESE	01055	WAIVED	2011/08/10	121.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2011/08/10	7.800	
SILVER	01077	WAIVED	2011/08/10	< .000	
SODIUM	00929	WAIVED	2011/08/10	49.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801035-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED			

INORGANIC

ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801035***

System Name: ***ROUND HILL WINERY***

PS Code: ***2801035-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801035***

System Name: ***ROUND HILL WINERY***

PS Code: ***2801035-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801035***

System Name: ***ROUND HILL WINERY***

PS Code: ***2801035-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801035***

System Name: ***ROUND HILL WINERY***

PS Code: ***2801035-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801036***

System Name: ***SCHRAMSBERG WINERY***

PS Code: ***2801036-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE/MT. DIAMOND***

Source Number: ***001***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2008/08/04	.000		
INORGANIC						
ALUMINUM	01105	108	2008/08/04	.000	2017/08	
ANTIMONY	01097	108	2008/08/04	.000	2017/08	
ARSENIC	01002	108	2008/08/04	4.800	2017/08	
ASBESTOS	81855	108	2009/10/07	.000	2018/10	
BARIUM	01007	108	2008/08/04	.000	2017/08	
BERYLLIUM	01012	108	2008/08/04	.000	2017/08	
CADMIUM	01027	108	2008/08/04	.000	2017/08	
CHROMIUM (TOTAL)	01034	108	2008/08/04	.000	2017/08	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	108	2008/08/04	.000	2017/08	
LEAD	01051	WAIVED	2008/08/04	.000		
MERCURY	71900	108	2008/08/04	.000	2017/08	
NICKEL	01067	108	2008/08/04	.000	2017/08	
PERCHLORATE	A-031	108	2010/01/07	.000	2019/01	
SELENIUM	01147	108	2008/08/04	.000	2017/08	
THALLIUM	01059	108	2008/08/04	.000	2017/08	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	108	2010/07/08	.000	2019/07	
NITRITE (AS N)	00620	108	2008/08/04	.000	2017/08	
RADIOLOGICAL						
GROSS ALPHA	01501	000				**DUE**
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801036***

System Name: ***SCHRAMSBERG WINERY***

PS Code: ***2801036-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE/MT. DIAMOND***

Source Number: ***001***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2008/08/04	.000	
2,4-D	39730	WAIVED	2008/08/04	.000	
ALACHLOR	77825	WAIVED	2008/08/04	.000	
ATRAZINE	39033	WAIVED	2008/08/04	.000	
BENTAZON	38710	WAIVED	2008/08/04	.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED	2008/08/04	.000	
CHLORDANE	39350	WAIVED	2003/06/16	.000	
DALAPON	38432	WAIVED	2008/08/04	.000	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2008/08/04	.000	
DINOSEB	81287	WAIVED	2008/08/04	.000	
DIQUAT	78885	WAIVED	2008/08/04	.000	
ENDOTHALL	38926	WAIVED	2008/08/04	.000	
ENDRIN	39390	WAIVED	2003/06/16	.000	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2008/08/04	.000	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2003/06/16	.000	
HEPTACHLOR EPOXIDE	39420	WAIVED	2003/06/16	.000	
HEXACHLOROBENZENE	39700	WAIVED	2003/06/16	.000	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2003/06/16	.000	
LINDANE	39340	WAIVED	2003/06/16	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801036***

System Name: ***SCHRAMSBERG WINERY***

PS Code: ***2801036-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE/MT. DIAMOND***

Source Number: ***001***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED	2003/06/16	.000	
MOLINATE	82199	WAIVED	2008/08/04	.000	
OXAMYL	38865	WAIVED	2008/08/04	.000	
PENTACHLOROPHENOL	39032	WAIVED	2008/08/04	.000	
PICLORAM	39720	WAIVED	2008/08/04	.000	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2003/06/16	.000	
SIMAZINE	39055	WAIVED	2008/08/04	.000	
THIOBENCARB	A-001	WAIVED	2008/08/04	.000	
TOXAPHENE	39400	WAIVED	2003/06/16	.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED	2008/08/04	.000	
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED	2008/08/04	.000	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED	2008/08/04	.000	
1,1,2-TRICHLOROETHANE	34511	WAIVED	2008/08/04	.000	
1,1-DICHLOROETHANE	34496	WAIVED	2008/08/04	.000	
1,1-DICHLOROETHYLENE	34501	WAIVED	2008/08/04	.000	
1,2,4-TRICHLOROBENZENE	34551	WAIVED	2008/08/04	.000	
1,2-DICHLOROBENZENE	34536	WAIVED	2008/08/04	.000	
1,2-DICHLOROETHANE	34531	WAIVED	2008/08/04	.000	
1,2-DICHLOROPROPANE	34541	WAIVED	2008/08/04	.000	
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED	2008/08/04	.000	
1,4-DICHLOROBENZENE	34571	WAIVED	2008/08/04	.000	
BENZENE	34030	WAIVED	2008/08/04	.000	
CARBON TETRACHLORIDE	32102	WAIVED	2008/08/04	.000	
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED	2008/08/04	.000	
DICHLOROMETHANE	34423	WAIVED	2008/08/04	.000	
ETHYLBENZENE	34371	WAIVED	2008/08/04	.000	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	108	2008/08/04	.000	2017/08
MONOCHLOROBENZENE	34301	WAIVED	2008/08/04	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801036***

System Name: ***SCHRAMSBERG WINERY***

PS Code: ***2801036-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE/MT. DIAMOND***

Source Number: ***001***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED VOC						
STYRENE	77128	WAIVED	2008/08/04	.000		
TETRACHLOROETHYLENE	34475	WAIVED	2008/08/04	.000		
TOLUENE	34010	WAIVED	2008/08/04	.000		
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED	2008/08/04	.000		
TRICHLOROETHYLENE	39180	WAIVED	2008/08/04	.000		
TRICHLOROFLUOROMETHANE	34488	WAIVED	2008/08/04	.000		
VINYL CHLORIDE	39175	WAIVED	2008/08/04	.000		
XYLENES (TOTAL)	81551	WAIVED	2008/08/04	.000		
SECONDARY/GP						
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED				
BICARBONATE ALKALINITY	00440	108	2008/08/04	90.000	2017/08	
CALCIUM	00916	108	2008/08/04	10.000	2017/08	
CARBONATE ALKALINITY	00445	108	2008/08/04	.000	2017/08	
CHLORIDE	00940	000				**DUE**
COLOR	00081	000				**DUE**
COPPER	01042	000				**DUE**
FOAMING AGENTS (MBAS)	38260	000				**DUE**
HARDNESS (TOTAL) AS CACO3	00900	108	2008/08/04	52.000	2017/08	
HYDROXIDE ALKALINITY	71830	108	2008/08/04	.000	2017/08	
IRON	01045	108	2008/08/04	300.000	2017/08	
MAGNESIUM	00927	108	2008/08/04	4.900	2017/08	
MANGANESE	01055	108	2008/08/04	.000	2017/08	
ODOR THRESHOLD @ 60 C	00086	000				**DUE**
PH, LABORATORY	00403	108	2008/08/04	6.900	2017/08	
SILVER	01077	108	2008/08/04	.000	2017/08	
SODIUM	00929	108	2008/08/04	15.000	2017/08	
SPECIFIC CONDUCTANCE	00095	000				**DUE**
SULFATE	00945	000				**DUE**
TOTAL DISSOLVED SOLIDS	70300	000				**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801036***

System Name: ***SCHRAMSBERG WINERY***

PS Code: ***2801036-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE/MT. DIAMOND***

Source Number: ***001***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
TURBIDITY, LABORATORY	82079	000				DUE
ZINC	01092	000				DUE

PS Code: ***2801036-002***

Source Name: ***WELL 002/MC CRACKON***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED	2008/08/04	.000	

INORGANIC

ALUMINUM	01105	108	2008/08/04	.000	2017/08
ANTIMONY	01097	108	2008/08/04	.000	2017/08
ARSENIC	01002	108	2008/08/04	6.100	2017/08
ASBESTOS	81855	108	2009/10/07	.000	2018/10
BARIUM	01007	108	2008/08/04	.000	2017/08
BERYLLIUM	01012	108	2008/08/04	.000	2017/08
CADMIUM	01027	108	2008/08/04	.000	2017/08
CHROMIUM (TOTAL)	01034	108	2008/08/04	.000	2017/08
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	108	2008/08/04	.000	2017/08
LEAD	01051	WAIVED	2008/08/04	.000	
MERCURY	71900	108	2008/08/04	.000	2017/08
NICKEL	01067	108	2008/08/04	.000	2017/08
PERCHLORATE	A-031	108	2010/01/07	.000	2019/01
SELENIUM	01147	108	2008/08/04	.000	2017/08
THALLIUM	01059	108	2008/08/04	.000	2017/08

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801036***

System Name: ***SCHRAMSBERG WINERY***

PS Code: ***2801036-002***

Source Name: ***WELL 002/MC CRACKON***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	108	2010/07/08	.000	2019/07	
NITRITE (AS N)	00620	108	2008/08/04	.000	2017/08	
RADIOLOGICAL						
GROSS ALPHA	01501	000				**DUE**
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2008/08/04	.000		
2,4-D	39730	WAIVED	2008/08/04	.000		
ALACHLOR	77825	WAIVED	2008/08/04	.000		
ATRAZINE	39033	WAIVED	2008/08/04	.000		
BENTAZON	38710	WAIVED	2008/08/04	.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	WAIVED	2008/08/04	.000		
CHLORDANE	39350	WAIVED				
DALAPON	38432	WAIVED	2008/08/04	.000		
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2008/11/05	.000		
DINOSEB	81287	WAIVED	2008/08/04	.000		
DIQUAT	78885	WAIVED	2008/09/05	.000		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801036***

System Name: ***SCHRAMSBERG WINERY***

PS Code: ***2801036-002***

Source Name: ***WELL 002/MC CRACKON***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED	2008/08/04	.000	
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2008/11/05	.000	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	000			DUE
HEPTACHLOR EPOXIDE	39420	000			DUE
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	000			DUE
METHOXYCHLOR	39480	000			DUE
MOLINATE	82199	WAIVED	2008/08/04	.000	
OXAMYL	38865	WAIVED	2008/08/04	.000	
PENTACHLOROPHENOL	39032	WAIVED	2008/08/04	.000	
PICLORAM	39720	WAIVED	2008/08/04	.000	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED	2008/08/04	.000	
THIOBENCARB	A-001	WAIVED	2008/08/04	.000	
TOXAPHENE	39400	000			DUE
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED	2008/11/05	.000	
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED	2008/11/05	.000	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED	2008/11/05	.000	
1,1,2-TRICHLOROETHANE	34511	WAIVED	2008/11/05	.000	
1,1-DICHLOROETHANE	34496	WAIVED	2008/11/05	.000	
1,1-DICHLOROETHYLENE	34501	WAIVED	2008/11/05	.000	
1,2,4-TRICHLOROBENZENE	34551	WAIVED	2008/11/05	.000	
1,2-DICHLOROBENZENE	34536	WAIVED	2008/11/05	.000	
1,2-DICHLOROETHANE	34531	WAIVED	2008/11/05	.000	
1,2-DICHLOROPROPANE	34541	WAIVED	2008/11/05	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801036***

System Name: ***SCHRAMSBERG WINERY***

PS Code: ***2801036-002***

Source Name: ***WELL 002/MC CRACKON***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED VOC						
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED	2008/11/05	.000		
1,4-DICHLOROBENZENE	34571	WAIVED	2008/11/05	.000		
BENZENE	34030	WAIVED	2008/11/05	.000		
CARBON TETRACHLORIDE	32102	WAIVED	2008/11/05	.000		
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED	2008/11/05	.000		
DICHLOROMETHANE	34423	WAIVED	2008/11/05	.000		
ETHYLBENZENE	34371	WAIVED	2008/11/05	.000		
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	108	2008/11/05	.000	2017/11	
MONOCHLOROBENZENE	34301	WAIVED	2008/11/05	.000		
STYRENE	77128	WAIVED	2008/11/05	.000		
TETRACHLOROETHYLENE	34475	WAIVED	2008/11/05	.000		
TOLUENE	34010	WAIVED	2008/11/05	.000		
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED	2008/11/05	.000		
TRICHLOROETHYLENE	39180	WAIVED	2008/11/05	.000		
TRICHLOROFLUOROMETHANE	34488	WAIVED	2008/11/05	.000		
VINYL CHLORIDE	39175	WAIVED	2008/11/05	.000		
XYLENES (TOTAL)	81551	WAIVED	2008/11/05	.000		
SECONDARY/GP						
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED				
BICARBONATE ALKALINITY	00440	108	2008/08/04	74.000	2017/08	
CALCIUM	00916	108	2008/08/04	11.000	2017/08	
CARBONATE ALKALINITY	00445	108	2008/08/04	.000	2017/08	
CHLORIDE	00940	000				**DUE**
COLOR	00081	000				**DUE**
COPPER	01042	000				**DUE**
FOAMING AGENTS (MBAS)	38260	000				**DUE**
HARDNESS (TOTAL) AS CACO3	00900	108	2008/08/04	52.000	2017/08	
HYDROXIDE ALKALINITY	71830	108	2008/08/04	.000	2017/08	
IRON	01045	000				**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801036***

System Name: ***SCHRAMSBERG WINERY***

PS Code: ***2801036-002***

Source Name: ***WELL 002/MC CRACKON***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
SECONDARY/GP						
MAGNESIUM	00927	108	2008/08/04	4.100	2017/08	
MANGANESE	01055	108	2008/08/04	.000	2017/08	
ODOR THRESHOLD @ 60 C	00086	000				DUE
PH, LABORATORY	00403	108	2008/08/04	6.500	2017/08	
SILVER	01077	108	2008/08/04	.000	2017/08	
SODIUM	00929	108	2008/08/04	9.800	2017/08	
SPECIFIC CONDUCTANCE	00095	000				DUE
SULFATE	00945	000				DUE
TOTAL DISSOLVED SOLIDS	70300	000				DUE
TURBIDITY, LABORATORY	82079	000				DUE
ZINC	01092	000				DUE

PS Code: ***2801036-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15		
DIAZINON	39570	WAIVED
INORGANIC		
ALUMINUM	01105	WAIVED
ANTIMONY	01097	WAIVED
ARSENIC	01002	WAIVED
ASBESTOS	81855	WAIVED
BARIUM	01007	WAIVED
BERYLLIUM	01012	WAIVED
CADMIUM	01027	WAIVED
CHROMIUM (TOTAL)	01034	WAIVED
CYANIDE	01291	WAIVED

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801036***

System Name: ***SCHRAMSBERG WINERY***

PS Code: ***2801036-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801036***

System Name: ***SCHRAMSBERG WINERY***

PS Code: ***2801036-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801036***

System Name: ***SCHRAMSBERG WINERY***

PS Code: ***2801036-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801036***

System Name: ***SCHRAMSBERG WINERY***

PS Code: ***2801036-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801036-004***

Source Name: ***TRACTOR WELL***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED	2010/07/13	< .000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801036***

System Name: ***SCHRAMSBERG WINERY***

PS Code: ***2801036-004***

Source Name: ***TRACTOR WELL***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
INORGANIC						
ALUMINUM	01105	000				DUE
ANTIMONY	01097	000				DUE
ARSENIC	01002	000				DUE
ASBESTOS	81855	108	2010/07/13	.000	2019/07	
BARIUM	01007	000				DUE
BERYLLIUM	01012	000				DUE
CADMIUM	01027	000				DUE
CHROMIUM (TOTAL)	01034	000				DUE
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				DUE
LEAD	01051	WAIVED				
MERCURY	71900	000				DUE
NICKEL	01067	000				DUE
PERCHLORATE	A-031	036	2011/10/06	< .000	2014/10	
SELENIUM	01147	000				DUE
THALLIUM	01059	000				DUE
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/04/28	< .000	2012/04	
NITRITE (AS N)	00620	000				DUE
RADIOLOGICAL						
GROSS ALPHA	01501	108	2012/01/26	1.490	2021/01	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801036***

System Name: ***SCHRAMSBERG WINERY***

PS Code: ***2801036-004***

Source Name: ***TRACTOR WELL***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2010/07/13	< .000		
2,4-D	39730	WAIVED	2010/07/13	< .000		
ALACHLOR	77825	WAIVED	2010/07/13	< .000		
ATRAZINE	39033	036	2010/07/13	< .000	2013/07	
BENTAZON	38710	WAIVED	2010/07/13	< .000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2010/07/13	< .000	2013/07	
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2010/07/13	< .000	2013/07	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED	2010/07/13	< .000		
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2010/07/13	< .000		
DINOSEB	81287	036	2010/07/13	< .000	2013/07	
DIQUAT	78885	036	2010/07/13	< .000	2013/07	
ENDOTHALL	38926	036	2010/07/13	< .000	2013/07	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2010/07/13	< .000		
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**
METHOXYCHLOR	39480	WAIVED	2010/07/13	< .000		
MOLINATE	82199	WAIVED	2010/07/13	< .000		
OXAMYL	38865	036	2010/07/13	< .000	2013/07	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801036***

System Name: ***SCHRAMSBERG WINERY***

PS Code: ***2801036-004***

Source Name: ***TRACTOR WELL***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
PENTACHLOROPHENOL	39032	036	2010/07/13	< .000	2013/07	
PICLORAM	39720	036	2010/07/13	< .000	2013/07	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2010/07/13	< .000		
SIMAZINE	39055	036	2010/07/13	< .000	2013/07	
THIOBENCARB	A-001	WAIVED	2010/07/13	< .000		
TOXAPHENE	39400	WAIVED	2010/07/13	< .000		
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	000				DUE
1,1,2,2-TETRACHLOROETHANE	34516	000				DUE
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	000				DUE
1,1,2-TRICHLOROETHANE	34511	000				DUE
1,1-DICHLOROETHANE	34496	000				DUE
1,1-DICHLOROETHYLENE	34501	000				DUE
1,2,4-TRICHLOROBENZENE	34551	000				DUE
1,2-DICHLOROBENZENE	34536	000				DUE
1,2-DICHLOROETHANE	34531	000				DUE
1,2-DICHLOROPROPANE	34541	000				DUE
1,3-DICHLOROPROPENE (TOTAL)	34561	000				DUE
1,4-DICHLOROBENZENE	34571	000				DUE
BENZENE	34030	000				DUE
CARBON TETRACHLORIDE	32102	000				DUE
CIS-1,2-DICHLOROETHYLENE	77093	000				DUE
DICHLOROMETHANE	34423	000				DUE
ETHYLBENZENE	34371	000				DUE
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	000				DUE
MONOCHLOROBENZENE	34301	000				DUE
STYRENE	77128	000				DUE
TETRACHLOROETHYLENE	34475	000				DUE
TOLUENE	34010	000				DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801036***

System Name: ***SCHRAMSBERG WINERY***

PS Code: ***2801036-004***

Source Name: ***TRACTOR WELL***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
TRANS-1,2-DICHLOROETHYLENE	34546	000			DUE
TRICHLOROETHYLENE	39180	000			DUE
TRICHLOROFLUOROMETHANE	34488	000			DUE
VINYL CHLORIDE	39175	000			DUE
XYLENES (TOTAL)	81551	000			DUE
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801037***

System Name: ***SEQUOIA GROVE VINEYARDS***

PS Code: ***2801037-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED	2010/07/12	.000	
ANTIMONY	01097	WAIVED	2010/07/12	.000	
ARSENIC	01002	WAIVED	2010/07/12	.000	
ASBESTOS	81855	WAIVED	2010/07/12	.000	
BARIUM	01007	WAIVED	2010/07/12	103.000	
BERYLLIUM	01012	WAIVED	2010/07/12	.000	
CADMIUM	01027	WAIVED	2010/07/12	.000	
CHROMIUM (TOTAL)	01034	WAIVED	2010/07/12	.000	
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2010/07/12	.120	
LEAD	01051	WAIVED	2010/07/12	.000	
MERCURY	71900	WAIVED	2010/07/12	.000	
NICKEL	01067	WAIVED	2010/07/12	12.500	
PERCHLORATE	A-031	WAIVED	2008/07/07	.000	
SELENIUM	01147	WAIVED	2010/07/12	.000	
THALLIUM	01059	WAIVED	2010/07/12	.000	
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2011/07/11	< .000	2012/07
NITRITE (AS N)	00620	036	2010/07/12	.000	2013/07
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED	2008/10/20	1.240	
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801037***

System Name: ***SEQUOIA GROVE VINEYARDS***

PS Code: ***2801037-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2010/07/12	< .000	
2,4-D	39730	WAIVED	2010/07/12	< .000	
ALACHLOR	77825	WAIVED	2010/07/12	< .000	
ATRAZINE	39033	WAIVED	2010/07/12	< .000	
BENTAZON	38710	WAIVED	2010/07/12	< .000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED	2010/07/12	< .000	
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED	2010/07/12	< .000	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2010/07/12	.000	
DINOSEB	81287	WAIVED	2010/07/12	< .000	
DIQUAT	78885	WAIVED	2010/07/12	< .000	
ENDOTHALL	38926	WAIVED	2010/07/12	< .000	
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2010/07/12	.000	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801037***

System Name: ***SEQUOIA GROVE VINEYARDS***

PS Code: ***2801037-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED	2010/07/12	< .000	
OXAMYL	38865	WAIVED	2010/07/12	< .000	
PENTACHLOROPHENOL	39032	WAIVED	2010/07/12	< .000	
PICLORAM	39720	WAIVED	2010/07/12	< .000	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED	2010/07/12	< .000	
THIOBENCARB	A-001	WAIVED	2010/07/12	< .000	
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED	2010/07/12	.000	
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED	2010/07/12	.000	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED	2010/07/12	.000	
1,1,2-TRICHLOROETHANE	34511	WAIVED	2010/07/12	.000	
1,1-DICHLOROETHANE	34496	WAIVED	2010/07/12	.000	
1,1-DICHLOROETHYLENE	34501	WAIVED	2010/07/12	.000	
1,2,4-TRICHLOROBENZENE	34551	WAIVED	2010/07/12	.000	
1,2-DICHLOROBENZENE	34536	WAIVED	2010/07/12	.000	
1,2-DICHLOROETHANE	34531	WAIVED	2010/07/12	.000	
1,2-DICHLOROPROPANE	34541	WAIVED	2010/07/12	.000	
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED	2010/07/12	.000	
1,4-DICHLOROBENZENE	34571	WAIVED	2010/07/12	.000	
BENZENE	34030	WAIVED	2010/07/12	.000	
CARBON TETRACHLORIDE	32102	WAIVED	2010/07/12	.000	
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED	2010/07/12	.000	
DICHLOROMETHANE	34423	WAIVED	2010/07/12	.000	
ETHYLBENZENE	34371	WAIVED	2010/07/12	.000	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED	2010/07/12	.000	
MONOCHLOROBENZENE	34301	WAIVED	2010/07/12	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801037***

System Name: ***SEQUOIA GROVE VINEYARDS***

PS Code: ***2801037-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED	2010/07/12	.000	
TETRACHLOROETHYLENE	34475	WAIVED	2010/07/12	.000	
TOLUENE	34010	WAIVED	2010/07/12	.000	
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED	2010/07/12	.000	
TRICHLOROETHYLENE	39180	WAIVED	2010/07/12	.000	
TRICHLOROFLUOROMETHANE	34488	WAIVED	2010/07/12	.000	
VINYL CHLORIDE	39175	WAIVED	2010/07/12	.000	
XYLENES (TOTAL)	81551	WAIVED	2010/07/12	.000	
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2010/07/12	213.000	
CALCIUM	00916	WAIVED	2010/07/12	41.000	
CARBONATE ALKALINITY	00445	WAIVED	2010/07/12	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2010/07/12	210.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2010/07/12	.000	
IRON	01045	WAIVED	2010/07/12	.000	
MAGNESIUM	00927	WAIVED	2010/07/12	25.000	
MANGANESE	01055	WAIVED	2010/07/12	.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2010/07/12	7.000	
SILVER	01077	WAIVED	2010/07/12	.000	
SODIUM	00929	WAIVED	2010/07/12	15.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801037***

System Name: ***SEQUOIA GROVE VINEYARDS***

PS Code: ***2801037-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801037-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801037***

System Name: ***SEQUOIA GROVE VINEYARDS***

PS Code: ***2801037-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801037***

System Name: ***SEQUOIA GROVE VINEYARDS***

PS Code: ***2801037-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801037***

System Name: ***SEQUOIA GROVE VINEYARDS***

PS Code: ***2801037-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801037***

System Name: ***SEQUOIA GROVE VINEYARDS***

PS Code: ***2801037-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801038***

System Name: ***SILVER OAKS WINE CELLARS***

PS Code: ***2801038-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801038***

System Name: ***SILVER OAKS WINE CELLARS***

PS Code: ***2801038-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801038***

System Name: ***SILVER OAKS WINE CELLARS***

PS Code: ***2801038-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801038***

System Name: ***SILVER OAKS WINE CELLARS***

PS Code: ***2801038-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801038***

System Name: ***SILVER OAKS WINE CELLARS***

PS Code: ***2801038-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
SECONDARY/GP						
TURBIDITY, LABORATORY	82079	WAIVED				
ZINC	01092	WAIVED				

PS Code: ***2801038-003***

Source Name: ***WELL 002-AG WELL***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2006/12/26	.000		
INORGANIC						
ALUMINUM	01105	036	2009/09/08	.000	2012/09	
ANTIMONY	01097	036	2009/09/08	.000	2012/09	
ARSENIC	01002	036	2009/09/08	3.800	2012/09	
ASBESTOS	81855	000				**DUE**
BARIUM	01007	036	2009/09/08	150.000	2012/09	
BERYLLIUM	01012	036	2009/09/08	.000	2012/09	
CADMIUM	01027	036	2009/09/08	.000	2012/09	
CHROMIUM (TOTAL)	01034	036	2009/09/08	.000	2012/09	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2009/09/08	.000	2012/09	
LEAD	01051	WAIVED	2009/09/08	.000		
MERCURY	71900	036	2009/09/08	.000	2012/09	
NICKEL	01067	036	2009/09/08	.000	2012/09	
PERCHLORATE	A-031	006	**2009/09/08**	.000	**2010/03**	**DUE**
SELENIUM	01147	036	2009/09/08	.000	2012/09	
THALLIUM	01059	036	2009/09/08	.000	2012/09	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801038***

System Name: ***SILVER OAKS WINE CELLARS***

PS Code: ***2801038-003***

Source Name: ***WELL 002-AG WELL***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2012/01/05	< .000	2013/01
NITRITE (AS N)	00620	036	2010/01/21	< 400.000	2013/01
RADIOLOGICAL					
GROSS ALPHA	01501	108	2010/06/18	.290	2019/06
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2009/09/08	.000	
2,4-D	39730	WAIVED	2009/09/08	.000	
ALACHLOR	77825	WAIVED	2009/09/08	.000	
ATRAZINE	39033	036	2009/09/08	.000	2012/09
BENTAZON	38710	WAIVED	2009/09/08	.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	036	2009/09/08	.000	2012/09
CHLORDANE	39350	WAIVED	2007/02/07	< .100	
DALAPON	38432	036	2009/09/08	.000	2012/09
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2006/12/27	.000	
DINOSEB	81287	036	2009/09/08	.000	2012/09
DIQUAT	78885	036	2009/09/08	.000	2012/09

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2801038
System Name: SILVER OAKS WINE CELLARS

PS Code: 2801038-003
Source Name: WELL 002-AG WELL
Source Number: 003
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	036	2009/09/08	.000	2012/09
ENDRIN	39390	WAIVED	2007/02/07	< .100	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2006/12/27	.000	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2007/02/07	< .010	
HEPTACHLOR EPOXIDE	39420	WAIVED	2007/02/07	< .010	
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED	2007/02/07	< .200	
METHOXYCHLOR	39480	WAIVED	2007/02/07	< 10.000	
MOLINATE	82199	WAIVED	2009/09/08	.000	
OXAMYL	38865	036	2009/09/08	.000	2012/09
PENTACHLOROPHENOL	39032	036	2009/09/08	.000	2012/09
PICLORAM	39720	036	2009/09/08	.000	2012/09
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2007/02/07	< .500	
SIMAZINE	39055	036	2009/09/08	.000	2012/09
THIOBENCARB	A-001	WAIVED	2009/09/08	.000	
TOXAPHENE	39400	WAIVED	2007/02/07	< 1.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	072	2006/12/27	.000	2012/12
1,1,2,2-TETRACHLOROETHANE	34516	072	2006/12/27	.000	2012/12
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2006/12/27	.000	2012/12
1,1,2-TRICHLOROETHANE	34511	072	2006/12/27	.000	2012/12
1,1-DICHLOROETHANE	34496	072	2006/12/27	.000	2012/12
1,1-DICHLOROETHYLENE	34501	072	2006/12/27	.000	2012/12
1,2,4-TRICHLOROBENZENE	34551	072	2006/12/27	.000	2012/12
1,2-DICHLOROBENZENE	34536	072	2006/12/27	.000	2012/12
1,2-DICHLOROETHANE	34531	072	2006/12/27	.000	2012/12
1,2-DICHLOROPROPANE	34541	072	2006/12/27	.000	2012/12

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801038***

System Name: ***SILVER OAKS WINE CELLARS***

PS Code: ***2801038-003***

Source Name: ***WELL 002-AG WELL***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2006/12/27	.000	2012/12
1,4-DICHLOROBENZENE	34571	072	2006/12/27	.000	2012/12
BENZENE	34030	072	2006/12/27	.000	2012/12
CARBON TETRACHLORIDE	32102	072	2006/12/27	.000	2012/12
CIS-1,2-DICHLOROETHYLENE	77093	072	2006/12/27	.000	2012/12
DICHLOROMETHANE	34423	072	2006/12/27	.000	2012/12
ETHYLBENZENE	34371	072	2006/12/27	.000	2012/12
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2009/09/08	.000	2015/09
MONOCHLOROBENZENE	34301	072	2006/12/27	.000	2012/12
STYRENE	77128	072	2006/12/27	.000	2012/12
TETRACHLOROETHYLENE	34475	072	2006/12/27	.000	2012/12
TOLUENE	34010	072	2006/12/27	.000	2012/12
TRANS-1,2-DICHLOROETHYLENE	34546	072	2006/12/27	.000	2012/12
TRICHLOROETHYLENE	39180	072	2006/12/27	.000	2012/12
TRICHLOROFLUOROMETHANE	34488	072	2006/12/27	.000	2012/12
VINYL CHLORIDE	39175	072	2006/12/27	.000	2012/12
XYLENES (TOTAL)	81551	072	2006/12/27	.000	2012/12
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2009/09/08	350.000	
CALCIUM	00916	WAIVED	2009/09/08	38.000	
CARBONATE ALKALINITY	00445	WAIVED	2009/09/08	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2009/09/08	360.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2009/09/08	.000	
IRON	01045	WAIVED	2009/09/08	670.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801038***

System Name: ***SILVER OAKS WINE CELLARS***

PS Code: ***2801038-003***

Source Name: ***WELL 002-AG WELL***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
SECONDARY/GP						
MAGNESIUM	00927	WAIVED	2009/09/08	46.000		
MANGANESE	01055	WAIVED	2009/09/08	140.000		
ODOR THRESHOLD @ 60 C	00086	WAIVED				
PH, LABORATORY	00403	WAIVED	2009/09/08	7.700		
SILVER	01077	WAIVED	2009/09/08	.000		
SODIUM	00929	WAIVED	2009/09/08	33.000		
SPECIFIC CONDUCTANCE	00095	WAIVED				
SULFATE	00945	WAIVED				
TOTAL DISSOLVED SOLIDS	70300	WAIVED				
TURBIDITY, LABORATORY	82079	WAIVED				
ZINC	01092	WAIVED				

PS Code: ***2801038-004***

Source Name: ***WELL 003***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	036	2012/01/31	< .000	2015/01	
ANTIMONY	01097	036	2012/01/31	< .000	2015/01	
ARSENIC	01002	036	2012/01/31	3.800	2015/01	
ASBESTOS	81855	000				**DUE**
BARIUM	01007	036	2012/01/31	< .000	2015/01	
BERYLLIUM	01012	036	2012/01/31	< .000	2015/01	
CADMIUM	01027	036	2012/01/31	< .000	2015/01	
CHROMIUM (TOTAL)	01034	036	2012/01/31	< .000	2015/01	
CYANIDE	01291	WAIVED	2009/09/22	.000		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801038***

System Name: ***SILVER OAKS WINE CELLARS***

PS Code: ***2801038-004***

Source Name: ***WELL 003***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
INORGANIC						
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2012/01/31	< .000	2015/01	
LEAD	01051	WAIVED	2012/01/31	< .000		
MERCURY	71900	036	2012/01/31	< .000	2015/01	
NICKEL	01067	036	2012/01/31	< .000	2015/01	
PERCHLORATE	A-031	006				**DUE**
SELENIUM	01147	036	2012/01/31	< .000	2015/01	
THALLIUM	01059	036	2012/01/31	< .000	2015/01	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2012/01/05	< .000	2013/01	
NITRITE (AS N)	00620	000				**DUE**
RADIOLOGICAL						
GROSS ALPHA	01501	108	2009/10/16	1.890	2018/10	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2012/01/31	< 1.000		
2,4-D	39730	WAIVED	2012/01/31	< 10.000		
ALACHLOR	77825	WAIVED	2009/09/22	.000		
ATRAZINE	39033	036	2012/01/31	< .500	2015/01	
BENTAZON	38710	WAIVED	2012/01/31	< 2.000		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801038***

System Name: ***SILVER OAKS WINE CELLARS***

PS Code: ***2801038-004***

Source Name: ***WELL 003***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2012/01/31	< 5.000	2015/01	
CHLORDANE	39350	WAIVED	2009/09/22	.000		
DALAPON	38432	036	2012/01/31	< 10.000	2015/01	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	036	2012/01/31	< 2.000	2015/01	
DIQUAT	78885	036	2012/01/31	< 4.000	2015/01	
ENDOTHALL	38926	036	2012/01/31	< 45.000	2015/01	
ENDRIN	39390	WAIVED	2009/09/22	.000		
ETHYLENE DIBROMIDE (EDB)	77651	000				**DUE**
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	WAIVED	2009/09/22	.000		
HEPTACHLOR EPOXIDE	39420	WAIVED	2009/09/22	.000		
HEXACHLOROBENZENE	39700	WAIVED	2009/09/22	.000		
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2009/09/22	.000		
LINDANE	39340	WAIVED	2009/09/22	.000		
METHOXYCHLOR	39480	WAIVED	2009/09/22	.000		
MOLINATE	82199	WAIVED	2009/09/22	.000		
OXAMYL	38865	036	2012/01/31	< 20.000	2015/01	
PENTACHLOROPHENOL	39032	036	2012/01/31	< .200	2015/01	
PICLORAM	39720	036	2012/01/31	< 1.000	2015/01	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2009/09/22	.000		
SIMAZINE	39055	036	2012/01/31	< 1.000	2015/01	
THIOBENCARB	A-001	WAIVED	2009/09/22	.000		
TOXAPHENE	39400	WAIVED	2009/09/22	.000		
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	000				**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801038***

System Name: ***SILVER OAKS WINE CELLARS***

PS Code: ***2801038-004***

Source Name: ***WELL 003***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	000			DUE
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	000			DUE
1,1,2-TRICHLOROETHANE	34511	000			DUE
1,1-DICHLOROETHANE	34496	000			DUE
1,1-DICHLOROETHYLENE	34501	000			DUE
1,2,4-TRICHLOROBENZENE	34551	000			DUE
1,2-DICHLOROBENZENE	34536	000			DUE
1,2-DICHLOROETHANE	34531	000			DUE
1,2-DICHLOROPROPANE	34541	000			DUE
1,3-DICHLOROPROPENE (TOTAL)	34561	000			DUE
1,4-DICHLOROBENZENE	34571	000			DUE
BENZENE	34030	000			DUE
CARBON TETRACHLORIDE	32102	000			DUE
CIS-1,2-DICHLOROETHYLENE	77093	000			DUE
DICHLOROMETHANE	34423	000			DUE
ETHYLBENZENE	34371	000			DUE
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	000			DUE
MONOCHLOROBENZENE	34301	000			DUE
STYRENE	77128	000			DUE
TETRACHLOROETHYLENE	34475	000			DUE
TOLUENE	34010	000			DUE
TRANS-1,2-DICHLOROETHYLENE	34546	000			DUE
TRICHLOROETHYLENE	39180	000			DUE
TRICHLOROFLUOROMETHANE	34488	000			DUE
VINYL CHLORIDE	39175	000			DUE
XYLENES (TOTAL)	81551	000			DUE
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2012/01/31	255.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801038***

System Name: ***SILVER OAKS WINE CELLARS***

PS Code: ***2801038-004***

Source Name: ***WELL 003***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED	2012/01/31	24.000	
CARBONATE ALKALINITY	00445	WAIVED	2012/01/31	< .000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED	2009/09/22	.000	
FOAMING AGENTS (MBAS)	38260	WAIVED	2009/09/22	.000	
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2012/01/31	180.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2012/01/31	< .000	
IRON	01045	WAIVED	2012/01/31	< .000	
MAGNESIUM	00927	WAIVED	2012/01/31	27.000	
MANGANESE	01055	WAIVED	2012/01/31	108.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2012/01/31	7.300	
SILVER	01077	WAIVED	2012/01/31	< .000	
SODIUM	00929	WAIVED	2012/01/31	30.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED	2009/09/22	360.000	
TURBIDITY, LABORATORY	82079	WAIVED	2009/09/22	.230	
ZINC	01092	WAIVED	2009/09/22	140.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801039***

System Name: ***SILVERADO HILL CELLARS***

PS Code: ***2801039-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED	2003/08/29	.000		
ANTIMONY	01097	WAIVED	2003/08/29	.000		
ARSENIC	01002	WAIVED	2009/12/01	8.000		
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED	2003/08/29	200.000		
BERYLLIUM	01012	WAIVED	2003/08/29	.000		
CADMIUM	01027	WAIVED	2003/08/29	.000		
CHROMIUM (TOTAL)	01034	WAIVED	2003/08/29	.000		
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2003/08/29	.200		
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED	2003/08/29	.000		
NICKEL	01067	WAIVED	2003/08/29	.000		
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED	2003/08/29	.000		
THALLIUM	01059	WAIVED	2003/08/29	.000		
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2003/08/29	.000	2004/08	DUE
NITRITE (AS N)	00620	036	2003/08/29	.000	2006/08	DUE
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801039***

System Name: ***SILVERADO HILL CELLARS***

PS Code: ***2801039-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801039***

System Name: ***SILVERADO HILL CELLARS***

PS Code: ***2801039-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801039***

System Name: ***SILVERADO HILL CELLARS***

PS Code: ***2801039-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	WAIVED	2003/08/29	80.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801039***

System Name: ***SILVERADO HILL CELLARS***

PS Code: ***2801039-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801039-002***

Source Name: ***WELL 002***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED	2012/04/05	.000	
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801039***

System Name: ***SILVERADO HILL CELLARS***

PS Code: ***2801039-002***

Source Name: ***WELL 002***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED	2012/02/15	.000	
NITRITE (AS N)	00620	WAIVED	2010/02/09	.000	
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801039***

System Name: ***SILVERADO HILL CELLARS***

PS Code: ***2801039-002***

Source Name: ***WELL 002***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801039***

System Name: ***SILVERADO HILL CELLARS***

PS Code: ***2801039-002***

Source Name: ***WELL 002***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED	2011/05/03	1100.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801039***

System Name: ***SILVERADO HILL CELLARS***

PS Code: ***2801039-002***

Source Name: ***WELL 002***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED	2011/05/03	520.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801041***

System Name: ***SILVERADO VINEYARDS***

PS Code: ***2801041-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2009/02/19	.000		
INORGANIC						
ALUMINUM	01105	036	2012/03/12	< .000	2015/03	
ANTIMONY	01097	036	2012/03/12	< .000	2015/03	
ARSENIC	01002	036	2012/03/12	3.900	2015/03	
ASBESTOS	81855	000				**DUE**
BARIUM	01007	036	2012/03/12	< .000	2015/03	
BERYLLIUM	01012	036	2012/03/12	< .000	2015/03	
CADMIUM	01027	036	2012/03/12	< .000	2015/03	
CHROMIUM (TOTAL)	01034	036	2012/03/12	< .000	2015/03	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2012/03/12	.160	2015/03	
LEAD	01051	WAIVED	2012/03/12	< .000		
MERCURY	71900	036	2012/03/12	< .000	2015/03	
NICKEL	01067	036	2012/03/12	< .000	2015/03	
PERCHLORATE	A-031	036	2010/03/10	.000	2013/03	
SELENIUM	01147	036	2012/03/12	< .000	2015/03	
THALLIUM	01059	036	2012/03/12	< .000	2015/03	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2012/01/10	< .000	2013/01	
NITRITE (AS N)	00620	036	2010/03/10	.000	2013/03	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2007/12/03	1.770	2016/12	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801041***

System Name: ***SILVERADO VINEYARDS***

PS Code: ***2801041-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2012/03/12	< 1.000		
2,4-D	39730	WAIVED	2012/03/12	< 10.000		
ALACHLOR	77825	WAIVED	2009/02/19	.000		
ATRAZINE	39033	036	**2009/02/19**	.000	**2012/02**	**DUE**
BENTAZON	38710	WAIVED	2012/03/12	< 2.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2012/03/12	< 5.000	2015/03	
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2012/03/12	< 10.000	2015/03	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2008/04/16	.000		
DINOSEB	81287	036	2012/03/12	< 2.000	2015/03	
DIQUAT	78885	036	2012/03/12	< 4.000	2015/03	
ENDOTHALL	38926	036	2012/03/12	< 45.000	2015/03	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2008/04/16	.000		
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801041***

System Name: ***SILVERADO VINEYARDS***

PS Code: ***2801041-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	000				DUE
MOLINATE	82199	WAIVED	2009/02/19	.000		
OXAMYL	38865	036	2012/03/12	< 20.000	2015/03	
PENTACHLOROPHENOL	39032	036	2012/03/12	< .200	2015/03	
PICLORAM	39720	036	2012/03/12	< 1.000	2015/03	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2009/02/19	.000	2012/02	DUE
THIOBENCARB	A-001	WAIVED	2009/02/19	.000		
TOXAPHENE	39400	000				DUE
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2008/04/16	.000	2014/04	
1,1,2,2-TETRACHLOROETHANE	34516	072	2008/04/16	.000	2014/04	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2008/04/16	.000	2014/04	
1,1,2-TRICHLOROETHANE	34511	072	2008/04/16	.000	2014/04	
1,1-DICHLOROETHANE	34496	072	2008/04/16	.000	2014/04	
1,1-DICHLOROETHYLENE	34501	072	2008/04/16	.000	2014/04	
1,2,4-TRICHLOROBENZENE	34551	072	2008/04/16	.000	2014/04	
1,2-DICHLOROBENZENE	34536	072	2008/04/16	.000	2014/04	
1,2-DICHLOROETHANE	34531	072	2008/04/16	.000	2014/04	
1,2-DICHLOROPROPANE	34541	072	2008/04/16	.000	2014/04	
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2008/04/16	.000	2014/04	
1,4-DICHLOROBENZENE	34571	072	2008/04/16	.000	2014/04	
BENZENE	34030	072	2008/04/16	.000	2014/04	
CARBON TETRACHLORIDE	32102	072	2008/04/16	.000	2014/04	
CIS-1,2-DICHLOROETHYLENE	77093	072	2008/04/16	.000	2014/04	
DICHLOROMETHANE	34423	072	2008/04/16	.000	2014/04	
ETHYLBENZENE	34371	072	2008/04/16	.000	2014/04	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2008/04/16	.000	2014/04	
MONOCHLOROBENZENE	34301	072	2008/04/16	.000	2014/04	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801041***

System Name: ***SILVERADO VINEYARDS***

PS Code: ***2801041-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2008/04/16	.000	2014/04
TETRACHLOROETHYLENE	34475	072	2008/04/16	.000	2014/04
TOLUENE	34010	072	2008/04/16	.000	2014/04
TRANS-1,2-DICHLOROETHYLENE	34546	072	2008/04/16	.000	2014/04
TRICHLOROETHYLENE	39180	072	2008/04/16	.000	2014/04
TRICHLOROFLUOROMETHANE	34488	072	2008/04/16	.000	2014/04
VINYL CHLORIDE	39175	072	2008/04/16	.000	2014/04
XYLENES (TOTAL)	81551	072	2008/04/16	.000	2014/04
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2010/03/10	250.000	
CALCIUM	00916	WAIVED	2010/03/10	35.000	
CARBONATE ALKALINITY	00445	WAIVED	2010/03/10	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2010/03/10	220.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2010/03/10	.000	
IRON	01045	WAIVED	2010/03/10	.000	
MAGNESIUM	00927	WAIVED	2010/03/10	28.000	
MANGANESE	01055	WAIVED	2010/03/10	180.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2010/03/10	7.600	
SILVER	01077	WAIVED	2012/03/12	< .000	
SODIUM	00929	WAIVED	2010/03/10	28.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801041***

System Name: ***SILVERADO VINEYARDS***

PS Code: ***2801041-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801041-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801041***

System Name: ***SILVERADO VINEYARDS***

PS Code: ***2801041-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801041***

System Name: ***SILVERADO VINEYARDS***

PS Code: ***2801041-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801041***

System Name: ***SILVERADO VINEYARDS***

PS Code: ***2801041-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801041***

System Name: ***SILVERADO VINEYARDS***

PS Code: ***2801041-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801042***

System Name: ***SINSKEY WINERY***

PS Code: ***2801042-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED	2003/04/02	< 6.000		
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED	2003/04/02	< 1.000		
CADMIUM	01027	WAIVED	2003/04/02	< 1.000		
CHROMIUM (TOTAL)	01034	WAIVED	2003/04/02	.000		
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED	2003/04/02	< 1.000		
NICKEL	01067	WAIVED	2003/04/02	< 10.000		
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED	2003/04/02	< 5.000		
THALLIUM	01059	WAIVED	2003/04/02	< 1.000		
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	**2011/01/31**	< 2.000	**2012/01**	**DUE**
NITRITE (AS N)	00620	036	2009/04/01	< 400.000	2012/04	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801042***

System Name: ***SINSKEY WINERY***

PS Code: ***2801042-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801042***

System Name: ***SINSKEY WINERY***

PS Code: ***2801042-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801042***

System Name: ***SINSKEY WINERY***

PS Code: ***2801042-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801042***

System Name: ***SINSKEY WINERY***

PS Code: ***2801042-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801042-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
DIAZINON	39570	WAIVED			

INORGANIC

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
ALUMINUM	01105	WAIVED	2008/10/29	< 50.000	
ANTIMONY	01097	WAIVED	2008/10/29	< 6.000	
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED	2008/10/29	< 1.000	
CADMIUM	01027	WAIVED	2008/10/29	< 1.000	
CHROMIUM (TOTAL)	01034	WAIVED	2008/10/29	< 1.000	
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2008/10/29	.340	
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED	2008/10/29	< 1.000	
NICKEL	01067	WAIVED	2008/10/29	< 10.000	
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED	2008/10/29	< 5.000	
THALLIUM	01059	WAIVED	2008/10/29	< 1.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801042***

System Name: ***SINSKEY WINERY***

PS Code: ***2801042-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/01/31	< 2.000	2012/01	DUE
NITRITE (AS N)	00620	036	2008/10/29	< 400.000	2011/10	DUE
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED				
2,4-D	39730	WAIVED				
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	WAIVED				
BENTAZON	38710	WAIVED				
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	WAIVED				
CHLORDANE	39350	WAIVED				
DALAPON	38432	WAIVED				
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	WAIVED				
DIQUAT	78885	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801042***

System Name: ***SINSKEY WINERY***

PS Code: ***2801042-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801042***

System Name: ***SINSKEY WINERY***

PS Code: ***2801042-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2008/10/29	440.000	
CALCIUM	00916	000			**DUE**
CARBONATE ALKALINITY	00445	WAIVED	2008/10/29	< 1.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2008/10/29	82.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2008/10/29	< 1.000	
IRON	01045	WAIVED	2008/10/29	990.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801042***

System Name: ***SINSKEY WINERY***

PS Code: ***2801042-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
SECONDARY/GP						
MAGNESIUM	00927	000				DUE
MANGANESE	01055	000				DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED				
PH, LABORATORY	00403	000				DUE
SILVER	01077	WAIVED	2008/10/29	< 10.000		
SODIUM	00929	000				DUE
SPECIFIC CONDUCTANCE	00095	WAIVED				
SULFATE	00945	WAIVED				
TOTAL DISSOLVED SOLIDS	70300	WAIVED				
TURBIDITY, LABORATORY	82079	WAIVED				
ZINC	01092	WAIVED				

PS Code: ***2801042-003***

Source Name: ***WELL #3***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED	2008/10/29	< 6.000		
ARSENIC	01002	WAIVED	2008/12/03	11.000		
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED	2008/10/29	110.000		
BERYLLIUM	01012	WAIVED	2008/10/29	< 1.000		
CADMIUM	01027	WAIVED	2008/10/29	< 1.000		
CHROMIUM (TOTAL)	01034	WAIVED	2008/10/29	< 1.000		
CYANIDE	01291	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801042***

System Name: ***SINSKEY WINERY***

PS Code: ***2801042-003***

Source Name: ***WELL #3***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
INORGANIC						
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2008/10/29	.380		
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED	2008/10/29	< 1.000		
NICKEL	01067	WAIVED	2008/10/29	62.000		
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED	2008/10/29	< 5.000		
THALLIUM	01059	WAIVED	2008/10/29	< 1.000		
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/01/31	< 2.000	2012/01	DUE
NITRITE (AS N)	00620	036	2008/10/29	< 400.000	2011/10	DUE
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED				
2,4-D	39730	WAIVED				
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	WAIVED				
BENTAZON	38710	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801042***

System Name: ***SINSKEY WINERY***

PS Code: ***2801042-003***

Source Name: ***WELL #3***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801042***

System Name: ***SINSKEY WINERY***

PS Code: ***2801042-003***

Source Name: ***WELL #3***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2008/10/29	350.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801042***

System Name: ***SINSKEY WINERY***

PS Code: ***2801042-003***

Source Name: ***WELL #3***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED	2008/10/29	94.000	
CARBONATE ALKALINITY	00445	WAIVED	2008/10/29	< 1.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2008/10/29	440.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2008/10/29	< 1.000	
IRON	01045	000			**DUE**
MAGNESIUM	00927	WAIVED	2008/10/29	50.000	
MANGANESE	01055	000			**DUE**
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2008/10/29	7.400	
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED	2008/10/29	39.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801042-004***

Source Name: ***WELL 4***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801042***

System Name: ***SINSKEY WINERY***

PS Code: ***2801042-004***

Source Name: ***WELL 4***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
INORGANIC						
ALUMINUM	01105	WAIVED	2008/10/29	< 50.000		
ANTIMONY	01097	WAIVED	2008/10/29	< 6.000		
ARSENIC	01002	WAIVED	2008/10/29	4.300		
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED	2008/10/29	130.000		
BERYLLIUM	01012	WAIVED	2008/10/29	< 1.000		
CADMIUM	01027	WAIVED	2008/10/29	< 1.000		
CHROMIUM (TOTAL)	01034	WAIVED	2008/10/29	< 1.000		
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2008/10/29	.340		
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED	2008/10/29	< 1.000		
NICKEL	01067	WAIVED	2008/10/29	< 10.000		
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED	2008/10/29	< 5.000		
THALLIUM	01059	WAIVED	2008/10/29	< 1.000		
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/01/31	< 2.000	2012/01	DUE
NITRITE (AS N)	00620	036	2008/10/29	< 400.000	2011/10	DUE
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801042***

System Name: ***SINSKEY WINERY***

PS Code: ***2801042-004***

Source Name: ***WELL 4***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801042***

System Name: ***SINSKEY WINERY***

PS Code: ***2801042-004***

Source Name: ***WELL 4***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801042***

System Name: ***SINSKEY WINERY***

PS Code: ***2801042-004***

Source Name: ***WELL 4***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2008/10/29	460.000	
CALCIUM	00916	WAIVED	2008/10/29	48.000	
CARBONATE ALKALINITY	00445	WAIVED	2008/10/29	< 1.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2008/10/29	230.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2008/10/29	< 1.000	
IRON	01045	WAIVED	2008/10/29	1100.000	
MAGNESIUM	00927	WAIVED	2008/10/29	27.000	
MANGANESE	01055	WAIVED	2008/10/29	120.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2008/10/29	7.500	
SILVER	01077	WAIVED	2008/10/29	< 10.000	
SODIUM	00929	WAIVED	2008/10/29	110.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801042***

System Name: ***SINSKEY WINERY***

PS Code: ***2801042-005***

Source Name: ***TREATMENT PLANT***

Source Number: ***005***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801042***

System Name: ***SINSKEY WINERY***

PS Code: ***2801042-005***

Source Name: ***TREATMENT PLANT***

Source Number: ***005***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801042***

System Name: ***SINSKEY WINERY***

PS Code: ***2801042-005***

Source Name: ***TREATMENT PLANT***

Source Number: ***005***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801042***

System Name: ***SINSKEY WINERY***

PS Code: ***2801042-005***

Source Name: ***TREATMENT PLANT***

Source Number: ***005***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801042***

System Name: ***SINSKEY WINERY***

PS Code: ***2801042-005***

Source Name: ***TREATMENT PLANT***

Source Number: ***005***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801043***

System Name: ***SKYLINE PARK***

PS Code: ***2801043-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED	2008/05/20	.000	
ANTIMONY	01097	WAIVED	2008/05/20	.000	
ARSENIC	01002	WAIVED	2008/05/20	3.000	
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED	2008/05/20	.000	
BERYLLIUM	01012	WAIVED	2008/05/20	.000	
CADMIUM	01027	WAIVED	2008/05/20	.000	
CHROMIUM (TOTAL)	01034	WAIVED	2008/05/20	.000	
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2008/05/20	.120	
LEAD	01051	WAIVED	2008/05/20	.000	
MERCURY	71900	WAIVED	2008/05/20	.000	
NICKEL	01067	WAIVED	2008/05/20	.000	
PERCHLORATE	A-031	WAIVED	2009/05/22	.000	
SELENIUM	01147	WAIVED	2008/05/20	.000	
THALLIUM	01059	WAIVED	2008/05/20	.000	
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2012/04/23	< .000	2013/04
NITRITE (AS N)	00620	036	2011/04/19	< .000	2014/04
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED	2009/02/03	.780	
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801043***

System Name: ***SKYLINE PARK***

PS Code: ***2801043-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801043***

System Name: ***SKYLINE PARK***

PS Code: ***2801043-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801043***

System Name: ***SKYLINE PARK***

PS Code: ***2801043-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2008/05/20	130.000	
CALCIUM	00916	WAIVED	2008/05/20	17.000	
CARBONATE ALKALINITY	00445	WAIVED	2008/05/20	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2008/05/20	77.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2008/05/20	.000	
IRON	01045	WAIVED	2008/05/20	350.000	
MAGNESIUM	00927	WAIVED	2008/05/20	8.600	
MANGANESE	01055	WAIVED	2008/05/20	100.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2008/05/20	7.500	
SILVER	01077	WAIVED	2008/05/20	.000	
SODIUM	00929	WAIVED	2008/05/20	22.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801043***

System Name: ***SKYLINE PARK***

PS Code: ***2801043-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801043-002***

Source Name: ***WEST WELL***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED	2008/05/19	.000	
ANTIMONY	01097	WAIVED	2008/05/19	.000	
ARSENIC	01002	WAIVED	2008/05/19	4.000	
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED	2008/05/19	.000	
BERYLLIUM	01012	WAIVED	2008/05/19	.000	
CADMIUM	01027	WAIVED	2008/05/19	.000	
CHROMIUM (TOTAL)	01034	WAIVED	2008/05/19	.000	
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2008/05/19	.000	
LEAD	01051	WAIVED	2008/05/19	.000	
MERCURY	71900	WAIVED	2008/05/19	.000	
NICKEL	01067	WAIVED	2008/05/19	.000	
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED	2008/05/19	.000	
THALLIUM	01059	WAIVED	2008/05/19	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801043***

System Name: ***SKYLINE PARK***

PS Code: ***2801043-002***

Source Name: ***WEST WELL***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2012/04/23	4.400	2013/04
NITRITE (AS N)	00620	036	2011/04/19	< .000	2014/04
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801043***

System Name: ***SKYLINE PARK***

PS Code: ***2801043-002***

Source Name: ***WEST WELL***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801043***

System Name: ***SKYLINE PARK***

PS Code: ***2801043-002***

Source Name: ***WEST WELL***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2008/05/19	120.000	
CALCIUM	00916	WAIVED	2008/05/19	16.000	
CARBONATE ALKALINITY	00445	WAIVED	2008/05/19	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2008/05/19	78.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2008/05/19	.000	
IRON	01045	WAIVED	2008/05/19	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801043***

System Name: ***SKYLINE PARK***

PS Code: ***2801043-002***

Source Name: ***WEST WELL***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED	2008/05/19	9.000	
MANGANESE	01055	WAIVED	2008/05/19	.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2008/05/19	6.800	
SILVER	01077	WAIVED	2008/05/19	.000	
SODIUM	00929	WAIVED	2008/05/19	14.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2801045
System Name: ST. CLEMENT VINEYARDS INC.

PS Code: 2801045-001
Source Name: LPA REPORTED PRIMARY SOURCE
Source Number: 001
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED	2008/12/19	< 50.000		
ANTIMONY	01097	WAIVED	2008/12/19	< 6.000		
ARSENIC	01002	WAIVED	2008/12/19	13.000		
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED	2008/12/19	280.000		
BERYLLIUM	01012	WAIVED	2008/12/19	< 1.000		
CADMIUM	01027	WAIVED	2008/12/19	< 1.000		
CHROMIUM (TOTAL)	01034	WAIVED	2008/12/19	< 1.000		
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2008/12/19	.200		
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED	2008/12/19	< 1.000		
NICKEL	01067	WAIVED	2008/12/19	< 10.000		
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED	2008/12/19	< 5.000		
THALLIUM	01059	WAIVED	2008/12/19	< 1.000		
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2010/03/10	8.900	2011/03	DUE
NITRITE (AS N)	00620	036	2008/12/19	< 400.000	2011/12	DUE
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801045***

System Name: ***ST. CLEMENT VINEYARDS INC.***

PS Code: ***2801045-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801045***

System Name: ***ST. CLEMENT VINEYARDS INC.***

PS Code: ***2801045-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801045***

System Name: ***ST. CLEMENT VINEYARDS INC.***

PS Code: ***2801045-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2008/12/19	340.000	
CALCIUM	00916	WAIVED	2008/12/19	27.000	
CARBONATE ALKALINITY	00445	WAIVED	2008/12/19	< 1.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2008/12/19	260.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2008/12/19	< 1.000	
IRON	01045	WAIVED	2008/12/19	< 100.000	
MAGNESIUM	00927	WAIVED	2008/12/19	46.000	
MANGANESE	01055	WAIVED	2008/12/19	340.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2008/12/19	7.900	
SILVER	01077	WAIVED	2008/12/19	< 10.000	
SODIUM	00929	WAIVED	2008/12/19	17.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801045***

System Name: ***ST. CLEMENT VINEYARDS INC.***

PS Code: ***2801045-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801046***

System Name: ***ST. SUPERY WINERY***

PS Code: ***2801046-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2007/04/05	.000		
INORGANIC						
ALUMINUM	01105	036	2010/04/13	86.000	2013/04	
ANTIMONY	01097	036	2010/04/13	.000	2013/04	
ARSENIC	01002	036	2010/04/13	.000	2013/04	
ASBESTOS	81855	108	2009/02/04	.000	2018/02	
BARIUM	01007	036	2010/04/13	130.000	2013/04	
BERYLLIUM	01012	036	2010/04/13	.000	2013/04	
CADMIUM	01027	036	2010/04/13	.000	2013/04	
CHROMIUM (TOTAL)	01034	036	2010/04/13	.000	2013/04	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2010/04/13	.000	2013/04	
LEAD	01051	WAIVED	2010/04/13	.000		
MERCURY	71900	036	2010/04/13	.000	2013/04	
NICKEL	01067	036	2010/04/13	.000	2013/04	
PERCHLORATE	A-031	036	**2009/02/04**	.000	**2012/02**	**DUE**
SELENIUM	01147	036	2010/04/13	.000	2013/04	
THALLIUM	01059	036	2010/04/13	.000	2013/04	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/05/03	< .000	2012/05	
NITRITE (AS N)	00620	036	2010/04/13	.000	2013/04	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2010/01/18	3.080	2019/01	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801046***

System Name: ***ST. SUPERY WINERY***

PS Code: ***2801046-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2009/02/04	.000		
2,4-D	39730	WAIVED	2009/02/04	.000		
ALACHLOR	77825	WAIVED	2007/04/09	< 1.000		
ATRAZINE	39033	036	2010/10/29	< .500	2013/10	
BENTAZON	38710	WAIVED	2009/02/04	.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2009/02/04	.000	2012/02	DUE
CHLORDANE	39350	WAIVED	2007/04/09	< .100		
DALAPON	38432	036	2009/02/04	.000	2012/02	DUE
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2010/04/13	.000		
DINOSEB	81287	036	2009/02/04	.000	2012/02	DUE
DIQUAT	78885	036	2009/02/04	.000	2012/02	DUE
ENDOTHALL	38926	036	2009/02/04	.000	2012/02	DUE
ENDRIN	39390	WAIVED	2007/04/09	< .100		
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2010/04/13	.000		
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	WAIVED	2007/04/09	< .010		
HEPTACHLOR EPOXIDE	39420	WAIVED	2007/04/09	< .010		
HEXACHLOROBENZENE	39700	WAIVED	2002/09/09	.000		
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2002/09/09	.000		
LINDANE	39340	WAIVED	2007/04/09	< .200		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801046***

System Name: ***ST. SUPERY WINERY***

PS Code: ***2801046-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	WAIVED	2007/04/09	< 10.000		
MOLINATE	82199	WAIVED	2007/04/05	.000		
OXAMYL	38865	036	2009/02/04	.000	2012/02	DUE
PENTACHLOROPHENOL	39032	036	2009/02/04	.000	2012/02	DUE
PICLORAM	39720	036	2009/02/04	.000	2012/02	DUE
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2007/04/09	< .500		
SIMAZINE	39055	036	2010/10/29	< 1.000	2013/10	
THIOBENCARB	A-001	WAIVED	2007/04/05	.000		
TOXAPHENE	39400	WAIVED	2007/04/09	< 1.000		
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2010/04/13	.000	2016/04	
1,1,2,2-TETRACHLOROETHANE	34516	072	2010/04/13	.000	2016/04	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2010/04/13	.000	2016/04	
1,1,2-TRICHLOROETHANE	34511	072	2010/04/13	.000	2016/04	
1,1-DICHLOROETHANE	34496	072	2010/04/13	.000	2016/04	
1,1-DICHLOROETHYLENE	34501	072	2010/04/13	.000	2016/04	
1,2,4-TRICHLOROBENZENE	34551	072	2010/04/13	.000	2016/04	
1,2-DICHLOROBENZENE	34536	072	2010/04/13	.000	2016/04	
1,2-DICHLOROETHANE	34531	072	2010/04/13	.000	2016/04	
1,2-DICHLOROPROPANE	34541	072	2010/04/13	.000	2016/04	
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2010/04/13	.000	2016/04	
1,4-DICHLOROBENZENE	34571	072	2010/04/13	.000	2016/04	
BENZENE	34030	072	2010/04/13	.000	2016/04	
CARBON TETRACHLORIDE	32102	072	2010/04/13	.000	2016/04	
CIS-1,2-DICHLOROETHYLENE	77093	072	2010/04/13	.000	2016/04	
DICHLOROMETHANE	34423	072	2010/04/13	.000	2016/04	
ETHYLBENZENE	34371	072	2010/04/13	.000	2016/04	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2010/04/13	.000	2016/04	
MONOCHLOROBENZENE	34301	072	2010/04/13	.000	2016/04	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801046***

System Name: ***ST. SUPERY WINERY***

PS Code: ***2801046-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2010/04/13	.000	2016/04
TETRACHLOROETHYLENE	34475	072	2010/04/13	.000	2016/04
TOLUENE	34010	072	2010/04/13	.000	2016/04
TRANS-1,2-DICHLOROETHYLENE	34546	072	2010/04/13	.000	2016/04
TRICHLOROETHYLENE	39180	072	2010/04/13	.000	2016/04
TRICHLOROFLUOROMETHANE	34488	072	2010/04/13	.000	2016/04
VINYL CHLORIDE	39175	072	2010/04/13	.000	2016/04
XYLENES (TOTAL)	81551	072	2010/04/13	.000	2016/04
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2010/04/13	210.000	
CALCIUM	00916	WAIVED	2010/04/13	29.000	
CARBONATE ALKALINITY	00445	WAIVED	2010/04/13	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2010/04/13	220.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2010/04/13	.000	
IRON	01045	WAIVED	2010/04/13	360.000	
MAGNESIUM	00927	WAIVED	2010/04/13	33.000	
MANGANESE	01055	WAIVED	2010/04/13	.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2010/04/13	6.600	
SILVER	01077	WAIVED	2010/04/13	.000	
SODIUM	00929	WAIVED	2010/04/13	47.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801046***

System Name: ***ST. SUPERY WINERY***

PS Code: ***2801046-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801046-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED	2007/04/05	.000	
INORGANIC					
ALUMINUM	01105	036	2010/04/15	.000	2013/04
ANTIMONY	01097	036	2010/04/15	.000	2013/04
ARSENIC	01002	036	2010/04/15	.000	2013/04
ASBESTOS	81855	108	2009/02/04	.000	2018/02
BARIUM	01007	036	2010/04/15	180.000	2013/04
BERYLLIUM	01012	036	2010/04/15	.000	2013/04
CADMIUM	01027	036	2010/04/15	1.400	2013/04
CHROMIUM (TOTAL)	01034	036	2010/04/15	.000	2013/04
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2010/04/15	.100	2013/04
LEAD	01051	WAIVED	2010/04/15	.000	
MERCURY	71900	036	2010/04/15	.000	2013/04
NICKEL	01067	036	2010/04/15	.000	2013/04
PERCHLORATE	A-031	036	2010/04/15	.000	2013/04
SELENIUM	01147	036	2010/04/15	.000	2013/04
THALLIUM	01059	036	2010/04/15	.000	2013/04

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801046***

System Name: ***ST. SUPERY WINERY***

PS Code: ***2801046-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/05/18	< .000	2012/05	
NITRITE (AS N)	00620	036	2010/04/15	.000	2013/04	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2012/01/18	1.220	2021/01	
GROSS BETA	03501	WAIVED	2008/08/14	1.900		
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED	2010/10/29	.000		
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2009/02/04	.000		
2,4-D	39730	WAIVED	2009/02/04	.000		
ALACHLOR	77825	WAIVED	2007/04/09	< 1.000		
ATRAZINE	39033	036	2010/10/29	< .500	2013/10	
BENTAZON	38710	WAIVED	2009/02/04	.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2009/02/04	.000	2012/02	DUE
CHLORDANE	39350	WAIVED	2009/02/04	.000		
DALAPON	38432	036	2009/02/04	.000	2012/02	DUE
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2007/04/09	< .010		
DINOSEB	81287	036	2009/02/04	.000	2012/02	DUE
DIQUAT	78885	036	2009/02/04	.000	2012/02	DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801046***

System Name: ***ST. SUPERY WINERY***

PS Code: ***2801046-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
ENDOTHALL	38926	036	2009/02/04	.000	2012/02	DUE
ENDRIN	39390	WAIVED	2009/02/04	.000		
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2007/04/09	< .020		
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	WAIVED	2009/02/04	.000		
HEPTACHLOR EPOXIDE	39420	WAIVED	2009/02/04	.000		
HEXACHLOROBENZENE	39700	WAIVED	2009/02/04	.000		
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2009/02/04	.000		
LINDANE	39340	WAIVED	2009/02/04	.000		
METHOXYCHLOR	39480	WAIVED	2009/02/04	.000		
MOLINATE	82199	WAIVED	2007/04/05	.000		
OXAMYL	38865	036	2009/02/04	.000	2012/02	DUE
PENTACHLOROPHENOL	39032	036	2009/02/04	.000	2012/02	DUE
PICLORAM	39720	036	2009/02/04	.000	2012/02	DUE
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2009/02/04	.000		
SIMAZINE	39055	036	2010/10/29	< 1.000	2013/10	
THIOBENCARB	A-001	WAIVED	2007/04/05	.000		
TOXAPHENE	39400	WAIVED	2009/02/04	.000		
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2007/04/05	.000	2013/04	
1,1,2,2-TETRACHLOROETHANE	34516	072	2007/04/05	.000	2013/04	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2007/04/05	.000	2013/04	
1,1,2-TRICHLOROETHANE	34511	072	2007/04/05	.000	2013/04	
1,1-DICHLOROETHANE	34496	072	2007/04/05	.000	2013/04	
1,1-DICHLOROETHYLENE	34501	072	2007/04/05	.000	2013/04	
1,2,4-TRICHLOROBENZENE	34551	072	2007/04/05	.000	2013/04	
1,2-DICHLOROBENZENE	34536	072	2007/04/05	.000	2013/04	
1,2-DICHLOROETHANE	34531	072	2007/04/05	.000	2013/04	
1,2-DICHLOROPROPANE	34541	072	2007/04/05	.000	2013/04	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801046***

System Name: ***ST. SUPERY WINERY***

PS Code: ***2801046-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2007/04/05	.000	2013/04
1,4-DICHLOROBENZENE	34571	072	2007/04/05	.000	2013/04
BENZENE	34030	072	2007/04/05	.000	2013/04
CARBON TETRACHLORIDE	32102	072	2007/04/05	.000	2013/04
CIS-1,2-DICHLOROETHYLENE	77093	072	2007/04/05	.000	2013/04
DICHLOROMETHANE	34423	072	2007/04/05	.000	2013/04
ETHYLBENZENE	34371	072	2007/04/05	.000	2013/04
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2010/04/15	.000	2016/04
MONOCHLOROBENZENE	34301	072	2007/04/05	.000	2013/04
STYRENE	77128	072	2007/04/05	.000	2013/04
TETRACHLOROETHYLENE	34475	072	2007/04/05	.000	2013/04
TOLUENE	34010	072	2007/04/05	.000	2013/04
TRANS-1,2-DICHLOROETHYLENE	34546	072	2007/04/05	.000	2013/04
TRICHLOROETHYLENE	39180	072	2007/04/05	.000	2013/04
TRICHLOROFLUOROMETHANE	34488	072	2007/04/05	.000	2013/04
VINYL CHLORIDE	39175	072	2007/04/05	.000	2013/04
XYLENES (TOTAL)	81551	072	2007/04/05	.000	2013/04
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2010/04/15	230.000	
CALCIUM	00916	WAIVED	2010/04/15	41.000	
CARBONATE ALKALINITY	00445	WAIVED	2010/04/15	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2010/04/15	240.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2010/04/15	.000	
IRON	01045	WAIVED	2010/04/15	5300.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801046***

System Name: ***ST. SUPERY WINERY***

PS Code: ***2801046-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
MAGNESIUM	00927	WAIVED	2010/04/15	30.000	
MANGANESE	01055	WAIVED	2010/04/15	1100.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2010/04/15	6.900	
SILVER	01077	WAIVED	2010/04/15	.000	
SODIUM	00929	WAIVED	2010/04/15	33.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801046-003***

Source Name: ***DISTRIBUTION SYSTEM***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801046***

System Name: ***ST. SUPERY WINERY***

PS Code: ***2801046-003***

Source Name: ***DISTRIBUTION SYSTEM***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801046***

System Name: ***ST. SUPERY WINERY***

PS Code: ***2801046-003***

Source Name: ***DISTRIBUTION SYSTEM***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801046***

System Name: ***ST. SUPERY WINERY***

PS Code: ***2801046-003***

Source Name: ***DISTRIBUTION SYSTEM***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801046***

System Name: ***ST. SUPERY WINERY***

PS Code: ***2801046-003***

Source Name: ***DISTRIBUTION SYSTEM***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801047***

System Name: ***STAG S LEAP WINE CELLARS***

PS Code: ***2801047-001***

Source Name: ***OLD WELL-1986***

Source Number: ***001***

Source Status: ***STANDBY RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	108	2009/08/10	880.000	2018/08
ANTIMONY	01097	108	2009/08/10	< 6.000	2018/08
ARSENIC	01002	108	2009/08/10	7.400	2018/08
ASBESTOS	81855	108	2007/03/14	.000	2016/03
BARIUM	01007	108	2009/08/10	< 100.000	2018/08
BERYLLIUM	01012	108	2009/08/10	< 1.000	2018/08
CADMIUM	01027	108	2009/08/10	< 1.000	2018/08
CHROMIUM (TOTAL)	01034	108	2009/08/10	< 1.000	2018/08
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	108	2009/08/10	.830	2018/08
LEAD	01051	WAIVED			
MERCURY	71900	108	2009/08/10	< 1.000	2018/08
NICKEL	01067	108	2009/08/10	< 10.000	2018/08
PERCHLORATE	A-031	108	2010/11/17	< 4.000	2019/11
SELENIUM	01147	108	2009/08/10	< 5.000	2018/08
THALLIUM	01059	108	2009/08/10	< 1.000	2018/08
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	108	2010/11/17	< 2.000	2019/11
NITRITE (AS N)	00620	108	2009/08/10	< 400.000	2018/08
RADIOLOGICAL					
GROSS ALPHA	01501	108	2008/12/10	1.540	2017/12
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801047***

System Name: ***STAG S LEAP WINE CELLARS***

PS Code: ***2801047-001***

Source Name: ***OLD WELL-1986***

Source Number: ***001***

Source Status: ***STANDBY RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2010/12/08	.000	
2,4-D	39730	WAIVED	2010/12/08	.000	
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED	2010/12/08	.000	
BENTAZON	38710	WAIVED	2010/12/08	.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED	2010/12/08	.000	
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED	2010/12/08	.000	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED	2000/04/11	.000	
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED	2000/04/11	.000	
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED	2010/12/08	.000	
DIQUAT	78885	WAIVED	2010/12/08	.000	
ENDOTHALL	38926	WAIVED	2010/12/08	.000	
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	000			DUE
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	000			DUE
HEPTACHLOR EPOXIDE	39420	000			DUE
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801047***

System Name: ***STAG S LEAP WINE CELLARS***

PS Code: ***2801047-001***

Source Name: ***OLD WELL-1986***

Source Number: ***001***

Source Status: ***STANDBY RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	000				DUE
MOLINATE	82199	WAIVED				
OXAMYL	38865	WAIVED	2010/12/08	.000		
PENTACHLOROPHENOL	39032	WAIVED	2010/12/08	.000		
PICLORAM	39720	WAIVED	2010/12/08	.000		
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	WAIVED	2010/12/08	.000		
THIOBENCARB	A-001	WAIVED				
TOXAPHENE	39400	000				DUE
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	WAIVED	2001/11/14	.000		
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED	2001/11/14	.000		
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED	2001/11/14	.000		
1,1,2-TRICHLOROETHANE	34511	WAIVED	2001/11/14	.000		
1,1-DICHLOROETHANE	34496	WAIVED	2001/11/14	.000		
1,1-DICHLOROETHYLENE	34501	WAIVED	2001/11/14	.000		
1,2,4-TRICHLOROBENZENE	34551	WAIVED	2001/11/14	.000		
1,2-DICHLOROBENZENE	34536	WAIVED	2001/11/14	.000		
1,2-DICHLOROETHANE	34531	WAIVED	2001/11/14	.000		
1,2-DICHLOROPROPANE	34541	WAIVED	2001/11/14	.000		
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED	2001/11/14	.000		
1,4-DICHLOROBENZENE	34571	WAIVED	2001/11/14	.000		
BENZENE	34030	WAIVED	2001/11/14	.000		
CARBON TETRACHLORIDE	32102	WAIVED	2001/11/14	.000		
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED	2001/11/14	.000		
DICHLOROMETHANE	34423	WAIVED	2001/11/14	.000		
ETHYLBENZENE	34371	WAIVED	2001/11/14	.000		
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	108	2009/08/10	.000	2018/08	
MONOCHLOROBENZENE	34301	WAIVED	2001/11/14	.000		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2801047
System Name: STAG S LEAP WINE CELLARS

PS Code: 2801047-001
Source Name: OLD WELL-1986
Source Number: 001
Source Status: STANDBY RAW
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED VOC						
STYRENE	77128	WAIVED	2001/11/14	.000		
TETRACHLOROETHYLENE	34475	WAIVED	2001/11/14	.000		
TOLUENE	34010	WAIVED	2001/11/14	.000		
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED	2001/11/14	.000		
TRICHLOROETHYLENE	39180	WAIVED	2001/11/14	.000		
TRICHLOROFLUOROMETHANE	34488	WAIVED	2001/11/14	.000		
VINYL CHLORIDE	39175	WAIVED	2001/11/14	.000		
XYLENES (TOTAL)	81551	WAIVED	2001/11/14	.000		
SECONDARY/GP						
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED				
BICARBONATE ALKALINITY	00440	108	2009/08/10	110.000	2018/08	
CALCIUM	00916	108	2009/08/10	22.000	2018/08	
CARBONATE ALKALINITY	00445	108	2009/08/10	< 1.000	2018/08	
CHLORIDE	00940	108	2002/05/08	4.100	2011/05	DUE
COLOR	00081	000				DUE
COPPER	01042	000				DUE
FOAMING AGENTS (MBAS)	38260	108	2002/03/06	< .050	2011/03	DUE
HARDNESS (TOTAL) AS CACO3	00900	108	2009/08/10	92.000	2018/08	
HYDROXIDE ALKALINITY	71830	108	2009/08/10	< 1.000	2018/08	
IRON	01045	108	2009/08/10	3500.000	2018/08	
MAGNESIUM	00927	108	2009/08/10	8.900	2018/08	
MANGANESE	01055	108	2010/03/16	150.000	2019/03	
ODOR THRESHOLD @ 60 C	00086	000				DUE
PH, LABORATORY	00403	108	2009/08/10	7.400	2018/08	
SILVER	01077	108	2002/05/08	< 10.000	2011/05	DUE
SODIUM	00929	108	2009/08/10	39.000	2018/08	
SPECIFIC CONDUCTANCE	00095	108	2002/05/08	790.000	2011/05	DUE
SULFATE	00945	000				DUE
TOTAL DISSOLVED SOLIDS	70300	000				DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801047***

System Name: ***STAG S LEAP WINE CELLARS***

PS Code: ***2801047-001***

Source Name: ***OLD WELL-1986***

Source Number: ***001***

Source Status: ***STANDBY RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
SECONDARY/GP						
TURBIDITY, LABORATORY	82079	108	2007/12/12	.290	2016/12	
ZINC	01092	000				DUE

PS Code: ***2801047-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15		
DIAZINON	39570	WAIVED
INORGANIC		
ALUMINUM	01105	WAIVED
ANTIMONY	01097	WAIVED
ARSENIC	01002	WAIVED
ASBESTOS	81855	WAIVED
BARIUM	01007	WAIVED
BERYLLIUM	01012	WAIVED
CADMIUM	01027	WAIVED
CHROMIUM (TOTAL)	01034	WAIVED
CYANIDE	01291	WAIVED
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED
LEAD	01051	WAIVED
MERCURY	71900	WAIVED
NICKEL	01067	WAIVED
PERCHLORATE	A-031	WAIVED
SELENIUM	01147	WAIVED
THALLIUM	01059	WAIVED

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801047***

System Name: ***STAG S LEAP WINE CELLARS***

PS Code: ***2801047-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801047***

System Name: ***STAG S LEAP WINE CELLARS***

PS Code: ***2801047-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801047***

System Name: ***STAG S LEAP WINE CELLARS***

PS Code: ***2801047-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2801047
System Name: STAG S LEAP WINE CELLARS

PS Code: 2801047-002
Source Name: TREATMENT PLANT
Source Number: 002
Source Status: ACTIVE TREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: 2801047-003
Source Name: NEW WELL-1996
Source Number: 003
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	036	2009/08/10	< 50.000	2012/08
ANTIMONY	01097	036	2009/08/10	< 6.000	2012/08
ARSENIC	01002	036	2009/08/10	2.300	2012/08
ASBESTOS	81855	108	2007/03/14	.000	2016/03
BARIUM	01007	036	2009/08/10	< 100.000	2012/08
BERYLLIUM	01012	036	2009/08/10	< 1.000	2012/08
CADMIUM	01027	036	2009/08/10	< 1.000	2012/08
CHROMIUM (TOTAL)	01034	036	2009/08/10	< 1.000	2012/08
CYANIDE	01291	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2801047
System Name: STAG S LEAP WINE CELLARS

PS Code: 2801047-003
Source Name: NEW WELL-1996
Source Number: 003
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
INORGANIC						
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2009/08/10	.430	2012/08	
LEAD	01051	WAIVED				
MERCURY	71900	036	2009/08/10	< 1.000	2012/08	
NICKEL	01067	036	2009/08/10	< 10.000	2012/08	
PERCHLORATE	A-031	036	2010/06/16	< 4.000	2013/06	
SELENIUM	01147	036	2009/08/10	< 5.000	2012/08	
THALLIUM	01059	036	2009/08/10	< 1.000	2012/08	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2010/11/17	5.100	2011/11	DUE
NITRITE (AS N)	00620	036	2009/08/10	< 400.000	2012/08	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2008/12/10	.485	2017/12	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2009/08/10	.000		
2,4-D	39730	WAIVED	2009/08/10	.000		
ALACHLOR	77825	WAIVED	2007/12/12	.000		
ATRAZINE	39033	036	2009/08/10	.000	2012/08	
BENTAZON	38710	WAIVED	2009/08/10	.000		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801047***

System Name: ***STAG S LEAP WINE CELLARS***

PS Code: ***2801047-003***

Source Name: ***NEW WELL-1996***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	036	2009/08/10	.000	2012/08
CHLORDANE	39350	WAIVED	2007/12/12	.000	
DALAPON	38432	036	2009/08/10	.000	2012/08
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	036	2009/08/10	.000	2012/08
DIQUAT	78885	036	2009/08/10	.000	2012/08
ENDOTHALL	38926	036	2009/08/10	.000	2012/08
ENDRIN	39390	WAIVED	2007/12/12	.000	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2007/12/12	.000	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2007/12/12	.000	
HEPTACHLOR EPOXIDE	39420	WAIVED	2007/12/12	.000	
HEXACHLOROBENZENE	39700	WAIVED	2007/12/12	.000	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2007/12/12	.000	
LINDANE	39340	WAIVED	2007/12/12	.000	
METHOXYCHLOR	39480	WAIVED	2007/12/12	.000	
MOLINATE	82199	WAIVED			
OXAMYL	38865	036	2009/08/10	.000	2012/08
PENTACHLOROPHENOL	39032	036	2009/08/10	.000	2012/08
PICLORAM	39720	036	2009/08/10	.000	2012/08
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	036	2009/08/10	.000	2012/08
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED	2007/12/12	.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	072	2011/09/14	.000	2017/09

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2801047
System Name: STAG S LEAP WINE CELLARS

PS Code: 2801047-003
Source Name: NEW WELL-1996
Source Number: 003
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	072	2011/09/14	.000	2017/09
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2011/09/14	.000	2017/09
1,1,2-TRICHLOROETHANE	34511	072	2011/09/14	.000	2017/09
1,1-DICHLOROETHANE	34496	072	2011/09/14	.000	2017/09
1,1-DICHLOROETHYLENE	34501	072	2011/09/14	.000	2017/09
1,2,4-TRICHLOROBENZENE	34551	072	2011/09/14	.000	2017/09
1,2-DICHLOROBENZENE	34536	072	2011/09/14	.000	2017/09
1,2-DICHLOROETHANE	34531	072	2011/09/14	.000	2017/09
1,2-DICHLOROPROPANE	34541	072	2011/09/14	.000	2017/09
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2011/09/14	.000	2017/09
1,4-DICHLOROBENZENE	34571	072	2011/09/14	.000	2017/09
BENZENE	34030	072	2011/09/14	.000	2017/09
CARBON TETRACHLORIDE	32102	072	2011/09/14	.000	2017/09
CIS-1,2-DICHLOROETHYLENE	77093	072	2011/09/14	.000	2017/09
DICHLOROMETHANE	34423	072	2011/09/14	.000	2017/09
ETHYLBENZENE	34371	072	2011/09/14	.000	2017/09
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2011/09/14	.000	2017/09
MONOCHLOROBENZENE	34301	072	2011/09/14	.000	2017/09
STYRENE	77128	072	2011/09/14	.000	2017/09
TETRACHLOROETHYLENE	34475	072	2011/09/14	.000	2017/09
TOLUENE	34010	072	2011/09/14	.000	2017/09
TRANS-1,2-DICHLOROETHYLENE	34546	072	2011/09/14	.000	2017/09
TRICHLOROETHYLENE	39180	072	2011/09/14	.000	2017/09
TRICHLOROFLUOROMETHANE	34488	072	2011/09/14	.000	2017/09
VINYL CHLORIDE	39175	072	2011/09/14	.000	2017/09
XYLENES (TOTAL)	81551	072	2011/09/14	.000	2017/09
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2009/08/10	120.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2801047
System Name: STAG S LEAP WINE CELLARS

PS Code: 2801047-003
Source Name: NEW WELL-1996
Source Number: 003
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED	2009/08/10	17.000	
CARBONATE ALKALINITY	00445	WAIVED	2009/08/10	< 1.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2009/08/10	56.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2009/08/10	< 1.000	
IRON	01045	WAIVED	2009/08/10	310.000	
MAGNESIUM	00927	WAIVED	2009/08/10	3.400	
MANGANESE	01055	WAIVED	2010/11/17	29.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2009/08/10	7.900	
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED	2009/08/10	43.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED	2007/12/12	.210	
ZINC	01092	WAIVED			

PS Code: 2801047-004
Source Name: WELL 003
Source Number: 004
Source Status: STANDBY RAW
Water type: GROUNDWATER OR WELL

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801047***

System Name: ***STAG S LEAP WINE CELLARS***

PS Code: ***2801047-004***

Source Name: ***WELL 003***

Source Number: ***004***

Source Status: ***STANDBY RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
ALUMINUM	01105	108	2010/03/16	< 50.000	2019/03
ANTIMONY	01097	108	2010/03/16	< 6.000	2019/03
ARSENIC	01002	108	2010/03/16	< 2.000	2019/03
ASBESTOS	81855	108	2007/03/14	.000	2016/03
BARIUM	01007	108	2010/03/16	< 100.000	2019/03
BERYLLIUM	01012	108	2010/03/16	< 1.000	2019/03
CADMIUM	01027	108	2010/03/16	< 1.000	2019/03
CHROMIUM (TOTAL)	01034	108	2010/03/16	< 1.000	2019/03
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	108	2010/03/16	.880	2019/03
LEAD	01051	WAIVED			
MERCURY	71900	108	2010/03/16	< 1.000	2019/03
NICKEL	01067	108	2010/03/16	< 10.000	2019/03
PERCHLORATE	A-031	108	2010/11/17	< 4.000	2019/11
SELENIUM	01147	108	2010/03/16	< 5.000	2019/03
THALLIUM	01059	108	2010/03/16	< 1.000	2019/03
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	108	2010/03/16	< 2.000	2019/03
NITRITE (AS N)	00620	108	2010/03/16	< 400.000	2019/03
RADIOLOGICAL					
GROSS ALPHA	01501	108	2008/12/10	.000	2017/12
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801047***

System Name: ***STAG S LEAP WINE CELLARS***

PS Code: ***2801047-004***

Source Name: ***WELL 003***

Source Number: ***004***

Source Status: ***STANDBY RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2010/12/08	.000	
2,4-D	39730	WAIVED	2010/12/08	.000	
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED	2010/12/08	.000	
BENTAZON	38710	WAIVED	2010/12/08	.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED	2010/12/08	.000	
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED	2010/12/08	.000	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED	2010/12/08	.000	
DIQUAT	78885	WAIVED	2010/12/08	.000	
ENDOTHALL	38926	WAIVED	2010/12/08	.000	
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	000			DUE
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	000			DUE
HEPTACHLOR EPOXIDE	39420	000			DUE
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	000			DUE
METHOXYCHLOR	39480	000			DUE
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED	2010/12/08	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801047***

System Name: ***STAG S LEAP WINE CELLARS***

PS Code: ***2801047-004***

Source Name: ***WELL 003***

Source Number: ***004***

Source Status: ***STANDBY RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
PENTACHLOROPHENOL	39032	WAIVED	2010/12/08	.000		
PICLORAM	39720	WAIVED	2010/12/08	.000		
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	WAIVED	2010/12/08	.000		
THIOBENCARB	A-001	WAIVED				
TOXAPHENE	39400	000				**DUE**
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	WAIVED	2006/08/30	.000		
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED	2006/08/30	.000		
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED	2006/08/30	.000		
1,1,2-TRICHLOROETHANE	34511	WAIVED	2006/08/30	.000		
1,1-DICHLOROETHANE	34496	WAIVED	2006/08/30	.000		
1,1-DICHLOROETHYLENE	34501	WAIVED	2006/08/30	.000		
1,2,4-TRICHLOROBENZENE	34551	WAIVED	2006/08/30	.000		
1,2-DICHLOROBENZENE	34536	WAIVED	2006/08/30	.000		
1,2-DICHLOROETHANE	34531	WAIVED	2006/08/30	.000		
1,2-DICHLOROPROPANE	34541	WAIVED	2006/08/30	.000		
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED	2006/08/30	.000		
1,4-DICHLOROBENZENE	34571	WAIVED	2006/08/30	.000		
BENZENE	34030	WAIVED	2006/08/30	.000		
CARBON TETRACHLORIDE	32102	WAIVED	2006/08/30	.000		
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED	2006/08/30	.000		
DICHLOROMETHANE	34423	WAIVED	2006/08/30	.000		
ETHYLBENZENE	34371	WAIVED	2006/08/30	.000		
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	108	2007/12/12	.000	2016/12	
MONOCHLOROBENZENE	34301	WAIVED	2006/08/30	.000		
STYRENE	77128	WAIVED	2006/08/30	.000		
TETRACHLOROETHYLENE	34475	WAIVED	2006/08/30	.000		
TOLUENE	34010	WAIVED	2006/08/30	.000		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801047***

System Name: ***STAG S LEAP WINE CELLARS***

PS Code: ***2801047-004***

Source Name: ***WELL 003***

Source Number: ***004***

Source Status: ***STANDBY RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED VOC						
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED	2006/08/30	.000		
TRICHLOROETHYLENE	39180	WAIVED	2006/08/30	.000		
TRICHLOROFLUOROMETHANE	34488	WAIVED	2006/08/30	.000		
VINYL CHLORIDE	39175	WAIVED	2006/08/30	.000		
XYLENES (TOTAL)	81551	WAIVED	2006/08/30	.000		
SECONDARY/GP						
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED				
BICARBONATE ALKALINITY	00440	108	2007/12/12	120.000	2016/12	
CALCIUM	00916	108	2007/12/12	5.900	2016/12	
CARBONATE ALKALINITY	00445	108	2007/12/12	12.000	2016/12	
CHLORIDE	00940	108	2007/12/12	5.200	2016/12	
COLOR	00081	000				**DUE**
COPPER	01042	108	2007/12/12	< 50.000	2016/12	
FOAMING AGENTS (MBAS)	38260	108	2007/12/12	< .050	2016/12	
HARDNESS (TOTAL) AS CACO3	00900	108	2007/12/12	28.000	2016/12	
HYDROXIDE ALKALINITY	71830	108	2007/12/12	< 1.000	2016/12	
IRON	01045	108	2007/12/12	< 100.000	2016/12	
MAGNESIUM	00927	108	2007/12/12	3.400	2016/12	
MANGANESE	01055	108	2007/12/12	70.000	2016/12	
ODOR THRESHOLD @ 60 C	00086	000				**DUE**
PH, LABORATORY	00403	108	2007/12/12	8.800	2016/12	
SILVER	01077	108	2010/03/16	< 10.000	2019/03	
SODIUM	00929	108	2007/12/12	58.000	2016/12	
SPECIFIC CONDUCTANCE	00095	000				**DUE**
SULFATE	00945	108	2007/12/12	17.000	2016/12	
TOTAL DISSOLVED SOLIDS	70300	000				**DUE**
TURBIDITY, LABORATORY	82079	108	2007/12/12	34.000	2016/12	
ZINC	01092	108	2007/12/12	< 50.000	2016/12	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801049***

System Name: ***THE RANCH WINERY***

PS Code: ***2801049-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2007/03/06	.000		
INORGANIC						
ALUMINUM	01105	036	2007/03/06	.000	2010/03	DUE
ANTIMONY	01097	036	2007/03/06	.000	2010/03	DUE
ARSENIC	01002	036	2007/03/06	3.100	2010/03	DUE
ASBESTOS	81855	108	2002/04/22	.000	2011/04	DUE
BARIUM	01007	036	2007/03/06	220.000	2010/03	DUE
BERYLLIUM	01012	036	2007/03/06	.000	2010/03	DUE
CADMIUM	01027	036	2007/03/06	.000	2010/03	DUE
CHROMIUM (TOTAL)	01034	036	2007/03/06	.000	2010/03	DUE
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2007/03/06	.000	2010/03	DUE
LEAD	01051	WAIVED	2007/03/06	.000		
MERCURY	71900	036	2007/03/06	.000	2010/03	DUE
NICKEL	01067	036	2007/03/06	.000	2010/03	DUE
PERCHLORATE	A-031	036	2011/08/23	< 4.000	2014/08	
SELENIUM	01147	036	2007/03/06	.000	2010/03	DUE
THALLIUM	01059	036	2007/03/06	.000	2010/03	DUE
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2012/02/27	5.200	2013/02	
NITRITE (AS N)	00620	036	2010/01/15	.000	2013/01	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2007/07/05	.930	2016/07	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801049***

System Name: ***THE RANCH WINERY***

PS Code: ***2801049-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2007/03/06	< 1.000		
2,4-D	39730	WAIVED	2007/03/06	< 10.000		
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	036	2007/03/06	.000	2010/03	DUE
BENTAZON	38710	WAIVED	2007/03/06	< 2.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2007/03/06	< 5.000	2010/03	DUE
CHLORDANE	39350	WAIVED	2004/07/14	.000		
DALAPON	38432	036	2007/03/06	< 10.000	2010/03	DUE
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2007/03/06	.000		
DINOSEB	81287	036	2007/03/06	< 2.000	2010/03	DUE
DIQUAT	78885	036	2007/03/06	< 4.000	2010/03	DUE
ENDOTHALL	38926	036	2007/03/06	< 45.000	2010/03	DUE
ENDRIN	39390	WAIVED	2004/07/14	.000		
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2007/03/06	.000		
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	WAIVED	2004/07/14	.000		
HEPTACHLOR EPOXIDE	39420	WAIVED	2004/07/14	.000		
HEXACHLOROBENZENE	39700	WAIVED	2004/07/14	.000		
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2004/07/14	.000		
LINDANE	39340	WAIVED	2004/07/14	.000		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801049***

System Name: ***THE RANCH WINERY***

PS Code: ***2801049-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	WAIVED	2004/07/14	.000		
MOLINATE	82199	WAIVED	2007/03/06	.000		
OXAMYL	38865	036	2007/03/06	< 20.000	2010/03	DUE
PENTACHLOROPHENOL	39032	036	2007/03/06	< .200	2010/03	DUE
PICLORAM	39720	036	2007/03/06	< 1.000	2010/03	DUE
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2004/07/14	.000		
SIMAZINE	39055	036	2007/03/06	.000	2010/03	DUE
THIOBENCARB	A-001	WAIVED	2007/03/06	.000		
TOXAPHENE	39400	WAIVED	2004/07/14	.000		
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2012/03/21	.000	2018/03	
1,1,2,2-TETRACHLOROETHANE	34516	072	2012/03/21	.000	2018/03	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2012/03/21	.000	2018/03	
1,1,2-TRICHLOROETHANE	34511	072	2012/03/21	.000	2018/03	
1,1-DICHLOROETHANE	34496	072	2012/03/21	.000	2018/03	
1,1-DICHLOROETHYLENE	34501	072	2012/03/21	.000	2018/03	
1,2,4-TRICHLOROBENZENE	34551	072	2012/03/21	.000	2018/03	
1,2-DICHLOROBENZENE	34536	072	2012/03/21	.000	2018/03	
1,2-DICHLOROETHANE	34531	072	2012/03/21	.000	2018/03	
1,2-DICHLOROPROPANE	34541	072	2012/03/21	.000	2018/03	
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2012/03/21	.000	2018/03	
1,4-DICHLOROBENZENE	34571	072	2012/03/21	.000	2018/03	
BENZENE	34030	072	2012/03/21	.000	2018/03	
CARBON TETRACHLORIDE	32102	072	2012/03/21	.000	2018/03	
CIS-1,2-DICHLOROETHYLENE	77093	072	2012/03/21	.000	2018/03	
DICHLOROMETHANE	34423	072	2012/03/21	.000	2018/03	
ETHYLBENZENE	34371	072	2012/03/21	.000	2018/03	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2012/03/21	.000	2018/03	
MONOCHLOROBENZENE	34301	072	2012/03/21	.000	2018/03	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801049***

System Name: ***THE RANCH WINERY***

PS Code: ***2801049-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2012/03/21	.000	2018/03
TETRACHLOROETHYLENE	34475	072	2012/03/21	.000	2018/03
TOLUENE	34010	072	2012/03/21	.000	2018/03
TRANS-1,2-DICHLOROETHYLENE	34546	072	2012/03/21	.000	2018/03
TRICHLOROETHYLENE	39180	072	2012/03/21	.000	2018/03
TRICHLOROFLUOROMETHANE	34488	072	2012/03/21	.000	2018/03
VINYL CHLORIDE	39175	072	2012/03/21	.000	2018/03
XYLENES (TOTAL)	81551	072	2012/03/21	.000	2018/03
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2007/03/06	210.000	
CALCIUM	00916	WAIVED	2007/03/06	30.000	
CARBONATE ALKALINITY	00445	WAIVED	2007/03/06	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2007/03/06	150.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2007/03/06	.000	
IRON	01045	WAIVED	2007/03/06	410.000	
MAGNESIUM	00927	WAIVED	2007/03/06	15.000	
MANGANESE	01055	WAIVED	2007/03/06	450.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2007/03/06	7.600	
SILVER	01077	WAIVED	2007/03/06	.000	
SODIUM	00929	WAIVED	2007/03/06	30.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801049***

System Name: ***THE RANCH WINERY***

PS Code: ***2801049-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
SECONDARY/GP						
TURBIDITY, LABORATORY	82079	WAIVED				
ZINC	01092	WAIVED				

PS Code: ***2801049-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2007/03/06	.000		
INORGANIC						
ALUMINUM	01105	036	2011/08/23	< 50.000	2014/08	
ANTIMONY	01097	036	2011/08/23	< 6.000	2014/08	
ARSENIC	01002	036	2011/08/23	2.200	2014/08	
ASBESTOS	81855	000				**DUE**
BARIUM	01007	036	2011/08/23	180.000	2014/08	
BERYLLIUM	01012	036	2011/08/23	< 1.000	2014/08	
CADMIUM	01027	036	2011/08/23	< 1.000	2014/08	
CHROMIUM (TOTAL)	01034	036	2011/08/23	< 10.000	2014/08	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	**2007/03/06**	.000	**2010/03**	**DUE**
LEAD	01051	WAIVED	2007/03/06	.000		
MERCURY	71900	036	2011/08/23	< 1.000	2014/08	
NICKEL	01067	036	2011/08/23	< 10.000	2014/08	
PERCHLORATE	A-031	036	2011/08/23	< 4.000	2014/08	
SELENIUM	01147	036	2011/08/23	< 5.000	2014/08	
THALLIUM	01059	036	2011/08/23	< 1.000	2014/08	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801049***

System Name: ***THE RANCH WINERY***

PS Code: ***2801049-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2012/02/27	7.300	2013/02	
NITRITE (AS N)	00620	036	2010/01/15	.000	2013/01	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2007/07/05	1.010	2016/07	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2007/03/06	< 1.000		
2,4-D	39730	WAIVED	2007/03/06	< 10.000		
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	036	2007/03/06	.000	2010/03	DUE
BENTAZON	38710	WAIVED	2007/03/06	< 2.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2007/03/06	< 5.000	2010/03	DUE
CHLORDANE	39350	WAIVED	2004/07/14	.000		
DALAPON	38432	036	2007/03/06	< 10.000	2010/03	DUE
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2007/03/06	.000		
DINOSEB	81287	036	2007/03/06	< 2.000	2010/03	DUE
DIQUAT	78885	036	2007/03/06	< 4.000	2010/03	DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801049***

System Name: ***THE RANCH WINERY***

PS Code: ***2801049-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
ENDOTHALL	38926	036	2007/03/06	< 45.000	2010/03	DUE
ENDRIN	39390	WAIVED	2004/07/14	.000		
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2007/03/06	.000		
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	WAIVED	2004/07/14	.000		
HEPTACHLOR EPOXIDE	39420	WAIVED	2004/07/14	.000		
HEXACHLOROBENZENE	39700	WAIVED	2004/07/14	.000		
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2004/07/14	.000		
LINDANE	39340	WAIVED	2004/07/14	.000		
METHOXYCHLOR	39480	WAIVED	2004/07/14	.000		
MOLINATE	82199	WAIVED	2007/03/06	.000		
OXAMYL	38865	036	2007/03/06	< 20.000	2010/03	DUE
PENTACHLOROPHENOL	39032	036	2007/03/06	< .200	2010/03	DUE
PICLORAM	39720	036	2007/03/06	< 1.000	2010/03	DUE
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2004/07/14	.000		
SIMAZINE	39055	036	2007/03/06	.000	2010/03	DUE
THIOBENCARB	A-001	WAIVED	2007/03/06	.000		
TOXAPHENE	39400	WAIVED	2004/07/14	.000		
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2007/03/06	.000	2013/03	
1,1,2,2-TETRACHLOROETHANE	34516	072	2007/03/06	.000	2013/03	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2007/03/06	.000	2013/03	
1,1,2-TRICHLOROETHANE	34511	072	2007/03/06	.000	2013/03	
1,1-DICHLOROETHANE	34496	072	2007/03/06	.000	2013/03	
1,1-DICHLOROETHYLENE	34501	072	2007/03/06	.000	2013/03	
1,2,4-TRICHLOROBENZENE	34551	072	2012/03/21	.000	2018/03	
1,2-DICHLOROBENZENE	34536	072	2007/03/06	.000	2013/03	
1,2-DICHLOROETHANE	34531	072	2007/03/06	.000	2013/03	
1,2-DICHLOROPROPANE	34541	072	2007/03/06	.000	2013/03	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801049***

System Name: ***THE RANCH WINERY***

PS Code: ***2801049-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2007/03/06	.000	2013/03
1,4-DICHLOROBENZENE	34571	072	2007/03/06	.000	2013/03
BENZENE	34030	072	2007/03/06	.000	2013/03
CARBON TETRACHLORIDE	32102	072	2007/03/06	.000	2013/03
CIS-1,2-DICHLOROETHYLENE	77093	072	2007/03/06	.000	2013/03
DICHLOROMETHANE	34423	072	2007/03/06	.000	2013/03
ETHYLBENZENE	34371	072	2007/03/06	.000	2013/03
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2011/08/23	.000	2017/08
MONOCHLOROBENZENE	34301	072	2007/03/06	.000	2013/03
STYRENE	77128	072	2011/08/23	.000	2017/08
TETRACHLOROETHYLENE	34475	072	2007/03/06	.000	2013/03
TOLUENE	34010	072	2007/03/06	.000	2013/03
TRANS-1,2-DICHLOROETHYLENE	34546	072	2007/03/06	.000	2013/03
TRICHLOROETHYLENE	39180	072	2007/03/06	.000	2013/03
TRICHLOROFLUOROMETHANE	34488	072	2011/08/23	.000	2017/08
VINYL CHLORIDE	39175	072	2007/03/06	.000	2013/03
XYLENES (TOTAL)	81551	072	2007/03/06	.000	2013/03
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2011/08/23	260.000	
CALCIUM	00916	WAIVED	2011/08/23	39.000	
CARBONATE ALKALINITY	00445	WAIVED	2011/08/23	< 1.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2011/08/23	220.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2011/08/23	< 1.000	
IRON	01045	WAIVED	2011/08/23	< 100.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801049***

System Name: ***THE RANCH WINERY***

PS Code: ***2801049-002***

Source Name: ***WELL #2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
MAGNESIUM	00927	WAIVED	2011/08/23	29.000	
MANGANESE	01055	WAIVED	2011/08/23	140.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2011/08/23	7.000	
SILVER	01077	WAIVED	2011/08/23	< 10.000	
SODIUM	00929	WAIVED	2011/08/23	27.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801049-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801049***

System Name: ***THE RANCH WINERY***

PS Code: ***2801049-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801049***

System Name: ***THE RANCH WINERY***

PS Code: ***2801049-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801049***

System Name: ***THE RANCH WINERY***

PS Code: ***2801049-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801049***

System Name: ***THE RANCH WINERY***

PS Code: ***2801049-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801052***

System Name: ***DIAMOND OAKS VINEYARD***

PS Code: ***2801052-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED	2004/03/18	.000		
ANTIMONY	01097	WAIVED	2004/03/18	.000		
ARSENIC	01002	WAIVED	2004/03/18	7.000		
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED	2004/03/18	.000		
BERYLLIUM	01012	WAIVED	2004/03/18	.000		
CADMIUM	01027	WAIVED	2004/03/18	.000		
CHROMIUM (TOTAL)	01034	WAIVED	2004/03/18	.000		
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2004/03/18	.200		
LEAD	01051	WAIVED	2003/01/16	.000		
MERCURY	71900	WAIVED	2004/03/18	.000		
NICKEL	01067	WAIVED	2004/03/18	.000		
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED	2004/03/18	.000		
THALLIUM	01059	WAIVED	2004/03/18	.000		
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2004/03/18	.000	2005/03	DUE
NITRITE (AS N)	00620	036	2004/03/18	.000	2007/03	DUE
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801052***

System Name: ***DIAMOND OAKS VINEYARD***

PS Code: ***2801052-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801052***

System Name: ***DIAMOND OAKS VINEYARD***

PS Code: ***2801052-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801052***

System Name: ***DIAMOND OAKS VINEYARD***

PS Code: ***2801052-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2003/12/02	150.000	
CALCIUM	00916	WAIVED	2003/12/02	22.000	
CARBONATE ALKALINITY	00445	WAIVED	2003/12/02	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2003/12/02	120.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2003/12/02	.000	
IRON	01045	WAIVED	2003/12/02	.000	
MAGNESIUM	00927	WAIVED	2003/12/02	12.000	
MANGANESE	01055	WAIVED	2003/12/02	.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2003/12/02	7.100	
SILVER	01077	WAIVED	2003/01/16	.000	
SODIUM	00929	WAIVED	2003/12/02	14.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801052***

System Name: ***DIAMOND OAKS VINEYARD***

PS Code: ***2801052-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801052-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801052***

System Name: ***DIAMOND OAKS VINEYARD***

PS Code: ***2801052-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801052***

System Name: ***DIAMOND OAKS VINEYARD***

PS Code: ***2801052-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801052***

System Name: ***DIAMOND OAKS VINEYARD***

PS Code: ***2801052-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801052***

System Name: ***DIAMOND OAKS VINEYARD***

PS Code: ***2801052-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801054***

System Name: ***WHITE SULPHUR SPRINGS RESORT***

PS Code: ***2801054-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED	2002/06/05	< 50.000		
ANTIMONY	01097	WAIVED	2002/06/05	< 6.000		
ARSENIC	01002	WAIVED	2002/06/05	< 2.000		
ASBESTOS	81855	WAIVED	2002/06/05	< .200		
BARIUM	01007	WAIVED	2002/06/05	< 100.000		
BERYLLIUM	01012	WAIVED	2002/06/05	< 1.000		
CADMIUM	01027	WAIVED	2002/06/05	< 1.000		
CHROMIUM (TOTAL)	01034	WAIVED	2002/06/05	.000		
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2002/06/05	.220		
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED	2002/06/05	< 1.000		
NICKEL	01067	WAIVED	2002/06/05	< 10.000		
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED	2002/06/05	< 5.000		
THALLIUM	01059	WAIVED	2002/06/05	< 1.000		
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2008/04/02	< 2.000	2009/04	DUE
NITRITE (AS N)	00620	036	2002/03/20	< 10.000	2005/03	DUE
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801054***

System Name: ***WHITE SULPHUR SPRINGS RESORT***

PS Code: ***2801054-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2002/06/05	.000	
2,4-D	39730	WAIVED	2002/06/05	.000	
ALACHLOR	77825	WAIVED	2002/06/05	.000	
ATRAZINE	39033	WAIVED	2002/06/05	.000	
BENTAZON	38710	WAIVED	2002/06/05	.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED	2002/06/05	.000	
CHLORDANE	39350	WAIVED	2002/06/05	.000	
DALAPON	38432	WAIVED	2002/06/05	.000	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED	2002/06/05	.000	
DIQUAT	78885	WAIVED	2002/06/05	.000	
ENDOTHALL	38926	WAIVED	2002/06/05	.000	
ENDRIN	39390	WAIVED	2002/06/05	.000	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2002/06/05	.000	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2002/06/05	.000	
HEPTACHLOR EPOXIDE	39420	WAIVED	2002/06/05	.000	
HEXACHLOROBENZENE	39700	WAIVED	2002/06/05	.000	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2002/06/05	.000	
LINDANE	39340	WAIVED	2002/06/05	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2801054
System Name: WHITE SULPHUR SPRINGS RESORT

PS Code: 2801054-001
Source Name: LPA REPORTED PRIMARY SOURCE
Source Number: 001
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED	2002/06/05	.000	
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED	2002/06/05	.000	
PENTACHLOROPHENOL	39032	WAIVED	2002/06/05	.000	
PICLORAM	39720	WAIVED	2002/06/05	.000	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED	2002/06/05	.000	
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED	2002/06/05	.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED	2002/06/05	.000	
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED	2002/06/05	.000	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED	2002/06/05	.000	
1,1,2-TRICHLOROETHANE	34511	WAIVED	2002/06/05	.000	
1,1-DICHLOROETHANE	34496	WAIVED	2002/06/05	.000	
1,1-DICHLOROETHYLENE	34501	WAIVED	2002/06/05	.000	
1,2,4-TRICHLOROBENZENE	34551	WAIVED	2002/06/05	.000	
1,2-DICHLOROBENZENE	34536	WAIVED	2002/06/05	.000	
1,2-DICHLOROETHANE	34531	WAIVED	2002/06/05	.000	
1,2-DICHLOROPROPANE	34541	WAIVED	2002/06/05	.000	
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED	2002/06/05	.000	
1,4-DICHLOROBENZENE	34571	WAIVED	2002/06/05	.000	
BENZENE	34030	WAIVED	2002/06/05	.000	
CARBON TETRACHLORIDE	32102	WAIVED	2002/06/05	.000	
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED	2002/06/05	.000	
DICHLOROMETHANE	34423	WAIVED	2002/06/05	.000	
ETHYLBENZENE	34371	WAIVED	2002/06/05	.000	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED	2002/06/05	.000	
MONOCHLOROBENZENE	34301	WAIVED	2002/06/05	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2801054

System Name: WHITE SULPHUR SPRINGS RESORT

PS Code: 2801054-001

Source Name: LPA REPORTED PRIMARY SOURCE

Source Number: 001

Source Status: ACTIVE UNTREATED

Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED	2002/06/05	.000	
TETRACHLOROETHYLENE	34475	WAIVED	2002/06/05	.000	
TOLUENE	34010	WAIVED	2002/06/05	.000	
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED	2002/06/05	.000	
TRICHLOROETHYLENE	39180	WAIVED	2002/06/05	.000	
TRICHLOROFLUOROMETHANE	34488	WAIVED	2002/06/05	.000	
VINYL CHLORIDE	39175	WAIVED	2002/06/05	.000	
XYLENES (TOTAL)	81551	WAIVED	2002/06/05	.000	
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2002/03/20	230.000	
CALCIUM	00916	WAIVED	2002/03/20	48.000	
CARBONATE ALKALINITY	00445	WAIVED	2002/03/20	< 1.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2002/03/20	210.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2002/03/20	< 1.000	
IRON	01045	WAIVED	2002/03/20	190.000	
MAGNESIUM	00927	WAIVED	2002/03/20	24.000	
MANGANESE	01055	WAIVED	2002/03/20	< 30.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2002/03/20	7.700	
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED	2002/03/20	22.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801054***

System Name: ***WHITE SULPHUR SPRINGS RESORT***

PS Code: ***2801054-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801054-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801054***

System Name: ***WHITE SULPHUR SPRINGS RESORT***

PS Code: ***2801054-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801054***

System Name: ***WHITE SULPHUR SPRINGS RESORT***

PS Code: ***2801054-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801054***

System Name: ***WHITE SULPHUR SPRINGS RESORT***

PS Code: ***2801054-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801054***

System Name: ***WHITE SULPHUR SPRINGS RESORT***

PS Code: ***2801054-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801055***

System Name: ***WILLIAM HILL WINERY***

PS Code: ***2801055-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED	2007/12/13	< 2.000	
INORGANIC					
ALUMINUM	01105	036	2012/03/07	< .000	2015/03
ANTIMONY	01097	036	2012/03/07	< .000	2015/03
ARSENIC	01002	036	2012/03/07	4.200	2015/03
ASBESTOS	81855	108	2007/12/13	.000	2016/12
BARIUM	01007	036	2012/03/07	< .000	2015/03
BERYLLIUM	01012	036	2012/03/07	< .000	2015/03
CADMIUM	01027	036	2012/03/07	< .000	2015/03
CHROMIUM (TOTAL)	01034	036	2012/03/07	< .000	2015/03
CYANIDE	01291	WAIVED	2007/12/13	< .005	
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2012/03/07	< .000	2015/03
LEAD	01051	WAIVED	2012/03/07	< .000	
MERCURY	71900	036	2012/03/07	< .000	2015/03
NICKEL	01067	036	2012/03/07	< .000	2015/03
PERCHLORATE	A-031	036	2009/05/13	.000	2012/05
SELENIUM	01147	036	2012/03/07	< .000	2015/03
THALLIUM	01059	036	2012/03/07	< .000	2015/03
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2011/12/01	3.300	2012/12
NITRITE (AS N)	00620	036	2010/12/03	.000	2013/12
RADIOLOGICAL					
GROSS ALPHA	01501	108	2009/03/20	6.020	2018/03
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801055***

System Name: ***WILLIAM HILL WINERY***

PS Code: ***2801055-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2010/12/14	< 1.000		
2,4-D	39730	WAIVED	2010/12/14	< 10.000		
ALACHLOR	77825	WAIVED	2007/12/13	< .200		
ATRAZINE	39033	036	2010/12/14	< .500	2013/12	
BENTAZON	38710	WAIVED	2010/12/14	< 2.000		
BENZO (A) PYRENE	34247	WAIVED	2010/12/14	< .100		
CARBOFURAN	81405	036	2010/12/14	< 5.000	2013/12	
CHLORDANE	39350	WAIVED	2007/12/13	< .100		
DALAPON	38432	036	2010/12/14	< 10.000	2013/12	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED	2010/12/14	< 5.000		
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED	2010/12/14	< 3.000		
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2007/12/13	< .010		
DINOSEB	81287	036	2010/12/14	< 2.000	2013/12	
DIQUAT	78885	036	2010/12/14	< 4.000	2013/12	
ENDOTHALL	38926	036	**2007/12/13**	< 40.000	**2010/12**	**DUE**
ENDRIN	39390	WAIVED	2007/12/13	< .010		
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2007/12/13	< .020		
GLYPHOSATE	79743	WAIVED	2007/12/13	< 20.000		
HEPTACHLOR	39410	WAIVED	2007/12/13	< .010		
HEPTACHLOR EPOXIDE	39420	WAIVED	2007/12/13	< .010		
HEXACHLOROBENZENE	39700	WAIVED	2010/12/14	< .500		
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2010/12/14	< 1.000		
LINDANE	39340	WAIVED	2007/12/13	< .050		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801055***

System Name: ***WILLIAM HILL WINERY***

PS Code: ***2801055-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED	2007/12/13	< .100	
MOLINATE	82199	WAIVED	2010/12/14	< 2.000	
OXAMYL	38865	036	2010/12/14	< 20.000	2013/12
PENTACHLOROPHENOL	39032	036	2010/12/14	< .200	2013/12
PICLORAM	39720	036	2010/12/14	< 1.000	2013/12
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2002/06/10	.000	
SIMAZINE	39055	036	2010/12/14	< 1.000	2013/12
THIOBENCARB	A-001	WAIVED	2010/12/14	< 1.000	
TOXAPHENE	39400	WAIVED	2007/12/13	< .500	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	072	2007/12/13	< .500	2013/12
1,1,2,2-TETRACHLOROETHANE	34516	072	2007/12/13	< .500	2013/12
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2007/12/13	< .500	2013/12
1,1,2-TRICHLOROETHANE	34511	072	2007/12/13	< .500	2013/12
1,1-DICHLOROETHANE	34496	072	2007/12/13	< .500	2013/12
1,1-DICHLOROETHYLENE	34501	072	2007/12/13	< .500	2013/12
1,2,4-TRICHLOROBENZENE	34551	072	2007/12/13	< .500	2013/12
1,2-DICHLOROBENZENE	34536	072	2007/12/13	< .500	2013/12
1,2-DICHLOROETHANE	34531	072	2007/12/13	< .500	2013/12
1,2-DICHLOROPROPANE	34541	072	2007/12/13	< .500	2013/12
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2007/05/07	.000	2013/05
1,4-DICHLOROBENZENE	34571	072	2007/12/13	< .500	2013/12
BENZENE	34030	072	2007/12/13	< .500	2013/12
CARBON TETRACHLORIDE	32102	072	2007/12/13	< .500	2013/12
CIS-1,2-DICHLOROETHYLENE	77093	072	2007/12/13	< .500	2013/12
DICHLOROMETHANE	34423	072	2007/12/13	< .500	2013/12
ETHYLBENZENE	34371	072	2007/12/13	< .500	2013/12
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2007/12/13	< 1.000	2013/12
MONOCHLOROBENZENE	34301	072	2007/12/13	< .500	2013/12

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2801055
System Name: WILLIAM HILL WINERY

PS Code: 2801055-001
Source Name: LPA REPORTED PRIMARY SOURCE
Source Number: 001
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2007/12/13	< .500	2013/12
TETRACHLOROETHYLENE	34475	072	2007/12/13	< .500	2013/12
TOLUENE	34010	072	2007/12/13	< .500	2013/12
TRANS-1,2-DICHLOROETHYLENE	34546	072	2007/12/13	< .500	2013/12
TRICHLOROETHYLENE	39180	072	2007/12/13	< .500	2013/12
TRICHLOROFLUOROMETHANE	34488	072	2007/12/13	< .500	2013/12
VINYL CHLORIDE	39175	072	2007/12/13	< .500	2013/12
XYLENES (TOTAL)	81551	072	2007/12/13	< .500	2013/12
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED	2007/12/13	11.400	
BICARBONATE ALKALINITY	00440	WAIVED	2010/12/14	336.000	
CALCIUM	00916	WAIVED	2010/12/14	34.000	
CARBONATE ALKALINITY	00445	WAIVED	2010/12/14	.000	
CHLORIDE	00940	WAIVED	2007/12/13	9.000	
COLOR	00081	WAIVED	2007/12/13	< 5.000	
COPPER	01042	WAIVED	2007/12/13	40.000	
FOAMING AGENTS (MBAS)	38260	WAIVED	2007/12/13	< .100	
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2010/12/14	170.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2010/12/14	.000	
IRON	01045	WAIVED	2010/12/14	.000	
MAGNESIUM	00927	WAIVED	2010/12/14	24.000	
MANGANESE	01055	WAIVED	2010/12/14	.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED	2007/12/13	< 1.000	
PH, LABORATORY	00403	WAIVED	2010/12/14	7.500	
SILVER	01077	WAIVED	2012/03/07	< .000	
SODIUM	00929	WAIVED	2010/12/14	56.000	
SPECIFIC CONDUCTANCE	00095	WAIVED	2007/12/13	595.000	
SULFATE	00945	WAIVED	2007/12/13	8.000	
TOTAL DISSOLVED SOLIDS	70300	WAIVED	2007/12/13	420.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801055***

System Name: ***WILLIAM HILL WINERY***

PS Code: ***2801055-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	**82079**	**WAIVED**	2007/12/13	**.300**	
ZINC	**01092**	**WAIVED**	2007/12/13	**70.000**	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801056***

System Name: ***Z D WINES***

PS Code: ***2801056-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED	2005/03/30	< 50.000		
ANTIMONY	01097	WAIVED	2005/03/30	< 6.000		
ARSENIC	01002	WAIVED	2008/11/12	4.000		
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED	2005/03/30	< 100.000		
BERYLLIUM	01012	WAIVED	2005/03/30	< 1.000		
CADMIUM	01027	WAIVED	2005/03/30	< 1.000		
CHROMIUM (TOTAL)	01034	WAIVED	2005/03/30	1.900		
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2005/03/30	.390		
LEAD	01051	WAIVED	2005/03/30	< 5.000		
MERCURY	71900	WAIVED	2005/03/30	< 1.000		
NICKEL	01067	WAIVED	2005/03/30	< 10.000		
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED	2005/03/30	< 5.000		
THALLIUM	01059	WAIVED	2005/03/30	< 1.000		
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/05/11	5.700	2012/05	
NITRITE (AS N)	00620	036	**2008/04/09**	< 400.000	**2011/04**	**DUE**
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801056***

System Name: ***Z D WINES***

PS Code: ***2801056-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801056***

System Name: ***Z D WINES***

PS Code: ***2801056-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801056***

System Name: ***Z D WINES***

PS Code: ***2801056-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED	2005/03/30	10.900	
BICARBONATE ALKALINITY	00440	WAIVED	2005/03/30	170.000	
CALCIUM	00916	WAIVED	2005/03/30	17.000	
CARBONATE ALKALINITY	00445	WAIVED	2005/03/30	< 1.000	
CHLORIDE	00940	WAIVED	2005/03/30	8.400	
COLOR	00081	WAIVED			
COPPER	01042	WAIVED	2005/03/30	350.000	
FOAMING AGENTS (MBAS)	38260	WAIVED	2005/03/30	< .050	
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2005/03/30	130.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2005/03/30	< 1.000	
IRON	01045	WAIVED	2005/03/30	< 100.000	
MAGNESIUM	00927	WAIVED	2005/03/30	20.000	
MANGANESE	01055	WAIVED	2005/03/30	< 20.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2005/03/30	7.100	
SILVER	01077	WAIVED	2005/03/30	< 10.000	
SODIUM	00929	WAIVED	2005/03/30	18.000	
SPECIFIC CONDUCTANCE	00095	WAIVED	2005/03/30	320.000	
SULFATE	00945	WAIVED	2005/03/30	7.100	
TOTAL DISSOLVED SOLIDS	70300	WAIVED	2005/03/30	230.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801056***

System Name: ***Z D WINES***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)

PS Code: ***2801056-001***

Source Name: ***LPA REPORTED PRIMARY SOURCE***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

TURBIDITY, LABORATORY	82079	WAIVED		
ZINC	01092	WAIVED	2005/03/30	< 50.000

PS Code: ***2801056-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED		

INORGANIC

ALUMINUM	01105	WAIVED		
ANTIMONY	01097	WAIVED		
ARSENIC	01002	WAIVED		
ASBESTOS	81855	WAIVED		
BARIUM	01007	WAIVED		
BERYLLIUM	01012	WAIVED		
CADMIUM	01027	WAIVED		
CHROMIUM (TOTAL)	01034	WAIVED		
CYANIDE	01291	WAIVED		
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED		
LEAD	01051	WAIVED		
MERCURY	71900	WAIVED		
NICKEL	01067	WAIVED		
PERCHLORATE	A-031	WAIVED		
SELENIUM	01147	WAIVED		
THALLIUM	01059	WAIVED		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801056***

System Name: ***Z D WINES***

PS Code: ***2801056-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801056***

System Name: ***Z D WINES***

PS Code: ***2801056-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801056***

System Name: ***Z D WINES***

PS Code: ***2801056-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801056***

System Name: ***Z D WINES***

PS Code: ***2801056-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801070***

System Name: ***BERINGER VINEYARDS***

PS Code: ***2801070-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801070***

System Name: ***BERINGER VINEYARDS***

PS Code: ***2801070-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801070***

System Name: ***BERINGER VINEYARDS***

PS Code: ***2801070-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801070***

System Name: ***BERINGER VINEYARDS***

PS Code: ***2801070-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801070***

System Name: ***BERINGER VINEYARDS***

PS Code: ***2801070-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801073***

System Name: ***PROVENANCE VINEYARDS***

PS Code: ***2801073-003***

Source Name: ***WELL #3***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED	2008/09/18	.000		
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/09/20	< .000	2012/09	
NITRITE (AS N)	00620	036	2011/09/20	< .000	2014/09	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801073***

System Name: ***PROVENANCE VINEYARDS***

PS Code: ***2801073-003***

Source Name: ***WELL #3***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801073***

System Name: ***PROVENANCE VINEYARDS***

PS Code: ***2801073-003***

Source Name: ***WELL #3***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801073***

System Name: ***PROVENANCE VINEYARDS***

PS Code: ***2801073-003***

Source Name: ***WELL #3***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801073***

System Name: ***PROVENANCE VINEYARDS***

PS Code: ***2801073-003***

Source Name: ***WELL #3***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801075***

System Name: ***CAKEBREAD CELLAR***

PS Code: ***2801075-001***

Source Name: ***WELL NO. 1 RIVER WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	036	2011/06/08	< 50.000	2014/06	
ANTIMONY	01097	036	2011/06/08	< 6.000	2014/06	
ARSENIC	01002	036	2011/06/08	< 2.000	2014/06	
ASBESTOS	81855	108	2008/06/13	.000	2017/06	
BARIUM	01007	036	2011/06/08	130.000	2014/06	
BERYLLIUM	01012	036	2011/06/08	< 1.000	2014/06	
CADMIUM	01027	036	2011/06/08	< 1.000	2014/06	
CHROMIUM (TOTAL)	01034	036	2011/06/08	< 1.000	2014/06	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2011/06/08	.280	2014/06	
LEAD	01051	WAIVED	2005/06/28	< 5.000		
MERCURY	71900	036	2011/06/08	< 1.000	2014/06	
NICKEL	01067	036	2011/06/08	< 10.000	2014/06	
PERCHLORATE	A-031	036	**2009/02/04**	< 4.000	**2012/02**	**DUE**
SELENIUM	01147	036	2011/06/08	< 5.000	2014/06	
THALLIUM	01059	036	2011/06/08	< 1.000	2014/06	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2012/04/04	5.500	2013/04	
NITRITE (AS N)	00620	036	2011/06/08	< 400.000	2014/06	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2009/03/04	.719	2018/03	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801075***

System Name: ***CAKEBREAD CELLAR***

PS Code: ***2801075-001***

Source Name: ***WELL NO. 1 RIVER WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2012/04/04	.000	
2,4-D	39730	WAIVED	2012/04/04	.000	
ALACHLOR	77825	WAIVED	2012/04/04	.000	
ATRAZINE	39033	036	2012/04/04	.000	2015/04
BENTAZON	38710	WAIVED	2012/04/04	.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	036	2012/04/04	.000	2015/04
CHLORDANE	39350	WAIVED	2012/04/04	.000	
DALAPON	38432	036	2012/04/04	.000	2015/04
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	036	2012/04/04	.000	2015/04
DIQUAT	78885	036	2012/04/04	.000	2015/04
ENDOTHALL	38926	036	2012/04/04	.000	2015/04
ENDRIN	39390	WAIVED	2012/04/04	.000	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2012/04/04	.000	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2012/04/04	.000	
HEPTACHLOR EPOXIDE	39420	WAIVED	2012/04/04	.000	
HEXACHLOROBENZENE	39700	WAIVED	2012/04/04	.000	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2012/04/04	.000	
LINDANE	39340	WAIVED	2012/04/04	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801075***

System Name: ***CAKEBREAD CELLAR***

PS Code: ***2801075-001***

Source Name: ***WELL NO. 1 RIVER WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED	2012/04/04	.000	
MOLINATE	82199	WAIVED			
OXAMYL	38865	036	2012/04/04	.000	2015/04
PENTACHLOROPHENOL	39032	036	2012/04/04	.000	2015/04
PICLORAM	39720	036	2012/04/04	.000	2015/04
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	036	2012/04/04	.000	2015/04
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED	2012/04/04	.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	072	2011/06/08	.000	2017/06
1,1,2,2-TETRACHLOROETHANE	34516	072	2011/06/08	.000	2017/06
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2011/06/08	.000	2017/06
1,1,2-TRICHLOROETHANE	34511	072	2011/06/08	.000	2017/06
1,1-DICHLOROETHANE	34496	072	2011/06/08	.000	2017/06
1,1-DICHLOROETHYLENE	34501	072	2011/06/08	.000	2017/06
1,2,4-TRICHLOROBENZENE	34551	072	2011/06/08	.000	2017/06
1,2-DICHLOROBENZENE	34536	072	2011/06/08	.000	2017/06
1,2-DICHLOROETHANE	34531	072	2011/06/08	.000	2017/06
1,2-DICHLOROPROPANE	34541	072	2011/06/08	.000	2017/06
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2011/06/08	.000	2017/06
1,4-DICHLOROBENZENE	34571	072	2011/06/08	.000	2017/06
BENZENE	34030	072	2011/06/08	.000	2017/06
CARBON TETRACHLORIDE	32102	072	2011/06/08	.000	2017/06
CIS-1,2-DICHLOROETHYLENE	77093	072	2011/06/08	.000	2017/06
DICHLOROMETHANE	34423	072	2011/06/08	.000	2017/06
ETHYLBENZENE	34371	072	2011/06/08	.000	2017/06
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2011/06/08	.000	2017/06
MONOCHLOROBENZENE	34301	072	2011/06/08	.000	2017/06

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2801075
System Name: CAKEBREAD CELLAR

PS Code: 2801075-001
Source Name: WELL NO. 1 RIVER WELL
Source Number: 001
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2011/06/08	.000	2017/06
TETRACHLOROETHYLENE	34475	072	2011/06/08	.000	2017/06
TOLUENE	34010	072	2011/06/08	.000	2017/06
TRANS-1,2-DICHLOROETHYLENE	34546	072	2011/06/08	.000	2017/06
TRICHLOROETHYLENE	39180	072	2011/06/08	.000	2017/06
TRICHLOROFLUOROMETHANE	34488	072	2011/06/08	.000	2017/06
VINYL CHLORIDE	39175	072	2011/06/08	.000	2017/06
XYLENES (TOTAL)	81551	072	2011/06/08	.000	2017/06
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2011/06/08	280.000	
CALCIUM	00916	WAIVED	2011/06/08	23.000	
CARBONATE ALKALINITY	00445	WAIVED	2011/06/08	< 1.000	
CHLORIDE	00940	WAIVED	2012/04/04	11.000	
COLOR	00081	WAIVED	2012/04/04	10.000	
COPPER	01042	WAIVED	2005/06/28	< 50.000	
FOAMING AGENTS (MBAS)	38260	WAIVED	2012/04/04	< .050	
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2011/06/08	140.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2011/06/08	< 1.000	
IRON	01045	WAIVED	2011/06/08	< 100.000	
MAGNESIUM	00927	WAIVED	2011/06/08	20.000	
MANGANESE	01055	WAIVED	2011/06/08	180.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED	2012/04/04	2.000	
PH, LABORATORY	00403	WAIVED	2011/06/08	7.900	
SILVER	01077	WAIVED	2011/06/08	< 10.000	
SODIUM	00929	WAIVED	2011/06/08	48.000	
SPECIFIC CONDUCTANCE	00095	WAIVED	2012/04/04	500.000	
SULFATE	00945	WAIVED	2012/04/04	42.000	
TOTAL DISSOLVED SOLIDS	70300	WAIVED	2012/04/04	300.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801075***

System Name: ***CAKEBREAD CELLAR***

PS Code: ***2801075-001***

Source Name: ***WELL NO. 1 RIVER WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
SECONDARY/GP						
TURBIDITY, LABORATORY	82079	WAIVED	2012/04/04	1.200		
ZINC	01092	WAIVED	2005/06/28	< 50.000		

PS Code: ***2801075-002***

Source Name: ***BACK UP WELL***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	108	2006/06/28	< 50.000	2015/06	
ANTIMONY	01097	108	2006/06/28	< 6.000	2015/06	
ARSENIC	01002	108	2006/06/28	4.200	2015/06	
ASBESTOS	81855	108	2006/06/29	.000	2015/06	
BARIUM	01007	108	2006/06/28	< 100.000	2015/06	
BERYLLIUM	01012	108	2006/06/28	< 1.000	2015/06	
CADMIUM	01027	108	2006/06/28	< 1.000	2015/06	
CHROMIUM (TOTAL)	01034	108	2006/06/28	< 1.000	2015/06	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	108	2006/06/28	.270	2015/06	
LEAD	01051	WAIVED				
MERCURY	71900	108	2006/06/28	< 1.000	2015/06	
NICKEL	01067	108	2006/06/28	< 10.000	2015/06	
PERCHLORATE	A-031	000				**DUE**
SELENIUM	01147	108	2006/06/28	< 5.000	2015/06	
THALLIUM	01059	108	2006/06/28	< 1.000	2015/06	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801075***

System Name: ***CAKEBREAD CELLAR***

PS Code: ***2801075-002***

Source Name: ***BACK UP WELL***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	108	2007/04/18	< 2.000	2016/04
NITRITE (AS N)	00620	108	2006/06/28	< 400.000	2015/06
RADIOLOGICAL					
GROSS ALPHA	01501	108	2007/04/18	.397	2016/04
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2006/06/28	.000	
2,4-D	39730	WAIVED	2006/06/28	.000	
ALACHLOR	77825	WAIVED	2004/06/23	.000	
ATRAZINE	39033	WAIVED	2006/06/28	.000	
BENTAZON	38710	WAIVED	2006/06/28	.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED	2006/06/28	.000	
CHLORDANE	39350	WAIVED	2004/06/23	.000	
DALAPON	38432	WAIVED	2006/06/28	.000	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED	2006/06/28	.000	
DIQUAT	78885	WAIVED	2006/06/28	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801075***

System Name: ***CAKEBREAD CELLAR***

PS Code: ***2801075-002***

Source Name: ***BACK UP WELL***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED	2006/06/28	.000	
ENDRIN	39390	WAIVED	2004/06/23	.000	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2004/06/23	.000	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2004/06/23	.000	
HEPTACHLOR EPOXIDE	39420	WAIVED	2004/06/23	.000	
HEXACHLOROBENZENE	39700	WAIVED	2004/06/23	.000	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2004/06/23	.000	
LINDANE	39340	WAIVED	2004/06/23	.000	
METHOXYCHLOR	39480	WAIVED	2004/06/23	.000	
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED	2006/06/28	.000	
PENTACHLOROPHENOL	39032	WAIVED	2006/06/28	.000	
PICLORAM	39720	WAIVED	2006/06/28	.000	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED	2006/06/28	.000	
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED	2004/06/23	.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	000			DUE
1,1,2,2-TETRACHLOROETHANE	34516	000			DUE
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	000			DUE
1,1,2-TRICHLOROETHANE	34511	000			DUE
1,1-DICHLOROETHANE	34496	000			DUE
1,1-DICHLOROETHYLENE	34501	000			DUE
1,2,4-TRICHLOROBENZENE	34551	000			DUE
1,2-DICHLOROBENZENE	34536	000			DUE
1,2-DICHLOROETHANE	34531	000			DUE
1,2-DICHLOROPROPANE	34541	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801075***

System Name: ***CAKEBREAD CELLAR***

PS Code: ***2801075-002***

Source Name: ***BACK UP WELL***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED VOC						
1,3-DICHLOROPROPENE (TOTAL)	34561	000				DUE
1,4-DICHLOROBENZENE	34571	000				DUE
BENZENE	34030	000				DUE
CARBON TETRACHLORIDE	32102	000				DUE
CIS-1,2-DICHLOROETHYLENE	77093	000				DUE
DICHLOROMETHANE	34423	000				DUE
ETHYLBENZENE	34371	000				DUE
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	000				DUE
MONOCHLOROBENZENE	34301	000				DUE
STYRENE	77128	000				DUE
TETRACHLOROETHYLENE	34475	000				DUE
TOLUENE	34010	000				DUE
TRANS-1,2-DICHLOROETHYLENE	34546	000				DUE
TRICHLOROETHYLENE	39180	000				DUE
TRICHLOROFLUOROMETHANE	34488	000				DUE
VINYL CHLORIDE	39175	000				DUE
XYLENES (TOTAL)	81551	000				DUE
SECONDARY/GP						
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED				
BICARBONATE ALKALINITY	00440	108	2006/06/28	270.000	2015/06	
CALCIUM	00916	108	2006/06/28	29.000	2015/06	
CARBONATE ALKALINITY	00445	108	2006/06/28	< 1.000	2015/06	
CHLORIDE	00940	000				DUE
COLOR	00081	000				DUE
COPPER	01042	000				DUE
FOAMING AGENTS (MBAS)	38260	000				DUE
HARDNESS (TOTAL) AS CACO3	00900	108	2006/06/28	150.000	2015/06	
HYDROXIDE ALKALINITY	71830	108	2006/06/28	< 1.000	2015/06	
IRON	01045	108	2006/06/28	260.000	2015/06	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801075***

System Name: ***CAKEBREAD CELLAR***

PS Code: ***2801075-002***

Source Name: ***BACK UP WELL***

Source Number: ***002***

Source Status: ***STANDBY UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
SECONDARY/GP						
MAGNESIUM	00927	108	2006/06/28	20.000	2015/06	
MANGANESE	01055	108	2006/06/28	500.000	2015/06	
ODOR THRESHOLD @ 60 C	00086	000				DUE
PH, LABORATORY	00403	108	2006/06/28	7.700	2015/06	
SILVER	01077	000				DUE
SODIUM	00929	108	2006/06/28	36.000	2015/06	
SPECIFIC CONDUCTANCE	00095	000				DUE
SULFATE	00945	000				DUE
TOTAL DISSOLVED SOLIDS	70300	000				DUE
TURBIDITY, LABORATORY	82079	000				DUE
ZINC	01092	000				DUE

PS Code: ***2801075-003***

Source Name: ***OAKVILLE WINERY WELL***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	036	2011/06/08	< 50.000	2014/06	
ANTIMONY	01097	036	2011/06/08	< 6.000	2014/06	
ARSENIC	01002	036	2011/06/08	2.300	2014/06	
ASBESTOS	81855	108	2011/06/08	.000	2020/06	
BARIUM	01007	036	2011/06/08	< 100.000	2014/06	
BERYLLIUM	01012	036	2011/06/08	< 1.000	2014/06	
CADMIUM	01027	036	2011/06/08	< 1.000	2014/06	
CHROMIUM (TOTAL)	01034	036	2011/06/08	< 1.000	2014/06	
CYANIDE	01291	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801075***

System Name: ***CAKEBREAD CELLAR***

PS Code: ***2801075-003***

Source Name: ***OAKVILLE WINERY WELL***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
INORGANIC						
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2011/06/08	.330	2014/06	
LEAD	01051	WAIVED	2005/06/28	< 5.000		
MERCURY	71900	036	2011/06/08	< 1.000	2014/06	
NICKEL	01067	036	2011/06/08	< 10.000	2014/06	
PERCHLORATE	A-031	036	**2009/02/04**	< 4.000	**2012/02**	**DUE**
SELENIUM	01147	036	2011/06/08	< 5.000	2014/06	
THALLIUM	01059	036	2011/06/08	< 1.000	2014/06	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2012/04/04	< 2.000	2013/04	
NITRITE (AS N)	00620	036	2011/06/08	< 400.000	2014/06	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2009/03/04	2.610	2018/03	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2011/06/08	.000		
2,4-D	39730	WAIVED	2011/06/08	.000		
ALACHLOR	77825	WAIVED	2012/04/04	.000		
ATRAZINE	39033	036	2011/06/08	.000	2014/06	
BENTAZON	38710	WAIVED	2011/06/08	.000		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801075***

System Name: ***CAKEBREAD CELLAR***

PS Code: ***2801075-003***

Source Name: ***OAKVILLE WINERY WELL***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	036	2011/06/08	.000	2014/06
CHLORDANE	39350	WAIVED	2012/04/04	.000	
DALAPON	38432	036	2011/06/08	.000	2014/06
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	036	2011/06/08	.000	2014/06
DIQUAT	78885	036	2011/06/08	.000	2014/06
ENDOTHALL	38926	036	2011/06/08	.000	2014/06
ENDRIN	39390	WAIVED	2012/04/04	.000	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2012/04/04	.000	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2012/04/04	.000	
HEPTACHLOR EPOXIDE	39420	WAIVED	2012/04/04	.000	
HEXACHLOROBENZENE	39700	WAIVED	2012/04/04	.000	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2012/04/04	.000	
LINDANE	39340	WAIVED	2012/04/04	.000	
METHOXYCHLOR	39480	WAIVED	2012/04/04	.000	
MOLINATE	82199	WAIVED			
OXAMYL	38865	036	2011/06/08	.000	2014/06
PENTACHLOROPHENOL	39032	036	2011/06/08	.220	2014/06
PICLORAM	39720	036	2011/06/08	.000	2014/06
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	036	2011/06/08	.000	2014/06
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED	2012/04/04	.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	072	2011/06/08	.000	2017/06

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801075***

System Name: ***CAKEBREAD CELLAR***

PS Code: ***2801075-003***

Source Name: ***OAKVILLE WINERY WELL***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	072	2011/06/08	.000	2017/06
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2011/06/08	.000	2017/06
1,1,2-TRICHLOROETHANE	34511	072	2011/06/08	.000	2017/06
1,1-DICHLOROETHANE	34496	072	2011/06/08	.000	2017/06
1,1-DICHLOROETHYLENE	34501	072	2011/06/08	.000	2017/06
1,2,4-TRICHLOROBENZENE	34551	072	2011/06/08	.000	2017/06
1,2-DICHLOROBENZENE	34536	072	2011/06/08	.000	2017/06
1,2-DICHLOROETHANE	34531	072	2011/06/08	.000	2017/06
1,2-DICHLOROPROPANE	34541	072	2011/06/08	.000	2017/06
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2011/06/08	.000	2017/06
1,4-DICHLOROBENZENE	34571	072	2011/06/08	.000	2017/06
BENZENE	34030	072	2011/06/08	.000	2017/06
CARBON TETRACHLORIDE	32102	072	2011/06/08	.000	2017/06
CIS-1,2-DICHLOROETHYLENE	77093	072	2011/06/08	.000	2017/06
DICHLOROMETHANE	34423	072	2011/06/08	.000	2017/06
ETHYLBENZENE	34371	072	2011/06/08	.000	2017/06
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2011/06/08	.000	2017/06
MONOCHLOROBENZENE	34301	072	2011/06/08	.000	2017/06
STYRENE	77128	072	2011/06/08	.000	2017/06
TETRACHLOROETHYLENE	34475	072	2011/06/08	.000	2017/06
TOLUENE	34010	072	2011/06/08	.000	2017/06
TRANS-1,2-DICHLOROETHYLENE	34546	072	2011/06/08	.000	2017/06
TRICHLOROETHYLENE	39180	072	2011/06/08	.000	2017/06
TRICHLOROFLUOROMETHANE	34488	072	2011/06/08	.000	2017/06
VINYL CHLORIDE	39175	072	2011/06/08	.000	2017/06
XYLENES (TOTAL)	81551	072	2011/06/08	.000	2017/06
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2011/06/08	270.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801075***

System Name: ***CAKEBREAD CELLAR***

PS Code: ***2801075-003***

Source Name: ***OAKVILLE WINERY WELL***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED	2011/06/08	18.000	
CARBONATE ALKALINITY	00445	WAIVED	2011/06/08	< 1.000	
CHLORIDE	00940	WAIVED	2012/04/04	7.700	
COLOR	00081	WAIVED	2012/04/04	5.000	
COPPER	01042	WAIVED	2005/06/28	< 50.000	
FOAMING AGENTS (MBAS)	38260	WAIVED	2012/04/04	< .050	
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2011/06/08	120.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2011/06/08	< 1.000	
IRON	01045	WAIVED	2011/06/08	< 100.000	
MAGNESIUM	00927	WAIVED	2011/06/08	18.000	
MANGANESE	01055	WAIVED	2011/06/08	210.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED	2012/04/04	< 1.000	
PH, LABORATORY	00403	WAIVED	2011/06/08	8.200	
SILVER	01077	WAIVED	2011/06/08	< 10.000	
SODIUM	00929	WAIVED	2011/06/08	41.000	
SPECIFIC CONDUCTANCE	00095	WAIVED	2012/04/04	480.000	
SULFATE	00945	WAIVED	2012/04/04	12.000	
TOTAL DISSOLVED SOLIDS	70300	WAIVED	2012/04/04	320.000	
TURBIDITY, LABORATORY	82079	WAIVED	2012/04/04	.350	
ZINC	01092	WAIVED	2005/06/28	500.000	

PS Code: ***2801075-004***

Source Name: ***TREATMENT PLANT***

Source Number: ***004***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801075***

System Name: ***CAKEBREAD CELLAR***

PS Code: ***2801075-004***

Source Name: ***TREATMENT PLANT***

Source Number: ***004***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801075***

System Name: ***CAKEBREAD CELLAR***

PS Code: ***2801075-004***

Source Name: ***TREATMENT PLANT***

Source Number: ***004***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801075***

System Name: ***CAKEBREAD CELLAR***

PS Code: ***2801075-004***

Source Name: ***TREATMENT PLANT***

Source Number: ***004***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801075***

System Name: ***CAKEBREAD CELLAR***

PS Code: ***2801075-004***

Source Name: ***TREATMENT PLANT***

Source Number: ***004***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801076***

System Name: ***CAYMUS VINEYARDS***

PS Code: ***2801076-001***

Source Name: ***WELL #1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2010/01/25	6.900	2011/01	**DUE**
NITRITE (AS N)	00620	036	2009/02/10	.000	2012/02	**DUE**
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801076***

System Name: ***CAYMUS VINEYARDS***

PS Code: ***2801076-001***

Source Name: ***WELL #1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801076***

System Name: ***CAYMUS VINEYARDS***

PS Code: ***2801076-001***

Source Name: ***WELL #1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801076***

System Name: ***CAYMUS VINEYARDS***

PS Code: ***2801076-001***

Source Name: ***WELL #1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801076***

System Name: ***CAYMUS VINEYARDS***

PS Code: ***2801076-001***

Source Name: ***WELL #1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801076-002***

Source Name: ***WELL # 2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	000			**DUE**
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801076***

System Name: ***CAYMUS VINEYARDS***

PS Code: ***2801076-002***

Source Name: ***WELL # 2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2010/01/25	8.300	2011/01	DUE
NITRITE (AS N)	00620	036	2009/02/10	.000	2012/02	DUE
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED				
2,4-D	39730	WAIVED				
ALACHLOR	77825	WAIVED				
ATRAZINE	39033	WAIVED				
BENTAZON	38710	WAIVED				
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	WAIVED				
CHLORDANE	39350	WAIVED				
DALAPON	38432	WAIVED				
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	WAIVED				
DIQUAT	78885	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801076***

System Name: ***CAYMUS VINEYARDS***

PS Code: ***2801076-002***

Source Name: ***WELL # 2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801076***

System Name: ***CAYMUS VINEYARDS***

PS Code: ***2801076-002***

Source Name: ***WELL # 2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801076***

System Name: ***CAYMUS VINEYARDS***

PS Code: ***2801076-002***

Source Name: ***WELL # 2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
MAGNESIUM	00927	000				DUE
MANGANESE	01055	000				DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED				
PH, LABORATORY	00403	000				DUE
SILVER	01077	WAIVED				
SODIUM	00929	000				DUE
SPECIFIC CONDUCTANCE	00095	WAIVED				
SULFATE	00945	WAIVED				
TOTAL DISSOLVED SOLIDS	70300	WAIVED				
TURBIDITY, LABORATORY	82079	WAIVED				
ZINC	01092	WAIVED				

PS Code: ***2801076-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED				

INORGANIC

ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801076***

System Name: ***CAYMUS VINEYARDS***

PS Code: ***2801076-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801076***

System Name: ***CAYMUS VINEYARDS***

PS Code: ***2801076-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801076***

System Name: ***CAYMUS VINEYARDS***

PS Code: ***2801076-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801076***

System Name: ***CAYMUS VINEYARDS***

PS Code: ***2801076-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2801077
System Name: CHIMNEY ROCK WINERY

PS Code: 2801077-001
Source Name: WELL - LPA GENERATED
Source Number: 001
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED	2002/04/03	.000	
ANTIMONY	01097	WAIVED	2002/04/03	.000	
ARSENIC	01002	WAIVED	2002/04/03	5.000	
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED	2002/04/03	.000	
BERYLLIUM	01012	WAIVED	2002/04/03	.000	
CADMIUM	01027	WAIVED	2002/04/03	.000	
CHROMIUM (TOTAL)	01034	WAIVED	2002/04/03	.000	
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2002/04/03	.800	
LEAD	01051	WAIVED	2002/04/03	.000	
MERCURY	71900	WAIVED	2002/04/03	.000	
NICKEL	01067	WAIVED	2002/04/03	.000	
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED	2002/04/03	.000	
THALLIUM	01059	WAIVED	2002/04/03	.000	
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2012/04/05	< .000	2013/04
NITRITE (AS N)	00620	036	2011/04/01	< .000	2014/04
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801077***

System Name: ***CHIMNEY ROCK WINERY***

PS Code: ***2801077-001***

Source Name: ***WELL - LPA GENERATED***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801077***

System Name: ***CHIMNEY ROCK WINERY***

PS Code: ***2801077-001***

Source Name: ***WELL - LPA GENERATED***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801077***

System Name: ***CHIMNEY ROCK WINERY***

PS Code: ***2801077-001***

Source Name: ***WELL - LPA GENERATED***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	WAIVED	2002/04/03	800.000	
MAGNESIUM	00927	000			DUE
MANGANESE	01055	WAIVED	2002/04/03	620.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED	2002/04/03	.000	
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801077***

System Name: ***CHIMNEY ROCK WINERY***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)

PS Code: ***2801077-001***

Source Name: ***WELL - LPA GENERATED***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801077-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED			

INORGANIC

ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801077***

System Name: ***CHIMNEY ROCK WINERY***

PS Code: ***2801077-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801077***

System Name: ***CHIMNEY ROCK WINERY***

PS Code: ***2801077-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801077***

System Name: ***CHIMNEY ROCK WINERY***

PS Code: ***2801077-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801077***

System Name: ***CHIMNEY ROCK WINERY***

PS Code: ***2801077-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801080***

System Name: ***MILTON ROAD WATER COMPANY***

PS Code: ***2801080-001***

Source Name: ***WELL NO. 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2005/07/29	.000		
INORGANIC						
ALUMINUM	01105	036	2005/07/29	.000	2008/07	DUE
ANTIMONY	01097	036	2005/07/29	.000	2008/07	DUE
ARSENIC	01002	036	2005/07/29	4.500	2008/07	DUE
ASBESTOS	81855	108	2009/11/22	.000	2018/11	
BARIUM	01007	036	2005/07/29	1100.000	2008/07	DUE
BERYLLIUM	01012	036	2005/07/29	.000	2008/07	DUE
CADMIUM	01027	036	2005/07/29	.000	2008/07	DUE
CHROMIUM (TOTAL)	01034	036	2005/07/29	.000	2008/07	DUE
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2005/07/29	.000	2008/07	DUE
LEAD	01051	WAIVED	2005/07/29	26.000		
MERCURY	71900	036	2005/07/29	.000	2008/07	DUE
NICKEL	01067	036	2005/07/29	.000	2008/07	DUE
PERCHLORATE	A-031	006				DUE
SELENIUM	01147	036	2005/07/29	.000	2008/07	DUE
THALLIUM	01059	036	2005/07/29	.000	2008/07	DUE
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2005/07/29	.000	2006/07	DUE
NITRITE (AS N)	00620	036	2005/07/29	.000	2008/07	DUE
RADIOLOGICAL						
GROSS ALPHA	01501	108	2009/11/22	5.010	2018/11	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED	2009/11/22	1.500		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801080***

System Name: ***MILTON ROAD WATER COMPANY***

PS Code: ***2801080-001***

Source Name: ***WELL NO. 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	108	2009/11/22	.000	2018/11	
2,4-D	39730	WAIVED	2009/11/22	.000		
ALACHLOR	77825	WAIVED	2009/11/22	.000		
ATRAZINE	39033	036	2009/11/22	.000	2012/11	
BENTAZON	38710	WAIVED	2009/11/22	.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	WAIVED	2009/11/22	.000		
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2009/11/22	.000	2012/11	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	WAIVED	2009/11/22	.000		
DIQUAT	78885	036	2009/11/22	.000	2012/11	
ENDOTHALL	38926	036	2009/11/22	.000	2012/11	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	000				**DUE**
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801080***

System Name: ***MILTON ROAD WATER COMPANY***

PS Code: ***2801080-001***

Source Name: ***WELL NO. 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	000				DUE
MOLINATE	82199	WAIVED	2009/11/22	.000		
OXAMYL	38865	036	2009/11/22	.000	2012/11	
PENTACHLOROPHENOL	39032	036	2009/11/22	.000	2012/11	
PICLORAM	39720	036	2009/11/22	.000	2012/11	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2009/11/22	.000	2012/11	
THIOBENCARB	A-001	WAIVED	2009/11/22	.000		
TOXAPHENE	39400	WAIVED				
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2002/06/20	.000	2008/06	DUE
1,1,2,2-TETRACHLOROETHANE	34516	072	2002/06/20	.000	2008/06	DUE
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2002/06/20	.000	2008/06	DUE
1,1,2-TRICHLOROETHANE	34511	072	2002/06/20	.000	2008/06	DUE
1,1-DICHLOROETHANE	34496	072	2002/06/20	.000	2008/06	DUE
1,1-DICHLOROETHYLENE	34501	072	2002/06/20	.000	2008/06	DUE
1,2,4-TRICHLOROBENZENE	34551	072	2002/06/20	.000	2008/06	DUE
1,2-DICHLOROBENZENE	34536	072	2002/06/20	.000	2008/06	DUE
1,2-DICHLOROETHANE	34531	072	2002/06/20	.000	2008/06	DUE
1,2-DICHLOROPROPANE	34541	072	2002/06/20	.000	2008/06	DUE
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2002/06/20	.000	2008/06	DUE
1,4-DICHLOROBENZENE	34571	072	2002/06/20	.000	2008/06	DUE
BENZENE	34030	072	2002/06/20	.000	2008/06	DUE
CARBON TETRACHLORIDE	32102	072	2002/06/20	.000	2008/06	DUE
CIS-1,2-DICHLOROETHYLENE	77093	072	2002/06/20	.000	2008/06	DUE
DICHLOROMETHANE	34423	072	2002/06/20	.000	2008/06	DUE
ETHYLBENZENE	34371	072	2002/06/20	.000	2008/06	DUE
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	036	2005/07/29	.000	2008/07	DUE
MONOCHLOROBENZENE	34301	072	2002/06/20	.000	2008/06	DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2801080
System Name: MILTON ROAD WATER COMPANY

PS Code: 2801080-001
Source Name: WELL NO. 1
Source Number: 001
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED VOC						
STYRENE	77128	072	2002/06/20	.000	2008/06	DUE
TETRACHLOROETHYLENE	34475	072	2002/06/20	.000	2008/06	DUE
TOLUENE	34010	072	2002/06/20	.000	2008/06	DUE
TRANS-1,2-DICHLOROETHYLENE	34546	072	2002/06/20	.000	2008/06	DUE
TRICHLOROETHYLENE	39180	072	2002/06/20	.000	2008/06	DUE
TRICHLOROFLUOROMETHANE	34488	072	2002/06/20	.000	2008/06	DUE
VINYL CHLORIDE	39175	072	2002/06/20	.000	2008/06	DUE
XYLENES (TOTAL)	81551	072	2002/06/20	.000	2008/06	DUE
SECONDARY/GP						
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED	2005/07/29	12.100		
BICARBONATE ALKALINITY	00440	036	2005/07/29	270.000	2008/07	DUE
CALCIUM	00916	036	2005/07/29	120.000	2008/07	DUE
CARBONATE ALKALINITY	00445	036	2005/07/29	.000	2008/07	DUE
CHLORIDE	00940	036	2005/07/29	850.000	2008/07	DUE
COLOR	00081	036	2005/07/29	22.000	2008/07	DUE
COPPER	01042	036	2005/07/29	98.000	2008/07	DUE
FOAMING AGENTS (MBAS)	38260	036	2005/07/29	.000	2008/07	DUE
HARDNESS (TOTAL) AS CACO3	00900	036	2005/07/29	790.000	2008/07	DUE
HYDROXIDE ALKALINITY	71830	036	2005/07/29	.000	2008/07	DUE
IRON	01045	036	2005/07/29	2600.000	2008/07	DUE
MAGNESIUM	00927	036	2005/07/29	120.000	2008/07	DUE
MANGANESE	01055	036	2005/07/29	1700.000	2008/07	DUE
ODOR THRESHOLD @ 60 C	00086	036	2005/07/29	.000	2008/07	DUE
PH, LABORATORY	00403	036	2005/07/29	7.400	2008/07	DUE
SILVER	01077	036	2005/07/29	.000	2008/07	DUE
SODIUM	00929	036	2005/07/29	240.000	2008/07	DUE
SPECIFIC CONDUCTANCE	00095	036	2005/07/29	2800.000	2008/07	DUE
SULFATE	00945	036	2005/07/29	20.000	2008/07	DUE
TOTAL DISSOLVED SOLIDS	70300	036	2005/07/29	1700.000	2008/07	DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801080***

System Name: ***MILTON ROAD WATER COMPANY***

PS Code: ***2801080-001***

Source Name: ***WELL NO. 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
SECONDARY/GP						
TURBIDITY, LABORATORY	82079	036	2005/07/29	20.000	2008/07	DUE
ZINC	01092	036	2005/07/29	.031	2008/07	DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801081***

System Name: ***MT. GEORGE ESTATES***

PS Code: ***2801081-001***

Source Name: ***WELL NO. 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2009/09/28	.000	2010/09	**DUE**
NITRITE (AS N)	00620	036	2009/09/28	.000	2012/09	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801081***

System Name: ***MT. GEORGE ESTATES***

PS Code: ***2801081-001***

Source Name: ***WELL NO. 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801081***

System Name: ***MT. GEORGE ESTATES***

PS Code: ***2801081-001***

Source Name: ***WELL NO. 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801081***

System Name: ***MT. GEORGE ESTATES***

PS Code: ***2801081-001***

Source Name: ***WELL NO. 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801081***

System Name: ***MT. GEORGE ESTATES***

PS Code: ***2801081-001***

Source Name: ***WELL NO. 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: 2801084
System Name: RUTHERFORD HILL WINERY

PS Code: 2801084-001
Source Name: WELL - LPA GENERATED
Source Number: 001
Source Status: ACTIVE UNTREATED
Water type: GROUNDWATER OR WELL

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED	2010/05/19	< .025	
INORGANIC					
ALUMINUM	01105	036	2010/05/19	< 50.000	2013/05
ANTIMONY	01097	036	2010/05/19	< 6.000	2013/05
ARSENIC	01002	036	2010/05/19	< 2.000	2013/05
ASBESTOS	81855	108	2007/06/13	.000	2016/06
BARIUM	01007	036	2010/05/19	< 100.000	2013/05
BERYLLIUM	01012	036	2010/05/19	< 1.000	2013/05
CADMIUM	01027	036	2010/05/19	< 1.000	2013/05
CHROMIUM (TOTAL)	01034	036	2010/05/19	< 1.000	2013/05
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2010/05/19	.180	2013/05
LEAD	01051	WAIVED			
MERCURY	71900	036	2010/05/19	< 1.000	2013/05
NICKEL	01067	036	2010/05/19	34.000	2013/05
PERCHLORATE	A-031	036	2009/05/15	< 4.000	2012/05
SELENIUM	01147	036	2010/05/19	< 5.000	2013/05
THALLIUM	01059	036	2010/05/19	< 1.000	2013/05
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2011/05/18	< 2.000	2012/05
NITRITE (AS N)	00620	036	2010/05/19	< 400.000	2013/05
RADIOLOGICAL					
GROSS ALPHA	01501	108	2008/09/17	.000	2017/09
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801084***

System Name: ***RUTHERFORD HILL WINERY***

PS Code: ***2801084-001***

Source Name: ***WELL - LPA GENERATED***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2010/05/19	.000		
2,4-D	39730	WAIVED	2010/05/19	.000		
ALACHLOR	77825	WAIVED	2010/05/19	.000		
ATRAZINE	39033	036	2010/05/19	.000	2013/05	
BENTAZON	38710	WAIVED	2010/05/19	.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2010/05/19	.000	2013/05	
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2010/05/19	.000	2013/05	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED				
DINOSEB	81287	036	2010/05/19	.000	2013/05	
DIQUAT	78885	036	2010/05/19	.000	2013/05	
ENDOTHALL	38926	036	2010/05/19	.000	2013/05	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	000				**DUE**
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801084***

System Name: ***RUTHERFORD HILL WINERY***

PS Code: ***2801084-001***

Source Name: ***WELL - LPA GENERATED***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	000				**DUE**
MOLINATE	82199	WAIVED	2010/05/19	.000		
OXAMYL	38865	036	2010/05/19	.000	2013/05	
PENTACHLOROPHENOL	39032	036	2010/05/19	.000	2013/05	
PICLORAM	39720	036	2010/05/19	.000	2013/05	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2010/05/19	.000	2013/05	
THIOBENCARB	A-001	WAIVED	2010/05/19	.000		
TOXAPHENE	39400	000				**DUE**
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2007/06/13	.000	2013/06	
1,1,2,2-TETRACHLOROETHANE	34516	072	2007/06/13	.000	2013/06	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2007/06/13	.000	2013/06	
1,1,2-TRICHLOROETHANE	34511	072	2007/06/13	.000	2013/06	
1,1-DICHLOROETHANE	34496	072	2007/06/13	.000	2013/06	
1,1-DICHLOROETHYLENE	34501	072	2007/06/13	.000	2013/06	
1,2,4-TRICHLOROBENZENE	34551	072	2007/06/13	.000	2013/06	
1,2-DICHLOROBENZENE	34536	072	2007/06/13	.000	2013/06	
1,2-DICHLOROETHANE	34531	072	2007/06/13	.000	2013/06	
1,2-DICHLOROPROPANE	34541	072	2007/06/13	.000	2013/06	
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2007/06/13	.000	2013/06	
1,4-DICHLOROBENZENE	34571	072	2007/06/13	.000	2013/06	
BENZENE	34030	072	2007/06/13	.000	2013/06	
CARBON TETRACHLORIDE	32102	072	2007/06/13	.000	2013/06	
CIS-1,2-DICHLOROETHYLENE	77093	072	2007/06/13	.000	2013/06	
DICHLOROMETHANE	34423	072	2007/06/13	.000	2013/06	
ETHYLBENZENE	34371	072	2007/06/13	.000	2013/06	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2007/06/13	.000	2013/06	
MONOCHLOROBENZENE	34301	072	2007/06/13	.000	2013/06	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801084***

System Name: ***RUTHERFORD HILL WINERY***

PS Code: ***2801084-001***

Source Name: ***WELL - LPA GENERATED***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2007/06/13	.000	2013/06
TETRACHLOROETHYLENE	34475	072	2007/06/13	.000	2013/06
TOLUENE	34010	072	2007/06/13	.000	2013/06
TRANS-1,2-DICHLOROETHYLENE	34546	072	2007/06/13	.000	2013/06
TRICHLOROETHYLENE	39180	072	2007/06/13	.000	2013/06
TRICHLOROFLUOROMETHANE	34488	072	2007/06/13	.000	2013/06
VINYL CHLORIDE	39175	072	2007/06/13	.000	2013/06
XYLENES (TOTAL)	81551	072	2007/06/13	.000	2013/06
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2010/05/19	120.000	
CALCIUM	00916	WAIVED	2010/05/19	9.400	
CARBONATE ALKALINITY	00445	WAIVED	2010/05/19	< 1.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2010/05/19	160.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2010/05/19	< 1.000	
IRON	01045	WAIVED	2010/05/19	< 100.000	
MAGNESIUM	00927	WAIVED	2010/05/19	34.000	
MANGANESE	01055	WAIVED	2010/05/19	< 20.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2010/05/19	7.400	
SILVER	01077	WAIVED	2010/05/19	< 10.000	
SODIUM	00929	WAIVED	2010/05/19	10.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801084***

System Name: ***RUTHERFORD HILL WINERY***

PS Code: ***2801084-001***

Source Name: ***WELL - LPA GENERATED***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
SECONDARY/GP						
TURBIDITY, LABORATORY	82079	WAIVED				
ZINC	01092	WAIVED				

PS Code: ***2801084-002***

Source Name: ***WELL 2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	036	2012/02/03	< 50.000	2015/02	
ANTIMONY	01097	036	2012/02/03	< 6.000	2015/02	
ARSENIC	01002	036	2012/02/03	< 2.000	2015/02	
ASBESTOS	81855	108	2007/06/13	.000	2016/06	
BARIUM	01007	036	2012/02/03	< 100.000	2015/02	
BERYLLIUM	01012	036	2012/02/03	< 1.000	2015/02	
CADMIUM	01027	036	2012/02/03	< 1.000	2015/02	
CHROMIUM (TOTAL)	01034	036	2012/02/03	< 1.000	2015/02	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2012/02/03	.240	2015/02	
LEAD	01051	WAIVED	2008/09/17	< 5.000		
MERCURY	71900	036	2012/02/03	< 1.000	2015/02	
NICKEL	01067	036	2012/02/03	< 10.000	2015/02	
PERCHLORATE	A-031	036	**2008/09/17**	< 4.000	**2011/09**	**DUE**
SELENIUM	01147	036	2012/02/03	< 5.000	2015/02	
THALLIUM	01059	036	2012/02/03	< 1.000	2015/02	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801084***

System Name: ***RUTHERFORD HILL WINERY***

PS Code: ***2801084-002***

Source Name: ***WELL 2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2012/02/03	< 2.000	2013/02
NITRITE (AS N)	00620	036	2012/02/03	< 400.000	2015/02
RADIOLOGICAL					
GROSS ALPHA	01501	108	2008/09/17	.000	2017/09
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2012/02/03	.000	
2,4-D	39730	WAIVED	2012/02/03	.000	
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	036	2012/02/03	.000	2015/02
BENTAZON	38710	WAIVED	2012/02/03	.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	036	2012/02/03	.000	2015/02
CHLORDANE	39350	WAIVED			
DALAPON	38432	036	2012/02/03	.000	2015/02
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	036	2012/02/03	.000	2015/02
DIQUAT	78885	036	2012/02/03	.000	2015/02

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801084***

System Name: ***RUTHERFORD HILL WINERY***

PS Code: ***2801084-002***

Source Name: ***WELL 2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
ENDOTHALL	38926	036	2012/02/03	.000	2015/02	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	000				**DUE**
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**
METHOXYCHLOR	39480	000				**DUE**
MOLINATE	82199	WAIVED				
OXAMYL	38865	036	2012/02/03	.000	2015/02	
PENTACHLOROPHENOL	39032	036	2012/02/03	.000	2015/02	
PICLORAM	39720	036	2012/02/03	.000	2015/02	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2012/02/03	.000	2015/02	
THIOBENCARB	A-001	WAIVED				
TOXAPHENE	39400	000				**DUE**
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2007/06/13	.000	2013/06	
1,1,2,2-TETRACHLOROETHANE	34516	072	2007/06/13	.000	2013/06	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2007/06/13	.000	2013/06	
1,1,2-TRICHLOROETHANE	34511	072	2007/06/13	.000	2013/06	
1,1-DICHLOROETHANE	34496	072	2007/06/13	.000	2013/06	
1,1-DICHLOROETHYLENE	34501	072	2007/06/13	.000	2013/06	
1,2,4-TRICHLOROBENZENE	34551	072	2007/06/13	.000	2013/06	
1,2-DICHLOROBENZENE	34536	072	2007/06/13	.000	2013/06	
1,2-DICHLOROETHANE	34531	072	2007/06/13	.000	2013/06	
1,2-DICHLOROPROPANE	34541	072	2007/06/13	.000	2013/06	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801084***

System Name: ***RUTHERFORD HILL WINERY***

PS Code: ***2801084-002***

Source Name: ***WELL 2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2007/06/13	.000	2013/06
1,4-DICHLOROBENZENE	34571	072	2007/06/13	.000	2013/06
BENZENE	34030	072	2007/06/13	.000	2013/06
CARBON TETRACHLORIDE	32102	072	2007/06/13	.000	2013/06
CIS-1,2-DICHLOROETHYLENE	77093	072	2007/06/13	.000	2013/06
DICHLOROMETHANE	34423	072	2007/06/13	.000	2013/06
ETHYLBENZENE	34371	072	2007/06/13	.000	2013/06
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2007/06/13	.000	2013/06
MONOCHLOROBENZENE	34301	072	2007/06/13	.000	2013/06
STYRENE	77128	072	2007/06/13	.000	2013/06
TETRACHLOROETHYLENE	34475	072	2007/06/13	.000	2013/06
TOLUENE	34010	072	2007/06/13	.000	2013/06
TRANS-1,2-DICHLOROETHYLENE	34546	072	2007/06/13	.000	2013/06
TRICHLOROETHYLENE	39180	072	2007/06/13	.000	2013/06
TRICHLOROFLUOROMETHANE	34488	072	2007/06/13	.000	2013/06
VINYL CHLORIDE	39175	072	2007/06/13	.000	2013/06
XYLENES (TOTAL)	81551	072	2007/06/13	.000	2013/06
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2012/02/03	270.000	
CALCIUM	00916	WAIVED	2012/02/03	7.600	
CARBONATE ALKALINITY	00445	WAIVED	2012/02/03	< 1.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED	2004/03/31	< 50.000	
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2012/02/03	93.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2012/02/03	< 1.000	
IRON	01045	WAIVED	2012/02/03	150.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801084***

System Name: ***RUTHERFORD HILL WINERY***

PS Code: ***2801084-002***

Source Name: ***WELL 2***

Source Number: ***002***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
MAGNESIUM	00927	WAIVED	2012/02/03	18.000	
MANGANESE	01055	WAIVED	2012/02/03	< 20.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2012/02/03	7.900	
SILVER	01077	WAIVED	2012/02/03	< 10.000	
SODIUM	00929	WAIVED	2012/02/03	86.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801084-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801084***

System Name: ***RUTHERFORD HILL WINERY***

PS Code: ***2801084-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
INORGANIC					
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801084***

System Name: ***RUTHERFORD HILL WINERY***

PS Code: ***2801084-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801084***

System Name: ***RUTHERFORD HILL WINERY***

PS Code: ***2801084-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801084***

System Name: ***RUTHERFORD HILL WINERY***

PS Code: ***2801084-003***

Source Name: ***TREATMENT PLANT***

Source Number: ***003***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801086***

System Name: ***STAGS LEAP WINERY***

PS Code: ***2801086-001***

Source Name: ***WELL # 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2006/05/25	.000		
INORGANIC						
ALUMINUM	01105	036	2012/04/18	< .000	2015/04	
ANTIMONY	01097	036	2012/04/18	< .000	2015/04	
ARSENIC	01002	036	2012/04/18	3.300	2015/04	
ASBESTOS	81855	000				**DUE**
BARIUM	01007	036	2012/04/18	< .000	2015/04	
BERYLLIUM	01012	036	2012/04/18	< .000	2015/04	
CADMIUM	01027	036	2012/04/18	< .000	2015/04	
CHROMIUM (TOTAL)	01034	036	2012/04/18	< .000	2015/04	
CYANIDE	01291	WAIVED	2000/04/11	< 5.000		
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2012/04/18	.190	2015/04	
LEAD	01051	WAIVED	2012/04/18	< .000		
MERCURY	71900	036	2012/04/18	< .000	2015/04	
NICKEL	01067	036	2012/04/18	< .000	2015/04	
PERCHLORATE	A-031	036	2009/07/23	.000	2012/07	
SELENIUM	01147	036	2012/04/18	< .000	2015/04	
THALLIUM	01059	036	2012/04/18	< .000	2015/04	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2012/04/18	< .000	2013/04	
NITRITE (AS N)	00620	036	2012/04/18	< .000	2015/04	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2007/04/12	1.560	2016/04	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED	2007/04/12	.000		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801086***

System Name: ***STAGS LEAP WINERY***

PS Code: ***2801086-001***

Source Name: ***WELL # 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2012/04/18	< 1.000	
2,4-D	39730	WAIVED	2012/04/18	< 10.000	
ALACHLOR	77825	WAIVED	2009/04/20	.000	
ATRAZINE	39033	036	2012/04/18	< .500	2015/04
BENTAZON	38710	WAIVED	2012/04/18	< 2.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	036	2012/04/18	< 5.000	2015/04
CHLORDANE	39350	WAIVED	2009/04/20	.000	
DALAPON	38432	036	2012/04/18	< 10.000	2015/04
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2009/07/23	.000	
DINOSEB	81287	036	2012/04/18	< 2.000	2015/04
DIQUAT	78885	036	2012/04/18	< 4.000	2015/04
ENDOTHALL	38926	036	2012/04/18	< 45.000	2015/04
ENDRIN	39390	WAIVED	2009/04/20	.000	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2009/07/23	.000	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2009/04/20	.000	
HEPTACHLOR EPOXIDE	39420	WAIVED	2009/04/20	.000	
HEXACHLOROBENZENE	39700	WAIVED	2009/04/20	.000	
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2009/04/20	.000	
LINDANE	39340	WAIVED	2009/04/20	.000	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801086***

System Name: ***STAGS LEAP WINERY***

PS Code: ***2801086-001***

Source Name: ***WELL # 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED	2009/04/20	.000	
MOLINATE	82199	WAIVED	2009/04/20	.000	
OXAMYL	38865	036	2012/04/18	< 20.000	2015/04
PENTACHLOROPHENOL	39032	036	2012/04/18	< .200	2015/04
PICLORAM	39720	036	2012/04/18	< 1.000	2015/04
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED	2009/04/20	.000	
SIMAZINE	39055	036	2012/04/18	< 1.000	2015/04
THIOBENCARB	A-001	WAIVED	2009/04/20	.000	
TOXAPHENE	39400	WAIVED	2009/04/20	.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	072	2009/07/23	.000	2015/07
1,1,2,2-TETRACHLOROETHANE	34516	072	2009/07/23	.000	2015/07
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2009/07/23	.000	2015/07
1,1,2-TRICHLOROETHANE	34511	072	2009/07/23	.000	2015/07
1,1-DICHLOROETHANE	34496	072	2009/07/23	.000	2015/07
1,1-DICHLOROETHYLENE	34501	072	2009/07/23	.000	2015/07
1,2,4-TRICHLOROBENZENE	34551	072	2009/07/23	.000	2015/07
1,2-DICHLOROBENZENE	34536	072	2009/07/23	.000	2015/07
1,2-DICHLOROETHANE	34531	072	2009/07/23	.000	2015/07
1,2-DICHLOROPROPANE	34541	072	2009/07/23	.000	2015/07
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2009/07/23	.000	2015/07
1,4-DICHLOROBENZENE	34571	072	2009/07/23	.000	2015/07
BENZENE	34030	072	2009/07/23	.000	2015/07
CARBON TETRACHLORIDE	32102	072	2009/07/23	.000	2015/07
CIS-1,2-DICHLOROETHYLENE	77093	072	2009/07/23	.000	2015/07
DICHLOROMETHANE	34423	072	2009/07/23	.000	2015/07
ETHYLBENZENE	34371	072	2009/07/23	.000	2015/07
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2009/07/23	.000	2015/07
MONOCHLOROBENZENE	34301	072	2009/07/23	.000	2015/07

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801086***

System Name: ***STAGS LEAP WINERY***

PS Code: ***2801086-001***

Source Name: ***WELL # 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2009/07/23	.000	2015/07
TETRACHLOROETHYLENE	34475	072	2009/07/23	.000	2015/07
TOLUENE	34010	072	2009/07/23	.000	2015/07
TRANS-1,2-DICHLOROETHYLENE	34546	072	2009/07/23	.000	2015/07
TRICHLOROETHYLENE	39180	072	2009/07/23	.000	2015/07
TRICHLOROFLUOROMETHANE	34488	072	2009/07/23	.000	2015/07
VINYL CHLORIDE	39175	072	2009/07/23	.000	2015/07
XYLENES (TOTAL)	81551	072	2009/07/23	.000	2015/07
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2012/04/18	212.000	
CALCIUM	00916	WAIVED	2012/04/18	42.000	
CARBONATE ALKALINITY	00445	WAIVED	2012/04/18	< .000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2012/04/18	130.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2012/04/18	< .000	
IRON	01045	WAIVED	2012/04/18	< .000	
MAGNESIUM	00927	WAIVED	2012/04/18	7.000	
MANGANESE	01055	WAIVED	2012/04/18	53.200	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2012/04/18	7.500	
SILVER	01077	WAIVED	2012/04/18	< .000	
SODIUM	00929	WAIVED	2012/04/18	35.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801086***

System Name: ***STAGS LEAP WINERY***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)

PS Code: ***2801086-001***

Source Name: ***WELL # 1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801086-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED			

INORGANIC

ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801086***

System Name: ***STAGS LEAP WINERY***

PS Code: ***2801086-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801086***

System Name: ***STAGS LEAP WINERY***

PS Code: ***2801086-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801086***

System Name: ***STAGS LEAP WINERY***

PS Code: ***2801086-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801086***

System Name: ***STAGS LEAP WINERY***

PS Code: ***2801086-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801088***

System Name: ***V. SATTUI WINERY***

PS Code: ***2801088-001***

Source Name: ***WELL - LPA GENERATED***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2006/07/13	.000		
INORGANIC						
ALUMINUM	01105	036	2009/08/13	.000	2012/08	
ANTIMONY	01097	036	2009/08/13	.000	2012/08	
ARSENIC	01002	036	2009/08/13	.000	2012/08	
ASBESTOS	81855	000				**DUE**
BARIUM	01007	036	2009/08/13	.000	2012/08	
BERYLLIUM	01012	036	2009/08/13	.000	2012/08	
CADMIUM	01027	036	2009/08/13	.000	2012/08	
CHROMIUM (TOTAL)	01034	036	2009/08/13	.000	2012/08	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2009/08/13	.150	2012/08	
LEAD	01051	WAIVED	2006/07/13	.000		
MERCURY	71900	036	2009/08/13	.000	2012/08	
NICKEL	01067	036	2009/08/13	.000	2012/08	
PERCHLORATE	A-031	006	**2009/08/13**	.000	**2010/02**	**DUE**
SELENIUM	01147	036	2009/08/13	.000	2012/08	
THALLIUM	01059	036	2009/08/13	.000	2012/08	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	**2010/06/29**	4.700	**2011/06**	**DUE**
NITRITE (AS N)	00620	036	2009/08/13	.000	2012/08	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2010/05/12	5.640	2019/05	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801088***

System Name: ***V. SATTUI WINERY***

PS Code: ***2801088-001***

Source Name: ***WELL - LPA GENERATED***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED	2009/08/13	.000	
2,4-D	39730	WAIVED	2009/08/13	.000	
ALACHLOR	77825	WAIVED	2009/08/13	.000	
ATRAZINE	39033	036	2009/08/13	.000	2012/08
BENTAZON	38710	WAIVED	2009/08/13	.000	
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	036	2009/08/13	.000	2012/08
CHLORDANE	39350	WAIVED	2006/07/13	< .100	
DALAPON	38432	036	2009/08/13	.000	2012/08
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2006/07/13	< .010	
DINOSEB	81287	036	2009/08/13	.000	2012/08
DIQUAT	78885	036	2009/08/13	.000	2012/08
ENDOTHALL	38926	036	2009/08/13	.000	2012/08
ENDRIN	39390	WAIVED	2006/07/13	< .100	
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2006/07/13	< .020	
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED	2006/07/13	< .010	
HEPTACHLOR EPOXIDE	39420	WAIVED	2006/07/13	< .010	
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED	2006/07/13	< .200	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801088***

System Name: ***V. SATTUI WINERY***

PS Code: ***2801088-001***

Source Name: ***WELL - LPA GENERATED***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED	2006/07/13	< 10.000	
MOLINATE	82199	WAIVED	2009/08/13	.000	
OXAMYL	38865	036	2009/08/13	.000	2012/08
PENTACHLOROPHENOL	39032	036	2009/08/13	.000	2012/08
PICLORAM	39720	036	2009/08/13	.000	2012/08
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	036	2009/08/13	.000	2012/08
THIOBENCARB	A-001	WAIVED	2009/08/13	.000	
TOXAPHENE	39400	WAIVED	2006/07/13	< 1.000	
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	072	2011/07/11	< .000	2017/07
1,1,2,2-TETRACHLOROETHANE	34516	072	2011/07/11	< .000	2017/07
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2011/07/11	< .000	2017/07
1,1,2-TRICHLOROETHANE	34511	072	2011/07/11	< .000	2017/07
1,1-DICHLOROETHANE	34496	072	2011/07/11	< .000	2017/07
1,1-DICHLOROETHYLENE	34501	072	2011/07/11	< .000	2017/07
1,2,4-TRICHLOROBENZENE	34551	072	2011/07/11	< .000	2017/07
1,2-DICHLOROBENZENE	34536	072	2011/07/11	< .000	2017/07
1,2-DICHLOROETHANE	34531	072	2011/07/11	< .000	2017/07
1,2-DICHLOROPROPANE	34541	072	2011/07/11	< .000	2017/07
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2011/07/11	< .000	2017/07
1,4-DICHLOROBENZENE	34571	072	2011/07/11	< .000	2017/07
BENZENE	34030	072	2011/07/11	< .000	2017/07
CARBON TETRACHLORIDE	32102	072	2011/07/11	< .000	2017/07
CIS-1,2-DICHLOROETHYLENE	77093	072	2011/07/11	< .000	2017/07
DICHLOROMETHANE	34423	072	2011/07/11	< .000	2017/07
ETHYLBENZENE	34371	072	2011/07/11	< .000	2017/07
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2011/07/11	< .000	2017/07
MONOCHLOROBENZENE	34301	072	2011/07/11	< .000	2017/07

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801088***

System Name: ***V. SATTUI WINERY***

PS Code: ***2801088-001***

Source Name: ***WELL - LPA GENERATED***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2011/07/11	< .000	2017/07
TETRACHLOROETHYLENE	34475	072	2011/07/11	< .000	2017/07
TOLUENE	34010	072	2011/07/11	< .000	2017/07
TRANS-1,2-DICHLOROETHYLENE	34546	072	2011/07/11	< .000	2017/07
TRICHLOROETHYLENE	39180	072	2011/07/11	< .000	2017/07
TRICHLOROFLUOROMETHANE	34488	072	2011/07/11	< .000	2017/07
VINYL CHLORIDE	39175	072	2011/07/11	< .000	2017/07
XYLENES (TOTAL)	81551	072	2011/07/11	< .000	2017/07
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2009/08/13	190.000	
CALCIUM	00916	WAIVED	2009/08/13	25.000	
CARBONATE ALKALINITY	00445	WAIVED	2009/08/13	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2010/06/29	120.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2009/08/13	.000	
IRON	01045	WAIVED	2009/08/13	.000	
MAGNESIUM	00927	WAIVED	2009/08/13	13.000	
MANGANESE	01055	WAIVED	2009/08/13	.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2009/08/13	7.600	
SILVER	01077	WAIVED	2009/08/13	.000	
SODIUM	00929	WAIVED	2009/08/13	28.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801088***

System Name: ***V. SATTUI WINERY***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)

PS Code: ***2801088-001***

Source Name: ***WELL - LPA GENERATED***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801088-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED			

INORGANIC

ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801088***

System Name: ***V. SATTUI WINERY***

PS Code: ***2801088-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801088***

System Name: ***V. SATTUI WINERY***

PS Code: ***2801088-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801088***

System Name: ***V. SATTUI WINERY***

PS Code: ***2801088-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801088***

System Name: ***V. SATTUI WINERY***

PS Code: ***2801088-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801089***

System Name: ***DI ROSA ART PRESERVE***

PS Code: ***2801089-001***

Source Name: ***WELL #1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED	2002/04/30	.000		
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED	2002/04/30	.000		
CADMIUM	01027	WAIVED	2002/04/30	.000		
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED	2002/04/30	.000		
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED	2002/04/30	.000		
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2012/01/10	< .000	2013/01	
NITRITE (AS N)	00620	000				**DUE**
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801089***

System Name: ***DI ROSA ART PRESERVE***

PS Code: ***2801089-001***

Source Name: ***WELL #1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801089***

System Name: ***DI ROSA ART PRESERVE***

PS Code: ***2801089-001***

Source Name: ***WELL #1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801089***

System Name: ***DI ROSA ART PRESERVE***

PS Code: ***2801089-001***

Source Name: ***WELL #1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801089***

System Name: ***DI ROSA ART PRESERVE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)

PS Code: ***2801089-001***

Source Name: ***WELL #1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801089-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED			

INORGANIC

ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801089***

System Name: ***DI ROSA ART PRESERVE***

PS Code: ***2801089-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801089***

System Name: ***DI ROSA ART PRESERVE***

PS Code: ***2801089-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801089***

System Name: ***DI ROSA ART PRESERVE***

PS Code: ***2801089-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801089***

System Name: ***DI ROSA ART PRESERVE***

PS Code: ***2801089-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801936***

System Name: ***O SHAUGHNESSY WINERY***

PS Code: ***2801936-001***

Source Name: ***WELL #1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED	2005/06/29	.000		
ANTIMONY	01097	WAIVED	2005/06/29	.000		
ARSENIC	01002	WAIVED	2005/06/29	4.600		
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED	2005/06/29	.000		
BERYLLIUM	01012	WAIVED	2005/06/29	.000		
CADMIUM	01027	WAIVED	2005/06/29	.000		
CHROMIUM (TOTAL)	01034	WAIVED	2005/06/29	.000		
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2005/06/29	.160		
LEAD	01051	WAIVED	2005/06/29	.000		
MERCURY	71900	WAIVED	2005/06/29	.000		
NICKEL	01067	WAIVED	2005/06/29	.000		
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED	2005/06/29	.000		
THALLIUM	01059	WAIVED	2005/06/29	.000		
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2010/06/10	.000	2011/06	DUE
NITRITE (AS N)	00620	036	2009/06/17	.000	2012/06	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801936***

System Name: ***O SHAUGHNESSY WINERY***

PS Code: ***2801936-001***

Source Name: ***WELL #1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801936***

System Name: ***O SHAUGHNESSY WINERY***

PS Code: ***2801936-001***

Source Name: ***WELL #1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801936***

System Name: ***O SHAUGHNESSY WINERY***

PS Code: ***2801936-001***

Source Name: ***WELL #1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2005/06/29	79.000	
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	WAIVED	2005/06/29	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	WAIVED	2005/06/29	.000	
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED	2005/06/29	.000	
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801936***

System Name: ***O SHAUGHNESSY WINERY***

PS Code: ***2801936-001***

Source Name: ***WELL #1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2801936-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801936***

System Name: ***O SHAUGHNESSY WINERY***

PS Code: ***2801936-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801936***

System Name: ***O SHAUGHNESSY WINERY***

PS Code: ***2801936-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801936***

System Name: ***O SHAUGHNESSY WINERY***

PS Code: ***2801936-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2801936***

System Name: ***O SHAUGHNESSY WINERY***

PS Code: ***2801936-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2802715***

System Name: ***NORMAN ALUMBAUGH CO., INC.***

PS Code: ***2802715-001***

Source Name: ***WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2012/03/07	< 2.000	2013/03	
NITRITE (AS N)	00620	036	2012/03/07	< 400.000	2015/03	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2802715***

System Name: ***NORMAN ALUMBAUGH CO., INC.***

PS Code: ***2802715-001***

Source Name: ***WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2802715***

System Name: ***NORMAN ALUMBAUGH CO., INC.***

PS Code: ***2802715-001***

Source Name: ***WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2802715***

System Name: ***NORMAN ALUMBAUGH CO., INC.***

PS Code: ***2802715-001***

Source Name: ***WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2802715***

System Name: ***NORMAN ALUMBAUGH CO., INC.***

PS Code: ***2802715-001***

Source Name: ***WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2802715-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2802715***

System Name: ***NORMAN ALUMBAUGH CO., INC.***

PS Code: ***2802715-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2802715***

System Name: ***NORMAN ALUMBAUGH CO., INC.***

PS Code: ***2802715-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2802715***

System Name: ***NORMAN ALUMBAUGH CO., INC.***

PS Code: ***2802715-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2802715***

System Name: ***NORMAN ALUMBAUGH CO., INC.***

PS Code: ***2802715-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803137***

System Name: ***MUCHO DINERO AQUA CIA WATER***

PS Code: ***2803137-001***

Source Name: ***WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED	2005/04/26	3.000		
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED	2005/04/26	< 100.000		
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED	2005/04/26	< 1.000		
CHROMIUM (TOTAL)	01034	WAIVED	2005/04/26	< 1.000		
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2005/04/26	.490		
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED	2005/04/26	< 1.000		
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED	2005/04/26	< 5.000		
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2005/04/26	< 2.000	2006/04	DUE
NITRITE (AS N)	00620	036	2005/04/26	< 400.000	2008/04	DUE
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803137***

System Name: ***MUCHO DINERO AQUA CIA WATER***

PS Code: ***2803137-001***

Source Name: ***WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803137***

System Name: ***MUCHO DINERO AQUA CIA WATER***

PS Code: ***2803137-001***

Source Name: ***WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803137***

System Name: ***MUCHO DINERO AQUA CIA WATER***

PS Code: ***2803137-001***

Source Name: ***WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803137***

System Name: ***MUCHO DINERO AQUA CIA WATER***

PS Code: ***2803137-001***

Source Name: ***WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2803137-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803137***

System Name: ***MUCHO DINERO AQUA CIA WATER***

PS Code: ***2803137-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803137***

System Name: ***MUCHO DINERO AQUA CIA WATER***

PS Code: ***2803137-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803137***

System Name: ***MUCHO DINERO AQUA CIA WATER***

PS Code: ***2803137-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803137***

System Name: ***MUCHO DINERO AQUA CIA WATER***

PS Code: ***2803137-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803657***

System Name: ***WOODLAND RIDGE MUTUAL WATER CO***

PS Code: ***2803657-001***

Source Name: ***WELL-BRADY WELL (FORMERLY MITCHELL)***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2012/05/02	< 2.000	2013/05	
NITRITE (AS N)	00620	036	2012/05/02	< 400.000	2015/05	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803657***

System Name: ***WOODLAND RIDGE MUTUAL WATER CO***

PS Code: ***2803657-001***

Source Name: ***WELL-BRADY WELL (FORMERLY MITCHELL)***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803657***

System Name: ***WOODLAND RIDGE MUTUAL WATER CO***

PS Code: ***2803657-001***

Source Name: ***WELL-BRADY WELL (FORMERLY MITCHELL)***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803657***

System Name: ***WOODLAND RIDGE MUTUAL WATER CO***

PS Code: ***2803657-001***

Source Name: ***WELL-BRADY WELL (FORMERLY MITCHELL)***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803657***

System Name: ***WOODLAND RIDGE MUTUAL WATER CO***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)

PS Code: ***2803657-001***

Source Name: ***WELL-BRADY WELL (FORMERLY MITCHELL)***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP

TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2803657-003***

Source Name: ***WHITFIELD WELL***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type:

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED			

INORGANIC

ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	000			**DUE**
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803657***

System Name: ***WOODLAND RIDGE MUTUAL WATER CO***

PS Code: ***2803657-003***

Source Name: ***WHITFIELD WELL***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type:

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	**71850**	**012**	2012/05/02	**< 2.000**	2013/05
NITRITE (AS N)	**00620**	**036**	2012/05/02	**< 400.000**	2015/05
RADIOLOGICAL					
GROSS ALPHA	**01501**	**WAIVED**			
GROSS BETA	**03501**	**WAIVED**			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	**A-080**	**WAIVED**			
RA-226 OR TOTAL RA BY 903.0 C.E.	**A-081**	**WAIVED**			
RADIUM 226	**09501**	**WAIVED**			
RADIUM 228	**11501**	**WAIVED**			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	**A-082**	**WAIVED**			
STRONTIUM-90	**13501**	**WAIVED**			
TRITIUM	**07000**	**WAIVED**			
URANIUM (PCI/L)	**28012**	**WAIVED**			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	**34676**	**WAIVED**			
2,4,5-TP (SILVEX)	**39045**	**WAIVED**			
2,4-D	**39730**	**WAIVED**			
ALACHLOR	**77825**	**WAIVED**			
ATRAZINE	**39033**	**WAIVED**			
BENTAZON	**38710**	**WAIVED**			
BENZO (A) PYRENE	**34247**	**WAIVED**			
CARBOFURAN	**81405**	**WAIVED**			
CHLORDANE	**39350**	**WAIVED**			
DALAPON	**38432**	**WAIVED**			
DI(2-ETHYLHEXYL)ADIPATE	**A-026**	**WAIVED**			
DI(2-ETHYLHEXYL)PHTHALATE	**39100**	**WAIVED**			
DIBROMOCHLOROPROPANE (DBCP)	**38761**	**WAIVED**			
DINOSEB	**81287**	**WAIVED**			
DIQUAT	**78885**	**WAIVED**			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803657***

System Name: ***WOODLAND RIDGE MUTUAL WATER CO***

PS Code: ***2803657-003***

Source Name: ***WHITFIELD WELL***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type:

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803657***

System Name: ***WOODLAND RIDGE MUTUAL WATER CO***

PS Code: ***2803657-003***

Source Name: ***WHITFIELD WELL***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type:

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803657***

System Name: ***WOODLAND RIDGE MUTUAL WATER CO***

PS Code: ***2803657-003***

Source Name: ***WHITFIELD WELL***

Source Number: ***003***

Source Status: ***ACTIVE UNTREATED***

Water type:

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2803657-004***

Source Name: ***BOTHWELL WELL***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type:

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803657***

System Name: ***WOODLAND RIDGE MUTUAL WATER CO***

PS Code: ***2803657-004***

Source Name: ***BOTHWELL WELL***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type:

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
INORGANIC						
FLUORIDE (F) (NATURAL-SOURCE)	**00951**	**000**				**DUE**
LEAD	**01051**	**WAIVED**				
MERCURY	**71900**	**WAIVED**				
NICKEL	**01067**	**WAIVED**				
PERCHLORATE	**A-031**	**WAIVED**				
SELENIUM	**01147**	**WAIVED**				
THALLIUM	**01059**	**WAIVED**				
NITRATE/NITRITE						
NITRATE (AS NO3)	**71850**	**012**	2012/05/02	**< 2.000**	2013/05	
NITRITE (AS N)	**00620**	**036**	2012/05/02	**< 400.000**	2015/05	
RADIOLOGICAL						
GROSS ALPHA	**01501**	**WAIVED**				
GROSS BETA	**03501**	**WAIVED**				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	**A-080**	**WAIVED**				
RA-226 OR TOTAL RA BY 903.0 C.E.	**A-081**	**WAIVED**				
RADIUM 226	**09501**	**WAIVED**				
RADIUM 228	**11501**	**WAIVED**				
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	**A-082**	**WAIVED**				
STRONTIUM-90	**13501**	**WAIVED**				
TRITIUM	**07000**	**WAIVED**				
URANIUM (PCI/L)	**28012**	**WAIVED**				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	**34676**	**WAIVED**				
2,4,5-TP (SILVEX)	**39045**	**WAIVED**				
2,4-D	**39730**	**WAIVED**				
ALACHLOR	**77825**	**WAIVED**				
ATRAZINE	**39033**	**WAIVED**				
BENTAZON	**38710**	**WAIVED**				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803657***

System Name: ***WOODLAND RIDGE MUTUAL WATER CO***

PS Code: ***2803657-004***

Source Name: ***BOTHWELL WELL***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type:

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803657***

System Name: ***WOODLAND RIDGE MUTUAL WATER CO***

PS Code: ***2803657-004***

Source Name: ***BOTHWELL WELL***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type:

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803657***

System Name: ***WOODLAND RIDGE MUTUAL WATER CO***

PS Code: ***2803657-004***

Source Name: ***BOTHWELL WELL***

Source Number: ***004***

Source Status: ***ACTIVE UNTREATED***

Water type:

SECONDARY/GP

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803697***

System Name: ***STELTZNER WINERY***

PS Code: ***2803697-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED	2005/04/20	.000		
ANTIMONY	01097	WAIVED	2005/04/20	.000		
ARSENIC	01002	WAIVED	2005/04/20	7.500		
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED	2005/04/20	34.000		
BERYLLIUM	01012	WAIVED	2005/04/20	.000		
CADMIUM	01027	WAIVED	2005/04/20	.000		
CHROMIUM (TOTAL)	01034	WAIVED	2005/04/20	.000		
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2005/04/20	.410		
LEAD	01051	WAIVED	2004/09/10	.000		
MERCURY	71900	WAIVED	2005/04/20	.000		
NICKEL	01067	WAIVED	2005/04/20	8.700		
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED	2005/04/20	.000		
THALLIUM	01059	WAIVED	2005/04/20	.000		
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/03/10	.000	2012/03	DUE
NITRITE (AS N)	00620	036	2011/03/10	.000	2014/03	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803697***

System Name: ***STELTZNER WINERY***

PS Code: ***2803697-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803697***

System Name: ***STELTZNER WINERY***

PS Code: ***2803697-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803697***

System Name: ***STELTZNER WINERY***

PS Code: ***2803697-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED VOC						
STYRENE	77128	WAIVED				
TETRACHLOROETHYLENE	34475	WAIVED				
TOLUENE	34010	WAIVED				
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED				
TRICHLOROETHYLENE	39180	WAIVED				
TRICHLOROFLUOROMETHANE	34488	WAIVED				
VINYL CHLORIDE	39175	WAIVED				
XYLENES (TOTAL)	81551	WAIVED				
SECONDARY/GP						
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED				
BICARBONATE ALKALINITY	00440	WAIVED	2004/09/10	170.000		
CALCIUM	00916	000				**DUE**
CARBONATE ALKALINITY	00445	WAIVED	2004/09/10	.000		
CHLORIDE	00940	WAIVED				
COLOR	00081	WAIVED				
COPPER	01042	WAIVED				
FOAMING AGENTS (MBAS)	38260	WAIVED				
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2004/09/10	170.000		
HYDROXIDE ALKALINITY	71830	WAIVED	2004/09/10	.000		
IRON	01045	WAIVED	2004/09/10	100.000		
MAGNESIUM	00927	WAIVED	2004/09/10	12.000		
MANGANESE	01055	WAIVED	2004/09/10	.000		
ODOR THRESHOLD @ 60 C	00086	WAIVED				
PH, LABORATORY	00403	WAIVED	2004/09/10	8.100		
SILVER	01077	WAIVED	2004/09/10	.000		
SODIUM	00929	WAIVED	2004/09/10	20.000		
SPECIFIC CONDUCTANCE	00095	WAIVED				
SULFATE	00945	WAIVED				
TOTAL DISSOLVED SOLIDS	70300	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803697***

System Name: ***STELTZNER WINERY***

PS Code: ***2803697-001***

Source Name: ***WELL 01***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803879***

System Name: ***JARVIS VINEYARD***

PS Code: ***2803879-001***

Source Name: ***WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED				
ANTIMONY	01097	WAIVED				
ARSENIC	01002	WAIVED				
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED				
BERYLLIUM	01012	WAIVED				
CADMIUM	01027	WAIVED				
CHROMIUM (TOTAL)	01034	WAIVED				
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED				
MERCURY	71900	WAIVED				
NICKEL	01067	WAIVED				
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED				
THALLIUM	01059	WAIVED				
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2012/03/26	6.100	2013/03	
NITRITE (AS N)	00620	036	2010/03/22	< 400.000	2013/03	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803879***

System Name: ***JARVIS VINEYARD***

PS Code: ***2803879-001***

Source Name: ***WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803879***

System Name: ***JARVIS VINEYARD***

PS Code: ***2803879-001***

Source Name: ***WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803879***

System Name: ***JARVIS VINEYARD***

PS Code: ***2803879-001***

Source Name: ***WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803879***

System Name: ***JARVIS VINEYARD***

PS Code: ***2803879-001***

Source Name: ***WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2803879-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803879***

System Name: ***JARVIS VINEYARD***

PS Code: ***2803879-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED	2005/03/07	6.000	
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803879***

System Name: ***JARVIS VINEYARD***

PS Code: ***2803879-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803879***

System Name: ***JARVIS VINEYARD***

PS Code: ***2803879-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803879***

System Name: ***JARVIS VINEYARD***

PS Code: ***2803879-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803886***

System Name: ***RUTHERFORD GROVE WINERY***

PS Code: ***2803886-001***

Source Name: ***WELL #1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED				
INORGANIC						
ALUMINUM	01105	WAIVED	2002/05/02	100.000		
ANTIMONY	01097	WAIVED	2002/05/02	.000		
ARSENIC	01002	WAIVED	2002/05/02	.000		
ASBESTOS	81855	WAIVED				
BARIUM	01007	WAIVED	2002/05/02	.000		
BERYLLIUM	01012	WAIVED	2002/05/02	.000		
CADMIUM	01027	WAIVED	2002/05/02	.000		
CHROMIUM (TOTAL)	01034	WAIVED	2002/05/02	.000		
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	000				**DUE**
LEAD	01051	WAIVED	2002/05/02	6.000		
MERCURY	71900	WAIVED	2002/05/02	.000		
NICKEL	01067	WAIVED	2002/05/02	.000		
PERCHLORATE	A-031	WAIVED				
SELENIUM	01147	WAIVED	2002/05/02	.000		
THALLIUM	01059	WAIVED	2002/05/02	.000		
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/05/24	< .000	2012/05	
NITRITE (AS N)	00620	036	2009/05/04	.000	2012/05	
RADIOLOGICAL						
GROSS ALPHA	01501	WAIVED				
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803886***

System Name: ***RUTHERFORD GROVE WINERY***

PS Code: ***2803886-001***

Source Name: ***WELL #1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803886***

System Name: ***RUTHERFORD GROVE WINERY***

PS Code: ***2803886-001***

Source Name: ***WELL #1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803886***

System Name: ***RUTHERFORD GROVE WINERY***

PS Code: ***2803886-001***

Source Name: ***WELL #1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED	2002/05/02	.000	
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803886***

System Name: ***RUTHERFORD GROVE WINERY***

PS Code: ***2803886-001***

Source Name: ***WELL #1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803907***

System Name: ***MINER FAMILY WINERY***

PS Code: ***2803907-001***

Source Name: ***WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2009/01/06	.000		
INORGANIC						
ALUMINUM	01105	036	2011/12/05	< .000	2014/12	
ANTIMONY	01097	036	2011/12/05	< .000	2014/12	
ARSENIC	01002	036	2011/12/05	2.400	2014/12	
ASBESTOS	81855	108	2008/06/05	.000	2017/06	
BARIUM	01007	036	2011/12/05	< .000	2014/12	
BERYLLIUM	01012	036	2011/12/05	< .000	2014/12	
CADMIUM	01027	036	2011/12/05	< .000	2014/12	
CHROMIUM (TOTAL)	01034	036	2011/12/05	< .000	2014/12	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2008/11/05	.000	2011/11	DUE
LEAD	01051	WAIVED	2008/11/05	5.000		
MERCURY	71900	036	2011/12/05	< .000	2014/12	
NICKEL	01067	036	2011/12/05	< .000	2014/12	
PERCHLORATE	A-031	036	2010/01/20	.000	2013/01	
SELENIUM	01147	036	2011/12/05	< .000	2014/12	
THALLIUM	01059	036	2011/12/05	< .000	2014/12	
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2009/01/06	2.700	2010/01	DUE
NITRITE (AS N)	00620	036	2009/01/06	.000	2012/01	DUE
RADIOLOGICAL						
GROSS ALPHA	01501	108	2006/12/14	.000	2015/12	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED	2006/09/01	.000		
RADIUM 228	11501	WAIVED	2006/09/01	.360		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803907***

System Name: ***MINER FAMILY WINERY***

PS Code: ***2803907-001***

Source Name: ***WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2009/01/05	.000		
2,4-D	39730	WAIVED	2009/01/05	.000		
ALACHLOR	77825	WAIVED	2009/01/06	.000		
ATRAZINE	39033	036	**2009/01/06**	.000	**2012/01**	**DUE**
BENTAZON	38710	WAIVED	2009/01/05	.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	**2009/01/05**	.000	**2012/01**	**DUE**
CHLORDANE	39350	WAIVED	2005/12/07	.000		
DALAPON	38432	036	**2009/01/05**	.000	**2012/01**	**DUE**
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2010/12/15	.000		
DINOSEB	81287	036	**2009/01/05**	.000	**2012/01**	**DUE**
DIQUAT	78885	036	**2009/01/05**	.000	**2012/01**	**DUE**
ENDOTHALL	38926	036	**2009/01/05**	.000	**2012/01**	**DUE**
ENDRIN	39390	WAIVED	2005/12/07	.000		
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2010/12/15	.000		
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	WAIVED	2005/12/07	.000		
HEPTACHLOR EPOXIDE	39420	WAIVED	2005/12/07	.000		
HEXACHLOROBENZENE	39700	WAIVED	2005/12/07	.000		
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED	2005/12/07	.000		
LINDANE	39340	WAIVED	2005/12/07	.000		

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803907***

System Name: ***MINER FAMILY WINERY***

PS Code: ***2803907-001***

Source Name: ***WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	WAIVED	2005/12/07	.000		
MOLINATE	82199	WAIVED	2009/01/06	.000		
OXAMYL	38865	036	2009/01/05	.000	2012/01	DUE
PENTACHLOROPHENOL	39032	036	2009/01/05	.000	2012/01	DUE
PICLORAM	39720	036	2009/01/05	.000	2012/01	DUE
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2009/01/06	.000	2012/01	DUE
THIOBENCARB	A-001	WAIVED	2009/01/06	.000		
TOXAPHENE	39400	WAIVED	2005/12/07	.000		
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2010/12/15	.000	2016/12	
1,1,2,2-TETRACHLOROETHANE	34516	072	2010/12/15	.000	2016/12	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2010/12/15	.000	2016/12	
1,1,2-TRICHLOROETHANE	34511	072	2010/12/15	.000	2016/12	
1,1-DICHLOROETHANE	34496	072	2010/12/15	.000	2016/12	
1,1-DICHLOROETHYLENE	34501	072	2010/12/15	.000	2016/12	
1,2,4-TRICHLOROBENZENE	34551	072	2010/12/15	.000	2016/12	
1,2-DICHLOROBENZENE	34536	072	2010/12/15	.000	2016/12	
1,2-DICHLOROETHANE	34531	072	2010/12/15	.000	2016/12	
1,2-DICHLOROPROPANE	34541	072	2010/12/15	.000	2016/12	
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2010/12/15	.000	2016/12	
1,4-DICHLOROBENZENE	34571	072	2010/12/15	.000	2016/12	
BENZENE	34030	072	2010/12/15	.000	2016/12	
CARBON TETRACHLORIDE	32102	072	2010/12/15	.000	2016/12	
CIS-1,2-DICHLOROETHYLENE	77093	072	2010/12/15	.000	2016/12	
DICHLOROMETHANE	34423	072	2010/12/15	.000	2016/12	
ETHYLBENZENE	34371	072	2010/12/15	.000	2016/12	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2010/12/15	.000	2016/12	
MONOCHLOROBENZENE	34301	072	2010/12/15	.000	2016/12	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803907***

System Name: ***MINER FAMILY WINERY***

PS Code: ***2803907-001***

Source Name: ***WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2010/12/15	.000	2016/12
TETRACHLOROETHYLENE	34475	072	2010/12/15	.000	2016/12
TOLUENE	34010	072	2010/12/15	.000	2016/12
TRANS-1,2-DICHLOROETHYLENE	34546	072	2010/12/15	.000	2016/12
TRICHLOROETHYLENE	39180	072	2010/12/15	.000	2016/12
TRICHLOROFLUOROMETHANE	34488	072	2010/12/15	.000	2016/12
VINYL CHLORIDE	39175	072	2010/12/15	.000	2016/12
XYLENES (TOTAL)	81551	072	2010/12/15	.000	2016/12
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2011/12/05	123.000	
CALCIUM	00916	WAIVED	2011/12/05	12.000	
CARBONATE ALKALINITY	00445	WAIVED	2011/12/05	< .000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2011/12/05	84.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2011/12/05	< .000	
IRON	01045	WAIVED	2011/12/05	< .000	
MAGNESIUM	00927	WAIVED	2011/12/05	12.000	
MANGANESE	01055	WAIVED	2011/12/05	< .000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2011/12/05	7.100	
SILVER	01077	WAIVED	2008/11/05	.000	
SODIUM	00929	WAIVED	2011/12/05	11.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803907***

System Name: ***MINER FAMILY WINERY***

PS Code: ***2803907-001***

Source Name: ***WELL***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803911***

System Name: ***DOMINUS ESTATE WINERY***

PS Code: ***2803911-001***

Source Name: ***WELL#1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED	2002/04/19	.000	
ANTIMONY	01097	WAIVED	2002/04/19	.000	
ARSENIC	01002	WAIVED	2002/04/19	4.000	
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED	2002/04/19	.000	
BERYLLIUM	01012	WAIVED	2002/04/19	.000	
CADMIUM	01027	WAIVED	2002/04/19	.000	
CHROMIUM (TOTAL)	01034	WAIVED	2002/04/19	.000	
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED	2002/04/19	.300	
LEAD	01051	WAIVED	2002/04/19	.000	
MERCURY	71900	WAIVED	2002/04/19	.000	
NICKEL	01067	WAIVED	2002/04/19	.000	
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED	2002/04/19	.000	
THALLIUM	01059	WAIVED	2002/04/19	.000	
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	012	2012/03/21	< .000	2013/03
NITRITE (AS N)	00620	036	2011/03/04	.000	2014/03
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803911***

System Name: ***DOMINUS ESTATE WINERY***

PS Code: ***2803911-001***

Source Name: ***WELL#1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803911***

System Name: ***DOMINUS ESTATE WINERY***

PS Code: ***2803911-001***

Source Name: ***WELL#1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803911***

System Name: ***DOMINUS ESTATE WINERY***

PS Code: ***2803911-001***

Source Name: ***WELL#1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	WAIVED	2002/04/19	.000	
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED	2002/04/19	.000	
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803911***

System Name: ***DOMINUS ESTATE WINERY***

PS Code: ***2803911-001***

Source Name: ***WELL#1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803912***

System Name: ***BEAULIEU VINEYARD***

PS Code: ***2803912-001***

Source Name: ***WELL#1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
GENERAL NON CHAP 15						
DIAZINON	39570	WAIVED	2008/03/31	.000		
INORGANIC						
ALUMINUM	01105	036	2008/03/31	.000	2011/03	DUE
ANTIMONY	01097	036	2008/03/31	.000	2011/03	DUE
ARSENIC	01002	036	2009/06/18	5.000	2012/06	
ASBESTOS	81855	108	2008/03/31	.000	2017/03	
BARIUM	01007	036	2008/03/31	.000	2011/03	DUE
BERYLLIUM	01012	036	2008/03/31	.000	2011/03	DUE
CADMIUM	01027	036	2008/03/31	.000	2011/03	DUE
CHROMIUM (TOTAL)	01034	036	2012/01/03	< .000	2015/01	
CYANIDE	01291	WAIVED				
FLUORIDE (F) (NATURAL-SOURCE)	00951	036	2009/06/18	.140	2012/06	
LEAD	01051	WAIVED	2008/03/31	.000		
MERCURY	71900	036	2008/03/31	.000	2011/03	DUE
NICKEL	01067	036	2008/03/31	.000	2011/03	DUE
PERCHLORATE	A-031	036	2009/09/09	.000	2012/09	
SELENIUM	01147	036	2008/03/31	.000	2011/03	DUE
THALLIUM	01059	036	2008/03/31	.000	2011/03	DUE
NITRATE/NITRITE						
NITRATE (AS NO3)	71850	012	2011/06/09	28.000	2012/06	
NITRITE (AS N)	00620	036	2010/06/16	.000	2013/06	
RADIOLOGICAL						
GROSS ALPHA	01501	108	2012/03/14	.980	2021/03	
GROSS BETA	03501	WAIVED				
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED				
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED				
RADIUM 226	09501	WAIVED				
RADIUM 228	11501	WAIVED				

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803912***

System Name: ***BEAULIEU VINEYARD***

PS Code: ***2803912-001***

Source Name: ***WELL#1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
RADIOLOGICAL						
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED				
STRONTIUM-90	13501	WAIVED				
TRITIUM	07000	WAIVED				
URANIUM (PCI/L)	28012	WAIVED				
REGULATED SOC						
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED				
2,4,5-TP (SILVEX)	39045	WAIVED	2011/03/17	< 1.000		
2,4-D	39730	WAIVED	2011/03/17	< 10.000		
ALACHLOR	77825	WAIVED	2008/03/31	.000		
ATRAZINE	39033	036	2011/03/17	< .500	2014/03	
BENTAZON	38710	WAIVED	2011/03/17	< 2.000		
BENZO (A) PYRENE	34247	WAIVED				
CARBOFURAN	81405	036	2011/03/17	< 5.000	2014/03	
CHLORDANE	39350	WAIVED				
DALAPON	38432	036	2011/03/17	< 10.000	2014/03	
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED				
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED				
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED	2007/07/02	.000		
DINOSEB	81287	036	2011/03/17	< 2.000	2014/03	
DIQUAT	78885	036	2011/03/17	< 4.000	2014/03	
ENDOTHALL	38926	036	2011/03/17	< 45.000	2014/03	
ENDRIN	39390	WAIVED				
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED	2007/07/02	.000		
GLYPHOSATE	79743	WAIVED				
HEPTACHLOR	39410	000				**DUE**
HEPTACHLOR EPOXIDE	39420	000				**DUE**
HEXACHLOROBENZENE	39700	WAIVED				
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED				
LINDANE	39340	000				**DUE**

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803912***

System Name: ***BEAULIEU VINEYARD***

PS Code: ***2803912-001***

Source Name: ***WELL#1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)	
REGULATED SOC						
METHOXYCHLOR	39480	000				**DUE**
MOLINATE	82199	WAIVED	2008/03/31	.000		
OXAMYL	38865	036	2011/03/17	< 20.000	2014/03	
PENTACHLOROPHENOL	39032	036	2011/03/17	< .200	2014/03	
PICLORAM	39720	036	2011/03/17	< 1.000	2014/03	
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED				
SIMAZINE	39055	036	2011/03/17	< 1.000	2014/03	
THIOBENCARB	A-001	WAIVED	2008/03/31	.000		
TOXAPHENE	39400	000				**DUE**
REGULATED VOC						
1,1,1-TRICHLOROETHANE	34506	072	2007/07/02	.000	2013/07	
1,1,2,2-TETRACHLOROETHANE	34516	072	2007/07/02	.000	2013/07	
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	072	2007/07/02	.000	2013/07	
1,1,2-TRICHLOROETHANE	34511	072	2007/07/02	.000	2013/07	
1,1-DICHLOROETHANE	34496	072	2007/07/02	.000	2013/07	
1,1-DICHLOROETHYLENE	34501	072	2007/07/02	.000	2013/07	
1,2,4-TRICHLOROBENZENE	34551	072	2007/07/02	.000	2013/07	
1,2-DICHLOROBENZENE	34536	072	2007/07/02	.000	2013/07	
1,2-DICHLOROETHANE	34531	072	2007/07/02	.000	2013/07	
1,2-DICHLOROPROPANE	34541	072	2007/07/02	.000	2013/07	
1,3-DICHLOROPROPENE (TOTAL)	34561	072	2007/07/02	.000	2013/07	
1,4-DICHLOROBENZENE	34571	072	2007/07/02	.000	2013/07	
BENZENE	34030	072	2007/07/02	.000	2013/07	
CARBON TETRACHLORIDE	32102	072	2007/07/02	.000	2013/07	
CIS-1,2-DICHLOROETHYLENE	77093	072	2007/07/02	.000	2013/07	
DICHLOROMETHANE	34423	072	2007/07/02	.000	2013/07	
ETHYLBENZENE	34371	072	2007/07/02	.000	2013/07	
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	072	2012/01/03	< .000	2018/01	
MONOCHLOROBENZENE	34301	072	2007/07/02	.000	2013/07	

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803912***

System Name: ***BEAULIEU VINEYARD***

PS Code: ***2803912-001***

Source Name: ***WELL#1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	072	2007/07/02	.000	2013/07
TETRACHLOROETHYLENE	34475	072	2007/07/02	.000	2013/07
TOLUENE	34010	072	2007/07/02	.000	2013/07
TRANS-1,2-DICHLOROETHYLENE	34546	072	2007/07/02	.000	2013/07
TRICHLOROETHYLENE	39180	072	2007/07/02	.000	2013/07
TRICHLOROFLUOROMETHANE	34488	072	2007/07/02	.000	2013/07
VINYL CHLORIDE	39175	072	2007/07/02	.000	2013/07
XYLENES (TOTAL)	81551	072	2007/07/02	.000	2013/07
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED	2008/03/31	260.000	
CALCIUM	00916	WAIVED	2008/03/31	23.000	
CARBONATE ALKALINITY	00445	WAIVED	2008/03/31	.000	
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED	2009/06/18	150.000	
HYDROXIDE ALKALINITY	71830	WAIVED	2008/03/31	.000	
IRON	01045	WAIVED	2008/03/31	550.000	
MAGNESIUM	00927	WAIVED	2008/03/31	22.000	
MANGANESE	01055	WAIVED	2008/03/31	450.000	
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED	2009/06/18	7.500	
SILVER	01077	WAIVED	2008/03/31	.000	
SODIUM	00929	WAIVED	2009/06/18	41.000	
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803912***

System Name: ***BEAULIEU VINEYARD***

PS Code: ***2803912-001***

Source Name: ***WELL#1***

Source Number: ***001***

Source Status: ***ACTIVE UNTREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
SECONDARY/GP					
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2803912-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803912***

System Name: ***BEAULIEU VINEYARD***

PS Code: ***2803912-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803912***

System Name: ***BEAULIEU VINEYARD***

PS Code: ***2803912-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803912***

System Name: ***BEAULIEU VINEYARD***

PS Code: ***2803912-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2803912***

System Name: ***BEAULIEU VINEYARD***

PS Code: ***2803912-002***

Source Name: ***TREATMENT PLANT***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2810011***

System Name: ***PLEASURE COVE RESORT***

PS Code: ***2810011-002***

Source Name: ***TREATMENT PLANT-LAKE BERYESSA INTAKE-TRD***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
GENERAL NON CHAP 15					
DIAZINON	39570	WAIVED			
INORGANIC					
ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	WAIVED			
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			
NITRATE/NITRITE					
NITRATE (AS NO3)	71850	WAIVED			
NITRITE (AS N)	00620	WAIVED			
RADIOLOGICAL					
GROSS ALPHA	01501	WAIVED			
GROSS BETA	03501	WAIVED			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	A-080	WAIVED			
RA-226 OR TOTAL RA BY 903.0 C.E.	A-081	WAIVED			
RADIUM 226	09501	WAIVED			
RADIUM 228	11501	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2810011***

System Name: ***PLEASURE COVE RESORT***

PS Code: ***2810011-002***

Source Name: ***TREATMENT PLANT-LAKE BERYESSA INTAKE-TRD***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
RADIOLOGICAL					
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	A-082	WAIVED			
STRONTIUM-90	13501	WAIVED			
TRITIUM	07000	WAIVED			
URANIUM (PCI/L)	28012	WAIVED			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	34676	WAIVED			
2,4,5-TP (SILVEX)	39045	WAIVED			
2,4-D	39730	WAIVED			
ALACHLOR	77825	WAIVED			
ATRAZINE	39033	WAIVED			
BENTAZON	38710	WAIVED			
BENZO (A) PYRENE	34247	WAIVED			
CARBOFURAN	81405	WAIVED			
CHLORDANE	39350	WAIVED			
DALAPON	38432	WAIVED			
DI(2-ETHYLHEXYL)ADIPATE	A-026	WAIVED			
DI(2-ETHYLHEXYL)PHTHALATE	39100	WAIVED			
DIBROMOCHLOROPROPANE (DBCP)	38761	WAIVED			
DINOSEB	81287	WAIVED			
DIQUAT	78885	WAIVED			
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2810011***

System Name: ***PLEASURE COVE RESORT***

PS Code: ***2810011-002***

Source Name: ***TREATMENT PLANT-LAKE BERYESSA INTAKE-TRD***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2810011***

System Name: ***PLEASURE COVE RESORT***

PS Code: ***2810011-002***

Source Name: ***TREATMENT PLANT-LAKE BERYESSA INTAKE-TRD***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***SURFACE***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	WAIVED			
CALCIUM	00916	WAIVED			
CARBONATE ALKALINITY	00445	WAIVED			
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	WAIVED			
HYDROXIDE ALKALINITY	71830	WAIVED			
IRON	01045	WAIVED			
MAGNESIUM	00927	WAIVED			
MANGANESE	01055	WAIVED			
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	WAIVED			
SILVER	01077	WAIVED			
SODIUM	00929	WAIVED			
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2810011***

System Name: ***PLEASURE COVE RESORT***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)

PS Code: ***2810011-002***

Source Name: ***TREATMENT PLANT-LAKE BERYESSA INTAKE-TRD***

Source Number: ***002***

Source Status: ***ACTIVE TREATED***

Water type: ***SURFACE***

SECONDARY/GP

TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

PS Code: ***2810011-006***

Source Name: ***NEW WELL***

Source Number: ***006***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

GENERAL NON CHAP 15

DIAZINON	39570	WAIVED			

INORGANIC

ALUMINUM	01105	WAIVED			
ANTIMONY	01097	WAIVED			
ARSENIC	01002	WAIVED			
ASBESTOS	81855	WAIVED			
BARIUM	01007	WAIVED			
BERYLLIUM	01012	WAIVED			
CADMIUM	01027	WAIVED			
CHROMIUM (TOTAL)	01034	WAIVED			
CYANIDE	01291	WAIVED			
FLUORIDE (F) (NATURAL-SOURCE)	00951	000			**DUE**
LEAD	01051	WAIVED			
MERCURY	71900	WAIVED			
NICKEL	01067	WAIVED			
PERCHLORATE	A-031	WAIVED			
SELENIUM	01147	WAIVED			
THALLIUM	01059	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2810011***

System Name: ***PLEASURE COVE RESORT***

PS Code: ***2810011-006***

Source Name: ***NEW WELL***

Source Number: ***006***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
NITRATE/NITRITE					
NITRATE (AS NO3)	**71850**	**000**			**DUE**
NITRITE (AS N)	**00620**	**000**			**DUE**
RADIOLOGICAL					
GROSS ALPHA	**01501**	**WAIVED**			
GROSS BETA	**03501**	**WAIVED**			
RA-226 FOR CWS OR TOTAL RA FOR NTNC BY 903.0	**A-080**	**WAIVED**			
RA-226 OR TOTAL RA BY 903.0 C.E.	**A-081**	**WAIVED**			
RADIUM 226	**09501**	**WAIVED**			
RADIUM 228	**11501**	**WAIVED**			
RADIUM, TOTAL, MDA95-NTNC ONLY, BY 903.0	**A-082**	**WAIVED**			
STRONTIUM-90	**13501**	**WAIVED**			
TRITIUM	**07000**	**WAIVED**			
URANIUM (PCI/L)	**28012**	**WAIVED**			
REGULATED SOC					
2,3,7,8-TCDD (DIOXIN)	**34676**	**WAIVED**			
2,4,5-TP (SILVEX)	**39045**	**WAIVED**			
2,4-D	**39730**	**WAIVED**			
ALACHLOR	**77825**	**WAIVED**			
ATRAZINE	**39033**	**WAIVED**			
BENTAZON	**38710**	**WAIVED**			
BENZO (A) PYRENE	**34247**	**WAIVED**			
CARBOFURAN	**81405**	**WAIVED**			
CHLORDANE	**39350**	**WAIVED**			
DALAPON	**38432**	**WAIVED**			
DI(2-ETHYLHEXYL)ADIPATE	**A-026**	**WAIVED**			
DI(2-ETHYLHEXYL)PHTHALATE	**39100**	**WAIVED**			
DIBROMOCHLOROPROPANE (DBCP)	**38761**	**WAIVED**			
DINOSEB	**81287**	**WAIVED**			
DIQUAT	**78885**	**WAIVED**			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2810011***

System Name: ***PLEASURE COVE RESORT***

PS Code: ***2810011-006***

Source Name: ***NEW WELL***

Source Number: ***006***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED SOC					
ENDOTHALL	38926	WAIVED			
ENDRIN	39390	WAIVED			
ETHYLENE DIBROMIDE (EDB)	77651	WAIVED			
GLYPHOSATE	79743	WAIVED			
HEPTACHLOR	39410	WAIVED			
HEPTACHLOR EPOXIDE	39420	WAIVED			
HEXACHLOROBENZENE	39700	WAIVED			
HEXACHLOROCYCLOPENTADIENE	34386	WAIVED			
LINDANE	39340	WAIVED			
METHOXYCHLOR	39480	WAIVED			
MOLINATE	82199	WAIVED			
OXAMYL	38865	WAIVED			
PENTACHLOROPHENOL	39032	WAIVED			
PICLORAM	39720	WAIVED			
POLYCHLORINATED BIPHENYLS, TOTAL, AS DCB	39516	WAIVED			
SIMAZINE	39055	WAIVED			
THIOBENCARB	A-001	WAIVED			
TOXAPHENE	39400	WAIVED			
REGULATED VOC					
1,1,1-TRICHLOROETHANE	34506	WAIVED			
1,1,2,2-TETRACHLOROETHANE	34516	WAIVED			
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	81611	WAIVED			
1,1,2-TRICHLOROETHANE	34511	WAIVED			
1,1-DICHLOROETHANE	34496	WAIVED			
1,1-DICHLOROETHYLENE	34501	WAIVED			
1,2,4-TRICHLOROBENZENE	34551	WAIVED			
1,2-DICHLOROBENZENE	34536	WAIVED			
1,2-DICHLOROETHANE	34531	WAIVED			
1,2-DICHLOROPROPANE	34541	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2810011***

System Name: ***PLEASURE COVE RESORT***

PS Code: ***2810011-006***

Source Name: ***NEW WELL***

Source Number: ***006***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
REGULATED VOC					
1,3-DICHLOROPROPENE (TOTAL)	34561	WAIVED			
1,4-DICHLOROBENZENE	34571	WAIVED			
BENZENE	34030	WAIVED			
CARBON TETRACHLORIDE	32102	WAIVED			
CIS-1,2-DICHLOROETHYLENE	77093	WAIVED			
DICHLOROMETHANE	34423	WAIVED			
ETHYLBENZENE	34371	WAIVED			
METHYL-TERT-BUTYL-ETHER (MTBE)	46491	WAIVED			
MONOCHLOROBENZENE	34301	WAIVED			
STYRENE	77128	WAIVED			
TETRACHLOROETHYLENE	34475	WAIVED			
TOLUENE	34010	WAIVED			
TRANS-1,2-DICHLOROETHYLENE	34546	WAIVED			
TRICHLOROETHYLENE	39180	WAIVED			
TRICHLOROFLUOROMETHANE	34488	WAIVED			
VINYL CHLORIDE	39175	WAIVED			
XYLENES (TOTAL)	81551	WAIVED			
SECONDARY/GP					
AGGRSSIVE INDEX (CORROSIVITY)	82383	WAIVED			
BICARBONATE ALKALINITY	00440	000			DUE
CALCIUM	00916	000			DUE
CARBONATE ALKALINITY	00445	000			DUE
CHLORIDE	00940	WAIVED			
COLOR	00081	WAIVED			
COPPER	01042	WAIVED			
FOAMING AGENTS (MBAS)	38260	WAIVED			
HARDNESS (TOTAL) AS CACO3	00900	000			DUE
HYDROXIDE ALKALINITY	71830	000			DUE
IRON	01045	000			DUE

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported

System Number: ***2810011***

System Name: ***PLEASURE COVE RESORT***

PS Code: ***2810011-006***

Source Name: ***NEW WELL***

Source Number: ***006***

Source Status: ***ACTIVE RAW***

Water type: ***GROUNDWATER OR WELL***

SECONDARY/GP	STORET NUMBER	TESTING INTERVAL (MONTHS)*	LAST TEST DATE (yyyy/mm/dd)	LAST RESULT REPORTED	NEXT TEST DATE (yyyy/mm)
MAGNESIUM	00927	000			DUE
MANGANESE	01055	000			DUE
ODOR THRESHOLD @ 60 C	00086	WAIVED			
PH, LABORATORY	00403	000			DUE
SILVER	01077	WAIVED			
SODIUM	00929	000			DUE
SPECIFIC CONDUCTANCE	00095	WAIVED			
SULFATE	00945	WAIVED			
TOTAL DISSOLVED SOLIDS	70300	WAIVED			
TURBIDITY, LABORATORY	82079	WAIVED			
ZINC	01092	WAIVED			

**Testing interval is in months;*
0 = No data for this constituent and is DUE NOW
999 = Waived testing (not required)
I = Invalid (NOT) valid analyses reported