



SANDRA SHEWRY, MPH, MSW
Acting Director

State of California—Health and Human Services Agency
California Department of Public Health



GAVIN NEWSOM
Governor

San Onofre Nuclear Generating Station Independent Spent Nuclear Fuel Storage Installation

Report period: August 2020

This report provides radiation data at the San Onofre Nuclear Generating Station (SONGS) Independent Spent Fuel Storage Installation (ISFSI). The information was gathered according to an agreement between SONGS and the California Department of Public Health Radiologic Health Branch (RHB).

Dry Storage at SONGS

The first used fuel assemblies were transferred from wet (pool) storage to the dry cask storage units in the TN-NUHOMS system in October 2003. In total, 1,187 fuel assemblies are stored in the NUHOMS system in 50 canisters. The Holtec Hi-STORM UMAX dry storage system was constructed between April 2016 and the end of 2017, with the first assemblies transferred in January 2018. Loading of the UMAX system is ongoing with an expected completion date of mid-2020. The Holtec system will house 73 canisters of spent nuclear fuel.

Radiation Monitoring

Radiation level measurements around the ISFSI were initiated before fuel was placed in the NUHOMS system to determine background levels. Radiation measurements using sensitive Thermoluminescent Dosimeters (TLDs) have been made at locations around the ISFSI since then and reported to the Nuclear Regulatory Commission in SONGS Annual Radiological Environmental Operating Reports. These reports (through 2015) are available at [U.S. NRC Radioactive Effluent and Environmental Reports](#), or in the NRC public Document System (ADAMS). Reports beginning in 2016 are available at [SONGS Environmental Monitoring](#).

Additional TLDs were placed around the Holtec ISFSI in 2016 as it was constructed and before operation and have been in place since the first fuel canister was placed in 2018. Gamma-sensitive radiation monitors were added in 2019 at three locations in the ISFSI area and one additional monitor in a control location. The data are summarized in tables with daily averages, maxima, and minima. Those data tables are attached, one for each of the four locations.

More information on radiation monitoring is available at [SONGS Dry Fuel Storage Radiation Monitoring](#).

Locations

There are three radiation monitors in the ISFSI at locations depicted on the image below:



A fourth radiation monitor, at a control location, is located at the edge of the parking lot north of the ISFSI such that it measures background radiation in an unaffected reference area similar to the ISFSI.



It is important to note that while fuel transfer operations at SONGS are in progress, elevated radiation level readings will be seen as canisters of spent fuel pass by the continuous radiation monitors. The radiation monitor at Location #3, for instance, is adjacent to the path of the vertical cask transporter as it enters the storage pad for canister downloading. Higher readings will be seen on days in which fuel movement is occurring. Other ISFSI monitors may show these elevated readings as well until the canister is safely placed into its storage module. These temporarily elevated readings are normal and expected.

Fuel Transfer to the ISFSI

Fuel transfer / download during August 2020 occurred on the following dates:

- 8/6/2020 – 8/7/2020

Waste Shipments Offsite

There were no waste shipments offsite that impacted radiation measurements by the ISFSI Radiation Monitoring system during August 2020.

Other

There were no other relevant activities (i.e. temporary power outage, radiation monitor maintenance, etc.) during August 2020.

Table 1: Daily Results for August 2020 (in millirem per hour) for Location #1

Day	Average Dose Rate	Maximum Dose Rate	Minimum Dose Rate
1-Aug	0.024	0.030	0.019
2-Aug	0.024	0.032	0.017
3-Aug	0.024	0.031	0.018
4-Aug	0.023	0.031	0.018
5-Aug	0.024	0.032	0.018
6-Aug	0.024	0.037	0.018
7-Aug	0.035	0.280	0.019
8-Aug	0.024	0.031	0.018
9-Aug	0.024	0.031	0.018
10-Aug	0.023	0.030	0.018
11-Aug	0.024	0.031	0.018
12-Aug	0.024	0.033	0.017
13-Aug	0.024	0.032	0.019
14-Aug	0.024	0.032	0.019
15-Aug	0.024	0.031	0.018
16-Aug	0.024	0.031	0.018
17-Aug	0.024	0.031	0.018
18-Aug	0.024	0.030	0.016
19-Aug	0.024	0.030	0.019
20-Aug	0.023	0.034	0.016
21-Aug	0.024	0.032	0.017
22-Aug	0.023	0.030	0.018
23-Aug	0.024	0.030	0.019
24-Aug	0.023	0.035	0.018
25-Aug	0.023	0.034	0.016
26-Aug	0.024	0.032	0.018
27-Aug	0.024	0.030	0.017
28-Aug	0.024	0.030	0.018
29-Aug	0.023	0.031	0.017
30-Aug	0.023	0.031	0.017
31-Aug	0.023	0.032	0.016

Table 2: Daily Results for August 2020 (in millirem per hour) for Location #2

Day	Average Dose Rate	Maximum Dose Rate	Minimum Dose Rate
1-Aug	0.009	0.012	0.006
2-Aug	0.009	0.012	0.005
3-Aug	0.009	0.013	0.006
4-Aug	0.009	0.012	0.006
5-Aug	0.009	0.012	0.006
6-Aug	0.010	0.400	0.006
7-Aug	0.013	0.109	0.002
8-Aug	0.009	0.012	0.006
9-Aug	0.009	0.013	0.006
10-Aug	0.009	0.012	0.006
11-Aug	0.009	0.012	0.006
12-Aug	0.009	0.012	0.005
13-Aug	0.009	0.012	0.006
14-Aug	0.009	0.012	0.005
15-Aug	0.009	0.012	0.006
16-Aug	0.009	0.012	0.006
17-Aug	0.009	0.012	0.006
18-Aug	0.009	0.013	0.006
19-Aug	0.009	0.012	0.006
20-Aug	0.009	0.013	0.006
21-Aug	0.009	0.013	0.006
22-Aug	0.009	0.013	0.005
23-Aug	0.009	0.014	0.006
24-Aug	0.009	0.012	0.006
25-Aug	0.009	0.013	0.006
26-Aug	0.009	0.013	0.006
27-Aug	0.009	0.013	0.006
28-Aug	0.009	0.014	0.006
29-Aug	0.009	0.012	0.006
30-Aug	0.009	0.012	0.006
31-Aug	0.009	0.012	0.006

Table 3: Daily Results for August 2020 (in millirem per hour) for Location #3

Day	Average Dose Rate	Maximum Dose Rate	Minimum Dose Rate
1-Aug	0.015	0.020	0.011
2-Aug	0.014	0.020	0.010
3-Aug	0.015	0.022	0.011
4-Aug	0.015	0.019	0.011
5-Aug	0.015	0.020	0.011
6-Aug	0.015	0.020	0.011
7-Aug	0.064	0.800	0.011
8-Aug	0.015	0.020	0.010
9-Aug	0.015	0.019	0.011
10-Aug	0.015	0.020	0.011
11-Aug	0.015	0.021	0.010
12-Aug	0.015	0.020	0.012
13-Aug	0.015	0.020	0.011
14-Aug	0.015	0.020	0.012
15-Aug	0.015	0.020	0.011
16-Aug	0.015	0.020	0.011
17-Aug	0.015	0.020	0.010
18-Aug	0.015	0.020	0.011
19-Aug	0.015	0.020	0.010
20-Aug	0.015	0.021	0.011
21-Aug	0.015	0.020	0.011
22-Aug	0.015	0.021	0.010
23-Aug	0.015	0.019	0.011
24-Aug	0.015	0.021	0.010
25-Aug	0.015	0.021	0.010
26-Aug	0.015	0.021	0.011
27-Aug	0.015	0.021	0.011
28-Aug	0.015	0.020	0.010
29-Aug	0.015	0.019	0.011
30-Aug	0.015	0.019	0.011
31-Aug	0.015	0.018	0.011

Table 4: Daily Results for August 2020 [in millirem per hour) for Location #4 (Control)

Day	Average Dose Rate	Maximum Dose Rate	Minimum Dose Rate
1-Aug	0.006	0.009	0.004
2-Aug	0.006	0.009	0.004
3-Aug	0.006	0.010	0.004
4-Aug	0.006	0.009	0.004
5-Aug	0.006	0.009	0.004
6-Aug	0.006	0.009	0.004
7-Aug	0.006	0.010	0.004
8-Aug	0.006	0.008	0.003
9-Aug	0.006	0.008	0.004
10-Aug	0.006	0.009	0.004
11-Aug	0.006	0.009	0.004
12-Aug	0.006	0.010	0.004
13-Aug	0.006	0.010	0.004
14-Aug	0.006	0.009	0.003
15-Aug	0.006	0.010	0.004
16-Aug	0.006	0.010	0.004
17-Aug	0.006	0.009	0.003
18-Aug	0.006	0.009	0.004
19-Aug	0.006	0.009	0.004
20-Aug	0.006	0.010	0.004
21-Aug	0.006	0.009	0.004
22-Aug	0.006	0.009	0.004
23-Aug	0.006	0.010	0.004
24-Aug	0.006	0.010	0.003
25-Aug	0.007	0.009	0.004
26-Aug	0.007	0.010	0.004
27-Aug	0.007	0.011	0.005
28-Aug	0.006	0.009	0.004
29-Aug	0.006	0.009	0.004
30-Aug	0.006	0.009	0.004
31-Aug	0.006	0.010	0.004