

Nov 21 19, 04:49p

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  055956	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____		(X3) DATE SURVEY COMPLETED  11/05/2019
NAME OF PROVIDER OR SUPPLIER  BRIARWOOD POST ACUTE			STREET ADDRESS, CITY, STATE, ZIP CODE 5901 LEMON HILL AVE SACRAMENTO, CA 95824		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
E 000	Initial Comments  Surveyor: 32973 The following reflects the findings of the California Department of Public Health, during an Emergency Preparedness recertification survey. The findings are in accordance with 42 Code of Federal Regulations (CFR) 483.73, Requirement for Long Term Care (LTC) Facilities.  Representing the California Department of Public Health: 32973  The facility is not in substantial compliance with 42 CFR 483.73 for Long Term Care (LTC) Facilities	E 000			
E 006 SS=D	Census: 45 Plan Based on All Hazards Risk Assessment CFR(s): 483.73(a)(1)-(2)  [(a) Emergency Plan. The [facility] must develop and maintain an emergency preparedness plan that must be reviewed, and updated at least annually. The plan must do the following:]  (1) Be based on and include a documented, facility-based and community-based risk assessment, utilizing an all-hazards approach.*  *[For LTC facilities at §483.73(a)(1):] (1) Be based on and include a documented, facility-based and community-based risk assessment, utilizing an all-hazards approach, including missing residents.  *[For ICF/IIDs at §483.475(a)(1):] (1) Be based on and include a documented, facility-based and community-based risk assessment, utilizing an	E 006			

**RECEIVED****By LSC at 10:28 am, Nov 22, 2019**

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

Approved 12/16/2019 per Cynthia Luc, SSM I

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  055956	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____		(X3) DATE SURVEY COMPLETED  11/05/2019
NAME OF PROVIDER OR SUPPLIER  BRIARWOOD POST ACUTE			STREET ADDRESS, CITY, STATE, ZIP CODE 5901 LEMON HILL AVE SACRAMENTO, CA 95824		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 006	<p>Continued From page 1 all-hazards approach, including missing clients.</p> <p>(2) Include strategies for addressing emergency events identified by the risk assessment.</p> <p>* [For Hospices at §418.113(a)(2):] (2) Include strategies for addressing emergency events identified by the risk assessment, including the management of the consequences of power failures, natural disasters, and other emergencies that would affect the hospice's ability to provide care.</p> <p>This REQUIREMENT is not met as evidenced by: Surveyor: 32973 Based on document review and interview, the facility failed to maintain Emergency Preparedness (EP) assessment and planning. This was evidenced by the failure to provide an updated facility-based and community-based risk assessment, utilizing an all-hazards approach to reflect and include assessments for Missing Residents, and Natural Disasters within in the facility's geographical location. This affected 45 of 45 residents, and could result in ineffective emergency planning.</p> <p>Finding:</p> <p>During document review and interview with Administrative Staff (AS) on 11/5/19, the EP plan was requested and reviewed.</p> <p>At 2:05 p.m., the EP plan failed to have an updated facility-based and community-based risk assessment that included an evaluation/assessment for Missing Residents and Natural Disasters.</p> <p>The annual plan review was dated 1/31/19. Upon</p>	E 006			

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>055956</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>02</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>11/05/2019</b>
NAME OF PROVIDER OR SUPPLIER  <b>BRIARWOOD POST ACUTE</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>5901 LEMON HILL AVE SACRAMENTO, CA 95824</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 006	Continued From page 2	E 006			
E 015 SS=D	<p>interview, AS2 confirmed the finding after plan review.</p> <p>Subsistence Needs for Staff and Patients CFR(s): 483.73(b)(1)</p> <p>[(b) Policies and procedures. [Facilities] must develop and implement emergency preparedness policies and procedures, based on the emergency plan set forth in paragraph (a) of this section, risk assessment at paragraph (a)(1) of this section, and the communication plan at paragraph (c) of this section. The policies and procedures must be reviewed and updated at least annually.] At a minimum, the policies and procedures must address the following:</p> <p>(1) The provision of subsistence needs for staff and patients whether they evacuate or shelter in place, include, but are not limited to the following:</p> <p>(i) Food, water, medical and pharmaceutical supplies</p> <p>(ii) Alternate sources of energy to maintain the following:</p> <p>(A) Temperatures to protect patient health and safety and for the safe and sanitary storage of provisions.</p> <p>(B) Emergency lighting.</p> <p>(C) Fire detection, extinguishing, and alarm systems.</p> <p>(D) Sewage and waste disposal.</p> <p>*[For Inpatient Hospice at §418.113(b)(6)(iii):] Policies and procedures.</p> <p>(6) The following are additional requirements for hospice-operated inpatient care facilities only. The policies and procedures must address the following:</p> <p>(iii) The provision of subsistence needs for</p>	E 015			

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  055956	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____		(X3) DATE SURVEY COMPLETED  11/05/2019
NAME OF PROVIDER OR SUPPLIER  BRIARWOOD POST ACUTE			STREET ADDRESS, CITY, STATE, ZIP CODE 5901 LEMON HILL AVE SACRAMENTO, CA 95824		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 015	<p>Continued From page 3</p> <p>hospice employees and patients, whether they evacuate or shelter in place, include, but are not limited to the following:</p> <p>(A) Food, water, medical, and pharmaceutical supplies.</p> <p>(B) Alternate sources of energy to maintain the following:</p> <p>(1) Temperatures to protect patient health and safety and for the safe and sanitary storage of provisions.</p> <p>(2) Emergency lighting.</p> <p>(3) Fire detection, extinguishing, and alarm systems.</p> <p>(C) Sewage and waste disposal.</p> <p>This REQUIREMENT is not met as evidenced by:</p> <p>Surveyor: 32973</p> <p>Based on document review and interview, the facility failed to maintain the Emergency Preparedness (EP) Plan. This was evidenced by the failure to provide Policy and Procedure that addresses provision of subsistence needs. This affected 45 of 45 residents, and could result in an ineffective EP plan for sheltering in-place.</p> <p>Finding:</p> <p>During document review and interview with Administrative Staff (AS) on 11/5/19, the EP plan was requested and reviewed.</p> <p>At 2:25 p.m., the records provided failed to include a Policy and Procedure that addresses:</p> <p>1.) adequate supply of food, water, and pharmaceutical supplies</p> <p>2.) alternate energy sources to maintain fire alarm system, emergency lighting, and temperature to protect the health and safety of clients</p>	E 015			

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>055956</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>11/05/2019</b>
NAME OF PROVIDER OR SUPPLIER  <b>BRIARWOOD POST ACUTE</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>5901 LEMON HILL AVE SACRAMENTO, CA 95824</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 015	Continued From page 4 3.) sanitary storage and waste disposal.  Upon interview, AS2 confirmed the finding after review of the plan.	E 015			
E 024 SS=D	Policies/Procedures-Volunteers and Staffing CFR(s): 483.73(b)(6)  [(b) Policies and procedures. The [facilities] must develop and implement emergency preparedness policies and procedures, based on the emergency plan set forth in paragraph (a) of this section, risk assessment at paragraph (a)(1) of this section, and the communication plan at paragraph (c) of this section. The policies and procedures must be reviewed and updated at least annually. At a minimum, the policies and procedures must address the following:]  (6) [or (4), (5), or (7) as noted above] The use of volunteers in an emergency or other emergency staffing strategies, including the process and role for integration of State and Federally designated health care professionals to address surge needs during an emergency.  *[For RNHCIs at §403.748(b):] Policies and procedures. (6) The use of volunteers in an emergency and other emergency staffing strategies to address surge needs during an emergency.  *[For Hospice at §418.113(b):] Policies and procedures. (4) The use of hospice employees in an emergency and other emergency staffing strategies, including the process and role for integration of State and Federally designated health care professionals to address surge needs during an emergency.	E 024			

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  055956	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____		(X3) DATE SURVEY COMPLETED  11/05/2019
NAME OF PROVIDER OR SUPPLIER  BRIARWOOD POST ACUTE			STREET ADDRESS, CITY, STATE, ZIP CODE 5901 LEMON HILL AVE SACRAMENTO, CA 95824		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 024	Continued From page 5 This REQUIREMENT is not met as evidenced by: Surveyor: 32973 Based on document review and interview, the facility failed to maintain the Emergency Preparedness (EP) plan. This was evidenced by the failure to provide Policy and Procedure for the use of volunteers and other staffing strategies. This affected 45 of 45 residents, and could potentially result in ineffective emergency planning and evacuation.  Finding:  During document review and interview with Administrative Staff (AS) on 11/5/19, the EP plan was reviewed.  At 2:20 p.m., the EP plan failed to provide Policy and Procedure for arrangements and/or agreements, that addresses staffing strategies and the use of volunteers during emergencies.  Upon interview, AS2 and AS3 confirmed the finding, and stated that they were unable to locate the Policy and Procedure after review of the plan.	E 024			
E 037 SS=D	EP Training Program CFR(s): 483.73(d)(1)  (1) Training program. The [facility, except CAHs, ASCs, PACE organizations, PRTFs, Hospices, and dialysis facilities] must do all of the following:  (i) Initial training in emergency preparedness policies and procedures to all new and existing staff, individuals providing services under arrangement, and volunteers, consistent with their expected role.	E 037			

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  055956	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____		(X3) DATE SURVEY COMPLETED  11/05/2019
NAME OF PROVIDER OR SUPPLIER  BRIARWOOD POST ACUTE			STREET ADDRESS, CITY, STATE, ZIP CODE 5901 LEMON HILL AVE SACRAMENTO, CA 95824		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 037	<p>Continued From page 6</p> <p>(ii) Provide emergency preparedness training at least annually.</p> <p>(iii) Maintain documentation of the training.</p> <p>(iv) Demonstrate staff knowledge of emergency procedures.</p> <p>*[For Hospitals at §482.15(d) and RHCs/FQHCs at §491.12:] (1) Training program. The [Hospital or RHC/FQHC] must do all of the following:</p> <p>(i) Initial training in emergency preparedness policies and procedures to all new and existing staff, individuals providing on-site services under arrangement, and volunteers, consistent with their expected roles.</p> <p>(ii) Provide emergency preparedness training at least annually.</p> <p>(iii) Maintain documentation of the training.</p> <p>(iv) Demonstrate staff knowledge of emergency procedures.</p> <p>*[For Hospices at §418.113(d):] (1) Training. The hospice must do all of the following:</p> <p>(i) Initial training in emergency preparedness policies and procedures to all new and existing hospice employees, and individuals providing services under arrangement, consistent with their expected roles.</p> <p>(ii) Demonstrate staff knowledge of emergency procedures.</p> <p>(iii) Provide emergency preparedness training at least annually.</p> <p>(iv) Periodically review and rehearse its emergency preparedness plan with hospice employees (including nonemployee staff), with special emphasis placed on carrying out the procedures necessary to protect patients and others.</p> <p>*[For PRTFs at §441.184(d):] (1) Training</p>	E 037			

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  055956	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____		(X3) DATE SURVEY COMPLETED  11/05/2019	
NAME OF PROVIDER OR SUPPLIER  BRIARWOOD POST ACUTE			STREET ADDRESS, CITY, STATE, ZIP CODE 5901 LEMON HILL AVE SACRAMENTO, CA 95824			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE	
E 037	<p>Continued From page 7</p> <p>program. The PRTF must do all of the following:</p> <p>(i) Initial training in emergency preparedness policies and procedures to all new and existing staff, individuals providing services under arrangement, and volunteers, consistent with their expected roles.</p> <p>(ii) After initial training, provide emergency preparedness training at least annually.</p> <p>(iii) Demonstrate staff knowledge of emergency procedures.</p> <p>(iv) Maintain documentation of all emergency preparedness training.</p> <p>*[For PACE at §460.84(d):] (1) The PACE organization must do all of the following:</p> <p>(i) Initial training in emergency preparedness policies and procedures to all new and existing staff, individuals providing on-site services under arrangement, contractors, participants, and volunteers, consistent with their expected roles.</p> <p>(ii) Provide emergency preparedness training at least annually.</p> <p>(iii) Demonstrate staff knowledge of emergency procedures, including informing participants of what to do, where to go, and whom to contact in case of an emergency.</p> <p>(iv) Maintain documentation of all training.</p> <p>*[For CORFs at §485.68(d):](1) Training. The CORF must do all of the following:</p> <p>(i) Provide initial training in emergency preparedness policies and procedures to all new and existing staff, individuals providing services under arrangement, and volunteers, consistent with their expected roles.</p> <p>(ii) Provide emergency preparedness training at least annually.</p> <p>(iii) Maintain documentation of the training.</p>	E 037				



DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  055956	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____		(X3) DATE SURVEY COMPLETED  11/05/2019
NAME OF PROVIDER OR SUPPLIER  BRIARWOOD POST ACUTE			STREET ADDRESS, CITY, STATE, ZIP CODE 5901 LEMON HILL AVE SACRAMENTO, CA 95824		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 037	<p>Continued From page 8</p> <p>(iv) Demonstrate staff knowledge of emergency procedures. All new personnel must be oriented and assigned specific responsibilities regarding the CORF's emergency plan within 2 weeks of their first workday. The training program must include instruction in the location and use of alarm systems and signals and firefighting equipment.</p> <p>*[For CAHs at §485.625(d):] (1) Training program. The CAH must do all of the following:</p> <p>(i) Initial training in emergency preparedness policies and procedures, including prompt reporting and extinguishing of fires, protection, and where necessary, evacuation of patients, personnel, and guests, fire prevention, and cooperation with firefighting and disaster authorities, to all new and existing staff, individuals providing services under arrangement, and volunteers, consistent with their expected roles.</p> <p>(ii) Provide emergency preparedness training at least annually.</p> <p>(iii) Maintain documentation of the training.</p> <p>(iv) Demonstrate staff knowledge of emergency procedures.</p> <p>*[For CMHCs at §485.920(d):] (1) Training. The CMHC must provide initial training in emergency preparedness policies and procedures to all new and existing staff, individuals providing services under arrangement, and volunteers, consistent with their expected roles, and maintain documentation of the training. The CMHC must demonstrate staff knowledge of emergency procedures. Thereafter, the CMHC must provide emergency preparedness training at least annually.</p>	E 037			

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  055956	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____		(X3) DATE SURVEY COMPLETED  11/05/2019
NAME OF PROVIDER OR SUPPLIER  BRIARWOOD POST ACUTE			STREET ADDRESS, CITY, STATE, ZIP CODE 5901 LEMON HILL AVE SACRAMENTO, CA 95824		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 037	Continued From page 9  This REQUIREMENT is not met as evidenced by: Surveyor: 32973 Based on document review and interview, the facility failed to maintain emergency preparedness (EP) plan training. This was evidenced by the failure to provide documentation for initial and annual training, and competency evaluation in EP plan Policies and Procedures to all on-site service providers under arrangement, consistent with their expected roles. This affected 45 of 45 residents, and could result in an ineffective Emergency Preparedness (EP) plan.  Finding:  During record review and interview with Administrative Staff (AS) on 11/5/19, the EP plan training, was reviewed.  At 2:30 p.m., the facility's initial and annual training in EP Policies and Procedures, along with staff training files for completion and competency evaluation, were requested. The EP plan training provided failed to show that initial and annual training for all Therapist providing on-site services, had been completed.  Upon interview, AS2 confirmed the finding stating that the facility had not completed and/or documented initial and annual EP plan Policy and Procedure training and staff competency evaluation for all individuals providing on-site services under arrangement with their expected roles.	E 037			
E 039 SS=F	EP Testing Requirements CFR(s): 483.73(d)(2)	E 039			

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  055956		(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____		(X3) DATE SURVEY COMPLETED  11/05/2019	
NAME OF PROVIDER OR SUPPLIER  BRIARWOOD POST ACUTE				STREET ADDRESS, CITY, STATE, ZIP CODE 5901 LEMON HILL AVE SACRAMENTO, CA 95824			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE		
E 039	Continued From page 10  (2) Testing. The [facility, except for LTC facilities, RNHCIs and OPOs] must conduct exercises to test the emergency plan at least annually. The [facility, except for RNHCIs and OPOs] must do all of the following:  *[For LTC Facilities at §483.73(d):] (2) Testing. The LTC facility must conduct exercises to test the emergency plan at least annually, including unannounced staff drills using the emergency procedures. The LTC facility must do all of the following:]  (i) Participate in a full-scale exercise that is community-based or when a community-based exercise is not accessible, an individual, facility-based. If the [facility] experiences an actual natural or man-made emergency that requires activation of the emergency plan, the [facility] is exempt from engaging in a community-based or individual, facility-based full-scale exercise for 1 year following the onset of the actual event. (ii) Conduct an additional exercise that may include, but is not limited to the following: (A) A second full-scale exercise that is community-based or individual, facility-based. (B) A tabletop exercise that includes a group discussion led by a facilitator, using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan. (iii) Analyze the [facility's] response to and maintain documentation of all drills, tabletop exercises, and emergency events, and revise the [facility's] emergency plan, as needed.	E 039					

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  055956	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____		(X3) DATE SURVEY COMPLETED  11/05/2019
NAME OF PROVIDER OR SUPPLIER  BRIARWOOD POST ACUTE			STREET ADDRESS, CITY, STATE, ZIP CODE 5901 LEMON HILL AVE SACRAMENTO, CA 95824		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 039	<p>Continued From page 11</p> <p>*[For RNHCIs at §403.748 and OPOs at §486.360] (d)(2) Testing. The [RNHCI and OPO] must conduct exercises to test the emergency plan. The [RNHCI and OPO] must do the following:</p> <p>(i) Conduct a paper-based, tabletop exercise at least annually. A tabletop exercise is a group discussion led by a facilitator, using a narrated, clinically relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan.</p> <p>(ii) Analyze the [RNHCI's and OPO's] response to and maintain documentation of all tabletop exercises, and emergency events, and revise the [RNHCI's and OPO's] emergency plan, as needed.</p> <p>This REQUIREMENT is not met as evidenced by:</p> <p>Surveyor: 32973</p> <p>Based on document review and interview, the facility failed to maintain emergency preparedness (EP) plan testing. This was evidenced by the failure to perform a full-scale community based exercise and/or provide rationale for non-performance, and to conduct a second full scale drill. This affected 45 of 45 residents, and could result in an ineffective Emergency Preparedness (EP) plan.</p> <p>Finding:</p> <p>During document review and interview with Administrative Staff (AS) on 11/5/19, the EP drills were requested and reviewed.</p> <p>At 2:35 p.m., no documentation was submitted by the facility for a current full scale community</p>	E 039			

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>055956</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>11/05/2019</b>	
NAME OF PROVIDER OR SUPPLIER  <b>BRIARWOOD POST ACUTE</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>5901 LEMON HILL AVE SACRAMENTO, CA 95824</b>			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE	
E 039	Continued From page 12 based drill, and/or second full scale drill and the rationale for non-compliance.  Upon interview, AS3 confirmed the finding after reviewing the training records, and stated that the previous maintenance person handled the drills and was no longer employed by the facility.  During a Life Safety Code survey on 12/20/18, the facility was cited for the failure to provide the required drill.	E 039				
E 041 SS=F	Hospital CAH and LTC Emergency Power CFR(s): 483.73(e)  (e) Emergency and standby power systems. The hospital must implement emergency and standby power systems based on the emergency plan set forth in paragraph (a) of this section and in the policies and procedures plan set forth in paragraphs (b)(1)(i) and (ii) of this section.  §483.73(e), §485.625(e) (e) Emergency and standby power systems. The [LTC facility and the CAH] must implement emergency and standby power systems based on the emergency plan set forth in paragraph (a) of this section.  §482.15(e)(1), §483.73(e)(1), §485.625(e)(1) Emergency generator location. The generator must be located in accordance with the location requirements found in the Health Care Facilities Code (NFPA 99 and Tentative Interim Amendments TIA 12-2, TIA 12-3, TIA 12-4, TIA 12-5, and TIA 12-6), Life Safety Code (NFPA 101 and Tentative Interim Amendments TIA 12-1, TIA 12-2, TIA 12-3, and TIA 12-4), and NFPA 110, when a new structure is built or when an existing	E 041				

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>055956</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____	(X3) DATE SURVEY COMPLETED  <b>11/05/2019</b>
---	--	---	--

NAME OF PROVIDER OR SUPPLIER

**BRIARWOOD POST ACUTE**

STREET ADDRESS, CITY, STATE, ZIP CODE

**5901 LEMON HILL AVE  
SACRAMENTO, CA 95824**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
--------------------------	--	---------------------	--	----------------------------

E 041

Continued From page 13  
structure or building is renovated.

482.15(e)(2), §483.73(e)(2), §485.625(e)(2)  
Emergency generator inspection and testing. The  
[hospital, CAH and LTC facility] must implement  
the emergency power system inspection, testing,  
and maintenance requirements found in the  
Health Care Facilities Code, NFPA 110, and Life  
Safety Code.

482.15(e)(3), §483.73(e)(3), §485.625(e)(3)  
Emergency generator fuel. [Hospitals, CAHs and  
LTC facilities] that maintain an onsite fuel source  
to power emergency generators must have a plan  
for how it will keep emergency power systems  
operational during the emergency, unless it  
evacuates.

\*[For hospitals at §482.15(h), LTC at §483.73(g),  
and CAHs §485.625(g):]

The standards incorporated by reference in this  
section are approved for incorporation by  
reference by the Director of the Office of the  
Federal Register in accordance with 5 U.S.C.  
552(a) and 1 CFR part 51. You may obtain the  
material from the sources listed below. You may  
inspect a copy at the CMS Information Resource  
Center, 7500 Security Boulevard, Baltimore, MD  
or at the National Archives and Records  
Administration (NARA). For information on the  
availability of this material at NARA, call  
202-741-6030, or go to:

[http://www.archives.gov/federal\\_register/code\\_of\\_federal\\_regulations/ibr\\_locations.html](http://www.archives.gov/federal_register/code_of_federal_regulations/ibr_locations.html).

If any changes in this edition of the Code are  
incorporated by reference, CMS will publish a  
document in the Federal Register to announce  
the changes.

E 041

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  055956	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____		(X3) DATE SURVEY COMPLETED  11/05/2019
NAME OF PROVIDER OR SUPPLIER  BRIARWOOD POST ACUTE			STREET ADDRESS, CITY, STATE, ZIP CODE 5901 LEMON HILL AVE SACRAMENTO, CA 95824		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 041	<p>Continued From page 14</p> <p>(1) National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169, www.nfpa.org, 1.617.770.3000.</p> <p>(i) NFPA 99, Health Care Facilities Code, 2012 edition, issued August 11, 2011.</p> <p>(ii) Technical interim amendment (TIA) 12-2 to NFPA 99, issued August 11, 2011.</p> <p>(iii) TIA 12-3 to NFPA 99, issued August 9, 2012.</p> <p>(iv) TIA 12-4 to NFPA 99, issued March 7, 2013.</p> <p>(v) TIA 12-5 to NFPA 99, issued August 1, 2013.</p> <p>(vi) TIA 12-6 to NFPA 99, issued March 3, 2014.</p> <p>(vii) NFPA 101, Life Safety Code, 2012 edition, issued August 11, 2011.</p> <p>(viii) TIA 12-1 to NFPA 101, issued August 11, 2011.</p> <p>(ix) TIA 12-2 to NFPA 101, issued October 30, 2012.</p> <p>(x) TIA 12-3 to NFPA 101, issued October 22, 2013.</p> <p>(xi) TIA 12-4 to NFPA 101, issued October 22, 2013.</p> <p>(xiii) NFPA 110, Standard for Emergency and Standby Power Systems, 2010 edition, including TIAs to chapter 7, issued August 6, 2009.</p> <p>This REQUIREMENT is not met as evidenced by:</p> <p>Surveyor: 32973</p> <p>Based on document review and interview, the facility failed to maintain the Emergency Preparedness (EP) plan. This was evidenced by the failure to provide Policy and Procedure for maintaining the facility's emergency power supply system (EPSS) and on-site fuel source during an emergency. This affected 45 of 45 residents, and could result in an ineffective Emergency Preparedness (EP) plan.</p> <p>Finding:</p>	E 041			

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>055956</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>02</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>11/05/2019</b>
NAME OF PROVIDER OR SUPPLIER  <b>BRIARWOOD POST ACUTE</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>5901 LEMON HILL AVE SACRAMENTO, CA 95824</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 041	Continued From page 15  During record review and interview with Administrative Staff (AS) on 11/5/19, the EP plan was requested and reviewed.  At 2:45 p.m., the facility was observed with a permanent 15 kilowatt gasoline fueled generator, with an on-site fuel source. No Policy and Procedure was available for an operational plan indicating how the facility will keep the EPSS operational during an emergency, unless the facility evacuates.  Upon interview, AS3 confirmed the finding after review of the EP plan.  During a Life Safety Code survey on 12/20/18, the facility was cited for the failure to provide the required generator plan.	E 041			
K 000	INITIAL COMMENTS  Surveyor: 32973 K3 BUILDING: 01 K6 PLAN APPROVAL: 1969 K7 SURVEY UNDER: 2012 EXISTING  STRUCTURE TYPE: ONE STORY, CONSTRUCTION TYPE V (111), FULLY SPRINKLERED.  The following reflects the findings of the California Department of Public Health, during an annual Life Safety Code recertification survey. The findings are in accordance with 42 Code of Federal Regulations (CFR) §483.90(a)(b)(c)(j), National Fire Protection Association (NFPA) 101 - Life Safety Code, 2012 Edition, and NFPA 99 - Health Care Facilities Code, 2012 Edition.	K 000			



DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  055956	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____		(X3) DATE SURVEY COMPLETED  11/05/2019
NAME OF PROVIDER OR SUPPLIER  BRIARWOOD POST ACUTE			STREET ADDRESS, CITY, STATE, ZIP CODE 5901 LEMON HILL AVE SACRAMENTO, CA 95824		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 000	Continued From page 16	K 000			
K 211 SS=D	<p>Representing the California Department of Public Health: 32973</p> <p>The facility is not in substantial compliance with 42 CFR §483.90 for Long Term Care Facilities.</p> <p>Census: 45</p> <p>Means of Egress - General CFR(s): NFPA 101</p> <p>Means of Egress - General Aisles, passageways, corridors, exit discharges, exit locations, and accesses are in accordance with Chapter 7, and the means of egress is continuously maintained free of all obstructions to full use in case of emergency, unless modified by 18/19.2.2 through 18/19.2.11. 18.2.1, 19.2.1, 7.1.10.1</p> <p>This REQUIREMENT is not met as evidenced by: Surveyor: 32973 Based on observation and interview, the facility failed to maintain the means of egress. This was evidenced by the failure to post exit-discharge guidance and directional signs. This affected one of two smoke compartments, and could result in delayed evacuation in the event of an emergency.</p> <p>NFPA 101, Life Safety Code, 2012 Edition Chapter 7 Means of Egress 7.7 Discharge from Exits. 7.7.3 Arrangement and Marking of Exit Discharge. 7.7.3.1 Where more than one exit discharge is required, exit discharges shall be arranged to meet the</p>	K 211			

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>055956</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>02</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>11/05/2019</b>
NAME OF PROVIDER OR SUPPLIER  <b>BRIARWOOD POST ACUTE</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>5901 LEMON HILL AVE SACRAMENTO, CA 95824</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 211	<p>Continued From page 17</p> <p>remoteness criteria of 7.5.1.3.</p> <p>7.7.3.2 The exit discharge shall be arranged and marked to make clear the direction of egress travel from the exit discharge to a public way.</p> <p>7.10.2 Directional Signs.</p> <p>7.10.2.1* A sign complying with 7.10.3, with a directional indicator showing the direction of travel, shall be placed in every location where the direction of travel to reach the nearest exit is not apparent.</p> <p>Finding:</p> <p>During a facility tour and interview with staff on 11/5/19, the means of egress, was observed.</p> <p>At 10:50 a.m., the designated exit located in the access corridor by Room 109, and exit discharge to the public-way, were observed. The exit discharged into an enclosed and gated courtyard that had two pathways in two different directions, and a gate to reach the public way. No exit and directional signs were posted on the exit path or gate.</p> <p>Upon interview, Staff 4 confirmed the finding that the exit discharge path and exit gate leading out of the courtyard and to public way beyond, were not clearly marked.</p>	K 211			
K 293 SS=D	Exit Signage CFR(s): NFPA 101	K 293			

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  055956	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____		(X3) DATE SURVEY COMPLETED  11/05/2019
NAME OF PROVIDER OR SUPPLIER  BRIARWOOD POST ACUTE			STREET ADDRESS, CITY, STATE, ZIP CODE 5901 LEMON HILL AVE SACRAMENTO, CA 95824		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 293	<p>Continued From page 18</p> <p>Exit Signage 2012 EXISTING Exit and directional signs are displayed in accordance with 7.10 with continuous illumination also served by the emergency lighting system. 19.2.10.1 (Indicate N/A in one-story existing occupancies with less than 30 occupants where the line of exit travel is obvious.) This REQUIREMENT is not met as evidenced by: Surveyor: 32973 Based on observation, document review, and interview, the facility failed to maintain the exit signs. This was evidenced by the failure to document performance of monthly visual inspections. This affected two of two smoke compartments, and could result in exit sign failure, resulting in delayed egress by staff, residents, and visitors during an emergency evacuation.</p> <p>NFPA 101, Life Safety Code, 2012 Edition 19.2.10 Marking of Means of Egress. 19.2.10.1 Means of egress shall have signs in accordance with Section 7.10, unless otherwise permitted by 19.2.10.2, 19.2.10.3, or 19.2.10.4.</p> <p>7.10.9.1 Inspection. Exit signs shall be visually inspected for operation of the illumination sources at intervals not to exceed 30 days or shall be periodically monitored in accordance with 7.9.3.1.3.</p> <p>Finding:  During a facility tour, document review, and</p>	K 293			

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  055956	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____		(X3) DATE SURVEY COMPLETED  11/05/2019	
NAME OF PROVIDER OR SUPPLIER  BRIARWOOD POST ACUTE			STREET ADDRESS, CITY, STATE, ZIP CODE 5901 LEMON HILL AVE SACRAMENTO, CA 95824			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE	
K 293	Continued From page 19 interview with staff on 11/5/19, the path of egress and exits were observed.  At 12:15 p.m., hard wired illuminated exit signs were observed throughout all access corridors. No documentation was available for monthly visual inspections of the exit signs for the following months: 2/2019, 3/2019, 4/2019, 5/2019, 6/2019, 7/2019, 8/2019, and 9/2019. Upon interview, Staff 4 confirmed the finding after review of the record.	K 293				
K 321 SS=D	Hazardous Areas - Enclosure CFR(s): NFPA 101  Hazardous Areas - Enclosure Hazardous areas are protected by a fire barrier having 1-hour fire resistance rating (with 3/4 hour fire rated doors) or an automatic fire extinguishing system in accordance with 8.7.1 or 19.3.5.9. When the approved automatic fire extinguishing system option is used, the areas shall be separated from other spaces by smoke resisting partitions and doors in accordance with 8.4. Doors shall be self-closing or automatic-closing and permitted to have nonrated or field-applied protective plates that do not exceed 48 inches from the bottom of the door. Describe the floor and zone locations of hazardous areas that are deficient in REMARKS. 19.3.2.1, 19.3.5.9  Area Automatic Sprinkler Separation N/A a. Boiler and Fuel-Fired Heater Rooms b. Laundries (larger than 100 square feet) c. Repair, Maintenance, and Paint Shops d. Soiled Linen Rooms (exceeding 64 gallons) e. Trash Collection Rooms	K 321				

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  055956	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____		(X3) DATE SURVEY COMPLETED  11/05/2019
NAME OF PROVIDER OR SUPPLIER  BRIARWOOD POST ACUTE			STREET ADDRESS, CITY, STATE, ZIP CODE 5901 LEMON HILL AVE SACRAMENTO, CA 95824		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 321	Continued From page 20 (exceeding 64 gallons) f. Combustible Storage Rooms/Spaces (over 50 square feet) g. Laboratories (if classified as Severe Hazard - see K322) This REQUIREMENT is not met as evidenced by: Surveyor: 32973 Based on observation and interview, the facility failed to maintain the hazardous areas. This was evidenced by the failure to maintain the door. This affected one of two smoke compartments, and could result in a delay in containing smoke and/or fire to a hazardous area.  Finding:  During a facility tour and interview with staff on 11/5/19, the hazardous area enclosures were observed.  At 10:55 a.m., the Laundry Room, was observed. The room was greater than 100 (approximately 200) square feet. The room door was not self-closing. The self-closing device was disconnected and non-functional. Upon interview, Staff 4 confirmed the finding.	K 321			
K 324 SS=F	Cooking Facilities CFR(s): NFPA 101  Cooking Facilities Cooking equipment is protected in accordance with NFPA 96, Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations, unless: * residential cooking equipment (i.e., small appliances such as microwaves, hot plates, toasters) are used for food warming or limited	K 324			

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  055956	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING		(X3) DATE SURVEY COMPLETED  11/05/2019
NAME OF PROVIDER OR SUPPLIER  BRIARWOOD POST ACUTE			STREET ADDRESS, CITY, STATE, ZIP CODE 5901 LEMON HILL AVE SACRAMENTO, CA 95824		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 324	<p>Continued From page 21</p> <p>cooking in accordance with 18.3.2.5.2, 19.3.2.5.2</p> <p>* cooking facilities open to the corridor in smoke compartments with 30 or fewer patients comply with the conditions under 18.3.2.5.3, 19.3.2.5.3, or</p> <p>* cooking facilities in smoke compartments with 30 or fewer patients comply with conditions under 18.3.2.5.4, 19.3.2.5.4.</p> <p>Cooking facilities protected according to NFPA 96 per 9.2.3 are not required to be enclosed as hazardous areas, but shall not be open to the corridor.</p> <p>18.3.2.5.1 through 18.3.2.5.4, 19.3.2.5.1 through 19.3.2.5.5, 9.2.3, TIA 12-2</p> <p>This REQUIREMENT is not met as evidenced by: Surveyor: 32973 Based on observation, document review, and interview, the facility failed to maintain the cooking facilities. This was evidenced by the failure to perform hood cleaning on a semi-annual basis (every six months) for moderate volume cooking. This affected one of two smoke compartments, and could potentially result in the uncontrolled spread of a grease fire in the cooking area.</p> <p>NFPA 101. Life Safety Code, 2012 Edition 19.3.2.5 Cooking Facilities. 19.3.2.5.1 Cooking facilities shall be protected in accordance with 9.2.3</p> <p>9.2.3 Commercial Cooking Equipment. Commercial cooking equipment shall be in accordance with NFPA 96, Standard for</p>	K 324			

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>055956</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>11/05/2019</b>
NAME OF PROVIDER OR SUPPLIER  <b>BRIARWOOD POST ACUTE</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>5901 LEMON HILL AVE SACRAMENTO, CA 95824</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 324	<p>Continued From page 22</p> <p>Ventilation Control and Fire Protection of Commercial Cooking Operations, unless such installations are approved existing installations, which shall be permitted to be continued in service.</p> <p>NFPA 96, Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations, 2011 Edition Chapter 11 Procedures for the Use, Inspection, Testing, and Maintenance of Equipment 11.2 Inspection, Testing, and Maintenance of Fire-Extinguishing Systems. 11.2.1* Maintenance of the fire-extinguishing systems and listed exhaust hoods containing a constant or fire-activated water system that is listed to extinguish a fire in the grease removal devices, hood exhaust plenums, and exhaust ducts shall be made by properly trained, qualified, and certified person(s) acceptable to the authority having jurisdiction at least every 6 months.</p> <p>11.4* Inspection for Grease Buildup. The entire exhaust system shall be inspected for grease build up by a properly trained, qualified, and certified person(s) acceptable to the authority having jurisdiction and in accordance with Table 11.4. Table 11.4 Schedule of Inspection for Grease Buildup Type or Volume of Cooking</p>	K 324			

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  055956	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____		(X3) DATE SURVEY COMPLETED  11/05/2019
NAME OF PROVIDER OR SUPPLIER  BRIARWOOD POST ACUTE			STREET ADDRESS, CITY, STATE, ZIP CODE 5901 LEMON HILL AVE SACRAMENTO, CA 95824		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 324	Continued From page 23 Inspection Frequency Systems serving high-volume cooking operations, such as 24-hour cooking, charbroiling, or wok cooking Quarterly Systems serving moderate-volume cooking operations Semiannually  Finding:  During a facility tour, document review, and interview with staff on 11/5/19, the kitchen cooking area was observed and service records were requested.  At 1:05 p.m., the last available semi-annual inspection/service for hood cleaning was dated 9/2/18. No current inspection reports for moderate volume cooking for the past 12 months were available and/or submitted for review. Upon interview, Staff 4 confirmed the finding and stated that the current inspection reports could not be located.  During a Life Safety Code survey on 12/20/18, the facility was cited for the failure to provide the required record.	K 324			
K 345 SS=E	Fire Alarm System - Testing and Maintenance CFR(s): NFPA 101  Fire Alarm System - Testing and Maintenance A fire alarm system is tested and maintained in accordance with an approved program complying with the requirements of NFPA 70, National Electric Code, and NFPA 72, National Fire Alarm	K 345			



DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  055956	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____		(X3) DATE SURVEY COMPLETED  11/05/2019
NAME OF PROVIDER OR SUPPLIER  BRIARWOOD POST ACUTE			STREET ADDRESS, CITY, STATE, ZIP CODE 5901 LEMON HILL AVE SACRAMENTO, CA 95824		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 345	<p>Continued From page 24 and Signaling Code. Records of system acceptance, maintenance and testing are readily available. 9.6.1.3, 9.6.1.5, NFPA 70, NFPA 72 This REQUIREMENT is not met as evidenced by: Surveyor: 32973 Based on document review and interview, the facility failed to maintain the fire alarm system (FAS). This was evidenced by the absence of a semi-annual inspection. This affected two of two smoke compartments, and could result in a non-detected system malfunction in the event of a fire.</p> <p>NFPA 101, Life Safety Code, 2012 Edition 19.3.4.1 General. Health care occupancies shall be provided with a fire alarm system in accordance with section 9.6 9.6.1* General. 9.6.1.5* To ensure operational integrity, the fire alarm system shall have an approved maintenance and testing program complying with the applicable requirements of NFPA 70, National Electrical Code, and NFPA 72, National Fire Alarm and Signaling Code.</p> <p>NFPA 72, National Fire Alarm and Signaling Code, 2010 Edition. Chapter 14 Inspection, Testing, and Maintenance 14.1 Application. 14.1.1 The inspection, testing, and maintenance of systems, their initiating devices, and notification appliances shall comply with the requirements of this chapter. 14.3 Inspection. 14.3.1* Unless otherwise permitted by 14.3.2 visual inspections shall be performed in accordance with the schedules in Table 14.3.1 or</p>	K 345			

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  055956	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____		(X3) DATE SURVEY COMPLETED  11/05/2019	
NAME OF PROVIDER OR SUPPLIER  BRIARWOOD POST ACUTE			STREET ADDRESS, CITY, STATE, ZIP CODE 5901 LEMON HILL AVE SACRAMENTO, CA 95824			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE	
K 345	<p>Continued From page 25</p> <p>more often if required by the authority having jurisdiction.</p> <p>14.3.2 Devices or equipment that is inaccessible for safety considerations (e.g., continuous process operations, energized electrical equipment, radiation, and excessive height) shall be permitted to be inspected during scheduled shutdowns if approved by the authority having jurisdiction.</p> <p>14.3.4 The visual inspection shall be made to ensure that there are no changes that affect equipment performance.</p> <p>Table 14.3.1 Visual Inspection Frequencies-semiannually</p> <ol style="list-style-type: none"> <li>3. Batteries</li> <li>4. Transient suppressors</li> <li>5. Fire alarm control unit trouble signals</li> <li>7. In- building fire emergency voice/alarm communications equipment</li> <li>8. Remote annunciators</li> <li>9. Initiating devices</li> <li>10. Guard's tour equipment</li> <li>11. Combination systems (a) Fire extinguisher electronic monitoring device/systems (b) Carbon monoxide detectors/systems</li> <li>12. Interface equipment</li> <li>13. Alarm notification appliances</li> <li>14. Exit marking audible notification appliances</li> <li>15. Supervising station alarm systems-transmitters</li> <li>16. Special procedures</li> <li>17. Supervising station alarm systems-receivers</li> <li>18. Public emergency alarm reporting system transmission equipment</li> <li>20. Mass notification system, non-supervised systems installed prior to adoption of this edition</li> </ol> <p>14.6.2 Maintenance, Inspection, and Testing</p>	K 345				

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  055956	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____		(X3) DATE SURVEY COMPLETED  11/05/2019
NAME OF PROVIDER OR SUPPLIER  BRIARWOOD POST ACUTE			STREET ADDRESS, CITY, STATE, ZIP CODE 5901 LEMON HILL AVE SACRAMENTO, CA 95824		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 345	Continued From page 26 Records. 14.6.2.1 Records shall be retained until the next test and for 1 year thereafter. 14.6.2.4* A record of all inspections, testing, and maintenance shall be provided that includes the following information regarding tests and all the applicable information requested in Figure 14.6.2.4: (1) Date (2) Test frequency (3) Name of property (4) Address (5) Name of person performing inspection, maintenance, tests, or combination thereof, and affiliation, business address, and telephone number (6) Name, address, and representative of approving agency(ies) (7) Designation of the detector(S) tested (8) Functional test of detectors (9)*Functional test of required sequence of operations (10) Check of all smoke detectors (11) Loop resistance for all fixed-temperature, line-type heat detectors (12) Functional test of mass notification system control units (13) Functional test of signal transmission to mass notification systems (14) Functional test of ability of mass notification system to silence fire alarm notification appliances (15) Tests of intelligibility of mass notification system speakers (16) Other tests as required by the equipment manufacturer ' S published instructions (17) Other tests as required by the authority having jurisdiction (18) Signatures of tester and approved authority	K 345			

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  055956	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____		(X3) DATE SURVEY COMPLETED  11/05/2019
NAME OF PROVIDER OR SUPPLIER  BRIARWOOD POST ACUTE			STREET ADDRESS, CITY, STATE, ZIP CODE 5901 LEMON HILL AVE SACRAMENTO, CA 95824		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 345	Continued From page 27 representative (19) Disposition of problems identified during test (e.g., system owner notified, problem corrected/successfully retested, device abandoned in place)  Finding:  During document review and interview with staff on 11/5/19, the FAS was observed and records were requested.  At 1:00 p.m., the current Annual Fire Alarm Inspection/Testing Report was dated 1/28/19, and the previous inspection was dated 2/21/18. No semi-annual visual inspection with battery testing were available for review. Upon interview, Staff 4 confirmed the finding after review of the records.	K 345			
K 346 SS=C	Fire Alarm System - Out of Service CFR(s): NFPA 101  Fire Alarm - Out of Service Where required fire alarm system is out of services for more than 4 hours in a 24-hour period, the authority having jurisdiction shall be notified, and the building shall be evacuated or an approved fire watch shall be provided for all parties left unprotected by the shutdown until the fire alarm system has been returned to service. 9.6.1.6 This REQUIREMENT is not met as evidenced by: Surveyor: 32973 Based on document review and interview, the facility failed to maintain interim fire measures. This was evidenced by the failure to provide written protocol to ensure that if the fire alarm system was out of service for more than 4 hours	K 346			

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  055956	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____		(X3) DATE SURVEY COMPLETED  11/05/2019
NAME OF PROVIDER OR SUPPLIER  BRIARWOOD POST ACUTE			STREET ADDRESS, CITY, STATE, ZIP CODE 5901 LEMON HILL AVE SACRAMENTO, CA 95824		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 346	Continued From page 28 in a 24 hour period, the authority having jurisdiction (AHJ) would be notified. This affected two of two smoke compartments, and could potentially result in the AHJ not having the ability to exercise oversight in an acceptable time if the fire alarm system was to become inoperable.  Finding:  During document review and interview with staff on 11/5/19, the interim fire measures and Policy were requested for review.  At 1:15 p.m., the approved Fire Watch Policy provided did not include the time parameters and/or notification to the Department of Public Health if the fire alarm system was out of service for more than 4 hours in a 24 hour period. Upon interview, Staff 4 confirmed the finding after review of the policy.	K 346			
K 353 SS=F	Sprinkler System - Maintenance and Testing CFR(s): NFPA 101  Sprinkler System - Maintenance and Testing Automatic sprinkler and standpipe systems are inspected, tested, and maintained in accordance with NFPA 25, Standard for the Inspection, Testing, and Maintaining of Water-based Fire Protection Systems. Records of system design, maintenance, inspection and testing are maintained in a secure location and readily available. a) Date sprinkler system last checked  b) Who provided system test  c) Water system supply source	K 353			

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  055956	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____		(X3) DATE SURVEY COMPLETED  11/05/2019
NAME OF PROVIDER OR SUPPLIER  BRIARWOOD POST ACUTE			STREET ADDRESS, CITY, STATE, ZIP CODE 5901 LEMON HILL AVE SACRAMENTO, CA 95824		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 353	<p>Continued From page 29</p> <p>Provide in REMARKS information on coverage for any non-required or partial automatic sprinkler system.</p> <p>9.7.5, 9.7.7, 9.7.8, and NFPA 25</p> <p>This REQUIREMENT is not met as evidenced by:</p> <p>Surveyor: 32973</p> <p>Based on observation, document review, and interview, the facility failed to maintain the integrity of the automatic fire sprinkler system. This was evidenced by the absence of three of four quarterly inspections, monthly visual inspections, and a sprinkler head that had foreign debris. This affected two of two smoke compartments, and could result in the ineffective operation of the sprinkler system in the event of a fire.</p> <p>NFPA 101, Life Safety Code, 2012 Edition.</p> <p>19.3.5 Extinguishment Requirements.</p> <p>19.3.5.1 Buildings containing nursing homes shall be protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7, unless otherwise permitted by 19.3.5.5.</p> <p>9.7 Automatic Sprinklers and Other Extinguishing Equipment.</p> <p>9.7.5 Maintenance and Testing. All automatic sprinkler and standpipe systems required by this Code shall be inspected, tested, and maintained in accordance with NFPA 25, Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems.</p>	K 353			

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  055956	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____		(X3) DATE SURVEY COMPLETED  11/05/2019
NAME OF PROVIDER OR SUPPLIER  BRIARWOOD POST ACUTE			STREET ADDRESS, CITY, STATE, ZIP CODE 5901 LEMON HILL AVE SACRAMENTO, CA 95824		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 353	<p>Continued From page 30</p> <p>NFPA 25, Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems, 2011 Edition.</p> <p>4.3 Records</p> <p>4.3.1* Records shall be made for all inspections, tests, and maintenance of the system and its components and shall be made available to the authority having jurisdiction upon request.</p> <p>Chapter 5 Sprinkler Systems.</p> <p>5.1.1 Minimum Requirements.</p> <p>5.1.1.1 This chapter shall provide the minimum requirements for the routine inspection, testing, and maintenance of sprinkler systems.</p> <p>5.2.1 Sprinklers.</p> <p>5.2.1.1.1 Sprinklers shall not show signs of leakage; shall be free of corrosion, foreign materials, paint, and physical damage; and shall be installed in the correct orientation (e.g., upright, pendent, or sidewall).</p> <p>5.2.1.1.2 Any sprinkler that shows signs of any of the following shall be replaced:</p> <p>(1) Leakage</p> <p>(2) Corrosion</p> <p>(3) Physical damage</p> <p>(4) Loss of fluid in the glass bulb heat responsive element</p> <p>(5)*Loading</p> <p>(6) Painting unless painted by the sprinkler manufacturer</p> <p>5.2.4 Gauges</p> <p>5.2.4.1* Gauges on a wet pipe sprinkler shall be inspected monthly to ensure that they are in good condition and the normal water supply pressure is being maintained.</p>	K 353			

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  055956	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____		(X3) DATE SURVEY COMPLETED  11/05/2019
NAME OF PROVIDER OR SUPPLIER  BRIARWOOD POST ACUTE			STREET ADDRESS, CITY, STATE, ZIP CODE 5901 LEMON HILL AVE SACRAMENTO, CA 95824		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 353	<p>Continued From page 31</p> <p>5.2.5 Waterflow Alarm and Supervisory Devices. Waterflow alarms and supervisory alarm devices shall be inspected quarterly to verify that they are free of physical damage.</p> <p>5.2.6* Hydraulic Design Information Sign. The hydraulic design information sign for hydraulically designed systems shall be inspected quarterly to verify that it is attached securely to the sprinkler riser and is legible.</p> <p>5.3.3 Waterflow Alarm Devices. 5.3.3.1 Mechanical waterflow alarm devices including, but not limited to, water motor gongs, shall be tested quarterly.</p> <p>13.2.6 Alarm Devices. 13.7.1 Fire department connections shall be inspected quarterly to verify the following: (1) The fire department connections are visible and accessible. (2) Couplings or swivels are not damaged and rotate smoothly. (3) Plugs or caps are in place and undamaged. (4) Gaskets are in place and in good condition. (5) Identification signs are in place. (6) The check valve is not leaking. (7) The automatic drain valve is in place and operating properly. (8) The fire department connection clapper(s) is in place and operating properly.</p> <p>13.3.2.1.1 Valves secured with locks or supervised in accordance with applicable NFPA standards shall be permitted to be inspected monthly.</p> <p>13.3.2.2* The valve inspection shall verify that the valves are in the following condition:</p>	K 353			



DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  055956	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____		(X3) DATE SURVEY COMPLETED  11/05/2019
NAME OF PROVIDER OR SUPPLIER  BRIARWOOD POST ACUTE			STREET ADDRESS, CITY, STATE, ZIP CODE 5901 LEMON HILL AVE SACRAMENTO, CA 95824		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 353	<p>Continued From page 32</p> <p>(1) In the normal open or closed position (2)*Sealed, locked, or supervised (3) Accessible (4) Provided with correct wrenches (5) Free from external leaks (6) Provided with applicable identification</p> <p>13.4.1.1* Alarm valves and system riser check valves shall be externally inspected monthly and shall verify the following: (1) The gauges indicate normal supply water pressure is being maintained. (2) The valve is free of physical damage. (3) All valves are in the appropriate open or closed position. (4) The retarding chamber or alarm drains are not leaking.</p> <p>13.6.1.1.1 Valves secured with locks or electrically supervised in accordance with applicable NFPA standards shall be inspected monthly.</p> <p>Findings:</p> <p>During a facility tour, document review, and interview with staff on 11/5/19, the automatic fire sprinkler system was observed, and records were requested and reviewed.</p> <p>1. At 11:15 a.m., the pendant style sprinkler head located in the Main Dining Room above the ceiling fan, had foreign debris covering the deflector. Upon interview, Staff 4 confirmed the finding after viewing the sprinkler.</p> <p>2. At 1:10 p.m., records provided indicated that monthly visual inspections for the alarm, system</p>	K 353			

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  055956	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____		(X3) DATE SURVEY COMPLETED  11/05/2019
NAME OF PROVIDER OR SUPPLIER  BRIARWOOD POST ACUTE			STREET ADDRESS, CITY, STATE, ZIP CODE 5901 LEMON HILL AVE SACRAMENTO, CA 95824		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 353	Continued From page 33 riser check valves, and pressure gauges for the following months were not completed: February, March, April, May, June, July, August, September, October, November, and December 2018-2019. Upon interview, Staff 4 confirmed the finding stating that the previous maintenance person responsible for the inspections was no longer employed at the facility.	K 353			
K 712 SS=F	3. At 1:12 p.m., the facility was observed with a wet-automatic fire sprinkler system. No quarterly sprinkler inspection records were available for the second quarter (April, May, June), third quarter (July, August, September), and forth quarter (October, November, December) 2018-2019. Upon interview, Staff 4 confirmed the finding after review of the records.  Fire Drills CFR(s): NFPA 101  Fire Drills Fire drills include the transmission of a fire alarm signal and simulation of emergency fire conditions. Fire drills are held at expected and unexpected times under varying conditions, at least quarterly on each shift. The staff is familiar with procedures and is aware that drills are part of established routine. Where drills are conducted between 9:00 PM and 6:00 AM, a coded announcement may be used instead of audible alarms. 19.7.1.4 through 19.7.1.7 This REQUIREMENT is not met as evidenced by: Surveyor: 32973 Based on document review and interview, the facility failed to maintain the fire drills. This was evidenced by the absence of documentation for	K 712			

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  055956	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING		(X3) DATE SURVEY COMPLETED  11/05/2019
NAME OF PROVIDER OR SUPPLIER  BRIARWOOD POST ACUTE			STREET ADDRESS, CITY, STATE, ZIP CODE 5901 LEMON HILL AVE SACRAMENTO, CA 95824		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 712	<p>Continued From page 34</p> <p>eight of twelve required drills. This affected two of two smoke compartments, and could result in staff being untrained and unaware of shift-specific roles and responsibilities during an emergency.</p> <p>NFPA 101, Life Safety Code, 2012 Edition 19.7.1 Evacuation and Relocation Plan and Fire Drills. 19.7.1.2 All employees shall be periodically instructed and kept informed with respect to their duties under the plan required by 19.7.1.1.</p> <p>19.7.1.6 Drills shall be conducted quarterly on each shift to familiarize facility personnel (nurses, interns, maintenance engineers, and administrative staff) with the signals and emergency action required under varied conditions.</p> <p>Finding:</p> <p>During document review and interview with staff on 11/5/19, the fire drill records were requested and reviewed.</p> <p>At 11:30 a.m., documentation titled, "Fire Drills," was reviewed. No documentation were available for the first quarter P.M. and Night Shifts, second quarter A.M., P.M. and Night Shifts, and third quarter A.M., P.M., and Night Shifts, 2019.</p> <p>Upon interview, Staff 4 and Staff 2 confirmed the finding after reviewing the drills. Staff 2 stated that the drills had been completed by the previous maintenance person, and that facility was not able to locate the records as they are no longer</p>	K 712			

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>055956</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>02</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>11/05/2019</b>
NAME OF PROVIDER OR SUPPLIER  <b>BRIARWOOD POST ACUTE</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>5901 LEMON HILL AVE SACRAMENTO, CA 95824</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 712	Continued From page 35 employed at the facility.	K 712			
K 918 SS=D	Electrical Systems - Essential Electric System CFR(s): NFPA 101  Electrical Systems - Essential Electric System Maintenance and Testing The generator or other alternate power source and associated equipment is capable of supplying service within 10 seconds. If the 10-second criterion is not met during the monthly test, a process shall be provided to annually confirm this capability for the life safety and critical branches. Maintenance and testing of the generator and transfer switches are performed in accordance with NFPA 110. Generator sets are inspected weekly, exercised under load 30 minutes 12 times a year in 20-40 day intervals, and exercised once every 36 months for 4 continuous hours. Scheduled test under load conditions include a complete simulated cold start and automatic or manual transfer of all EES loads, and are conducted by competent personnel. Maintenance and testing of stored energy power sources (Type 3 EES) are in accordance with NFPA 111. Main and feeder circuit breakers are inspected annually, and a program for periodically exercising the components is established according to manufacturer requirements. Written records of maintenance and testing are maintained and readily available. EES electrical panels and circuits are marked, readily identifiable, and separate from normal power circuits. Minimizing the possibility of damage of the emergency power source is a design consideration for new installations. 6.4.4, 6.5.4, 6.6.4 (NFPA 99), NFPA 110, NFPA 111, 700.10 (NFPA 70)	K 918			

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  055956	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____		(X3) DATE SURVEY COMPLETED  11/05/2019
NAME OF PROVIDER OR SUPPLIER  BRIARWOOD POST ACUTE			STREET ADDRESS, CITY, STATE, ZIP CODE 5901 LEMON HILL AVE SACRAMENTO, CA 95824		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 918	<p>Continued From page 36</p> <p>This REQUIREMENT is not met as evidenced by:</p> <p>Surveyor: 32973</p> <p>Based on observation, document review, and interview, the facility failed to maintain the emergency power supply system (EPSS). This was evidenced by the absence of three of twelve monthly load and battery tests, and weekly visual inspections for two of twelve months. This affected two of two smoke compartments and could result in the failure of the generator in the event of a power outage.</p> <p>NFPA 99, Health Care Facilities Code, 2012 Edition.</p> <p>6.4.4.1.1.3 Maintenance shall be performed in accordance with NFPA 110, Standard for Emergency and Standby Power Systems, Chapter 8.</p> <p>NFPA 110, Standard for Emergency and Standby Power Systems, 2010 Edition.</p> <p>8.3 Maintenance and Operational Testing.</p> <p>8.3.4 A permanent record of the EPSS inspections, tests, exercises, operations and repairs shall be maintained and readily available.</p> <p>8.3.7.1 Maintenance of lead-acid batteries shall include the monthly testing and recording of electrolyte specific gravity. Battery conductance testing shall be permitted in lieu of the testing of specific gravity when applicable or warranted.</p> <p>8.4 Operational Inspection and Testing.</p> <p>8.4.1* EPSSs, including all appurtenant components, shall be inspected weekly and exercised under load at least monthly.</p> <p>Findings:</p>	K 918			

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/07/2019  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  055956	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____		(X3) DATE SURVEY COMPLETED  11/05/2019
NAME OF PROVIDER OR SUPPLIER  BRIARWOOD POST ACUTE			STREET ADDRESS, CITY, STATE, ZIP CODE 5901 LEMON HILL AVE SACRAMENTO, CA 95824		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 918	<p>Continued From page 37</p> <p>During a facility tour, document review, and interview with staff on 11/5/19, the EPSS was observed and records were requested.</p> <p>1. At 12:30 p.m., the facility was observed with a 15 kilowatt diesel generator equipped with two lead acid batteries, located outside behind the facility. Documentation titled, "Monthly Generator Testing" indicated that the generator was not exercised under a 30 minute load with battery testing for the months of February, September, and October 2019.</p> <p>2. At 12:40 p.m., documentation titled, "Weekly Inspections" indicated that weekly visual inspections were not completed for the months of February and October 2019.</p> <p>Upon interview, Staff 4 and Staff 5 confirmed the findings after a review of the records.</p>	K 918			

E 006

On 11/19/19 was able to find the emergency preparedness plan which was created and reviewed on 1/31/19 and it includes an updated facility based and community-based risk assessment. Also included in the emergency plan is an evaluation/assessment for missing residents and natural disasters.

All residents have the potential to be affected by this deficient practice.

Emergency preparedness plan will be updated annually by the maintenance director and administrator during the first quarter of the year. Copies of the Emergency Preparedness plan will be kept at the nurse station, maintenance office and administrator office.

Maintenance director and administrator will present the emergency preparedness plan to the IDT during our first quarterly QAPI meeting and will also in service the staff on the updates made to the emergency preparedness plan and where to find them.

Maintenance director and administrator will monitor for compliance.

Date: 11/21/19

**RECEIVED**

**By LSC at 10:28 am, Nov 22, 2019**

#### E 015 Subsistence Needs for Staff and Patients

As of 11/18/19 facility included policies related to Adequate Supply of Food, Water and Pharmaceuticals. 2. Auxiliary generator will provide necessary lights, temperature protection, and fire system capabilities. 3. 11/22/19 Maintenance and Housekeeping Staff to be in-serviced on appropriate disposal of wet/dry garbage.

All residents have the potential to be effected by this deficient practice.

Maintenance/Dietary Director and/or representative will monitor emergency food storage to ensure P&P compliance. Pharmaceutical supplies will be monitored by appropriate clinical staff.

Maintenance Director will ensure emergency power source via generator testing each month as designated by facility policies.

Maintenance Director will report emergency source availability and testing at QAPI meetings.  
Maintenance Director and Administrator will monitor for compliance

Date: 11/21/19

**RECEIVED**

**By LSC at 10:28 am, Nov 22, 2019**



E 024

On 11/12/19 the maintenance director found the policy and procedure for arrangements and/or agreements that address staffing strategies and the use of volunteers during emergencies.

All residents have the potential to be affected by this deficient practice.

Maintenance director placed the policy and procedure for use of volunteers during emergencies in the fire and disaster binder at the nurse's station and in serviced staff on where they can find the policy in case of an emergency.

Maintenance director will audit the fire and disaster binder monthly to ensure that the policy and procedure for the use of volunteers during emergencies are present. The findings from the audit will be presented to the IDT during our QAPI meetings.

Maintenance director and administrator will monitor for compliance.

Date: 11/21/19

**RECEIVED**

**By LSC at 10:28 am, Nov 22, 2019**

E 037

On 11/08/19, the maintenance director began in servicing the therapy department on the annual emergency preparedness policy and procedures along with competency evaluations.

All residents have the potential to be affected by this deficient practice.

Therapy staff will be placed on annual training along with the rest of the staff in the facility. The maintenance director will maintain the copies of the in services given to the therapy staff.

The maintenance director will present in service records of the emergency preparedness policy and procedure to the IDT during our QAPI meeting.

Maintenance director and administrator to monitor for compliance.

Date: 11/21/19

**RECEIVED**

**By LSC at 10:28 am, Nov 22, 2019**

E 039

On 12/4/19 facility administrator emailed multiple staff members from state and county offices of emergency services in an effort to join the next community based emergency drill. Facility will continue to reach out to representatives to ensure we will be included in the next event.

All residents have the potential to be affected by this deficient practice.

Administrator will present information on community drill to IDT when the information becomes available. The facility will make necessary preparations to fully participate in the drill.

Administrator and maintenance director will present the results of the community drill to the IDT during our QAPI meeting.

Administrator and maintenance director to monitor for compliance.

Date:

E 041

On 11/27/19 Administrator was able to locate the correct policy and procedure that indicates how the facility will keep the EPSS operational during an emergency, unless the facility evacuates.

All residents have the potential to be affected by this deficient practice.

Maintenance director was in serviced on the policy and procedure in regards to how the facility will keep the EPSS operational during an emergency, unless the facility evacuates.

Maintenance director will randomly check the generator to ensure that the appropriate levels of fuel are present and secure for the generator to perform properly in case of an emergency. Results of the random checks will be presented to the IDT during our QAPI meeting

Maintenance director and administrator to monitor for compliance.

Date:

K 211

On 11/11/19 the maintenance director ordered the exit sign for the facility. Maintenance director searched the facility for any other exits that were missing the appropriate signage with no other signs noted to be missing at that time.

All residents have the potential to be affected by this deficient practice.

Maintenance director will audit the facility on a monthly basis to ensure that all exits have appropriate signage labeling exits.

Maintenance director will present finding from the audits to the IDT during our QAPI meetings

Maintenance director and administrator will monitor for compliance.

Date: 11/21/19

**RECEIVED**

**By LSC at 10:28 am, Nov 22, 2019**

K 293

Maintenance director visually inspected the illuminated exit signs on 11/07/19 to ensure they were all working correctly. All signs were in good working condition.

All residents have the potential to be affected by this deficient practice.

Maintenance director will visually audit illuminated exit signs monthly to ensure they are in good working condition.

Maintenance director will present information from the visual audits of the illuminated signs to the IDT during our QAPI.

Maintenance director and administrator to monitor for compliance.

Date: 11/21/19

**RECEIVED**

**By LSC at 10:28 am, Nov 22, 2019**

K 321

Maintenance director special ordered the self-closing part for the door on 11/8/19 and it will be installed as soon as it arrives to the facility. Maintenance director inspected the facility to ensure that each door that needed a door closure had one and that it was in good working condition. No other doors noted to be out of compliance.

All residents have the potential to be affected by this deficient practice.

The laundry department has been instructed to keep the door closed until the part arrives and the door can be returned to functioning properly. Maintenance director will audit self-closing doors monthly to ensure they are in good working condition.

Maintenance director will present results of the audits to the IDT during our QAPI meeting.

Maintenance director and administrator to monitor for compliance.

Date: 11/21/19

**RECEIVED**

**By LSC at 10:28 am, Nov 22, 2019**

E 324

On 11/19/19 Maintenance director received confirmation form Sentinel Fire Equipment Company that they conduct the semi-annual/service for hood cleaning. The facility will also receive an inspection report from Sentinel Fire Equipment Company after the hood cleaning.

All residents have the potential to be affected by this deficient practice.

Maintenance director will schedule the semi- annual hood cleaning with sentinel before the end of the year to ensure the cleaning is done timely.

Maintenance director will bring the semi-annual hood cleaning schedule to QAPI and share with the IDT.

Maintenance director and Administrator will monitor for compliance.

Date: 11/21/19

**RECEIVED**

**By LSC at 10:28 am, Nov 22, 2019**



K 345

On 11/12/19 the maintenance director had Sacramento Fire conduct a full and comprehensive annual fire alarm test.

All residents have the potential to be affected by this deficient practice.

Semi-annual and annual fire alarm test will be scheduled 6 months in advanced.

Maintenance director will present upcoming fire alarm test to the IDT during our QAPI meeting to ensure the facility is in compliance.

Maintenance director and administrator to monitor for compliance.

Date: 11/21/19

**RECEIVED**

**By LSC at 10:28 am, Nov 22, 2019**

K 346

On 12/04/19 maintenance director and administrator amended our current policy and procedure for our fire watch to include time parameters if our fire alarm system is down and also notification instructions to California Department of Public Health.

All residents have the potential to be affected by this deficient practice.

Maintenance director in serviced staff beginning on 12/04/19 on our fire watch policy and procedure including the amendments made to the policy in regards to time parameters and notification to California Department of Public Health.

The results of the in-services will be presented to the IDT during our QAPI meeting by our maintenance director.

Maintenance director and administrator will monitor for compliance.

Date:

K 353

On 11/5/19 the maintenance director cleaned the debris from the sprinkler head in the main dining room above the ceiling fan. Maintenance director inspected the other sprinkler heads for debris with no other debris noted. On 11/12/19 Sentinel Fire and Equipment Company tested the fire alarm system and completed the quarterly inspection and 5year inspection.

All residents have the potential to be affected by this deficient practice.

The maintenance department will inspect and clean, if necessary, the sprinkler heads on a monthly basis. The maintenance director will work closely with Sentinel Fire and Equipment Company to ensure we are in compliance with our fire alarm system.

The results from the monthly sprinkler head inspections will be presented to the IDT by the maintenance staff during our QAPI meeting. Maintenance director will also bring updates on the fire alarm system to the QAPI meetings.

Maintenance director and administrator.

Date: 11/21/19

**RECEIVED**

**By LSC at 10:28 am, Nov 22, 2019**

K 712

On 11/05/19 maintenance director conducted a fire drill test on the pm shift.

All residents have the potential to be affected by this deficient practice.

Maintenance director will conduct monthly fire drills in the facility to ensure the facility is in compliance.  
Fire drills we be done one per shift per month.

The results of the previous month's fire drill will be presented to the IDT during our QAPI meeting in an effort to ensure compliance with state requirements.

Maintenance director and administrator will monitor for compliance.

Date: 11/21/19

**RECEIVED**

**By LSC at 10:28 am, Nov 22, 2019**

K 918

On 11/20/19 the maintenance director conducted a 30-minute load bearing test with the back-up batteries for the generator. Weekly visual inspections of the generator also began on 11/20/19.

All residents have the potential to be affected by this deficient practice.

Maintenance director will conduct monthly 30-minute load bearing test with the back-up batteries for the generator. Weekly visual inspections of the generator will also be completed by the maintenance director.

The results of the monthly 30-minute load bearing test and the weekly visual generator inspections will be presented to the IDT during our QAPI meeting.

Maintenance director and administrator will monitor for compliance.

Date: 11/21/19

**RECEIVED**

**By LSC at 10:28 am, Nov 22, 2019**