

STATE OF CALIFORNIA
DEPARTMENT OF PUBLIC HEALTH

IN RE: **MARIPOSA COUNTY PUBLIC WORKS**
PARKS AND RECREATION DIVISION
CATHEYS VALLEY PARK
Water System No. 2207094

TO: Mr. Peter Rei, Director
Mariposa County Public Works
4639 Ben Hur Road
Mariposa, CA 95338

CC: Mariposa County Environmental Health Department
Darryl Nielsen, Operator (same address)

CITATION FOR NONCOMPLIANCE
TOTAL COLIFORM MAXIMUM CONTAMINANT LEVEL VIOLATION
4th Quarter 2012

Issued February 12, 2013

Section 116650, Chapter 4, Part 12, Division 104 of the California Health and Safety Code (CHSC), authorizes the issuance of a citation for failure to comply with a requirement of the California Safe Drinking Water Act, or any regulation, standard, permit, or order issued thereunder.

VIOLATION

The Drinking Water Field Operations Branch of the California Department of Public Health (hereinafter 'Department') hereby issues a Citation to the Mariposa County Public Works –

1 Parks and Recreation Division Catheys Valley Park (hereinafter 'County'), for failure to
2 comply with Section 116555(a)(1) of the CHSC and Section 64426.1(b)(2) of Title 22,
3 California Code of Regulations (CCR). Specifically, the County (mailing address: 4639
4 Ben Hur Road, Mariposa, CA 95338) failed to comply with the total coliform Maximum
5 Contaminant Level (MCL) for the fourth quarter of 2012.

6
7 Section 64426.1(b)(2) specifies that a public water system collecting fewer than forty
8 samples per month is in violation of the total coliform MCL when more than one sample
9 collected during any month is total coliform-positive.

10
11 The County is required to collect a minimum of one distribution system bacteriological
12 sample per quarter. The routine quarterly sample collected on December 18, 2012, tested
13 positive for total coliform bacteria. The sample was negative for E.coli and/or fecal
14 coliform bacteria. Four repeat samples were collected on January 3, 2013. All of the repeat
15 samples tested positive for total coliform bacteria. The samples were negative for E.coli
16 and/or fecal coliform bacteria. County staff notified the Department on December 24, 2012
17 of the total coliform positive samples. The County was directed to conduct emergency
18 disinfection of the distribution system by Department staff. The system was disinfected and
19 flushed between December 25, 2012 and January 1, 2013. A second set of repeat samples
20 was collected on January 2, 2013. Two of the four samples tested positive for total coliform
21 bacteria. The samples were negative for E.coli and/or fecal coliform bacteria. The County
22 conducted a second emergency disinfection of the well head and the distribution system
23 between January 3, 2013 and January 9, 2013. A third set of repeat samples was collected
24 on January 10, 2013. Two of the four repeat samples were positive for total coliform
25 bacteria. The samples were negative for E.coli and/or fecal coliform bacteria. The County
26 conducted a third emergency disinfection of the well head and the distribution system
27 between January 11, 2013 and January 23, 2013. All of the repeat samples were negative

1 for total coliform bacteria. Due to the above mentioned positive samples, the County failed
2 the total coliform rule for the fourth quarter of 2012.

3
4 The cause of the contamination is thought to be from the well. The well was sampled for
5 coliform bacteria on December 21, 2012; January 2, 2013; January 10, 2013; and January
6 24, 2013. The sample results are listed below:

7 Sample Date	Total Coliform MPN/100mL	E.coli MPN/100mL
8 12/21/12	6.3	<1.0
9 1/2/13	<1.0	<1.0
10 1/10/13	4.1	<1.0
11 1/24/13	17	<1.0

12
13 The County was directed by the Department to install continuous chlorination equipment
14 until such a time that a new source of supply could be drilled. The County installed
15 chlorination equipment at the site on February 5, 2013.

16
17 The above violation is classified as a non-continuing violation.

18
19 **NOTIFICATION REQUIREMENTS**

20 Section 64426.1(c) requires a public water system to notify the Department and the
21 consumers of the water system, when a violation of Section 64426.1(b) (1) through (4)
22 occurs. Notification to the Department shall be by the end of the business day on which the
23 violation has been determined. If the Department is closed, notification shall be within 24
24 hours of the determination. The Department was notified on December 24, 2012, in
25 accordance with the above-referenced section.

1 A Tier 2 Public Notice for violations of paragraphs 64426.1(b) (2) shall be given pursuant
2 to Sections 64463.4 and 64465. The Tier 2 Public Notice shall include the mandatory
3 health effects language from Appendix 64465-A for a total coliform MCL failure.

4
5 Section 64463.4 allows non-community water systems to notify customers/consumers of the
6 TCR MCL violation by posting a Tier 2 notice in conspicuous locations throughout the area
7 served by the water system and the use of one or more of the following methods to notify
8 persons not likely reached by posting: publication in a daily or weekly newspaper or
9 newsletter distributed to customers, email message to employees or students, posting on the
10 Internet or intranet, or direct delivery to each customer. The Tier 2 notification methods are
11 included in Attachment A along with instructions on completing the public notice.

12
13 Proof of notification is required. The County shall complete Attachment B and return it to
14 the Department by **March 8, 2012**.

15
16
17
18
19
20
21
22
23
24
25
26
27

1 **DIRECTIVES**

2 The Mariposa County Public Works Department – Parks and Recreation Division – Catheys
3 Valley Park is hereby directed to take the following actions:

- 4
- 5 1. By **March 1, 2013**, the County shall provide public notification of the total coliform
6 Maximum Contaminant Level failure by posting the public notice in conspicuous
7 public places within the water system and on the internet (see Attachment A).
- 8
- 9 2. By **March 8, 2013**, the County shall provide proof of posting the public notice in
10 conspicuous public places within the water system and on the internet of the total
11 coliform MCL violation notification to each consumer using Attachment B.
- 12
- 13 3. The County shall collect five (5) routine samples for total coliform analysis during
14 the month of February 2013.
- 15
- 16 4. The County shall have on staff or under contract a minimum of a D1 Certified
17 Distribution System Operator to operate the chlorination equipment. Documentation
18 of the certification of the operator shall be provided to the Department by **March 8,**
19 **2013**. The operator shall visit the well site and review the chlorination treatment on
20 at least a weekly basis and document the date and time of the visit, the settings on
21 the chemical feed equipment, the chlorine stock on hand and the chlorine residual at
22 the well site and in the farthest part of the distribution system. Documentation of the
23 site visits shall be submitted to the Department by the 10th day of the following
24 month.
- 25
- 26 5. A chlorine residual of at least 1.0 mg/l shall be maintained in all areas of the
27 distribution system at all times.

- 1 6. The County shall initiate monthly bacteriological sampling of the distribution system
2 for total coliform and *E.coli* bacteria. The chlorine residual shall be measured at the
3 time and location of the collection of the monthly distribution system bacteriological
4 samples. This residual shall be provided to the Department on the laboratory
5 analysis report. The coliform test shall be performed using a density analytical
6 method and the results reported in units of MPN/100 mL. The results shall be
7 submitted to the Department by the tenth day of the following month.
- 8
- 9 7. The County shall initiate monthly sampling of the raw well water for analyses of
10 total coliform and *E.coli* bacteria. The sample must be collected at a location prior
11 to chlorine treatment. The coliform test shall be performed using a density analytical
12 method and the results reported in units of MPN/100 mL. The results shall be
13 submitted to the Department by the tenth day of the following month.
- 14
- 15 8. The County shall submit a Chlorination Operations Plan to the Department by
16 **March 31, 2013**. A template is provided in Attachment C.
- 17
- 18 9. By **March 31, 2013**, the County shall submit a plan and timeline for addressing the
19 current problems with the well. The County shall include all alternatives for the
20 replacement of the current well.
- 21
- 22 10. By **February 22, 2013**, the County shall submit a written response to the
23 Department acknowledging that it has received this citation and will comply with all
24 the directives listed herein.
- 25
- 26
- 27

11. All submittals required by this Citation shall be addressed to:

Carl L. Carlucci, Supervising Sanitary Engineer
California Department of Public Health
Drinking Water Field Operations Branch
265 W Bullard Avenue, Suite 101
Fresno, CA 93704

CIVIL PENALTIES

Sections 116650(d) and 116650(e) of the CHSC allow for the assessment of a civil penalty for failure to comply with requirements of the Safe Drinking Water Act. Failure to comply with any provision of this Citation may result in the Department imposing an administrative penalty of not less than \$100 (one hundred dollars) per day as of the date of violation of any provision of this Citation.

2-12-2013
Date


Carl L. Carlucci, P.E.
Supervising Sanitary Engineer, Merced District
Southern California Branch
DRINKING WATER FIELD OPERATIONS BRANCH

Attachments:

- Attachment A: Tier 2 Public Notification
- Attachment B: Proof of Notification
- Attachment C: Chlorination Operations Plan Template

CLC/mrw/2207094/Cit 03-11-13C-003.doc



Instructions for Tier 2 Resolved Total Coliform Notice Template

Template Attached

Since exceeding the total coliform bacteria maximum contaminant level is a Tier 2 violation, you must provide public notice to persons served as soon as practical but within 30 days after you learn of the violation [California Code of Regulations, Title 22, Chapter 15, Section 64463.4(b)]. **Each water system required to give public notice must submit the notice to the Department for approval prior to distribution or posting, unless otherwise directed by the Department [64463(b)].**

Notification Methods

You must use the methods summarized in the table below to deliver the notice to consumers. If you mail, post, or hand deliver, print your notice on letterhead, if available.

<i>If You Are a...</i>	<i>You Must Notify Consumers by...</i>	<i>...and By One or More of the Following Methods to Reach Persons Not Likely to be Reached by the Previous Method...</i>
Community Water System [64463.4(c)(1)]	Mail or direct delivery ^(a)	Publication in a local newspaper
		Posting ^(b) in public places served by the water system or on the Internet
		Delivery to community organizations
Non-Community Water System [64463.4(c)(2)]	Posting in conspicuous locations throughout the area served by the water system ^(b)	Publication in a local newspaper or newsletter distributed to customers
		Email message to employees or students
		Posting ^(b) on the Internet or intranet
		Direct delivery to each customer

(a) Notice must be distributed to each customer receiving a bill including those that provide their drinking water to others (e.g., schools or school systems, apartment building owners, or large private employers), and other service connections to which water is delivered by the water system.

(b) Notice must be posted in place for as long as the violation or occurrence continues, but in no case less than seven days.

The notice attached is appropriate for the methods described above. However, you may wish to modify it before using it for posting. If you do, you must still include all the required elements and leave the health effects and notification language in italics unchanged. This language is mandatory [64465].

Multilingual Requirement

Spanish. Each public notice must contain information in Spanish regarding (1) the importance of the notice or (2) contain a telephone number or address where Spanish-speaking residents may contact the water system to obtain a translated copy of the public notice or assistance in Spanish.

Non-English Speaking Groups Other than Spanish-Speaking. For each group that exceeds 1,000 residents or 10% of the residents in the community served, whichever is less, the public notice must (1) contain information in the appropriate language(s) regarding the importance of the notice or (2) contain a telephone number or address where such residents may contact the water system to obtain a translated copy of the notice or assistance in the appropriate language.

Population Served

Make sure it is clear who is served by your water system -- you may need to list the areas you serve.

Description of the Violation

Make sure that the notice is clear about the fact that the coliform problem has been resolved, and there is no current cause for concern. The description of the violation and the MCL vary depending on the number of samples you take. The following table should help you complete the second paragraph of the template.

<u>If You Take Fewer Than 40 Samples a Month</u>	<u>If You Take 40 or More Samples a Month</u>
State the number of samples testing positive for coliform. The standard is that no more than one sample per month may be positive.	State the percentage of samples testing positive for coliform. The standard is that no more than 5.0 percent of samples may test positive each month.

Corrective Action

In your notice, describe corrective actions you have taken. Listed below are some steps commonly taken by water systems with total coliform violations. Use one or more of the following actions, if appropriate, or develop your own:

- "We have increased sampling for coliform bacteria to catch the problem early if it recurs."
- "The well and/or distribution system has been disinfected and additional samples do not show presence of coliform bacteria."

After Issuing the Notice

Send a copy of each type of notice and a certification that you have met all the public notice requirements to the Department within ten days after you issue the notice [64469(d)].

It is recommended that you notify health professionals in the area of the violation. People may call their doctors with questions about how the violation may affect their health, and the doctors should have the information they need to respond appropriately.

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable.

Tradúzcalo o hable con alguien que lo entienda bien.

MCPR - Catheys Valley Park Has Levels of Coliform Bacteria Above the Drinking Water Standard

Our water system recently violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what you should do, what happened, and what we did to correct this situation.

We routinely monitor for drinking water contaminants. We took 21 samples to test for the presence of coliform bacteria during December and January 2013. Twelve of our samples showed the presence of total coliform bacteria. The standard is that no more than one sample per month may do so.

What should I do?

- **You do not need to boil your water or take other corrective actions.**
- This is not an emergency. If it had been, you would have been notified immediately. Total coliform bacteria are generally not harmful themselves. *Coliforms are bacteria which are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.*
- Usually, coliforms are a sign that there could be a problem with the system's treatment or distribution system (pipes). Whenever we detect coliform bacteria in any sample, we do follow-up testing to see if other bacteria of greater concern, such as fecal coliform or *E. coli*, are present. **We did not find any of these bacteria in our subsequent testing, and further testing shows that this problem has been resolved.**
- People with severely compromised immune systems, infants, and some elderly may be at increased risk. These people should seek advice about drinking water from their health care providers. General guidelines on ways to lessen the risk of infection by microbes are available from U.S. EPA's Safe Drinking Water Hotline at 1(800) 426-4791.
- If you have other health issues concerning the consumption of this water, you may wish to consult your doctor.

What happened? What was done?

[Describe corrective action].

For more information, please contact [name of contact] at [phone number] or [mailing address].

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.

Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- **SCHOOLS:** Must notify school employees, students, and parents (if the students are minors).
- **RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS** (including nursing homes and care facilities): Must notify tenants.
- **BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS:** Must notify employees of businesses located on the property.

This notice is being sent to you by the MCPR – Catheys Valley Park.

State Water System ID#: 2207094. Date distributed: _____.



RON CHAPMAN, MD, MPH
Director & State Health Officer

State of California—Health and Human Services Agency
California Department of Public Health

Attachment B



EDMUND G. BROWN JR.
Governor

PROOF OF NOTIFICATION
(Return with copy of notice)

As required by Section 116450 of the California Health and Safety Code, I notified all users of water supplied by the **Mariposa County Public Works Department – Parks and Recreation Division Catheys Valley Park** of the failure to meet the **Total Coliform Rule Maximum Contaminant Level (MCL)** requirement for the **fourth quarter of 2012** as directed by the Department.

Notification was made on _____ by _____
(date)
hand delivering / mailing / posting / publishing the _____ written
notice.

(circle all that apply)

Signature of Water System Representative

Date

DISCLOSURE: Be advised that Section 116725 and 116730 of the California Health and Safety Code state that any person who knowingly makes any false statement on any report or document submitted for the purpose of compliance with the attached order may be liable for a civil penalty not to exceed five thousand dollars (\$5,000) for separate violation for each day that violation continues. In addition, the violators may be prosecuted in criminal court and upon conviction, be punished by a fine of not more than \$25,000 for each day of violation, or be imprisoned in the county jail not to exceed one year, or by both the fine and imprisonment.

Due: March 8, 2013
TCR MCL Violation
System Number: 2207094
Citation No.: 03-11-13C-003

GUIDANCE: OPERATIONS PLAN FOR SMALL SYSTEMS with Chlorination

Written Description of Water Sources, Storage Tanks and Distribution System (with as-built maps or schematics) and General Record Keeping

We recommend a brief description of sources, storage, chlorinator unit (treatment) and number of connections and character (seasonal rental, year-round, etc.). Example; 200 foot well drilled in 1972, 1500 gallon welded steel storage tank, chlorinator with a diaphragm type pump (manufacturer and model) and 25 gallon disinfectant reservoir, serving 15 connections (one third seasonal occupancy).

We strongly recommend a multi-tabbed file be set up to keep copies of the laboratory results (10 year retention) and monitoring requirements and an accompanying calendar schedule for all sampling.

Other files that should be kept are a copy of correspondence from our Department (e.g., water supply permit), all sampling plans (Bacteriological Sample Siting Plan), water main and valve location maps, the well driller's report and County well construction permit that demonstrates conformance to its well ordinance (schematic documenting adequate horizontal protection of well from sanitary hazards), pump and storage tank information, and their accompanying service records, etc.

The Operations Plan elements are as follows:

- **Routine Operational Procedures for each component of the system:**
 - A. Visual inspection of **WELL** (daily or minimum of weekly).
 1. Check for the following; water leaks that could contaminate well, unscreened or openings where sealants can be applied, electrical hazards, chemical hazards (proper use of chemicals around well head). Tip: Maintain a log book for each well site that records maintenance and monthly water production and flow rates, water table depths and any maintenance performed.
 2. Well has the ability to be pumped to waste and sampling tap (non-threaded down-turned hose bib).
 3. Check the pump and controls for proper operation of well and chlorination equipment.
 4. General house keeping: remove rodent feces, dirt, vegetation, any standing water, control gophers/squirrel burrowing around well head to eliminate potential contamination hazards.

- B. Visual inspection of the **STORAGE TANKS** (daily or minimum of weekly).
1. Inspect vents and overflow outlets for proper protection (screens, flapper valve, etc.) to keep out rodents and insects.
 2. Inspect for any leaks or damage (record observations and repair as needed).
 3. Record system pressure. Record the pressure the pump turns on, the pressure the pump turns off and the duration of the run time so storage tank does not overflow.
 4. Scheduled inspection and cleaning of storage tank (quarterly, semi-annually or annually). Record kept for the date cleaned and any observations (e.g., remnants of rodents, etc.)
- C. Visual inspection of **CHLORINATOR PUMP** and disinfection reservoir (daily or minimum of weekly).
1. Inspect the pump for proper operation. Hypochlorinator pumps are prone to vapor lock (air bubble in line) and need to be equipped with degassing feature. Installation Tip: The problem can be greatly alleviated by maintaining positive pressure on the intake of the hypochlorinator pump by placing the hypochlorinator pump at the same elevation as the chlorine solution tank.
 2. Inspect the disinfectant in the reservoir for concentration and adequate volume for the operational period (record results).
 3. Determine if there is enough disinfectant on hand for one or more weeks.
- D. Measure the **DISINFECTANT RESIDUAL** in the distribution system (free chlorine test kit required).
1. Monitor and record the results from designated locations which are the same locations as the routine bacteriological sample sites. The residuals must be reported with the bacteriological results at the time the bacteriological sample is collected. This information is also used for reporting the quarterly chlorine residuals under the Disinfection Byproducts Rule). Reporting forms attached.
 2. Determine if an adequate level of disinfectant is maintained.
 - a. If disinfectant level is low (0.2 to 0.3 mg/L is generally the lowest level reportable using colorimetric test kits), determine the reason and correct. If enforcement action taken for repeated Total Coliform Rule violations, there may be more stringent chlorine residual requirements.
 - b. If no measurable disinfectant, notify owner, determine reason, and remedy. If no disinfectant residual for 24 hours, notify Merced District Office of the California Department of Public Health.
- E. Maintenance of **GAUGES and METERS**.
1. Inspect all gauges and meters for leaks and proper function daily. Repair or replace as needed (keep record of date). Schedule routine calibration checks to ensure accurate readings are being provided.

- F. Inspection and **EXERCISING of the VALVES**.
 - 1. Inspect valves for leaks (record observations, repair or replace if leaking).
 - 2. Exercise valves on a schedule, as needed (i.e. quarterly, semi-annually, annually, record dates on attached sheet).

- G. Operation and maintenance of **DISTRIBUTION FACILITIES**.
 - 1. Visually inspect the distribution system for leaks on a regular basis. Record date and observations.
 - 2. Flush dead end mains or lines periodically (quarterly, semi-annually, annually as needed. Record date and observations).

- **Monitoring and Reporting:**

- A. **BACTERIOLOGICAL MONITORING FROM DISTRIBUTION SYSTEM;** as per approved Bacteriological Sample Siting Plan, required monthly, report containing results submitted to the Department by the 10th day of the following month (refer to attached guidance). Recommend samples be collected early in the week in case repeat samples must be collected after a positive sample result is received. Repeat samples must be collected within 24 hours of receipt of positive result.
 - 1. If sample positive, lab must notify water system contact person or the Department if you can not be reached. Multiple repeat samples must be collected (three to four repeat samples depending on system classification). Department recommends that water system provides a copy of the Emergency Notification Plan form to analyzing laboratory.
 - 2. Take five routine samples the month following a positive sample.

BACTERIOLOGICAL MONITORING FROM WELL SOURCES; should be described in the sample siting plan and is required from raw water at well head PRIOR to chlorination. The samples are required to be analyzed using the density method. If sample positive, notify Department by telephone, e-mail for follow- up investigation. Frequency is dependent on type of water system and report containing the results submitted to the Department by the 10th day of the following month.

- B. **CHEMICAL SOURCE MONITORING;** as required by the Department, forward results to the Department (see attached Water Quality Monitoring Schedule).

DISINFECTION BYPRODUCT RULE MONITORING; as required every three years for nontransient noncommunity and community water systems. If less half the MCL for total trihalomethanes (TTHM) and haloacetic acids (HAA5), the sample can be reduced to once every three years. Next routine sample is due in 2007 during the warmest month of the year from a location with the longest detention time in the distribution system. Submit copy of laboratory results to the Merced District of the CDPH.

LEAD AND COPPER TAP MONITORING; as required for nontransient noncommunity and community water systems. Contact Department for when next round of monitoring is due.

H. **WATER PRODUCTION**

Recommend installation of instantaneous and totalizing flow meter and record daily or at least weekly instantaneous and monthly production volume readings. This is especially valuable and necessary for hard rock wells. This information is reported in the annual report form.

A. **PUBLIC NOTIFICATION** of violation required.

1. Notification shall be given as per Emergency Notification Plan (copy of form attached). Provide updated plans when personnel change to the Department (attached). Templates of the various for public notices are available at <http://www.cdph.ca.gov/certlic/drinkingwater/Pages/notices.aspx>
2. State the cause of problem, if known, and what steps has been taken to correct it.
3. Send a copy of the notification to the Department with proof of notification.

• **Emergency Notification Plan (ENP), Annual Report to the Drinking Water Program (ARDWP) and Consumer Confidence Report (CCR)**

- A. ENP; a form that lists the Department's and water system's contact information in the event of **water quality emergency** in which public notification must be performed. It must describe the methods to be followed in order to distribute the public notices to each customer as rapidly as possible. Small system may distribute notices by hand delivery. Attached is a copy of the form.
- B. ARDWP; a form for all water systems that summarizes system operations for the previous calendar year and includes number of service connections and population served and supplemental information relating to consumer complaints, annual water production, sources, and use of NSF approved treatment chemicals, etc. Also provides updated contact and mailing address information. This information is necessary for classification of the system and contact information.
- C. CCR; required for nontransient noncommunity and community water systems that summarizes all monitoring done during the previous calendar year. The CCR must be distributed by July of every year. A template available at <http://www.cdph.ca.gov/certlic/drinkingwater/Pages/CCR.aspx>

- **Emergency Operational Practices.**

List of **equipment on hand** for emergency repairs.

1. Miscellaneous wrenches.
2. Leak clamps

A. List of sources of needed **equipment, not on hand.**

1. Name and address of supplier and type of equipment.
2. If under contract or rental.

Name	Address	Phone #	Equipment	Rental/ Contract
			Steel Tank Welder	
			Electrical repair	
			Digging equipment	
			Generator	
			Chemicals	

B. List of distributors or suppliers of **replacement parts** for the system.

1. Name and address of supplier and type of equipment.

Name	Address	Phone #	Equipment
			PVC pipe, valves, and fittings
			pumps, pressure tank and gauges
			Chlorinator

C. List of **emergency contact numbers:**

	Name	Phone #
1.	Carl Carlucci, CDPH District Office	Office: (559) 447-3132 / Cell: (559) 280-6363
2.	Law Enforcement -	
3.	Electrician	
4.	Laboratory	
5.	Pump repair service	
6.	Chemical disinfectant supplier	
7.	Equipment supplier	
8.	Water System Owner	
9.	Certified Operators (include certification level)	

Attachments (Note: electronic copies of all forms available upon request):

1. Monthly water production and chlorine usage report
2. Coliform monitoring report forms for distribution and raw well sources
3. Quarterly chlorine residual report form for Disinfection Byproducts Rule
4. Bacteriological Sampling Siting Plan guidance
5. Water Quality Monitoring Schedule for transient and nontransient noncommunity (Cedar Lodge) water systems
6. Emergency Notification Plan form (please include job title and any operator certifications for names listed)
7. Lead and copper tap monitoring guidance